



2650 Queensview Drive
Ottawa, Ontario, K2B 8H6, CANADA
T: 1.613.688.1899 • www.exp.com

June 20, 2018

Mr. Michael Boucher
Manager of Planning
DCR Phoenix Group of Companies
18 Bentley Avenue
Ottawa, Ontario

Via e-mail: MBoucher@phoenixhomes.ca

Project Name: Proposed Residential Development, Fallowfield and Cedearview Roads,
Ottawa, Ontario
EXP Project Number: OTT-00243143-A0
Subject: **Planting Trees**

Dear Michael:

As requested, we have reviewed our geotechnical investigation report, Project Number OTT-00243143-A0 dated June 4, 2018 for the above-named project.

A review of the report indicates that the geotechnical conditions at the site comprise of some surficial fill or silty sand underlain by compact to very dense silty gravelly sand till, which extends to the refusal depth or to bedrock. Marine sensitive clays were not encountered at the site. Therefore, in our opinion, City of Ottawa Tree Planting Guidelines for sensitive marine clay soils do not apply to this site.

Should you have any questions, please contact this office.

Best Regards,

EXP Services Inc.

Surinder Aggarwal, M.Sc., P.Eng.
Senior Project Manager, Geotechnical Services
Earth and Environmental

Ismail Taki, M.Eng., P.Eng.
Manager, Geotechnical Services
Earth and Environmental



cc: Teresa Thomas [t.thomas@novatech-eng.com]
Mark Bissett [m.bissett@novatech-eng.com]
Greg Winters [G.Winters@novatech-eng.com]
James Lennox [jl@jbla.ca]
Mike Lennox [ml@jbla.ca]