



## Smith + Andersen

1600 Carling Ave Suite 530 Ottawa Ontario K1Z 1G3  
613 230 1186 f 613 230 2598 [smithandandersen.com](http://smithandandersen.com)

2019-08-16

**City of Ottawa**  
**Infrastructure Services and Community Sustainability**  
110 Laurier Avenue West  
Ottawa, Ontario  
K1P 1J1

**Attention: City Building Official**

**RE: 280 O'CONNOR RESIDENTIAL DEVELOPMENT**  
**OTTAWA, ONTRIO**  
**S+A PROJECT # 19111.000**  
**SITE LIGHTING CERTIFICATE**

Dear City Building Official:

This letter is to confirm that the exterior light fixtures used for this project meet the criteria for full cut-off classification as recognized by the IESNA and that the resulting light spillage onto adjacent properties is below the maximum allowable spillage (0.5 fc) by City of Ottawa Standards.

Yours truly,

SMITH + ANDERSEN

  
Mike Leong, P.Eng.  
Senior Associate

19111.000 Letter site Lighting.docx

C.C. Andre Drouin – Smith + Andersen

