

# TECHNICAL MEMORANDUM

DATE: JULY 31, 2020

TO: MIKE WIEBE

FROM: FRANÇOIS THAUVETTE

RE: ASSESSMENT OF ADEQUACY OF PUBLIC SERVICES PROPOSED MIXED-USE DEVELOPMENT- 1335 & 1339 BANK STREET

#### PROJECT: 119210 (NOVATECH REPORT REF. # R-2019-195)

Novatech has been retained by Lofty Riverside Development to assess the adequacy of the existing public services related to the proposed re-development of the 1335 & 1339 Bank Street properties. The proposed mixed-use development will consist of a 26-storey residential tower with a 6-storey podium, ground floor commercial space (i.e. café/bar, fitness gym), underground parking as well as indoor and outdoor amenity spaces. The purpose of this assessment is to demonstrate that the proposed development can be serviced by the existing municipal infrastructure surrounding the subject site.

This assessment includes a review of approximately 120m of the municipal sanitary sewer along Bank Street, from the southbound section of Riverside Drive down to the 1200mm dia. Rideau River collector sewer in the northbound section of Riverside Drive, south of the site. Also included in the assessment is the review of the watermain network adjacent to the subject site. The intent is to service the proposed development by extending new services to the municipal sanitary sewer and watermain in Bank Street. Stormwater from the site will be directed to the municipal storm sewer in Riverside Drive, north of the site, which outlets to the Rideau River.



#### Figure 1: Aerial View of the Subject Site

The subject site currently consists of two (2) separate properties located on the east side of Bank Street, which cover a total area of approximately 0.28 hectares. The existing sites include:

- a used car dealership (1335 Bank Street), located immediately south of the Rideau River and Riverside Drive (southbound), and
- a Harvey's Restaurant and associated parking lot (1339 Bank Street), located immediately to the south of the used car dealership

The properties will be merged to accommodate the proposed mixed-use development. As indicated on **Figure 1**, a multi-storey commercial tower and associated parking lot abuts the property to the northeast.

The Serviceability Report (R-816-65A), dated October 2017, prepared by T.L. Mak Engineering Consultants Ltd. for the proposed development of a 16-storey mixed-use building on the 1335 Bank Street property was also reviewed to compare the results of the current assessment with the values previously submitted to the City of Ottawa.

# Based on recent discussions with the City of Ottawa, it is understood that infrastructure upgrades to the municipal watermain network will be required to provide redundancy and adequate fire flow to the surrounding area. We are currently discussing watermain options with the City and working towards a feasible solution for the development.

## **Sanitary Servicing**

The existing commercial properties on the east side (1335 & 1339) and west side (1330, 1340 & 1346) of Bank Street, are currently being serviced by the existing 225mm dia. sanitary sewer in Bank Street. It is assumed that the property at 2211 Riverside Drive is also tributary to the sanitary sewer in Bank Street. There are no other upstream properties contributing flow to this sewer segment. The municipal sanitary sewer in Bank Street flows south and outlets into the 1200mm dia. Rideau River collector sewer located within the northbound section of Riverside Drive, south of the site.

Based on criteria in Section 4 of the City of Ottawa Sewer Design Guidelines, the total theoretical peak sanitary flows from the existing commercial sites (1335 & 1339 Bank Street), tributary to the 225mm dia. sewer, were calculated to be approximately 0.34 L/s. Detailed sanitary flow calculations are provided in **Appendix A** for reference. The existing flows calculated for the 1335 Bank Street property are consistent with the values calculated in the Serviceability Report (R-816-65A), prepared by T.L. Mak Engineering Consultants Ltd.

Sanitary flows for the proposed mixed-use development (1335 & 1339 Bank Street), were calculated using the Ottawa Sewer Design Guidelines, based on information provided by the architect. Under post-development conditions, the total theoretical peak sanitary flow has increased to approximately 6.85 L/s. Detailed sanitary flow calculations are provided in **Appendix A** for reference. Contributing flows from the properties on the west side of Bank Street are assumed to remained unchanged.

An analysis of the existing 225mm dia. sanitary sewer system was completed to estimate the total peak flows tributary to this sewer, including flows from the west side of Bank Street, down to the 1200m dia. sanitary collector sewer in Riverside Drive. The City's geoOttawa website was used to determine existing sanitary sewer sizes, invert elevations, and the tributary drainage areas. Despite the increase in total theoretical flow, the analysis demonstrates that existing municipal infrastructure has enough excess capacity to service the proposed mixed-use development. Refer to the Pre-Development and Post-Development Sanitary Sewer Drainage Area Plans, sanitary sewage calculations and to the Post-Development Sanitary Sewer Design Sheet provided in **Appendix A** for

details. It should however be noted that a 225mm dia. (9") sewer is no longer a typical size used for new infrastructure. Given the size of the existing sanitary sewer in the street, it is assumed that the proposed building will be serviced by a 200mm dia. (8") sanitary service at a minimum slope of 1.0%.

Although the details of the City of Ottawa Bank Street Renewal project are unknown at this time, it is anticipated the sanitary sewer in Bank Street, adjacent to the proposed development, will be replaced and upsized. An updated analysis will be provided as part of the detailed design phase of this project.

## Water for Domestic Use and Firefighting

The existing commercial properties on the east side of Bank Street are currently being serviced by the existing 200mm dia. watermain in Bank Street. It is expected that under post-development conditions, the proposed development will continue to be serviced by the municipal watermain in Bank Street. As per City of Ottawa Technical Bulletin (ISDTB-2014-02), the proposed development will require a second water service, as the daily water demands are greater than 50m<sup>3</sup>/day (0.58 L/s). It is assumed that the building will be sprinklered and therefore serviced by two 150mm dia. water services, separated by an isolation valve.

Preliminary water demand and fire flow calculations have been prepared for the proposed development based on criteria in Section 4 of the City of Ottawa Design Guidelines for Water Distribution Systems. The fire flows are calculated using the Fire Underwriters Survey (FUS) method, based on general assumptions and information provided by the architect, including building materials, a design population of 623 residents (i.e. 388 residential units) and approximately 1,861m<sup>2</sup> of commercial space. Preliminary water demands and fire flows are summarized in in the table below.

Proposed Building Use (1335 & 1339 Bank St.)	Avg. Daily Demand (L/s)	Max. Daily Demand (L/s)	Peak Hour Demand (L/s)	Fire Flow (L/s)
Residential + Commercial	2.6 L/s	6.4 L/s	14.0 L/s	167 L/s

The domestic water demands represent approximately three and a half (3.5) times the domestic demands calculated in the Serviceability Report (R-816-65A), previously prepared by T.L. Mak Engineering Consultants Ltd., however these latter values were for a 16-storey mixed-use development on the 1335 Bank Street property <u>only</u>. The proposed FUS fire flow has increased, due to the size and design of the building (now including a 26-storey residential tower with a 6-storey podium covering <u>both</u> the 1335 & 1339 Bank Street properties).

The following design criteria were taken from Section 4.2.2 – 'Watermain Pressure and Demand Objectives' of the City of Ottawa Design Guidelines for Water Distribution:

- Normal operating pressures are to range between 345 kPa (50 psi) and 483 kPa (70 psi) under Max Day demands
- Minimum system pressures are to be 276 kPa (40 psi) under Peak Hour demands
- Minimum system pressures are to be 140 kPa (20 psi) under Max Day + Fire Flow demands

The following table summarizes preliminary hydraulic analysis results based on municipal watermain boundary conditions provided by the City of Ottawa.

Municipal Watermain Boundary Condition	Boundary Condition	Normal Operating Pressure Range (psi)	Anticipated WM Pressure (psi)*		
Minimum HGL	101.0	10 mai (min.)			
(Peak Hour Demand)	121.0 m	40 psi (min.)			
Maximum HGL	101.0				
(Max Day Demand)	131.0 m	50-70 psi	~ 71 psi		
HGL (Max Day + Fire Flow)	Information Not Provided by City**	20 psi (min.)	> 20 psi		

\*Based on an approximate Bank Street roadway elevation of 60.3m.

\*\*Due to theoretical low fire flow availability in the area.

Based on preliminary calculations, it is anticipated that the pressure within the municipal watermain will exceed the upper end of the normal operating pressure range during Max Day Conditions. Pressure reducing valves (PRV) may be required given the high system pressures. Given the height of the proposed tower, it is anticipated that a booster pump(s) will be required to provide adequate water pressure to the upper floors of the tower.

Based on correspondence from the City of Ottawa, the theoretical maximum fire flow available within this area is 90 L/s. This assumes a dead-end scenario due to the closure of municipal valves between pressure zones and a non-looped watermain network through the Riverside Hospital. Although this scenario is unlikely, the theoretical fire flow available (as provided by the City of Ottawa) is less than what is required by the proposed development (and other developments in the area). As stated above, it is understood that infrastructure upgrades to the municipal watermain network will be required to provide redundancy and adequate fire flow to the surrounding area, including the proposed development. The current option being proposed by the City of Ottawa would be to extend an additional local watermain along the west side of Bank Street from the existing 1200mm dia. feeder main in Riverside Drive and loop the it with the existing municipal watermain along the east side of Bank Street. It is understood that the existing watermain will be replaced and upsized as part of the Bank Street renewal project in the future. Additional discussions related to the watermain (i.e. preferred solution, timing of works, funding /cost sharing, etc.) will be required. A multi-hydrant approach to firefighting will be required to supply the fire flow calculated above. This approach is in accordance with the City of Ottawa Technical Bulletin ISTB-2018-02. A complete analysis will be provided as part of the detailed design phase of the project, based on discussions with the City of Ottawa.

Refer to **Appendix B** for preliminary domestic water demand, FUS fire flow calculations, correspondence with the City of Ottawa as well as possible watermain options being considered.

# Storm Drainage and Stormwater Management

On-site stormwater management (SWM) will be required given the proximity of the site to the Rideau River. A SWM design and report, including both on-site stormwater quantity control and stormwater quality control (as required), will be prepared as part of the Site Plan Control application. The SWM criteria have been provided based on pre-consultation meetings with the City of Ottawa and the Rideau Valley Conservation Authority (RVCA). The allowable release rate from the site will be calculated using the Rational Method, with a maximum allowable runoff coefficient of C=0.5, a time of concentration of 10 minutes and a 5-year rainfall intensity from City of Ottawa IDF curves. Based

on discussions with the architect, it is anticipated that all stormwater runoff from the building roofs and rooftop amenity areas will be directed to an internal SWM storage tank and the peak flows will be controlled to meet the City of Ottawa quantity control requirements. A complete SWM analysis will be provided as part of the detailed design phase of the project.

## Conclusion

Based on our analysis of the information available, the existing municipal sanitary and storm sewers should have enough capacity to service the proposed mixed-use development. On-site stormwater management will be implemented to meet the requirements of the City of Ottawa and the Rideau Valley Conservation Authority (RVCA). *The City of Ottawa has acknowledged that infrastructure upgrades to the municipal watermain network will be required to provide redundancy and adequate fire flow to the surrounding area, including the proposed development. We are currently discussing watermain options with the City of Ottawa and working towards finding a feasible solution for the proposed development.* Further details will be provided as part of the Site Plan Control application.

# NOVATECH

Prepared by:

Stephen Matthews, B.A. (Env.) Senior Design Technologist

Reviewed by:



François Thauvette, P. Eng. Senior Project Manager

# **APPENDIX A**

Sanitary Drainage Area Plans, Sanitary Sewage Calculations & Sewer Design Sheet



SHT11X17.DWG - 279mmX432mm

# 1335 & 1339 Bank Street PRE-DEVELOPMENT SANITARY FLOWS

Commercial Use - 1335 Bank Street		
Site Area	0.114 ha	
Average Commercial Flow (Currently)	28,000 L/ha/day	
Average Commercial Flow (Previously)	50,000 L/ha/day	
Commercial Peaking Factor	1.5	
Peak Commercial Flow	0.10 L/s	Based on 50,000 L/ha/day
Commercial Use - 1339 Bank Street		
Site Area	0.169 ha	
Average Commercial Flow (Currently)	28,000 L/ha/day	
Average Commercial Flow (Previously)	50,000 L/ha/day	
Commercial Peaking Factor	1.5	
Peak Commercial Flow	0.15 L/s	Based on 50,000 L/ha/day
Site Area	0.283 ha	
Infiltration Allowance	0.33 L/s/ha	
Peak Extraneous Flows	0.09 L/s	
Total Peak Sanitary Flow	0.34 L/s	



SHT11X17.DWG - 279mmX432mm

# 1335 & 1339 Bank Street: [26-Storey Tower with 6-Storey Podium] POST-DEVELOPMENT SANITARY FLOWS

Residential Use		Floor 1: Commercial and Amenity Space
Number of Studio / 1-Bedroom Units	308	Floors 2 to 6: 5 storeys x (32 x Bach/1-Bdrm units + 1 x
Persons per Studio / 1-Bedroom Unit	1.4	2-Bdrm units + 1 x 3-Bdrm unit) per floor
Number of 2-Bedroom Units	56	Floor 7: (6 x Bach/1-Bdrm units + 0 x 2-Bdrm units + 1
Persons per 2-Bedroom Unit	2.1	x 3-Bdrm unit), amenity and outdoor space
Number of 3-Bedroom Units	24	Floor 8: (6 x Bach/1-Bdrm units + 0 x 2-Bdrm units + 1
Persons per 3-Bedroom Unit	3.1	x 3-Bdrm unit), amenity space
Total Number of Units	388	Floors 9 to 25: 17 storeys x (8 x Bach/1-Bdrm units + 3
Design Population	623	x 2-Bdrm units + 1 x 3-Bdrm units) per floor
Average Daily Flow	280 L/c/day	Floor 26: Penthouse Amentity Space
Peak Factor (Harmon Formula)	3.30	
Peak Residential Flow	6.66 L/s	
Commercial/Amenity Use		
Commercial Space	1,861 m <sup>2</sup>	
Average Commercial Flow	2.8 L/m <sup>2</sup> /day	
Commercial Peaking Factor	1.5	
Peak Commercial Flow	0.09 L/s	
Site Area	0.282 ha	
Infiltration Allowance	0.33 L/s/ha	
Peak Extraneous Flows	0.09 L/s	
Total Peak Sanitary Flow	6.85 L/s	



#### Post-Development Sanitary Flow Calculations

Loca	ation		Resid	lential	Commerci	ommercial / Institutional Residential Cumulative		Peak Factor		ak Factor Commercial / Institutional		Residential	Infiltration For		Foundation					Pipe	Data	-		
Street / Area	From	То	Population	Area (ha)	Area (ha)	Accu. Area (ha)	Pop.	Area (ha)	Res Peak Factor	Comm Peak Factor	Peak Flow (I/s)	Accu. Peak Flow	Acc. Peak Flow (I/s)	Infilt. Flow (I/s)	Accu Infil. Flow	Found. Flow (I/s)	Accu Found. Flow	PEAK DESIGN FLOW (I/s)	Size (mm)	Slope (%)	Length (m)	Capacity (I/s)	Full Flow Vel. (m/s)	Q/Q <sub>full</sub> (%)
Bank Street	SA32593	SA32594	623	0.28	0.74	0.74	623	0.28	3.3	1.5	0.36	0.36	6.74	0.34	0.34	2.75	2.75	10.19	225	0.35	102.3	26.5	0.67	38.4%
Bank Street	SA32594	SA01408	0	0.32	0.00	0.74	623	0.60	3.3	1.5	0.00	0.36	6.74	0.11	0.44	0.00	2.75	10.29	225	0.30	16.2	24.6	0.62	41.9%
				Green cells inclu	ude both existing	(west side) numbers a	nd proposed dev	elopment (east side	) numbers															
City of Ottawa Sewer Desig	<u>gn Guidelines</u>						, .,																	
2 Redroom Apertment Unit	nent Unit					1.4	persons/unit																	
3-Bedroom Apartment Unit						2.1	persons/unit																	
Average Domestic Flow						280	L/person/day	,																

 Institutional / Commercial Flow
 28,000
 L/ha/day

 Extraneous Flows
 0.33
 L/s/ha

 Foundation Drain Allowance
 5.0
 L/s/ha
 (use 5.0 L/s/ha for tributary areas < 10 ha; 3.0 L/s/ha for tributary areas >10 ha and < 100 ha; 2.0 L/s/ha for tributary areas >10 ha

 Residential Peaking Factor
 Harmon Equation, Correction Factor = 0.8

Institutional / Commercial Peaking Factor

Notes:

The number of units in the apartment building has been taken from preliminary architectural design plans.

Existing pipe information has been taken from the City of Ottawa geoOttawa website.

A foundation drain allowance has been accounted for along only those existing streets that do not have a separated storm sewer as indicated on the geoOttawa website.

1.5

# APPENDIX B

Preliminary Domestic Water Demand, FUS Fire Flow Calculations and E-mail correspondence from the City of Ottawa

# 1335 & 1339 Bank Street: [26-Storey Tower with 6-Storey Podium] WATER ANALYSIS

## DOMESTIC WATER DEMAND

Residential Use			Floor 1: Commercial and Amenity Space
Number of Studio / 1-Bedroom Units	308		Floors 2 to 6: 5 storeys x (32 x Bach/1-Bdrm units + 1
Persons per Studio / 1-Bedroom Unit	1.4		x 2-Bdrm units + 1 x 3-Bdrm unit) per floor
Number of 2-Bedroom Units	56		Floor 7: (6 x Bach/1-Bdrm units + 0 x 2-Bdrm units + 1
Persons per 2-Bedroom Unit	2.1		x 3-Bdrm unit), amenity and outdoor space
Number of 3-Bedroom Units	24		Floor 8: (6 x Bach/1-Bdrm units + 0 x 2-Bdrm units + 1
Persons per 3-Bedroom Unit	3.1		x 3-Bdrm unit), amenity space
Total Number of Units	388		Floors 9 to 25: 17 storeys x (8 x Bach/1-Bdrm units +
Total Design Population	623		3 x 2-Bdrm units + 1 x 3-Bdrm units) per floor
Average Day Demand (350 L/c/day)	2.52	L/s	Floor 26: Penthouse Amentity Space
Maximum Day Demand (2.5 x avg. day)	6.31	L/s	
Peak Hour Demand (2.2 x max. day)	13.88	L/s	
Commercial/Amenity Use			
Commercial Space	1,861	m <sup>2</sup>	
Average Day Demand (28,000 L/ha/day)	0.06	L/s	
Maximum Day Demand (1.5 x avg. day)	0.09	L/s	
Peak Hour Demand (1.8 x max. day)	0.16	L/s	
Total Average Day Demand	2.58	L/s	
Total Maximum Day Demand	6.40	L/s	
Total Peak Hour Demand	14.04	L/s	
BOUNDARY CONDITIONS (Provided by City of	Ottawa)		
Maximum HGL =	131	m	
Minimum HGL =	121	m	
Max Day + Fire Flow =	Not Provid	ded by City	
			PSI m OF HEAD
	_		1.42197 1
PRESSURE TESTS	To conver	t Head(m)	to PSI: multiply by 1.42
Average Ground Elevation			60.3 m
High Pressure Test = (Max HGL - Avg.Ground E	lev.) x 1.42 PS High Press	3I/m (shoul sure =	d be between 50- 70 PSI) <b>70.7</b> PSI
Low Pressure Test = (Min. HGL - Avg. Ground E	lev.) x 1.42 P Low Press	SI/m (shoul sure =	d be > 40 PSI) <b>60.7</b> PSI

# **FUS - Fire Flow Calculations**

As per 1999 Fire Underwriter's Survey Guidelines

Novatech Project #: 119210 Project Name: 1335 & 1339 Bank Street Date: 7/10/2020 Input By: S.Matthews Reviewed By: F.Thauvette



Engineers, Planners & Landscape Architects

Legend

Input by User No Information or Input Required

Building Description: 26-Storey Building with a 6-Storey Podium Fire Resistive Construction

						Total Fire		
Step			Choose		Value Used	Flow		
						(L/min)		
Base Fire Flow								
	Construction Ma	terial		Mult	iplier			
	Coefficient	Wood frame		1.5				
1	related to type	Ordinary construction		1				
	of construction	Non-combustible construction		0.8	0.6			
	С	Modified Fire resistive construction (2 hrs)	Yes	0.6				
	•	Fire resistive construction (> 3 hrs)		0.6				
	Floor Area							
		Podium Level Footprint (m <sup>2</sup> )	2035					
		Total Floors/Storeys (Podium)	6					
	•	Tower Footprint (m <sup>2</sup> )	869					
2	A	Total Floors/Storeys (Tower)	20					
_		Protected Openings (1 hr)						
		Area of structure considered (m <sup>2</sup> )			9,878			
	_	Base fire flow without reductions				40.000		
	F	$F = 220 C (A)^{0.5}$				13,000		
		Reductions or Surc	harges					
	Occupancy haza	rd reduction or surcharge		Reduction	/Surcharge			
	(1)	Non-combustible		-25%				
~		Limited combustible	Yes	-15%		1		
3		Combustible		0%	-15%	11,050		
		Free burning		15%		<i>,</i>		
		Rapid burning		25%				
	Sprinkler Reduc	tion		Redu	ction			
		Adequately Designed System (NFPA 13)	Yes	-30%	-30%			
4		Standard Water Supply	Yes	-10%	-10%			
	(2)	Fully Supervised System	No	-10%		-4,420		
			Cun	nulative Total	-40%	1		
	Exposure Surch		Surcharge					
		North Side	> 45 1m		0%			
_		Fast Side	10 1 - 20 m		15%	1		
5	(3)	South Side	30 1- 45 m		5%	3.315		
	(-)	West Side	20.1 - 30 m		10%	-,		
		Cumulat			30%	1		
		Results						
		Total Required Fire Flow, rounded to nea	rest 1000L/mir	า	L/min	10,000		
6	(1) + (2) + (3)	$(2,000 \downarrow \text{min} \neq \text{Eiro Elour } 45,000 \downarrow \text{min})$		or	L/s	167		
		(2,000 L/11111 < FILE FIOW < 45,000 L/MIN)		or	USGPM	2,642		
		Required Duration of Fire Flow (hours)			Hours	2		
7	Storage Volume	Required Volume of Fire Flow (m <sup>3</sup> )			m <sup>3</sup>	1200		
				1200				

# **Francois Thauvette**

From:	Baker, Adam <adam.baker@ottawa.ca></adam.baker@ottawa.ca>
Sent:	Thursday, July 30, 2020 3:33 PM
То:	Christine McCuaig
Cc:	Francois Thauvette; Kevin McMahon; Pierre Boulet; George Gaty; dougv@hobinarc.com;
	Xu, Lily; James, Douglas; Shillington, Jeffrey; Lodoen Unseth, Kelby
Subject:	RE: Bank Street - Servicing Issues - 1335/1339 Bank Street

Hello,

In response to the memo of Lloyd Phillips & Associates (dated July 9, 2020) and two accompanying geoOttawa Capture sketches showing the five options to provide a secondary watermain feed for redundancy to 1335 and 1339 Bank Street, please find below information:

- Option 1 This option will not provide the required redundancy to the site.
- Option 2 This option will not provide the required redundancy to the site (will not provide required fire flows).
- Option 3 This option, which proposes a connection to the 914mm backbone watermain is not an available option because this main is operated on a different pressure zone than the proposed site.
- Option 4 & 5 This general layout is viable in terms of providing the secondary watermain feed for redundancy to the project site. There are a few considerations:
  - Several utility poles are located in the sidewalk which will conflict with the proposed route of Option 5.
  - These layouts need to connect to and upsize the existing 203mm watermain running east-west on Riverside Drive to provide the required looping (illustrated below).
  - Consider connecting to the 1220mm watermain trunk rather than the 610mm as this would shorten the length of the proposed watermain and eliminate a watermain trunk crossing.



In terms of implementing the proposed watermain infrastructure, this will be a development driven project. The City is undertaking the Bank street infrastructure renewal project, currently scheduled for 2022, and will upgrade the existing 203mm diameter watermain to a 305mm diameter watermain (including in front of the subject properties – Riverside to Riverside) which will, based on current proposed water demands for the site, meet the primary domestic and fire demands. Cost-sharing of the construction of either Option 4 or 5 can be explored with the City through coordination of the proposed watermain works with this project to provide the required secondary feed for redundancy.

Thank you,

Adam Baker, EIT Project Manager Planning, Infrastructure and Economic Development Department - Services de la planification, de l'infrastructure et du développement économique Development Review - South Branch City of Ottawa | Ville d'Ottawa 110 Laurier Avenue West Ottawa, ON | 110, avenue. Laurier Ouest. Ottawa (Ontario) K1P 1J1 613.580.2424 ext./poste 26552, Adam.Baker@ottawa.ca

From: Christine McCuaig <christine@lloydphillips.com>

Sent: July 21, 2020 9:21 AM

To: Xu, Lily <Lily.Xu@ottawa.ca>; James, Douglas <Douglas.James@ottawa.ca>; Baker, Adam <adam.baker@ottawa.ca>;
 Shillington, Jeffrey <jeff.shillington@ottawa.ca>; Lodoen Unseth, Kelby <Kelby.LodoenUnseth@ottawa.ca>
 Cc: Francois Thauvette <f.thauvette@novatech-eng.com>; Kevin McMahon <kevin@loftydevelopments.com>; Pierre
 Boulet <pierreb@bouletconstruction.com>; George Gaty <ggaty@elkproperty.com>; dougv@hobinarc.com
 Subject: Bank Street - Servicing Issues - 1335/1339 Bank Street

CAUTION: This email originated from an External Sender. Please do not click links or open attachments unless you recognize the source.

ATTENTION : Ce courriel provient d'un expéditeur externe. Ne cliquez sur aucun lien et n'ouvrez pas de pièce jointe, excepté si vous connaissez l'expéditeur.

Hello Lily,

As you know, we are currently stalled until we can finalize a path forward to address the servicing constraints. On June 30th, we had a Teams meeting and the City requested options from Novatech. Francois prepared these and sent them to the City on July 2nd (email attached). We have not heard any response since.

I understand this is a larger issue, but we need to move forward with this project and request input and response from City staff on the presented options in order to service this proposal.

It would be greatly appreciated if you could obtain a response as soon as possible, ideally in the next couple days, so that our submission can be finalized.

Regards, Christine

--

/

Christine McCuaig, RPP MCIP M.PI Senior Planner | <u>Lloyd Phillips & Associates Ltd.</u> <u>christine@lloydphillips.com</u> 24 Kirkstall Avenue, Ottawa, ON, K2G 3M5 (c) 613-850-8345

#### Please consider the environment before printing this e-mail. / Pensez à l'environnement avant d'imprimer ce courriel

NOTE: This e-mail message and attachments may contain privileged and confidential information. If you have received this message in error, please immediately notify the sender and delete this e-mail message. / NOTE: Ce courriel peut contenir de l'information privilégiée et confidentielle. Si vous avez recu ce message par erreur, veuillez le mentionner immédiatement à l'expéditeur et effacer ce courriel.

AS OF AUGUST 1ST - NEW CONTACT DETAILS WILL BE: <u>christine@g9planning.com</u> | 613-850-8345 <u>www.g9planning.com</u>

ı.

ı

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

# **Francois Thauvette**

From:	Francois Thauvette
Sent:	Thursday, July 2, 2020 2:36 PM
То:	'Baker, Adam'; Mottalib, Abdul
Cc:	'Mike Wiebe'; 'dougv@hobinarc.com'; 'Shillington, Jeffrey'; Lee Sheets
Subject:	RE: 1335/1339 Bank Site Servicing (Watermain)
Attachments:	geoOttawaCapture(WM).pdf; geoOttawaCapture(WM2).pdf

#### Hi Adam and Abdul,

As requested during our Teams meeting on Tuesday (June 30), please find attached two (2) sketches showing possible watermain work (extensions) that might alleviate the (lack of) redundancy and (low) fire flow issues related to the current configuration of the municipal watermain network in the area. These options are for review and discussion purposes. Please let us know if any of these options may be feasible from the City's perspective. The City's water modelling group will have to analyze the various scenarios to determine the impact the suggested improvements may have on the municipal watermain network. By no means is this an exhaustive list of possible options. Depending on the City's review and modelling results, other options and/or multiple options may be required (i.e. Option 2 & 3) to meet the requirements of the future developments in the area. Options 3, 4 and/or 5 could be coordinated with the on-going Bank Street Renewal project.

#### Regards,

#### François Thauvette, P. Eng., Senior Project Manager | Land Development & Public Sector Engineering

**NOVATECH** Engineers, Planners & Landscape Architects

240 Michael Cowpland Drive, Suite 200, Ottawa, ON, K2M 1P6 | Tel: 613.254.9643 Ext: 219 | Cell: 613.276.0310 | Fax: 613.254.5867 The information contained in this email message is confidential and is for exclusive use of the addressee.

From: Francois Thauvette
Sent: Friday, June 26, 2020 2:02 PM
To: 'Baker, Adam' <adam.baker@ottawa.ca>
Cc: 'Mike Wiebe' <mike@loftydevelopments.com>; dougv@hobinarc.com; 'Shillington, Jeffrey'
<jeff.shillington@ottawa.ca>; Lee Sheets <l.sheets@novatech-eng.com>
Subject: RE: 1335/1339 Bank Site Servicing (Watermain)

Hi Adam,

Would the City have recent hydrant flow data for the hydrants in close proximity to our site (i.e. **Hydrants 368027-H024**, **368027-H025** and **368027-H064**)? I suspect that the fire flow is greater than the theoretical maximum of 90 L/s (previous provided by the City), as the private valves on the Riverside Hospital campus are likely open (the Hospital likely needs a redundant feed). If the valves are indeed open, then the watermain network is looped to the system on the east side of the Transitway.

If no data is available, could these hydrants be tested, so we can confirm the fire flow available? As discussed during our Teams Meeting on June 24/20, this has an impact on the <u>entire</u> area, including the Hospital as well as the residential and commercial properties, not just our site.

Also, does the City know if the watermain at the end of Sarah Billings Place is capped on the east or west side of the Transitway? If capped on the east side of the Transitway, it would be easy to extend the watermain (approx. 60m) onto

the Hospital property, to create a watermain loop that would be independent of the private Hospital watermain network. An easement may be required. See marked-up sketch (geoOttawa screen shot) for details.

Please also confirm when the City's water modelling group will be available to meet via Teams.

Regards,

#### François Thauvette, P. Eng., Senior Project Manager | Land Development & Public Sector Engineering

#### **NOVATECH** Engineers, Planners & Landscape Architects

240 Michael Cowpland Drive, Suite 200, Ottawa, ON, K2M 1P6 | Tel: 613.254.9643 Ext: 219 | Cell: 613.276.0310 | Fax: 613.254.5867 The information contained in this email message is confidential and is for exclusive use of the addressee.

From: Francois Thauvette
Sent: Thursday, June 25, 2020 4:02 PM
To: Baker, Adam <<u>adam.baker@ottawa.ca</u>>
Cc: Mike Wiebe <<u>mike@loftydevelopments.com</u>>
Subject: RE: 1335/1339 Bank Site Servicing

Hi Adam,

Have you had any luck scheduling a meeting with the City's water modelling group?

Regards,

François Thauvette, P. Eng., Senior Project Manager | Land Development & Public Sector Engineering

#### **NOVATECH** Engineers, Planners & Landscape Architects

240 Michael Cowpland Drive, Suite 200, Ottawa, ON, K2M 1P6 | Tel: 613.254.9643 Ext: 219 | Cell: 613.276.0310 | Fax: 613.254.5867 The information contained in this email message is confidential and is for exclusive use of the addressee.

From: Baker, Adam <<u>adam.baker@ottawa.ca</u>>
Sent: Monday, June 22, 2020 11:23 AM
To: Francois Thauvette <<u>f.thauvette@novatech-eng.com</u>>
Subject: RE: 1335/1339 Bank Site Servicing

# Hi Francois,

Yes, I've attached a screenshot of those invited to the meeting. Please feel free to forward the invite on if there's anyone else to include.



Thanks, Adam

-----Original Appointment----- **From:** Francois Thauvette <<u>f.thauvette@novatech-eng.com</u>> **Sent:** June 22, 2020 10:45 AM To: Baker, Adam Subject: Accepted: 1335/1339 Bank Site Servicing When: June 24, 2020 10:00 AM-12:00 PM (UTC-05:00) Eastern Time (US & Canada). Where: Microsoft Teams Meeting

CAUTION: This email originated from an External Sender. Please do not click links or open attachments unless you recognize the source.

ATTENTION : Ce courriel provient d'un expéditeur externe. Ne cliquez sur aucun lien et n'ouvrez pas de pièce jointe, excepté si vous connaissez l'expéditeur.

I can't see from the invitation, but I'm assuming that all others (i.e. architect, client, etc.) have also been invited to the meeting?

Regards,

ı.

ı

#### François Thauvette, P. Eng., Senior Project Manager | Land Development & Public Sector Engineering

#### **NOVATECH** Engineers, Planners & Landscape Architects

240 Michael Cowpland Drive, Suite 200, Ottawa, ON, K2M 1P6 | Tel: 613.254.9643 Ext: 219 | Cell: 613.276.0310 | Fax: 613.254.5867 The information contained in this email message is confidential and is for exclusive use of the addressee.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.





# **Francois Thauvette**

From:	Baker, Adam <adam.baker@ottawa.ca></adam.baker@ottawa.ca>
Sent:	Tuesday, June 16, 2020 3:55 PM
То:	Francois Thauvette
Cc:	Steve Matthews; Oram, Cody; Shillington, Jeffrey
Subject:	RE: 1335 & 1339 Bank Street - Redevelopment - WM Boundary Condition Request
Attachments:	Current configuration.pdf

Hi Francois,

Please find the response for your inquiry on the fire flow below with attached water map:

"The results provided are based on current configuration as shown in the attached figure. The 914mm watermain on Riverside is currently set up to be on 1W pressure, which is how Production normally operates. By doing so, the old 203mm UCI on Bank st is the main supply to the area in question, including the hydrants. You will not be able to pull more than 90L/s from the surrounding hydrants before which pressure falls below 20psi. The reason we didn't provide an HGL during fire is because the HGL/pressure is below 20psi based on their fire flow."

As well, unfortunately we have also determined that it is not feasible to use the 203mm watermain on Riverside west of Bank street to provide redundancy in case of a watermain break on Bank. The City's water departments are currently looking into available options that would be available to provide water service redundancy for these properties.

Once they have completed their due diligence, I am looking to set up a meeting with Novatech and include members of the City water department so that these issues can be discussed directly with them. I will be sure to keep you posted on any updated information that I receive in the meantime.

Thank you, Adam

Adam Baker, EIT

Engineering Intern Planning, Infrastructure and Economic Development Department - Services de la planification, de l'infrastructure et du développement économique Development Review - South Branch City of Ottawa | Ville d'Ottawa 110 Laurier Avenue West Ottawa, ON | 110, avenue. Laurier Ouest. Ottawa (Ontario) K1P 1J1 613.580.2424 ext./poste 26552, <u>Adam.Baker@ottawa.ca</u>

From: Francois Thauvette <f.thauvette@novatech-eng.com>
Sent: June 16, 2020 12:26 PM
To: Baker, Adam <adam.baker@ottawa.ca>
Cc: Steve Matthews <S.Matthews@novatech-eng.com>
Subject: RE: 1335 & 1339 Bank Street - Redevelopment - WM Boundary Condition Request

CAUTION: This email originated from an External Sender. Please do not click links or open attachments unless you recognize the source.

ATTENTION : Ce courriel provient d'un expéditeur externe. Ne cliquez sur aucun lien et n'ouvrez pas de pièce jointe, excepté si vous connaissez l'expéditeur.

Hi Adam,

Have you received any additional response from the water modelling group? Please advise.

Regards,

François Thauvette, P. Eng., Senior Project Manager | Land Development & Public Sector Engineering

**NOVATECH** Engineers, Planners & Landscape Architects

240 Michael Cowpland Drive, Suite 200, Ottawa, ON, K2M 1P6 | Tel: 613.254.9643 Ext: 219 | Cell: 613.276.0310 | Fax: 613.254.5867 The information contained in this email message is confidential and is for exclusive use of the addressee.

From: Baker, Adam <<u>adam.baker@ottawa.ca</u>>
Sent: Friday, June 12, 2020 11:46 AM
To: Francois Thauvette <<u>f.thauvette@novatech-eng.com</u>>
Cc: Steve Matthews <<u>S.Matthews@novatech-eng.com</u>>
Subject: RE: 1335 & 1339 Bank Street - Redevelopment - WM Boundary Condition Request

Hi Francois,

I forwarded your question regarding the fire flow to our water modelling group yesterday. I have made them aware that you and your client are very eager to submit. I will call you/set up a Teams meeting as soon as I hear back.

Thanks, Adam

Adam Baker, EIT

Engineering Intern Planning, Infrastructure and Economic Development Department - Services de la planification, de l'infrastructure et du développement économique Development Review - South Branch City of Ottawa | Ville d'Ottawa 110 Laurier Avenue West Ottawa, ON | 110, avenue. Laurier Ouest. Ottawa (Ontario) K1P 1J1 613.580.2424 ext./poste 26552, <u>Adam.Baker@ottawa.ca</u>

From: Francois Thauvette <<u>f.thauvette@novatech-eng.com</u>>
Sent: June 12, 2020 10:46 AM
To: Baker, Adam <<u>adam.baker@ottawa.ca</u>>
Cc: Steve Matthews <<u>S.Matthews@novatech-eng.com</u>>
Subject: RE: 1335 & 1339 Bank Street - Redevelopment - WM Boundary Condition Request

CAUTION: This email originated from an External Sender. Please do not click links or open attachments unless you recognize the source.

ATTENTION : Ce courriel provient d'un expéditeur externe. Ne cliquez sur aucun lien et n'ouvrez pas de pièce jointe, excepté si vous connaissez l'expéditeur.

Hi Adam,

Any chance you are available to chat via Teams? The client is very eager to submit, but we haven't received a response to the e-mail below.

Regards,

François Thauvette, P. Eng., Senior Project Manager | Land Development & Public Sector Engineering

**NOVATECH** Engineers, Planners & Landscape Architects 240 Michael Cowpland Drive, Suite 200, Ottawa, ON, K2M 1P6 | Tel: 613.254.9643 Ext: 219 | Cell: 613.276.0310 | Fax: 613.254.5867 The information contained in this email message is confidential and is for exclusive use of the addressee.

From: Francois Thauvette
Sent: Thursday, June 11, 2020 2:00 PM
To: Baker, Adam <<u>adam.baker@ottawa.ca</u>>
Cc: Steve Matthews <<u>S.Matthews@novatech-eng.com</u>>
Subject: RE: 1335 & 1339 Bank Street - Redevelopment - WM Boundary Condition Request

Hi Adam,

We have a concern with the following statement, provided in the e-mail below: *The total available flow @* 20psi using all hydrants within 150m of property is 90 L/s. Is this correct? It seems very low and should be addressed...

Please also provide the HGL during Max Day + Fire Flow conditions.

I will send you a Teams meeting invitation to discuss. What time works best for you?

Regards,

François Thauvette, P. Eng., Senior Project Manager | Land Development & Public Sector Engineering

**NOVATECH** Engineers, Planners & Landscape Architects

240 Michael Cowpland Drive, Suite 200, Ottawa, ON, K2M 1P6 | Tel: 613.254.9643 Ext: 219 | Cell: 613.276.0310 | Fax: 613.254.5867 The information contained in this email message is confidential and is for exclusive use of the addressee.

From: Baker, Adam <<u>adam.baker@ottawa.ca</u>>
Sent: Thursday, June 11, 2020 1:27 PM
To: Francois Thauvette <<u>f.thauvette@novatech-eng.com</u>>
Cc: Steve Matthews <<u>S.Matthews@novatech-eng.com</u>>
Subject: RE: 1335 & 1339 Bank Street - Redevelopment - WM Boundary Condition Request

Hi Francois,

We are still in the process of verifying that the unused watermain length along the portion of Riverside to the west of Bank could be put into use if there is a watermain break to provide temporary service to these properties in the case of a watermain break on Bank Street. I anticipate having an answer for you on this by the end of next week. If this is not a possibility, we will need to work with you further on how to provide water service redundancy for this development.

That being said, I understand that you and your client are very eager to submit the application. As such, I've provided the tentative boundary conditions below, which is based upon the proposed twin services, separated by a watermain valve, connecting on the 203mm Bank Street watermain:

The following are boundary conditions, HGL, for hydraulic analysis at 1335-1339 Bank St (zone 2W2C) assumed to be connected to the 203mm Bank St (see attached PDF for location).

Minimum HGL = 121.0m

Maximum HGL = 131.0m. The maximum pressure is estimated to be more than 80 psi. A pressure check at completion of construction is recommended to determine if pressure control is required.

## Multi-Hydrant Analysis

The total available flow @ 20psi using all hydrants within 150m of property is 90 L/s.

These are for current conditions and are based on computer model simulation.

Disclaimer: The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of watermains deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation.

Pleased to discuss further. Feel free to send over a Teams invite if you want to chat.

Thanks, Adam

#### Adam Baker, EIT

Engineering Intern Planning, Infrastructure and Economic Development Department - Services de la planification, de l'infrastructure et du développement économique Development Review - South Branch City of Ottawa | Ville d'Ottawa 110 Laurier Avenue West Ottawa, ON | 110, avenue. Laurier Ouest. Ottawa (Ontario) K1P 1J1 613.580.2424 ext./poste 26552, <u>Adam.Baker@ottawa.ca</u>

From: Francois Thauvette <<u>f.thauvette@novatech-eng.com</u>>
Sent: June 11, 2020 12:16 PM
To: Baker, Adam <<u>adam.baker@ottawa.ca</u>>
Subject: RE: 1335 & 1339 Bank Street - Redevelopment - WM Boundary Condition Request

CAUTION: This email originated from an External Sender. Please do not click links or open attachments unless you recognize the source.

ATTENTION : Ce courriel provient d'un expéditeur externe. Ne cliquez sur aucun lien et n'ouvrez pas de pièce jointe, excepté si vous connaissez l'expéditeur.

Hi Adam,

I am available any time if you want to chat via Teams (re: WM boundary conditions). My preference would be to call via Teams rather than by cell phone (if possible).

Regards,

François Thauvette, P. Eng., Senior Project Manager | Land Development & Public Sector Engineering

# **NOVATECH** Engineers, Planners & Landscape Architects

240 Michael Cowpland Drive, Suite 200, Ottawa, ON, K2M 1P6 | Tel: 613.254.9643 Ext: 219 | Cell: 613.276.0310 | Fax: 613.254.5867 The information contained in this email message is confidential and is for exclusive use of the addressee.

From: Baker, Adam <<u>adam.baker@ottawa.ca</u>>
Sent: Wednesday, June 10, 2020 10:45 AM
To: Francois Thauvette <<u>f.thauvette@novatech-eng.com</u>>
Cc: Steve Matthews <<u>S.Matthews@novatech-eng.com</u>>
Subject: RE: 1335 & 1339 Bank Street - Redevelopment - WM Boundary Condition Request

Hi Francois,

I've been working with our water resources group with regards to the water service redundancy on this site. Would you be available around 11:30 today for a Microsoft Teams call to discuss this?

Thanks, Adam

#### Adam Baker, EIT

Engineering Intern Planning, Infrastructure and Economic Development Department - Services de la planification, de l'infrastructure et du développement économique Development Review - South Branch City of Ottawa | Ville d'Ottawa 110 Laurier Avenue West Ottawa, ON | 110, avenue. Laurier Ouest. Ottawa (Ontario) K1P 1J1 613.580.2424 ext./poste 26552, <u>Adam.Baker@ottawa.ca</u>

From: Francois Thauvette <<u>f.thauvette@novatech-eng.com</u>>
Sent: June 10, 2020 9:57 AM
To: Baker, Adam <<u>adam.baker@ottawa.ca</u>>
Cc: Steve Matthews <<u>S.Matthews@novatech-eng.com</u>>
Subject: RE: 1335 & 1339 Bank Street - Redevelopment - WM Boundary Condition Request

CAUTION: This email originated from an External Sender. Please do not click links or open attachments unless you recognize the source.

ATTENTION : Ce courriel provient d'un expéditeur externe. Ne cliquez sur aucun lien et n'ouvrez pas de pièce jointe, excepté si vous connaissez l'expéditeur.

Hi Adam,

Any chance we can obtain the watermain boundary conditions today? The request was sent in over a week ago and the client is very eager to submit the Adequacy of Public Services report for OPA and ZBL amendments.

Regards,

François Thauvette, P. Eng., Senior Project Manager | Land Development & Public Sector Engineering

**NOVATECH** Engineers, Planners & Landscape Architects

240 Michael Cowpland Drive, Suite 200, Ottawa, ON, K2M 1P6 | Tel: 613.254.9643 Ext: 219 | Cell: 613.276.0310 | Fax: 613.254.5867 The information contained in this email message is confidential and is for exclusive use of the addressee.

From: Francois Thauvette <<u>f.thauvette@novatech-eng.com</u>> Sent: Tuesday, June 2, 2020 4:25 PM To: Baker, Adam <<u>adam.baker@ottawa.ca</u>>
 Cc: Steve Matthews <<u>S.Matthews@novatech-eng.com</u>>
 Subject: 1335 & 1339 Bank Street - Redevelopment - WM Boundary Condition Request

Hi Adam,

We are working on the proposed 25-storey mixed-use development at 1335 & 1339 Bank Street. The properties will be merged and the new building will replace the old car dealership (1335) and Harvey's restaurant (1339) sites.

We are sending you this e-mail to request watermain boundary conditions for the 200mm dia. WM in Bank Street (as shown on geoOttawa). The anticipated water demands for the proposed site are as follows:

- Average Day Demand = 2.54 L/s
- Maximum Day Demand = 6.31 L/s
- Peak Hour Demand = 13.85 L/s
- Maximum Fire Flow Demand = 167 L/s (see attached FUS calculations for details)

Please note that we anticipate requiring two (2) water services due to the high domestic demands. These will likely be located near the NW property corner. A multi-hydrant approach to firefighting is also anticipated to be required. Based on a review of geoOttawa, there are a few hydrants within 75m of the subject site, one of which is near the NW corner of the subject site. A hydraulic analysis will be completed, once the WM boundary conditions are provided by the City.

We are aware that a Bank Street Renewal project is underway, including roadway modifications as well as underground infrastructure upgrades, but have no information regarding this project. Would you be able to provide us with preliminary plans related to the Bank Street Renewal project, s this will have an impact on our grading and servicing design. Our understanding is that the City PM for the Bank Street Project is Roxanne Tubb (roxanne.tubb@ottawa.ca).

Please send us an e-mail should you require any additional information.

Regards,

ī

François Thauvette, P. Eng., Senior Project Manager | Land Development & Public Sector Engineering

#### **NOVATECH** Engineers, Planners & Landscape Architects

240 Michael Cowpland Drive, Suite 200, Ottawa, ON, K2M 1P6 | Tel: 613.254.9643 Ext: 219 | Cell: 613.276.0310 | Fax: 613.254.5867 The information contained in this email message is confidential and is for exclusive use of the addressee.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

י ו

' '

ı,

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.



