


1 Site Plan
1 : 200

APPROVED REFUSED
 THIS ____ DAY OF _____, 20____
 DERRICK MOODIE
 MANAGER, DEVELOPMENT REVIEW – WEST
 PLANNING, INFRASTRUCTURE & ECONOMIC
 DEVELOPMENT DEPARTMENT, CITY OF OTTAWA

HYDRO OTTAWA STANDARDS REFERENCES		
ITEM	SPEC ID	DRAWING TITLE
SWITCH GEAR MANHOLE AND TRANSFORMER PAD	UCS0025	MAHOLE PRECAST 2 WAY SWITCHING 612 - CONSTRUCTION DETAIL
SWITCHGEAR AND TRANSFORMER GROUNDING	UGS0002	GROUNDING, TRANSFORMER OR SWITCHGEAR BASE - CONSTRUCTION DETAIL
EQUIPMENT PROTECTION BOLLARDS	UFS0001	BOLLARDS PROTECTIVE - CONSTRUCTION DETAIL
TRANSFORMER CLEARANCES	UTS0038	TRANSFORMER CLEARANCE

Drawing Notes	
Key #	Comments
1	EXISTING HYDRO OTTAWA PAD MOUNTED SWITCHGEAR. CONCRETE FOUNDATION, PAD, MANHOLE AND BOLLARDS AS PER HYDROOTTAWA STANDARDS.
2	NEW PAD MOUNTED TRANSFORMER SUPPLIED AND INSTALLED BY HYDRO OTTAWA. CONCRETE FOUNDATION, PAD, AND BOLLARDS TO BE PROVIDED BY HYDRO CONTRACTOR AS PER HYDRO OTTAWA STANDARDS.
3	NEW INDOOR EMERGENCY GENERATOR (347/600V, 3Ø, 4W, 250kW/313kVA) C/W BASE FUEL TANK AND SOUND ENCLOSURE. THE GENERATOR TO ALSO BE PROVIDED WITH A BATTERY CHARGER, BLOCK HEATER AND MAIN BREAKER.
4	NEW MAIN UNDERGROUND ELECTRICAL FEED TO THE BUILDING, 347/600V, 3Ø, 4W, 1600A. MAIN FEEDERS SHALL BE 4 PARALLEL RUNS OF 4-500MCM-103Ø CONDUIT.
5	NEW EMERGENCY FEED FROM THE GENERATOR TO THE MAIN EMERGENCY SPLITTER TROUGH, 347/600V, 3Ø, 4W, 250A. FEEDERS SHALL RUN UNDERGROUND.
6	ELECTRICAL FEEDS FROM PANEL P-01 IN MAIN ELECTRICAL ROOM FOR THE GENERATOR BATTERY CHARGER (120V, 15A) AND BLOCK HEATER (120V, 15A).
7	FIBRE OPTIC AND CABLE COMMUNICATION PEDESTALS. COORDINATE EXACT LOCATION ON SITE.
8	PROVIDE ELECTRICAL FEED FOR EXTERIOR SIGN LIGHTING THROUGH THE CONCRETE FOUNDATION OF THE SIGN ALONG WITH SIGN LIGHT FIXTURES AS PER CLIENT REQUIREMENTS (120, 15A, 3-#10AWG, 25Ø).
9	PROVIDE POWER (600V) FOR ROOF MOUNTED ERV UNIT C/W WEATHERPROOF DISCONNECT SWITCH.
10	PROVIDE POWER (600V) FOR ROOF MOUNTED DRY-COOLER C/W WEATHERPROOF DISCONNECT SWITCH.
11	PROVIDE POWER (208V, 3Ø) FOR THE ROOF MOUNTED ELEVATOR SHAFT PRESSURIZATION FAN C/W WEATHERPROOF DISCONNECT SWITCH.
12	PROVIDE ROOFTOP 20A RECEPTACLE FOR EQUIPMENT MAINTENANCE PURPOSES C/W WEATHERPROOF COVER.
13	PROVIDE DUPLEX RECEPTACLE ON DEDICATED CIRCUIT FOR EXTERIOR USE C/W WEATHERPROOF COVER.
14	2-103Ø RIGID PVC CONDUITS (1 FIBRE OPTIC AND 1 CABLE) FOR COMMUNICATIONS TO BE PROVIDED WITH PULL CORDS AND TERMINATE IN THE MAIN ELECTRICAL ROOM ON LEVEL P1. COORDINATE EXACT TERMINATIONS WITH LOCAL UTILITIES.
15	PROVIDE 20A, 208V, 1Ø TWIST LOCK RECEPTACLE FOR SWING STAGE EQUIPMENT C/W WEATHERPROOF COVER.
16	PROVIDE DUPLEX RECEPTACLE ON DEDICATED CIRCUIT MOUNTED ON THE PROPOSED LIGHT POLE FOR EXTERIOR USE C/W WEATHERPROOF COVER.
17	ELECTRICAL BBQ OUTLET: NEMA 6-50R RECEPTACLE INSTALLED IN A RECESSED WALL BOX WITH A "WHILE-IN-USE" COVER.



DATE	REVISION	REF
20 JUL 17	RE-ISSUED FOR SITE PLAN APPLICATION	2
24 MAR 17	SITE PLAN APPLICATION	1

THE ENGINEER WAIVES ANY AND ALL RESPONSIBILITY AND LIABILITY FOR PROBLEMS WHICH ARISE FROM FAILURE TO FOLLOW THESE PLANS, SPECIFICATIONS AND THE DESIGN INTENT OR FOR PROBLEMS WHICH ARISE FROM OTHER FAILURE TO OBTAIN AND / OR FOLLOW THE ENGINEER'S GUIDANCE WITH RESPECT TO ANY ERRORS, OMISSIONS, INCONSISTENCIES, AMBIGUITIES OR CONFLICTS WHICH ARE ALLEGED.

THIS DRAWING IS THE PROPERTY OF GOODKEY WEEDMARK & ASSOCIATES LIMITED AND ALL COPYRIGHTS ARE RESERVED. NO USE OF THIS DRAWING MAY BE MADE WITHOUT EXPRESS WRITTEN CONSENT. DO NOT SCALE DRAWINGS.

L'INGÉNIEUR DÉCLINE TOUTE RESPONSABILITÉ DÉCOULANT DE PROBLÈMES FAISANT SUITE AU NON RESPECT DES PLANS, DEVIS ET DE L'INTENTION DU CONCEPT OU D'UN DÉFAUT D'OBTENIR ET / OU DE SUIVRE LES CONSEILS DE L'INGÉNIEUR EN CE QUI CONCERNE LES ERREURS, OMISSIONS, INCONSISTANCES, AMBIGUITÉS OU CONFLITS ALLEGÉS.

CE DESSIN EST LA PROPRIÉTÉ LITTÉRAIRE DE GOODKEY WEEDMARK & ASSOCIATES LIMITED ET TOUS LES DROITS SONT RÉSERVÉS. L'UTILISATION EST INTERDITE SANS LE CONSENTEMENT ÉCRIT DE L'INGÉNIEUR. NE PAS MESURER LES DESSINS À L'ÉCHELLE.

Goodkey Weedmark Consulting Engineers

GOODKEY WEEDMARK & ASSOCIATES LIMITED
 1688 Woodward Dr. Ottawa Ontario Canada K2C 3R8
 613 727-5111 Voice 613 727-5115 Fax www.gwal.com Web

Project/Projet Nord du projet

Project/Projet
**1136 MARITIME WAY
 KANATA, ON**

Drawing Title/Titre du dessin
**ELECTRICAL
 SITE PLAN**

Scale Échelle	AS NOTED	Project no./No. du projet 2017-190
Design by Conçu par	LEPINE	Drawing/Dessin
Drawn by Dessiné par	LEPINE	E001
Reviewed by Examiné par	GWAL	OF
Date Date	MARCH 2017	Revision no. 1 Acad file/Fichier: -

D07-12-17-0038