



**Goodkey, Weedmark
& Associates Limited**

Consulting Engineers

1688 Woodward Dr.
Ottawa, ON
Canada
K2C 3R8

Tel. 613-727-5111
Fax 613-727-5115
info@gwal.com

Principals & Associates

A. Bogdanowicz, P.Eng.
M.G. Carriere, C.E.T.
R.J. McIntyre, P.Eng.
F.W.A. Bann, P.Eng.
R. Lefebvre, P.Eng.
D.R. Vyas, P.Eng., MIEEE
S. Hamilton, P.Eng.
W. Needham, C.E.T.
J. Moffat, P.Eng.
E. Pérusse, P.Eng., ing.
R. Boivin, P.Eng., ing.
R. Leonard, P.Eng.
M. Sarasin, P.Eng.

July 20, 2017

VIA E-MAIL (alex@lepinecorp.com & home@lepinecorp.com)

Lepine Apartments
201 - 320 March Rd.
Kanata, ON
K2K 2E3

ATTENTION: MR. ALEXANDRE LALONDE, P.ENG., PROJECT ENGINEER

**SUBJECT: 1088 MARITIME WAY
NEW APARTMENT BUILDING
OUR PROJECT NO. 2017-189**

Dear Sir:

We have designed the site lighting for the new six (6) storey apartment building, located at 1088 Maritime Way, in accordance with the following guidelines as requested by Lepine Apartments:

1. It must be designed using only fixtures that meet the criteria for Full Cut-Off (Sharp cut-off) Classification, as recognized by the Illuminating Engineering Society of North America (IESNA or IES), and;
2. It must result in minimal light spillage onto adjacent properties. As a guideline, 0.5 fc is normally the maximum allowable spillage.
 - .1 There is an exception where light levels are above 0.5 fc at the driveway entrance to the parking garage.

Yours very truly,

GOODKEY, WEEDMARK & ASSOCIATES LIMITED



Richard Boivin, P.Eng., ing.
Associate

RB/lm

