



Smith + Andersen

1600 Carling Ave Suite 530 Ottawa Ontario K1Z 1G3
613 230 1186 f 613 230 2598 smithandandersen.com

2018-04-11

City of Ottawa

Infrastructure Services and Community Sustainability
110 Laurier Avenue West
Ottawa, ON
K1P 1J1

ATTENTION: CITY BUILDING OFFICIAL

**RE: ORLEANS HEALTH HUB
2225 MER-BLEUE ROAD, OTTAWA, ONTARIO
S+A PROJECT # 17191.001**

Dear City Building Official:

This letter is to confirm that the resulting light spillage onto adjacent properties is below the maximum allowable spillage (0.5 fc) by the City of Ottawa, and that the exterior light fixtures used for this project meet the criteria for full cut-off classification as recognized by the IESNA with the exception of:

- 4x Tree uplights – basis of design based on ecosense rise 080 single – 600 lumens, 3000K.



Yours truly,

SMITH + ANDERSEN

Andre Drouin, P.Eng.

Principal

17191.001.e200.ltr001.Site_ltg.docx

C.C. Mike Mitani – Smith + Andersen

