



City of Ottawa
Development Review
110 Laurier Avenue West, 4th Floor
Ottawa, Ontario, K1P 1J1

April 23, 2018

Attention: Stream Shen, MCIP RPP, Planner II

Phone: (613) 580-2424 x24488
Fax: --

**Re: CAMP-MART, 20 Frank Nighbor Place, Kanata, Ontario
WSP #171-18083-00**

Dear Stream,

This letter is to confirm that the exterior parking lot light fixtures and poles, proposed for this project, meet the criteria for full cut-off classification as recognized by the IESNA. The resulting light spillage onto adjacent properties is below the maximum allowable spillage 5.0 LUX (0.5 FC) by City of Ottawa Standards, and is below the maximum allowable spillage 0.5 LUX (0.05 FC) by MTO standards along MTO right of way.

Yours truly,



Craig Melvin, P.Eng., Senior Electrical Engineer

WSP Canada Inc.