



KEY	qty.	BOTANICAL NAME	COMMON NAME	SIZE	CONDITION	REMARKS
AR	AS	Acer rubrum	Red Maple	100mm DBH.	Good	
AS	1	Acer saccharum	Sugar Maple	400-700mm DBH.	Poor-Good	
GT	2	Gleditsia triacanthos	Yellow Locust	150mm DBH.	Good	
PA	*	Picea abies	Norway Spruce	200-400mm DBH.	Good	
PG	*	Picea glauca	White Spruce	200-400mm DBH.	Good	
PN	*	Pinus nigra	Austrian Pine	200-400mm DBH.	Good	
PP	*	Picea pungens	Colorado Spruce	200-400mm DBH.	Good	
SV	*	Syringa vulgaris	Common Purple Lilac	50-100mm DBH.	Good	

1. It is the responsibility of the approved contractor or official to report any errors, omissions or discrepancies on this plan with actual site conditions to the Landscape Architect before proceeding with construction.
2. The contractor is to notify all utility companies and authorities prior to any excavation and ascertain locations of underground services.
3. The contractor is to reinstate all areas and items damaged as a result of construction activity.
4. The contractor is to comply with all pertinent codes and by-laws.
5. The contractor is to maintain a positive surface run-off throughout the entire construction period.
6. The Landscape Architect is not responsible for subsurface conditions.
7. The contractor is to identify all existing trees to remain on site with the Landscape Architect prior to construction.
8. The contractor is to stake the proposed location of all plant material in conjunction with the Landscape Architect prior to excavation.
9. Minimum distances for selected deciduous trees are as follows:
  - Building Foundations 7.5m
  - Sidewalks 1.5m
  - Public Streets 2.5m
  - Underground Infrastructure 2.0m
10. All trees within 1m of underground utility trenches are to be excavated by hand.
11. Remove all protective wrapping from tree trunks after installation.
12. Staking of trees shall only be performed if necessary.
13. Ensure that mulch is pulled back a min. distance of 75mm from base of tree trunk.

1200mm

EXISTING TREE

NOTES:

- INSTALL FENCE PRIOR TO ANY CONSTRUCTION ACTIVITY
- NO CONSTRUCTION ACTIVITIES INCLUDING MATERIAL STORAGE OR DISPOSAL, OR PARKING IS TO TAKE PLACE WITHIN THE DESIGNATED PROTECTION AREA.
- ANY ROOTS ENCOUNTERED, ARE TO BE CLEANLY CUT WITH A SAW OR PRUNERS (DO NOT USE BACKHOE OR OTHER HEAVY EQUIPMENT). ROOTS ARE TO BE COVERED IMMEDIATELY WITH TOPSOIL, BURLAP OR MULCH AND KEPT DAMP.

1.2m SNOW FENCE WIRE (MIN 3) TO STEEL T-BAR POSTS (@ 2.4m C.C. MAX.) 150 x 150 WOOD TOP RAIL BOLTED TO POSTS.

2 TREE PROTECTION FENCE  
L1 SCALE: NTS

CIVIL  
ENGINEERS:

T L MAK ENGINEERING CONSULTANTS LTD.  
1455 YOUVILLE DRIVE  
ORLEANS, ONTARIO K1C 6Z7  
Tel: (613) 837-5516

EXISTING TREE TO REMAIN

GROUP OF EXISTING TREES TO REMAIN

EXISTING GRASS TO REMAIN

EXISTING TREE TO BE REMOVED

TREE PROTECTION FENCE

PROPOSED INTERLOCK PAVERS

PROPOSED PERMEABLE GRAVEL OR PAVERS

PROPOSED SEED

2	REVISED PER NEW SITE PLAN	05/02/2018	ML	JL	
1	ISSUED FOR DISCUSSION AND REVIEW	04/10/2018	ML	JL	
No.	Issue	Date mm/dd/yyyy	DR	CK	

**JAMES B. LENNOX & ASSOCIATES INC.**  
**LANDSCAPE ARCHITECTS**  
3332 CARLING AVE. OTTAWA, ONTARIO K2H 5A8  
Tel. (613) 722-5168 Fax. 1(866) 343-3942

PROPOSED ADDITION HIEU GIANG  
VIETNAMESE BUDDHIST TEMPLE

3310 LEITRIM ROAD, OTTAWA ON

TREE CONSERVATION REPORT AND  
LANDSCAPE PLAN

AS SHOWN
START DATE
MARCH 2018
PROJECT NO.
XX-XXX

## L.1

PLOT SIZE ARCH-D