

May 4, 2018

VIA E-MAIL

City of Ottawa
Planning, Transit, and the Environment
110 Laurier Avenue West
Ottawa, ON K1P 1J1

Re: File Number: D07-12-18-0063
Urbandale Kanata Lakes Plaza – Goulbourn Forced Road and Kanata
Avenue, Site Plan Permit Submission

With reference to the submitted site lighting plan, the site lighting has been designed with sharp cut-off fixtures such that a maximum light spillage of 0.5fc will occur on adjoining properties.

If you have any further questions or require any further clarification, please contact me at your earliest convenience.

Yours Truly,

JRP Engineering



Michael Gerrard, P.Eng

