

July 9, 2018

City of Ottawa  
Planning, Transit, and the Environment  
110 Laurier Avenue West  
Ottawa, ON K1P 1J1

Re: Cowan's Grove Plaza  
4791 Bank St


Site Plan Permit Submission

The site lighting plan has been designed with sharp cut-off fixtures such that a maximum light spillage of 0.5fc will occur on adjoining properties.

If you have any further questions or require any further clarification, please contact me at your earliest convenience.

Yours Truly,

JRP Engineering



Michael Gerrard, P.Eng

