



## Smith + Andersen

1600 Carling Ave Suite 530 Ottawa Ontario K1Z 1G3

613 230 1186 f 613 230 2598 [smithandandersen.com](http://smithandandersen.com)

2018-10-29

City of Ottawa | Ville d'Ottawa  
110 Laurier Avenue West | 110 avenue Laurier Ouest  
Ottawa, ON K1P 1J1

**Attention: Julie Lebrun**

**RE: MONTFORT HOSPITAL  
ORLEANS HEALTH HUB  
S+A PROJECT # 17191.001  
RESPONSES TO CITY COMMENTS FOR SPA**

Dear Ms. Lebrun:

The control flow roof drains have been designed to meet the storm water management objective requirements of the 2012 Ontario Building Code Section 7.4.10.4 and in accordance with the storm water management requirements as defined by the civil engineer.

Yours truly,

SMITH + ANDERSEN

Darrell Noseworthy, P.Eng

Associate

17191-001.M001.L001

