



LIMITING DISTANCE = 7.26m
 AREA OF EXPOSED BUILDING FACE (AREA 'A') = 498 sq.ft. (46.3m²)
 MAXIMUM PERMITTED U.P.O. = 85% (9.10.14.4)
 AREA OF U.P.O. = 182.0 sq.ft. (16.9m²)
 PERCENT OF U.P.O. = 36.5%
 REQUIRED WALL CONSTRUCTION (9.10.14.5)
 - 45 MIN. FIRE RESISTANCE RATING
 - COMBUSTIBLE CONSTRUCTION
 - COMBUSTIBLE CLADDING


M. David Blakely
 Architect Inc.
 2200 Prince of Wales Dr. - Suite 101
 Ottawa, Ontario K2E 6Z9
 Phone (613) 226-8811 Fax (613) 226-7942

GENERAL NOTES:
 1. THE CONTRACTOR IS RESPONSIBLE FOR CHECKING AND VERIFYING ALL DIMENSIONS. ANY DISCREPANCY MUST BE REPORTED TO M. DAVID BLAKELY ARCHITECT INC.
 2. ALL WORK AND MATERIALS TO BE IN COMPLIANCE WITH ALL CODES, REGULATIONS, AND BY-LAWS.
 3. ADDITIONAL DRAWINGS MAY BE ISSUED FOR CLARIFICATION TO ASSIST THE PROPER EXECUTION OF WORK. SUCH DRAWINGS WILL HAVE THE SAME MEANING AND INTENT AS IF THEY WERE INCLUDED WITH THE PLANS IN CONTRACT DOCUMENTS.
 4. DO NOT SCALE DRAWINGS.
 5. THIS DRAWING SHALL NOT BE USED OR COPIED WITHOUT THE AUTHORIZATION OF THE ARCHITECT.

POST SCHEDULE

P1 - 3" DIA. ADJUSTABLE STEEL TELEPOST 8500 POUND CAP. (MIN.)
 P2 - 2-2"x4.4 OR 8" (AS APPLICABLE)
 P3 - 3-2"x4.6 OR 8" (AS APPLICABLE)
 P4 - 4-2"x4.6 OR 8" (AS APPLICABLE)
 P5 - 5-2"x4.6 OR 8" (AS APPLICABLE)
 P6 - HSS 3"x3"x1/8" C/W 5"x3/8"x8" B. PL. & CAP PL.

BRICK LINTEL SCHEDULE

OPENING UP TO	ANGLE SIZE
5'-0"	L 3 1/2"x3 1/2"x5/16"
7'-0"	L 4"x3 1/2"x5/16"
8'-0"	L 5"x3 1/2"x5/16"
9'-0"	L 5"x3 1/2"x3/8"
10'-0"	L 6"x4"x3/8"

ARCHITECT SEAL:

12.		24.
11.		23.
10.		22.
9.		21.
8.		20.
7.		19.
6.		18.
5.		17.
4.		16.
3.		15.
2.		14.
1.	07/12/16	13.

NO.	DATE	DESCRIPTION	REVISED	DATE	DESCRIPTION	REVISED
1.	07/12/16	FOR REVIEW	SM.			

PROJECT: **BACK TO BACK TERRACE TRAILS EDGE**
 OTTAWA, ONTARIO
 CLIENT: 

DRAWING TITLE: **BLOCK 6 FOUNDATION PLAN & ELEVATIONS**
 DATE: DEC., 2016. SCALE: 3/16" = 1'-0"
 DRAWN BY: SBM CHECKED: MDB
 SHEET No.: **B6-1**

\\lon-pc\1\2017 PROJECTS\Richcraft Homes\Trails Edge\Blocks\Back to Back Terrace\Block 6 170728-For Site Plan.dwg, 28/07/2017 11:11:40 AM