

re: **Response to City Comments - Grading Plan Review**
Proposed Commercial Development
2390 Stevenage Drive - Ottawa

to: McIntosh Perry - **Mr. Evan Garfinkel** - e.garfinkel@mcintoshperry.com

date: January 18, 2019

file: PG4583-MEMO.01

Further to your request and authorization, Paterson Group (Paterson) prepared the current memorandum to provide a grading plan review for the proposed commercial development. This memorandum should be read in conjunction with Paterson Group Report PG4583-1 dated July 30, 2018.

The present memo has been prepared in response to Comment 56 in the City Review Comments dated November 28, 2018 for the aforementioned site.

Grading Plan Review

Paterson reviewed the following grading plan prepared by McIntosh Perry regarding the aforementioned development:

- Site Grading and Drainage Plan - Drawing No. C101 - Project CP-18-0170 - Revision 2 dated January 10, 2019.

Based on our review, the proposed grades are in conformance with our permissible grade raise recommendations provided in the above noted geotechnical report and are acceptable from a geotechnical perspective. Therefore, no lightweight fill is required at the subject site.

We trust that this information satisfies your requirements.

Paterson Group Inc.



Colin Belcourt, P.Eng.



David J. Gilbert, P.Eng.

Paterson Group Inc.

Head Office and Laboratory
154 Colonnade Road South
Ottawa - Ontario - K2E 7J5
Tel: (613) 226-7381 Fax: (613) 226-6344

Northern Office and Laboratory
63 Gibson Street
North Bay - Ontario - P1B 8Z4
Tel: (705) 472-5331 Fax: (705) 472-2334

St. Lawrence Office
993 Princess Street
Kingston - Ontario - K7L 1H3
Tel: (613) 542-7381