



Site Plan Control Approval

February 27, 2019

City of Ottawa

Dear Sir,

**Subject: Site Lighting – Sysco Parking Lot
Our File 181-15445-00**

I, the undersigned verify that site lighting from the site plan application for above project will not exceed 0.5 fc (5.38 lux) maintained on the adjacent properties at grade level.

Furthermore, all luminaries proposed on the aforementioned site plan will meet the criteria for Full Cut-Off (Sharp cut-off) Classification, as recognized by the Illuminating Engineering Society of North America (IESNA or IES).

Site lighting is proposed to be controlled through a time clock and photocell arrangement at the building such that the photocell will provide "on" function and time clock will provide "off" function for daily scheduling (time of day off/on function field adjustable).

Our site plan lighting design is based on the attached Site Plan Drawing c/w Photometric Lighting Calculations.

Please call if you require any additional information.

Yours very truly,

WSP Canada Inc.

A handwritten signature in blue ink, appearing to read 'Craig Melvin', written over the printed name.

Craig Melvin, P. Eng.
Senior Electrical Engineer, Buildings – Mechanical & Electrical

Attachment

Suite 300
2611 Queensview Drive
Ottawa, ON, Canada K2B 8K2

T +1 613 829-2800
F +1 613 829-8299
wsp.com