

Montreal March 27th,

Steve Belan, MCIP, RPP
City of Ottawa
Planning, Infrastructure and Economic Development
110 Laurier Avenue West, 4th Floor
Ottawa, ON, K1P 1J1

PROJECT: 4200 Innes Road (2029 Mer Bleue)
DLI FILE #: 19130
SUBJECT: Site lighting conformity declaration.

Dear Mr. Belan,

Following the first round of comments on the site plan control application (File No. D07-12-18-0179) with regards to comment A9 on the conformity of the site lighting design, we can confirm that even though the current early stage landscape drawings does not show any new lighting, once the design phase moves on for this project, the site will indeed incorporate new lighting on the building, pathways and parking lots. We can confirm that the lighting design has the intent to comply with city regulations. Full cut-off classification fixtures will be chosen. Careful positioning of the fixtures and lighting calculations will also make sure that there is minimum spillage (maximum of 0.5 fc) on adjacent properties.

Please accept, Mr. Belan, my best regards.

DUPRAS LEDOUX INC.

Francis Audette, P. Eng, MBA, PA LEED
Electrical Engineer, Director
Dupras Ledoux
225 Chabanel West, Suite 1100, Montreal, Quebec, H2N 2C9
438-993-5974

DUPRAS LEDOUX INC.
225 Chabanel West - suite 1100
Montreal, Canada, H2N 2C9
T 514.381.9205
✉ reception@dupras.com
www.dupras.com
Certified ISO 9001-2008