

Planning

Design and Design  
Review

Seismic Assessment

Structural Evaluation

Condition Surveys

Structural  
Rehabilitation

Feasibility Studies

Construction  
Engineering

Contract Administration  
and Tendering

Construction  
Inspection

Quality Verification  
Engineering (QVE)

# Chateau Laurier Expansion 1 Rideau Street Ottawa, ON

## SERVICING AND STORM WATER MANAGEMENT REPORT

Larco Investments Ltd.  
100 Park Royal S  
West Vancouver, BC V7T 1A2  
TEL.: (604) 925-2700

April 17<sup>th</sup>, 2019  
REVISION 5



**REMISZ**

Consulting  
Engineers

April 17, 2019

File No. 2016-146

Larco Investments Ltd  
100 Park Royal S  
West Vancouver, BC  
V7T 1A2

**RE:           Chateau Laurier Expansion  
              Ottawa, ON  
              Servicing and Storm Water Management Report**

---

## 1) Introduction

Remisz Consulting Engineers Ltd. has been retained by Larco Investments to develop a site servicing plan, grade control plan, drainage plan, storm water management report, and a site servicing report for the proposed expansion of the Chateau Laurier. The site is located at 1 Rideau Street in Ottawa, ON at the north-west corner of Rideau Street and Mackenzie Avenue. This report is a summary of the data and calculations required for the site servicing of this project, along with the necessary design drawings and supporting documentation.

Our servicing and site works design is done in accordance with the following documents and standards:

- *City of Ottawa Sewer Design Guidelines;*
- *City of Ottawa Design Guidelines – Water Distribution;*
- *City of Ottawa Standard Tender Documents;*
- *Ontario Provincial Standards for Road and Public Works;*
- *MTO Drainage Management Manual;*
- *MTO Highway Drainage Design Standards*

This report has been prepared in consideration of the above mentioned guidelines and with the site plan prepared by Architects Alliance for the proposed development. Should there be any changes in the design features affecting site servicing conditions, RCE should be accordingly notified to review the design recommendations.

The present report is focusing on the technical part of the work only. For legal aspects, i.e. Front Ending Agreement with the City of Ottawa, NCC approvals etc., will be submitted separately by the project planner.

## 2) Project Data

The site is located north of Rideau Street, West of Mackenzie Avenue. The new addition will be constructed north of the existing Chateau Laurier Hotel. The new addition to the historic landmark consists of a new courtyard, forecourt, glass link, and 7-storey building. Also included is a new underground parking garage with

5 levels of parking space available to hotel guests and the general public. Existing and designed site grades are provided in Grading Plan, see Appendix C.

### 3) Storm Water Management

General storm water management parameters were discussed with the City of Ottawa and conditions are provided in Appendix B. The storm water runoff for the site must be controlled to a 5 year storm at  $C=0.5$  or the existing  $C$  value (whichever is less) and hold up to a 100 year storm event on site.

The pre-development site surface consists of a parking garage, terrace, and entrance areas with coefficient  $C=0.95$ . As per City of Ottawa requirements for storm water calculations, coefficient  $C=0.5$  is taken. Post-development site surface consists of hotel roofs of 7<sup>th</sup> storey roof, 5<sup>th</sup> storey roof, ground floor roof, courtyard, glass link, and forecourt. Coefficient  $C$  for 5 years storm is 0.95, and for 100 years storm is 1.00. Terrace and entrance provide uncontrolled runoff which is subtracted from the allowable storm water release rate. Calculations are shown in Appendix D; results are summarized below.

<b>Allowable Controlled Runoff</b>	47.47 L/s
<b>Required storage of water on site (5 year storm)</b>	20.47 m <sup>3</sup>
<b>Required storage of water on site (100 year storm)</b>	58.91 m <sup>3</sup>
<b>Total Roof and Courtyard Area</b>	3280 m <sup>2</sup> (3169.8 m <sup>2</sup> inside property)

To provide the allowable water release, a total of 17 adjustable control units (see Appendix E) have been designed with closed weir opening. The devices have 10 gal/min flow rate, providing total release of 10.7 L/s. Schematic device placement is shown on Detail A of DWG S-01 in Appendix C. Flood depth for 5 years event is 80mm and stored amount of water is  $0.5 \times 1522\text{m}^2$  (flood area)  $\times$  0.08m (flood depth) = 60.9m<sup>3</sup>. Flood depth for 100 years event is 100mm and stored amount of water is  $0.5 \times 2326\text{m}^2$  (flood area)  $\times$  0.1m (flood depth) = 116.3m<sup>3</sup>. Allowable depth for 5 years event is 100mm; for 100 years event is 300mm. This meets the required conditions and amount of stored water is exceeding the requirements.

In case of flood exceeding 100 year event, storm water is designed to flow in West direction towards existing depressed area. There is no need to install additional back-up storm water management devices.

Existing storm and sanitary is connected to manhole located at the entrance of Major Hill's Park. There are three options for connecting the new sanitary and storm service lines. For each option once the lines reach the manhole, the new sanitary and storm services will connect to existing lines in existing deeper service tunnels.

**Option one** includes a 500mm diameter tunnel, sloped at 10% with gravity driven sanitary and storm lines within it extending from below the lowest level of the new hotel building to the existing manhole in Major Hill's Park. The sanitary and storm lines are 150mm in diameter.

**Option two** includes the use of a force main and pump to extend up from the lowest level of the new building up to the respective gravity driven lines located 2 meters below grade. The sanitary and storm lines may be 150mm or 200mm in diameter. Use of a 150mm diameter line may result in clogging and therefore increased maintenance costs. Pressurized sections of pipes diameter is as per manufacturer requirements in order to provide a lift of approximately 15 meters. Required storm water storage for this option, for one hour rain duration is 40m<sup>3</sup> with a set of pumps (one working and one standby) with a capacity of 11 L/sec. Sanitary storage is to be 10-12m<sup>3</sup> complete with a set of pumps (one working and one standby) with max flow capacity of 1.43 L/s.

**Option three** includes a gravity line for the hotel 2 meters below grade and the garage sewer to be collected at the lower level into smaller tank which is then pumped up to the gravity line. This reduces the size of the tank and the pumps. Required storm water storage for this option, for one hour rain duration is  $10\text{m}^3$  with a set of pumps (one working and one standby) with a capacity of 3 L/sec. Sanitary storage is to be  $3\text{m}^3$  complete with a set of pumps (one working and one standby) with max flow capacity of 0.6 L/s.

We recommend the use of **option one**. During our previous discussion with the City, option one was approved for implementation. For detailed design of the site servicing please see drawing S-02 and S-02.1 in Appendix H.

#### 4) Water Supply

General water supply parameters were discussed with the City of Ottawa and conditions are provided in Appendix B. The proposed site can be serviced via one connection to existing water main along Mackenzie Avenue, a second connection to the existing Hotel water main, and will require a looped system for redundancy. The water connection to the existing Hotel will require a water meter to track consumption of the new building. Calculations for water supply rates based on the City of Ottawa Design Guidelines are provided in Appendix F; results are summarized below.

<b>Average Daily Flow</b>	29.53 L/min or 0.49 L/s
<b>Maximum Day Flow</b>	44.30 L/min or 0.74 L/s
<b>Peak Hour Flow</b>	79.73 L/min or 1.33 L/s
<b>Total Required Fire Flow</b>	13,000 L/min or 217 L/s

Water demands have been submitted to the City of Ottawa and the following boundary conditions were provided:

Minimum HGL = **106.1m**  
Maximum HGL = **118.1m**  
Max. Day + Fire Flow = **103.2m**

The water analysis results are summarized in the table below.

Condition	Demand (L/s)	Min/Max Allowable Operating Pressures (psi)	Limits of Design Operating Pressures (psi)
High Pressure	0.49	80 (Max)	65.5
Maximum Daily Demand and <i>Fire Flow</i>	217.4	20 (Min)	44.4
Peak Hour	1.33	40 (Min)	48.5

Therefore, based on the boundary conditions provided by the City, the existing water main system can provide adequate domestic flows sufficient for minimum requirements. According to current design of the proposed development, structures are anticipated to reach a maximum height of 99.96m, while the available pressure for water supply for peak hour demand is 103.2m. This meets the required conditions.

The required size of the water service looped connection is 200mm. The proposed service connection is shown on the Site Services Plan, see Appendix H.

## 5) Sanitary Drainage

General sanitary drainage parameters were discussed with the City of Ottawa and conditions are provided in Appendix B. The new addition will not be allowed to drain into the existing combined sewer (on Mackenzie Avenue). The addition will require a new 500mm diameter tunnel to be constructed to connect to the existing manhole at the entrance of Major Hill's Park.

Calculations for sanitary flow are provided in Appendix G. The sanitary servicing design was provided accordingly. The design flows were calculated as per Ottawa Sewer Design Guidelines.

<b>Average Flow</b>	0.50 L/s
<b>Peak Flow</b>	0.50 L/s
<b>Peak Flow (Wet Weather)</b>	0.63 L/s

Existing storm and sanitary is connected to manhole located at the entrance of Major Hill's Park. There are three options for connecting the new sanitary and storm service lines. For each option once the lines reach the manhole, the new sanitary and storm services will connect to existing lines in existing deeper service tunnels.

**Option one** includes a 500mm diameter tunnel, sloped at 10% with gravity driven sanitary and storm lines within it extending from below the lowest level of the new hotel building to the existing manhole in Major Hill's Park. The sanitary and storm lines are 150mm in diameter.

**Option two** includes the use of a force main and pump to extend up from the lowest level of the new building up to the respective gravity driven lines located 2 meters below grade. The sanitary and storm lines may be 150mm or 200mm in diameter. Use of a 150mm diameter line has risk of clogging and therefore increased maintenance costs. Pressurized sections of pipes diameter is as per manufacturer requirements in order to provide a lift of approximately 15 meters. Required storm water storage for this option, for one hour rain duration is 40m<sup>3</sup> with a set of pumps (one working and one standby) with a capacity of 11 L/sec. Sanitary storage is to be 10-12m<sup>3</sup> complete with a set of pumps (one working and one standby) with max flow capacity of 1.43 L/s.

**Option three** includes a gravity line for the hotel 2 meters below grade and the garage sewer to be collected at the lower level into smaller tank which is then pumped up to the gravity line. This reduces the size of the tank and the pumps. Required storm water storage for this option, for one hour rain duration is 10m<sup>3</sup> with a set of pumps (one working and one standby) with a capacity of 3 L/sec. Sanitary storage is to be 3m<sup>3</sup> complete with a set of pumps (one working and one standby) with max flow capacity of 0.6 L/s.

We recommend the use of **option one**. During our previous discussion with the City, option one was approved for implementation. For detailed design of the site servicing please see drawing S-02 and S-02.1 in Appendix H. City of Ottawa Standard Drawings S11, S11.1, and S11.2 were referred on the drawing S-02.1 for information purposes only to show general approach to designing the connections. More detailed specific design will be provided at a later stage when we will have full set of drawings for the manhole rehabilitation along with access to the manhole in order to fully and accurately assess the needs for work.

---

## 6) Site Servicing

Based on site configuration, the proposed new addition to the Chateau Laurier is facing north and the existing manhole in Major Hill's Park is located on the north side of the building. We propose to construct storm water and sanitary sewer lines north of the building, through Major Hill's Park and to connect these services to deeper existing service tunnels via the existing manhole. Water servicing will utilize the existing lines east of the new addition, along Mackenzie Avenue and also connect to the existing Hotel water main on the south side of the new addition. Detailed layout and slopes are provided on the Site Services Plan drawings S-02 and S-02.1 in Appendix H.

## 7) Erosion and Sediment Control

The following measures should be implemented as part of the Erosion and Sediment Control Plan. A copy of this plan is to be posted on the site. As a part of the requirements of this plan, we confirm that no wetlands exist on site and this site is not located on a flood plain.

The contractor shall implement best management practices, to provide for protection of the area drainage system and the receiving watercourse, during construction activities. The contractor acknowledges that failure to implement appropriate erosion and sediment control measures may be subject to penalties imposed by any applicable regulatory agency.

### Erosion and Sediment Control

- Silt fences are to be installed along the canal pathway and between the excavation area and Major Hill's Park.
- The contractor hired by the site owner is responsible for installation, inspections, maintenance and removals of control measures.
- Daily inspections of this fence will be carried out by owner's representative and any repair work will be done as soon as a problem is noticed.
- Run-off from construction materials and stockpiles will be contained and discharged so as to prevent entry of sediment into the watercourses. Accumulated silt material will be removed as required and disposed of off-site.
- Heavy-duty silt fence will be installed as per the attached OPSD 219.130. Silt fence is to be a woven Class I geotextile as per location shown on Erosion and Sediment Control Plan Drawing S04.
- Grading and placement of granular materials will be carried out in an expeditious manner and confined to the affected locations.
- Cut and fill slopes will be stabilized by seeding and mulching within 15 days of any phase of grading.
- All openings in manholes and catch basins are to be covered by filter cloth during construction to prevent the entrance of sediments.

### Equipment Refueling, Maintenance and Washing

- All equipment will be cleaned of any excess surface oil, grease and dirt prior to its arrival on site.
  - Equipment will be kept in good working order.
  - Equipment with any leaks will stop work immediately until it is repaired.
  - Streets in front of the project will be kept clean at all times.
-

---

### Fire Protection Contingency

- There will be no burning of materials on the site. Construction debris will be picked up and placed in dump boxes and/or pick-up truck boxes.

These measures are to be considered a **“Living Document”** which may be modified in the event that the control measures are insufficient.

Erosion and Sediment Control Plan shall be permanently posted on site and made available for review by inspecting authorities. For erosion and sediment control plan see Appendix J.

### 8) Conclusion

In this report, Remisz Consulting Engineers Ltd. have presented the calculations made for storm water management, water demand, and sanitary services. The storm water management measures proposed will result in a 100 year release rate of 47.47 L/s which is equal to the allowable 5 year predevelopment release rate. The expected sanitary peak flow 1.18 L/s. The water demand for peak hour and maximum daily with fire flow is 1.55 L/s and 250.86 L/s, respectively. The average daily water demand is expected to be 0.57 L/s. We also provided site grading and site services layout including storm water sewer, sanitary sewer, and water service lines.

For pre-consultations and comments from reviewing agencies see Appendix K.

For the Development Servicing Study Checklist see Appendix L.

We trust that this report is sufficient for your requirements. If you have any questions concerning this information or if we can be of further assistance to you on this project, please contact us.

Yours truly,

**REMISZ Consulting Engineers Ltd.**




Boris Uriev, M.Sc., P.Eng.  
Senior Civil Engineer

A handwritten signature in black ink, appearing to read "S. Ladhani".

Sarah Ladhani, B.Eng., EIT  
Project Designer

## **APPENDIX A**

### Site Key Plan and Aerial Map



## **APPENDIX B**

### **Pre-Application Consultation Meeting Notes**

**From:** Hamlin, Allison [mailto:Allison.Hamlin@ottawa.ca]

**Sent:** Wednesday, March 16, 2016 3:58 PM

**To:** 'Art Phillips'; 'Mark Brandt'; 'Rob Cadeau'; 'Dennis Jacobs, MCIP, RPP'

**Cc:** 'pclewes@architectsalliance.com'; 'Hoyt, Christopher'; 'Chris Warden'

**Subject:** RE: Pre-application Consultation Meeting - Follow-up Email - Chateau Laurier, 1 Rideau Street

\*My email bounced back from many of you so I am resending it without the solid waste guidelines and road design plans attached. I will arrange to send these separately to Mark.

Hello Art, Mark, Rob and Dennis,

Sorry for the delay in getting back to you. Following our pre-application consultation meeting on March 2, 2016 for the proposed addition to the Chateau Laurier at 1 Rideau Street, I offer below a summary of our comments. Preliminary plans, including renderings and elevations, were provided for review in advance.

### **Official Plan, Zoning and other City Guidelines**

- [Official Plan](#) – designated ‘Central Area’, surrounded by scenic entry routes on Schedule I, and distinctive streets (Annex 9)
- [Central Area Secondary Plan](#) – the Canal Character Area
- [Zoning](#) – Mixed Use Downtown, MD, with a maximum floor space index of 4.5 and subject to the Heritage Overlay
- [Links](#) to Urban Design Guidelines for High-Rise Housing and Transit-Oriented Development Guidelines

### **Applications Required**

An application [for Site Plan Control](#) (Manager Approval, Public Consultation) and minor variance (or minor rezoning) will be required. The list of plans and studies required for the site plan application is attached. A cover letter should also be submitted with the minor variance application. If a minor rezoning is being contemplated, a new plans and studies list can be provided. You may wish to use this [guide](#) to preparing plans and studies as a reference.

### **Heritage Comments**

- Section 60 of the Zoning By-law applies to this site and states that additions to buildings are permitted only if “the height of the walls and the height and slope of the roof of the addition do not exceed those of the building”. The proposed towers do not meet this requirement and the height should be reduced. The varied silhouette of the roofline of the Chateau is an important heritage attribute of the building and impacts to this silhouette should be evaluated and mitigated.
- Further consideration should be given to the datum lines of the building and ensuring that the proposed additions are sympathetic to the Chateau style of the building.
- Further study of the window detailing and the ratio of solid to void is required.
- While there are no legally protected views of the Chateau Laurier, there are several iconic views that contribute to the Chateau’s heritage value as a landmark building. These views are well

documented in the NCC's 2008 Chateau Laurier Urban Design Guidance document and impacts to these views should be assessed through the design process.

### **Design Considerations**

Urban design comments will be provided separately through the UDRP process. It is recommended that urban design comments be coordinated following the ACPDR meeting.

### **Engineering Considerations**

The site is currently being serviced through a private combined sewer and from the water main on Rideau Street. The new addition will not be allowed to drain into the existing combined sewer. The addition will require a new sanitary sewer to be constructed. This may be accomplished in a number of ways with the most obvious being the extension of the sanitary sewer from Rideau Street, along Mackenzie Street to the frontage of the addition. The storm water runoff for the site must be controlled to a 5 year storm at C=0.5 or the existing C value (whichever is less) and hold up to a 100 year's storm event on site. The site can be serviced from the 305mm water main on Mackenzie Street and will require a looped system for redundancy.

As this area has combined sewers on all streets, Ministry of the Environment (MOE) approval is required and may take as long as 6 months.

- A Servicing Study is required
- Provide the water demands for the site (average day, max day, Peak hour, Fire Flow) so the City may provide boundary conditions for that water main. Fire Flow is based off of the FUS calculation
- A Noise Study is required. Please see updated [Environmental Noise Control Guidelines](#), January 2016.
- A Geotechnical Study is required
- Phase I ESA and (possibly) Phase II ESA required. Please ensure this is completed to O.Reg 153/04 and not the CSA Standard
- A Servicing and Grading plan will be required
- An Erosion and Sediment Control plan is required (and may be on the Servicing and Grading Plan)

Please contact Josh White (extension 15843) for more information regarding available infrastructure for the proposed development.

### **Brownfields Rehabilitation Grant**

This site may be eligible for a Brownfields Rehabilitation Grant or Development Charge Reduction Program. For more information, you may contact Richard Buchanan (extension 27801).

### **Transportation Considerations**

- Wellington Street, Rideau Street and Mackenzie Street are all designated as an Arterial road within the City's Official Plan.

- Mackenzie Avenue is identified as a City-wide route for on-road multi-use pathways (Schedule I of the Official Plan). There are plans for roads works along Mackenzie scheduled for 2016 to add cycling infrastructure and resurface the road. Drawings are attached.
- For the interlock pavers, landscaped areas and public art on City's road right-of-way the developer has to sign a "Maintenance and Liability Agreement" with the City to cover any claims.
- Ensure that the driveway grade does not exceed 2-6% within the private property for a distance of 9.0 metres from the highway line; see Section 25 (s) of the Private Approach By-Law #2003-447.
- The closure of an existing private approach requires reinstatement of the sidewalk, shoulder, curb and boulevard to City standards.
- Ensure that the pedestrian sidewalk along Mackenzie Street be a minimum of 5 metres in width (from building face to curb edge) and has a clear and unobstructed path of 2.0 metres width minimum.
- Bicycle parking spaces are required as per Section 111 of the Ottawa Comprehensive Zoning By-law. Bicycle parking spaces should be located in safe, secure places near main entrances and preferably protected from the weather.
- Where the Development Application is expected to generate fewer than 75 vehicles per hour (peak hour, two direction site generated trips) the City would require a Transportation Overview that analyzes the Trip Generation and Non-Auto Modes. The Transportation Overview would facilitate staff review in addressing councillor and public enquiries. Otherwise the trigger points for the type of Transportation Impact Assessment report are as follows; 76 vph-150 vph requires a Transportation Brief, greater than 150 vph requires a Transportation Impact Study.
- If you have questions, please contact Wally Dubyk at ext. 13783

### **Environmental Planning**

A review of the property at 1 Rideau Street has been undertaken and a scoped EIS is required to address any impacts of the proposed development on any potential habitat within the parking structure (e.g., for barn swallow) and in the immediate vicinity of the site (i.e., the escarpment to the north).

The Scoped EIS can take the form of a letter report or the Scoped EIS form contained within the Council-approved EIS Guidelines (a copy of the form linked below). The Scoped EIS will describe the habitat or lack thereof, presence or absence of species of concern, how the project would impact the habitat and be supported with several photographs where appropriate. It is important that the Scoped EIS be completed with a recent site visit that is conducted for the purpose of gathering information for this.

Scoped EIS Form

[http://app06.ottawa.ca/online\\_services/forms/planning/environmentalImpact\\_en.pdf](http://app06.ottawa.ca/online_services/forms/planning/environmentalImpact_en.pdf)

### **Waste Collection**

Separate collection areas will be required for the commercial (hotel) and residential units. Please see [City guidelines](#) regarding waste collection.

### **Other requirements – Cash-in-lieu of Parkland**

Cash-in-lieu of parkland must be paid in accordance with the Parkland Dedication By-law of the City of Ottawa, as well as the fee for appraisal services. The monies are to be paid at the time of execution of the Site Plan Agreement.

You may also want to reference information available on the City's website for [building permits](#) and [development charges](#) as well.

Finally, I also encourage you to discuss the proposal with the area Councillor, Mathieu Fleury, and local community associations. An up-to-date list of community associations is attached.

I trust this information is helpful. Please do not hesitate to contact me if you have questions or require clarification.

Regards, Allison


**Allison Hamlin, MCIP, RPP**  
Planner, Development Review  
Planning and Growth Management  
Urbaniste, Examen des demandes d'aménagement  
Urbanisme et gestion de la croissance




City of Ottawa | Ville d'Ottawa  
☎ 613.580.2424 ext./poste 25477  
[ottawa.ca/planning](http://ottawa.ca/planning) / [ottawa.ca/urbanisme](http://ottawa.ca/urbanisme)

## **APPENDIX C**

### **Proposed Site Layout and Grading**



KEY PLAN  
NTS



	AREA (m <sup>2</sup> )	5 YR FLOOD (m <sup>2</sup> ) 80mm DEPTH	100 YR FLOOD (m <sup>2</sup> ) 100mm DEPTH
A1	354	201.8	315.3
A2	610.3	353.7	552.7
A3	660	407.2	629.7
A4	273.9	142.7	205
A5	574.2	329.3	512.6
A6	91.8	63.7	79.6
A7	79.4	—	—
A8	59.8	—	—
A9	111.8	—	—
A10	109	—	—
A11	33.8	23.9	30.6
A12	48.5	—	—
A13	273.5	—	—
TOTAL	3280	1522.3	2325.5

LEGEND:

- 50.00 + EXISTING ELEVATIONS
- (50.00) + (NEW ELEVATIONS)
- NEW PROPOSED BUILDING
- 2% STORM WATER DRAINAGE, SLOPE AND DISTANCE
- 5 YEAR FLOOD
- 100 YEAR FLOOD
- ACCUTROL DEVICE

DETAIL A  
NTS

THE LOCATION OF UTILITIES IS APPROXIMATE ONLY, AND THE EXACT LOCATION SHOULD BE DETERMINED BY CONSULTING THE MUNICIPAL AUTHORITIES AND UTILITY COMPANIES CONCERNED. THE CONTRACTOR SHALL PROVE THE LOCATION OF UTILITIES AND SHALL BE RESPONSIBLE FOR ADEQUATE PROTECTION FROM DAMAGE DURING CONSTRUCTION.

GENERAL NOTES:

- ELEVATIONS ARE SHOWN IN METRES.
- CONTRACTOR IS RESPONSIBLE FOR LOCATING AND PROTECTING EXISTING UTILITIES.
- FINISHED GRADE ELEVATIONS ARE TO BE AS SHOWN ON THE DRAWING.
- ALL DIMENSIONS TO BE VERIFIED ON SITE BY CONTRACTOR PRIOR TO CONSTRUCTION.
- NO EXCESS DRAINAGE IS TO BE DIRECTED TO NEIGHBORING PROPERTIES DURING OR AFTER CONSTRUCTION.
- NO ALTERATIONS TO EXISTING GRADE ARE PERMITTED ON OR BEYOND PROPERTY LINE.
- ALL TREES TO BE PROTECTED BEFORE AND DURING CONSTRUCTION.
- EXISTING DRIVEWAY TO BE REMOVED AND REPLACED WITH INTERLOCK AS PER ARCHITECTURAL DESIGN.
- STORM WATER MANAGEMENT DEVICES TO BE CLOSED WEIR OPENING.



5	14/02/19	GENERAL REVISION	BU
4	18/07/18	AS PER CITY REVIEW	BU
3	19/01/18	AS PER CITY REVIEW	BU
2	20/07/17	AS PER DESIGNER REVISION	BU
1	08/06/17	AS PER CITY REVIEW	BU
No.	Date	Revision	By:



57 Auriga Dr. Suite 102  
Ottawa, ON, K2E 8B2  
tel: (613) 225-1162  
fax: (613) 225-4529

Client  
LARCO INVESTMENTS LTD.

Project  
CHATEAU LAURIER EXPANSION  
1 RIDEAU STREET  
OTTAWA, ON

Drawing  
GRADING PLAN

Designed	BU	Date	08/06/17
Drawn	SL	Scale	1:250
Checked	BU	Sheet	1 OF 6
Project No.	2016-146	Dwg. No.	S-01

## **APPENDIX D**

### **Storm Water Flow Drawings and Calculations**

## SECTION 5

## STORM AND COMBINED SEWER DESIGN

before such a system can be implemented. The use of this type of system will be reviewed on a case-by-case basis.

**5.2.6 Perforated Pipes**

Perforated pipes are used in various types of applications including the following:

- Rear yard drainage
- Ditch pipe systems
- Exfiltration/Infiltration systems
- Sub-base drainage
- Road ditch drainage

**5.2.7 Ditch Pipe Systems**

A ditch pipe system refers to a system that utilizes a combination of roadside ditches, perforated pipes, and storm sewers to provide both runoff conveyance and treatment. These systems are typically used as a best management practice for runoff quality control. The systems work by capturing runoff in the ditches and allowing it to seep into a perforated system under the ditches. The flow is then directed to a storm sewer system. During larger storm events, maintenance holes (slightly raised to promote flow storage) allow for direct flow capture and convey the runoff to the storm sewers.

Since these systems are also used for stormwater quality purposes, approval from the Ministry of the Environment will also be required. The City has implemented a Ditch Alteration Policy in order to provide a process for the City to permit filling or alteration of drainage ditches and drainage courses within City road rights-of-way and those in registered and unregistered easements that convey stormwater from public lands. Therefore approval from the City through this process on a case-by-case basis is required before such a system can be implemented. Due to additional maintenance costs associated with this type of system, the designer will have to provide the City with a cost benefit analysis. See Section 5.9 for more details.

**5.3 NON-CONVENTIONAL SYSTEMS**

Where variation and/or the introduction of innovative solutions will achieve a better technical and economical solution, a proposal should be presented to the City for approval. All new alternatives must be presented to the City for approval at the conceptual stage of design. Examples of non-conventional systems are ditch pipe systems and foundation drain collectors.

**5.4 DESIGN FLOWS/HYDROLOGY****5.4.1 General**

All design flows for storm and combined sewer systems shall meet level of service / return period requirements outlined in Section 5.1.

## SECTION 5

## STORM AND COMBINED SEWER DESIGN

**5.4.2 IDF Curves and Equations**

An IDF (Intensity Duration Frequency) curve is a statistical description of the expected rainfall intensity for a given duration and storm frequency. In Ottawa, the IDF curve is derived from Meteorological Services of Canada (MSC) rainfall data taken from the Macdonald-Cartier airport. Rainfall collected from 1967 to 1997 was analyzed using the Gumbel Distribution. The following Table 5.1 shows the analysis results provided by MSC. The IDF equations have been derived on the basis of a regression equation of the form:

$$Intensity = \left[ \frac{A}{Td + C} \right]^B$$

where:

*Intensity* = mm/hr

*Td* = time of duration (min)

*A, B, C* = regression constants for each return period

**Table 5.1 Ottawa IDF Table: 1967 to 1997**

<b>Time (min)</b>	<b>2 year (mm/hr)</b>	<b>5 year (mm/hr)</b>	<b>10 year (mm/hr)</b>	<b>25 year (mm/hr)</b>	<b>50 year (mm/hr)</b>	<b>100 year (mm/hr)</b>
5	102.80	140.20	165.00	196.00	219.00	242.60
10	77.10	104.40	122.50	145.30	162.20	179.00
15	63.30	85.60	100.40	119.10	133.00	146.80
30	39.90	53.90	63.10	74.70	83.40	91.90
60	24.20	32.00	37.10	43.60	48.50	53.20
120	14.30	18.90	22.00	25.80	28.70	31.50
360	6.20	8.40	9.90	11.70	13.10	14.50
720	3.60	4.80	5.60	6.60	7.30	8.00
1440	2.00	2.60	3.00	3.50	3.90	4.30

**IDF curve equations (Intensity in mm/hr)**

100 year Intensity	= 1735.688 / (Time in min + 6.014) <sup>0.820</sup>
50 year Intensity	= 1569.580 / (Time in min + 6.014) <sup>0.820</sup>
25 year Intensity	= 1402.884 / (Time in min + 6.018) <sup>0.819</sup>
10 year Intensity	= 1174.184 / (Time in min + 6.014) <sup>0.816</sup>
5 year Intensity	= 998.071 / (Time in min + 6.053) <sup>0.814</sup>
2 year Intensity	= 732.951 / (Time in min + 6.199) <sup>0.810</sup>

The IDF curves based on the above equations can be found in Appendix 5-A

**5.4.3 Design Storms**

Computer modeling requires the input of a design storm. The design storm is then used to generate a runoff hydrograph to determine how an area will respond and perform. Numerous types of design storms can be used ranging from historical storms to IDF curve-derived storms. This section briefly discusses the various types of design storms.

**5.4.3.1 Application to Hydrologic Models**

The design storms presented herein are meant to be used in hydrologic models to simulate runoff from events of various return frequencies. When choosing a design storm, the designer should perform a sensitivity analysis using various storms and use the one that is most conservative.

As noted below, the Chicago distribution is one of the most used storms for urban runoff applications. When dealing with rural areas, the SCS Type II storm is preferred. The AES storm can also be used for urban applications; however, care must be taken when choosing the type of distribution. As a rule of thumb, the 30% distribution should be used unless historical data proves otherwise.

When using a design storm, the designer must be careful in choosing the right storm time step. The storm's duration should be greater than twice the basin's time of concentration. A time step that is too small may overestimate peak flows. Should it be required to maintain a storm time step less than 10 minutes, consideration should be given to averaging the peak intensities to a 10-minute or greater average.

Some historical storms are also presented below and are to be used as a check of how various systems function during extreme events. It is not the intent of these guidelines to require that these storms be used for design purposes.

**5.4.3.2 Chicago Design Storm**

The Chicago storm distribution was developed by C.J. Keifer and H. Chu and is based on 25 years of rainfall record in the city of Chicago. This storm distribution, which is derived with IDF curves, is generally applied to urban basins where peak runoff rates are largely influenced by peak rainfall intensities.

PRE-DEVELOPMENT (UNCONTROLLED RUNOFF)The pre-development time of concentration is **10** minutes

where:

$$I_5 = 998.071 / (T_c + 6.053)^{0.814}$$

$$I_5 = \mathbf{104.2 \text{ mm/hr}}$$

$$I_{100} = 1735.688 / (T_c + 6.014)^{0.820}$$

$$I_{100} = \mathbf{178.6 \text{ mm/hr}}$$

Surface Type	ID	Area (ha)	Percent of total Area	C	A X C (ha)
Corridor	A1	0.0199	21.4%	1.00	0.020
Parking Access	A3	0.0733	78.6%	1.00	0.073
<b>TOTAL</b>		0.0932	100.0%		0.093
<b>Weighted C =</b>					0.90

$$Q_{5pre} = (2.78) \cdot (C) \cdot (I_5) \cdot (A)$$

$$Q_{5pre} = 2.78 \times 0.90 \times 104.2 \times 0.0932$$

$$Q_{5pre} = \mathbf{24.30 \text{ L/s}}$$

$$Q_{100pre} = (2.78) \cdot (C) \cdot (I_{100}) \cdot (A)$$

$$Q_{100pre} = 2.78 \times 1.13 \times 178.6 \times 0.0932$$

$$Q_{100pre} = \mathbf{52.06 \text{ L/s}}$$

1

C=0.5 used for predevelopment calculation (City of Ottawa requirement)

POST-DEVELOPMENT (UNCONTROLLED RUNOFF)The post-development time of concentration is **10** minutes

where:

$$I_5 = 998.071 / (T_c + 6.053)^{0.814}$$

$$I_5 = \mathbf{104.2 \text{ mm/hr}}$$

$$I_{100} = 1735.688 / (T_c + 6.014)^{0.820}$$

$$I_{100} = \mathbf{178.6 \text{ mm/hr}}$$

Surface Type	ID	Area (ha)	Percent of total Area	C	A X C (ha)
Corridor	A9	0.0112	25.8%	0.95	0.011
Hotel Roof	A12	0.0049	11.2%	0.95	0.005
Hotel Roof	A13	0.0274	63.0%	0.95	0.026
<b>TOTAL</b>		0.0434	100.0%		0.041
<b>Weighted C =</b>					0.95

$$Q_{5post} = (2.78) \cdot (C) \cdot (I_5) \cdot (A)$$

$$Q_{5post} = 2.78 \times 0.90 \times 104.2 \times 0.0434$$

$$Q_{5post} = \mathbf{11.31 \text{ L/s}}$$

$$Q_{100post} = (2.78) \cdot (C) \cdot (I_{100}) \cdot (A)$$

$$Q_{100post} = 2.78 \times 1.00 \times 178.6 \times 0.0434$$

$$Q_{100post} = \mathbf{21.54 \text{ L/s}}$$

### PRE-DEVELOPMENT (CONTROLIED RUNOFF)

The pre-development time of concentration is 10 minutes

where:

$$I_5 = 998.071 / (T_c + 6.053)^{0.814}$$

$$I_5 = 104.2 \text{ mm/hr}$$

$$I_{100} = 1735.688 / (T_c + 6.014)^{0.820}$$

$$I_{100} = \mathbf{178.6 \text{ mm/hr}}$$

Surface Type	ID	Area (ha)	Percent of total Area	C	A X C (ha)
Parking roof	A2	0.2381	100.0%	1.00	0.238
<b>TOTAL</b>		0.2381	100.0%		0.238
<b>Weighted C =</b>					0.50

C=0.5 used for predevelopment calculation (City of Ottawa requirement)

$$Q_{5pre} = (2.78) \cdot (C) \cdot (I_5) \cdot (A)$$

$$Q_{5pre} = 2.78 \times 0.50 \times 104.2 \times 0.2381$$

$$Q_{5pre} = 34.49 \text{ L/s}$$

$$Q_{100\text{pre}} = (2.78) \cdot (C) \cdot (I_{100}) \cdot (A)$$

$$Q_{100\text{pre}} = 2.78 \times 0.90 \times 178.6 \times 0.2381$$

$$Q_{100\text{pre}} = 106.40 \text{ L/s}$$

### POST-DEVELOPMENT (CONTROLLED RUNOFF)

The post-development time of concentration is 10 minutes

where:

$$I_5 = 998.071 / (T_c + 6.053)^{0.814}$$

$$I_5 = 104.2 \text{ mm/hr}$$

$$I_{100} = 1735.688 / (T_c + 6.014)^{0.820}$$

$$I_{100} = \mathbf{178.6 \text{ mm/hr}}$$

Surface Type	ID	Area (ha)	Percent of total Area	C	A X C (ha)
Hotel roof	A1	0.0354	12.4%	1.00	0.035
Courtyard	A2	0.0610	21.4%	1.00	0.061
	A3	0.0470	16.5%	1.00	0.047
	A4	0.0274	9.6%	1.00	0.027
	A5	0.0574	20.2%	1.00	0.057
	A6	0.0092	3.2%	1.00	0.009
	A7	0.0079	2.8%	1.00	0.008
	A8	0.0060	2.1%	1.00	0.006
	A10	0.0109	3.8%	1.00	0.011
	A11	0.0224	7.9%	1.00	0.022
TOTAL		0.2846	100.0%		0.285
Weighted C =					1.00

$$Q_{5\text{post}} = (2.78) \cdot (C) \cdot (I_5) \cdot (A)$$

$$Q_{5\text{post}} = 2.78 \times 0.90 \times 104.2 \times 0.2846$$

$$Q_{5\text{post}} = 74.20 \text{ L/s}$$

$$Q_{100\text{post}} = (2.78) \cdot (C) \cdot (I_{100}) \cdot (A)$$

$$Q_{100\text{post}} = 2.78 \times 1.00 \times 178.6 \times 0.2846$$

$$Q_{100\text{post}} = 141.32 \text{ L/s}$$

## ALLOWABLE RUNOFF



### Predevelopment Runoff:

#### Uncontrolled Runoff

5-year	24.30	l/sec
100-year	52.06	l/sec

#### Controlled Runoff:

5-year	34.49	l/sec
100-year	106.40	l/sec

### Postdevelopment Runoff:

#### Uncontrolled Runoff

5-year	11.31	l/sec
100-year	21.54	l/sec

#### Controlled Runoff:

5-year	74.20	l/sec
100-year	141.32	l/sec

### Controlled allowable runoff

#### Controlled Runoff:

<b>5-year</b>	<b>47.47</b>	<b>l/sec</b>
---------------	--------------	--------------

Comment:

### Storage Volumes (5-Year Storm)

Project: Chateau Laurier Hotel

$$\begin{aligned} T_c &= 10 \text{ (mins)} \\ C_{AVG} &= 1.00 \text{ (dimensionless)} \\ \text{Area} &= 0.2846 \text{ (hectares)} \\ \text{Storm} &= 5 \text{ (year)} \\ \text{Release Rate} &= 47.47 \text{ (L/sec)} \\ \text{Time Interval} &= 5 \text{ (mins)} \end{aligned}$$

Duration (min)	Rainfall Intensity (mm/hr)	Peak Flow (L/sec)	Release Rate (L/sec)	Storage Rate (L/sec)	Storage (m <sup>3</sup> )
1	204	16.1	47.47		
6	132	62.5	47.47	14.99	5.40
11	99	78.5	47.47	31.01	20.47
16	80	63.7	47.47	16.19	15.54
21	68	53.9	47.47	6.43	8.11
26	59	47.0	47.47	-0.52	-0.81
31	53	41.7	47.47	-5.74	-10.68
36	48	37.6	47.47	-9.83	-21.23
41	43	34.4	47.47	-13.12	-32.27
46	40	31.6	47.47	-15.83	-43.69
51	37	29.4	47.47	-18.11	-55.41
56	35	27.4	47.47	-20.05	-67.36
61	33	25.7	47.47	-21.73	-79.51
66	31	24.3	47.47	-23.19	-91.83
71	29	23.0	47.47	-24.48	-104.28
76	28	21.8	47.47	-25.63	-116.86
81	26	20.8	47.47	-26.65	-129.54
86	25	19.9	47.47	-27.58	-142.31
91	24	19.1	47.47	-28.42	-155.16
96	23	18.3	47.47	-29.18	-168.08
101	22	17.6	47.47	-29.88	-181.07
106	21	17.0	47.47	-30.52	-194.12
111	21	16.4	47.47	-31.11	-207.22
116	20	15.8	47.47	-31.66	-220.36
121	19	15.3	47.47	-32.17	-233.55
126	19	14.8	47.47	-32.64	-246.78
131	18	14.4	47.47	-33.08	-260.05
136	18	14.0	47.47	-33.50	-273.35

#### Notes

- 1 ) For a storm duration that is less than the time of concentration the peak flow is equal to the product of 2.78CIA and the ratio of the storm duration to the time of concentration.
- 2) Rainfall Intensity,  $I = 998.071 / (T_c + 6.053)^{0.814}$  (5 year, City of Ottawa)
- 3) Peak Flow = Duration/Tc x 2.78 x C x I x A (Duration < Tc)
- 4) Peak Flow = 2.78 x C x I x A (Duration > Tc)
- 5) Storage = Duration x Storage Rate


### Storage Volumes (100-Year Storm)

$$\begin{aligned} T_c &= 10 \text{ (mins)} \\ C_{AVG} &= 1.00 \text{ (dimensionless)} \\ \text{Area} &= 0.2846 \text{ (hectares)} \\ \text{Storm} &= 100 \text{ (year)} \\ \text{Release Rate} &= 47.47 \text{ (L/sec)} \\ \text{Time Interval} &= 5 \text{ (mins)} \end{aligned}$$

Duration (min)	Rainfall Intensity (mm/hr)	Peak Flow (L/sec)	Release Rate (L/sec)	Storage Rate (L/sec)	Storage (m <sup>3</sup> )
1	351	27.8	1.43		
6	226	107.3	47.47	59.82	21.54
11	170	134.4	47.47	86.96	57.40
16	138	108.8	47.47	61.36	58.91
21	116	92.0	47.47	44.54	56.13
26	101	80.1	47.47	32.58	50.83
31	90	71.1	47.47	23.60	43.90
36	81	64.1	47.47	16.59	35.83
41	74	58.4	47.47	10.94	26.92
46	68	53.8	47.47	6.30	17.38
51	63	49.9	47.47	2.40	7.34
56	59	46.6	47.47	-0.92	-3.10
61	55	43.7	47.47	-3.79	-13.87
66	52	41.2	47.47	-6.29	-24.92
71	49	39.0	47.47	-8.50	-36.20
76	47	37.0	47.47	-10.46	-47.69
81	45	35.3	47.47	-12.21	-59.35
86	43	33.7	47.47	-13.79	-71.16
91	41	32.3	47.47	-15.22	-83.11
96	39	31.0	47.47	-16.52	-95.17
101	38	29.8	47.47	-17.71	-107.35
106	36	28.7	47.47	-18.81	-119.62
111	35	27.7	47.47	-19.82	-131.97
116	34	26.7	47.47	-20.75	-144.41
121	33	25.9	47.47	-21.61	-156.92
126	32	25.1	47.47	-22.42	-169.50
131	31	24.3	47.47	-23.17	-182.14
136	30	23.6	47.47	-23.88	-194.83

#### Notes

- 1 ) For a storm duration that is less than the time of concentration the peak flow is equal to the product of 2.78CIA and the ratio of the storm duration to the time of concentration.
- 2) Rainfall Intensity,  $I = 1735.688 / (T_c + 6.014)^{0.820}$  (100 year, City of Ottawa)
- 3) Peak Flow = Duration/Tc x 2.78 x C x I x A (Duration < Tc)
- 4) Peak Flow = 2.78 x C x I x A (Duration > Tc)
- 5) Storage = Duration x Storage Rate



KEY PLAN  
NTS



THE LOCATION OF UTILITIES IS APPROXIMATE ONLY, AND THE EXACT LOCATION SHOULD BE DETERMINED BY CONSULTING THE MUNICIPAL AUTHORITIES AND UTILITY COMPANIES CONCERNED. THE CONTRACTOR SHALL PROVE THE LOCATION OF UTILITIES AND SHALL BE RESPONSIBLE FOR ADEQUATE PROTECTION FROM DAMAGE DURING CONSTRUCTION.

#### GENERAL NOTES:

1. ELEVATIONS ARE SHOWN IN METRES.
2. CONTRACTOR IS RESPONSIBLE FOR LOCATING AND PROTECTING EXISTING UTILITIES.
3. FINISHED GRADE ELEVATIONS ARE TO BE AS SHOWN ON THE DRAWING.
4. ALL DIMENSIONS TO BE VERIFIED ON SITE BY CONTRACTOR PRIOR TO CONSTRUCTION,
5. NO EXCESS DRAINAGE IS TO BE DIRECTED TO NEIGHBORING PROPERTIES DURING OR AFTER CONSTRUCTION.
6. NO ALTERATIONS TO EXISTING GRADE ARE PERMITTED ON OR BEYOND PROPERTY LINE.
7. ALL TREES TO BE PROTECTED BEFORE AND DURING CONSTRUCTION.
8. EXISTING DRIVEWAY TO BE REMOVED AND REPLACED WITH INTERLOCK AS PER ARCHITECTURAL DESIGN.



5	14/02/19	GENERAL REVISION	BU
4	18/07/18	AS PER CITY REVIEW	BU
3	19/01/18	AS PER CITY REVIEW	BU
2	20/07/17	AS PER DESIGNER REVISION	BU
1	08/06/17	AS PER CITY REVIEW	BU
No.	Date	Revision	By:




57 Auriga Dr. Suite 102  
Ottawa, ON, K2E 8B2  
tel.: (613) 225-1162  
fax: (613) 225-4529

Client  
**LARCO INVESTMENTS LTD.**

Project  
**CHATEAU LAURIER EXPANSION  
1 RIDEAU STREET  
OTTAWA, ON**


Drawing  
**PRE-DEVELOPMENT  
STORM WATER DRAINAGE**

Designed	—	Date	08/06/17
Drawn	SL	Scale	1:250
Checked	BU	Sheet	5 of 6
Project No.	2016-146	Dwg. No.	S-04



THE LOCATION OF UTILITIES IS APPROXIMATE ONLY, AND THE EXACT LOCATION SHOULD BE DETERMINED BY CONSULTING THE MUNICIPAL AUTHORITIES AND UTILITY COMPANIES CONCERNED. THE CONTRACTOR SHALL PROVE THE LOCATION OF UTILITIES AND SHALL BE RESPONSIBLE FOR ADEQUATE PROTECTION FROM DAMAGE DURING CONSTRUCTION.

- GENERAL NOTES:**
1. ELEVATIONS ARE SHOWN IN METRES.
  2. CONTRACTOR IS RESPONSIBLE FOR LOCATING AND PROTECTING EXISTING UTILITIES.
  3. FINISHED GRADE ELEVATIONS ARE TO BE AS SHOWN ON THE DRAWING.
  4. ALL DIMENSIONS TO BE VERIFIED ON SITE BY CONTRACTOR PRIOR TO CONSTRUCTION,
  5. NO EXCESS DRAINAGE IS TO BE DIRECTED TO NEIGHBORING PROPERTIES DURING OR AFTER CONSTRUCTION.
  6. NO ALTERATIONS TO EXISTING GRADE ARE PERMITTED ON OR BEYOND PROPERTY LINE.
  7. ALL TREES TO BE PROTECTED BEFORE AND DURING CONSTRUCTION.
  8. EXISTING DRIVEWAY TO BE REMOVED AND REPLACED WITH INTERLOCK AS PER ARCHITECTURAL DESIGN.



5	14/02/19	GENERAL REVISION	BU
4	18/07/18	AS PER CITY REVIEW	BU
3	19/01/18	AS PER CITY REVIEW	BU
2	20/07/17	AS PER DESIGNER REVISION	BU
1	08/06/17	AS PER CITY REVIEW	BU
No.	Date	Revision	By:

**REMISZ**  
Consulting Engineers Ltd.  
57 Auriga Dr. Suite 102  
Ottawa, ON, K2E 8B2  
tel.: (613) 225-1162  
fax: (613) 225-4529

Client  
**LARCO INVESTMENTS LTD.**

Project  
**CHATEAU LAURIER EXPANSION  
1 RIDEAU STREET  
OTTAWA, ON**

Drawing  
**POST DEVELOPMENT  
STORM WATER DRAINAGE**

Designed	—	Date	08/06/17
Drawn	SL	Scale	1:250
Checked	BU	Sheet	6 of 6
Project No.	2016-146	Dwg. No.	S-05

## **APPENDIX E**

### Storm Water Restriction Devices

### ADJUSTABLE ACCUTROL(for Large Sump Roof Drains only)

For more flexibility in controlling flow with heads deeper than 2", Watts Drainage offers the Adjustable Accutrol. The Adjustable Accutrol Weir is designed with a single parabolic opening that can be covered to restrict flow above 2" of head to less than 5 gpm per inch, up to 6" of head. To adjust the flow rate for depths over 2" of head, set the slot in the adjustable upper cone according to the flow rate required. Refer to Table 1 below.

Note: Flow rates are directly proportional to the amount of weir opening that is exposed.

#### EXAMPLE:

For example, if the adjustable upper cone is set to cover 1/2 of the weir opening, flow rates above 2" of head will be restricted to 2-1/2 gpm per inch of head.

Therefore, at 3" of head, the flow rate through the Accutrol Weir that has 1/2 the slot exposed will be:  
[ 5 gpm(per inch of head) x 2 inches of head ] + 2-1/2 gpm(for the third inch of head) = 12-1/2 gpm.





TABLE 1. Adjustable Accutrol Flow Rate Settings

Weir Opening Exposed	Head of Water					
	1"	2"	3"	4"	5"	6"
Fully Exposed	5	10	15	20	25	30
3/4	5	10	13.75	17.5	21.25	25
1/2	5	10	12.5	15	17.5	20
1/4	5	10	11.25	12.5	13.75	15
Closed	5	10	10	10	10	10

→  
17 Units

Job Name \_\_\_\_\_ Contractor \_\_\_\_\_

Job Location \_\_\_\_\_ Contractor's P.O. No. \_\_\_\_\_

Engineer \_\_\_\_\_ Representative \_\_\_\_\_

WATTS Drainage reserves the right to modify or change product design or construction without prior notice and without incurring any obligation to make similar changes and modifications to products previously or subsequently sold. See your WATTS Drainage representative for any clarification. Dimensions are subject to manufacturing tolerances.

## **APPENDIX F**

### **Water Supply Requirements and Data**

2. If the above is not possible then the next preferred measure is a pressure reducing valve, as a central unit, to be located in a chamber or facility.
3. As a last resort, pressure reducing valves to be installed immediately downstream of the isolation valve in the home/building, located downstream of the meter so it is owner maintained.

#### 4.2.8 Population Density

**Proposed Development Land** – When the number and type of housing units within a proposed development are known, the calculation of population for the proposed development shall be based on the following:

**Table 4.1 Per Unit Populations**

Unit Type	Persons Per Unit
Single Family	3.4
Semi-detached	2.7
Duplex	2.3
Townhouse (row)	2.7
<b>Apartments:</b>	
Bachelor	1.4
1 Bedroom	1.4
2 Bedroom	2.1
3 Bedroom	3.1
Average Apt.	1.8

(Source: custom tabulation of 1996 Census data for units built in the previous five years)

In the absence of any specific information use 60 persons per gross hectare density to estimate average population for suburban type of residential development.

**Pre-zoned Land** - When lands are already zoned for a specific residential use and detailed information is not available calculate the persons per net hectare by dividing the above persons per unit by the units per net hectares allowed by the zoning designation. Persons per gross hectare are approximately 61% of the persons per net hectare. See City of Ottawa Zoning By-law 2008-250.

**Table 4.2 Consumption Rates for Subdivisions of 501 to 3,000 Persons**

Demand Type	Amount	Units
<b>Average Day Demand</b>		
Residential	350	L/c/d
Industrial - Light	35,000	L/gross ha/d
Industrial - Heavy	55,000	L/gross ha/d

## SECTION 4

## WATER DISTRIBUTION SYSTEMS

Demand Type	Amount	Units
Commercial and Institutional		
- Shopping Centres	2500	L/(1000m <sup>2</sup> /d)
- Hospitals	900	L/(bed/day)
- Schools	70	L/(Student/d)
- Trailer Parks no Hook-Ups	340	L/(space/d)
- Trailer Parks with Hook-Ups	800	L/(space/d)
- Campgrounds	225	L/(campsite/d)
- Mobile Home Parks	1000	L/(Space/d)
- Motels	150	L/(bed-space/d)
- Hotels	225	L/(bed-space/d)
- Tourist Commercial	28,000	L/gross ha/d
- Other Commercial	28,000	L/gross ha/d
<b>Maximum Daily Demand</b>		
Residential	2.5 x avg. day	L/c/d
Industrial	1.5 x avg. day	L/gross ha/d
Commercial	1.5 x avg. day	L/gross ha/d
Institutional	1.5 x avg. day	L/gross ha/d
<b>Maximum Hour Demand</b>		
Residential	2.2 x avg. day	L/c/d
Industrial	1.8 x avg. day	L/gross ha/d
Commercial	1.8 x avg. day	L/gross ha/d
Institutional	1.8 x avg. day	L/gross ha/d

## Table Notes:

- Use Table 3-3 of the MOE Design Guidelines for Drinking-Water Systems to determine Maximum day and Maximum hour peaking factors for 0 to 500 persons
- For applications not covered by Table 4.2 consult the MOE Guidelines for direction.

Different consumption rates may be warranted for modeling of existing areas. Consult with the Water Resources Unit, Asset Management Branch for demand estimates for specific projects in existing areas.

**4.2.9 Areas Zoned Residential**

Undeveloped residential areas within the development area shall consider average daily consumption rates of 35 m<sup>3</sup>/ha/day for hydraulic design purposes.

develop the source of supply to meet more than the projected maximum daily flow, the storage volume can be reduced accordingly.

Average daily domestic consumption rates can vary from less than 180 L/(cap·d) [48 USgal/(cap·d)] to more than 1,500 L/(cap·d) [396 USgal/(cap·d)]. These values represent the average flow over a 24 hour period and do not reflect the fact that there are maximum day and peak hour/instantaneous demands in the system each day which will exceed the average value by a significant amount. It is essential that the source of supply and the distribution system be capable of meeting these maximum and peak demand rates without overtaxing the source or resulting in excessive pressure loss in the distribution system.

In general, small systems have higher peaking factors for maximum day and peak hour demand than large systems. The minimum rate, maximum day and peak rate factors for the system should be based on existing flow data or data from a similar nearby system where available. Table 3.3 provides peaking factors for use with average day demand when actual data are not available.

**Table 3-3: Peaking Factors for Drinking-Water Systems Serving Fewer than 500 People**

DWELLING UNITS SERVICED	EQUIVALENT POPULATION	NIGHT MINIMUM HOUR FACTOR	MAXIMUM DAY FACTOR	PEAK HOUR FACTOR
10	30	0.1	9.5	14.3
50	150	0.1	4.9	7.4
100	300	0.2	3.6	5.4
150	450	0.3	3.0	4.5
167	500	0.4	2.9	4.3

#### 3.4.5.2 Outdoor Water Use

For outdoor water use, it should be assumed that a maximum of 25% of the homeowners could be using an outdoor tap at any one time at a rate of 20 L/min (5.3 USgpm) for one hour per day. Where fire protection is provided, then this outdoor use need not be considered.

#### 3.4.5.3 Fire Protection

The decision as to whether or not fire protection will be provided via the communal water supply system is a municipal responsibility. In deciding upon

## PART II

### GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOW COPYRIGHT I.S.O.

**N.B.** It should be recognized that this is a "guide" in the true sense of the word, and requires a certain amount of knowledge and experience in fire protection engineering for its effective application. Its primary purpose is for the use of surveyors experienced in this field, but it is made available to municipal officials, consulting engineers and others interested as an aid in estimating fire flow requirements for municipal fire protection.

Required Fire Flow may be described as the amount and rate of water application required in firefighting to confine and control the fires possible in a building or group of buildings which comprise essentially the same fire area by virtue of immediate exposure. This may include as much as a city block.

1. An estimate of the fire flow required for a given area may be determined by the formula:

$$F = 220C\sqrt{A}$$

where

F = the required fire flow in litres per minute.

C = coefficient related to the type of construction.

= 1.5 for wood frame construction (structure essentially all combustible).

= 1.0 for ordinary construction (brick or other masonry walls, combustible floor and interior).

= 0.8 for non-combustible construction (unprotected metal structural components, masonry or metal walls).

= 0.6 for fire-resistive construction (fully protected frame, floors, roof).

**Note:** For types of construction that do not fall within the categories given, coefficients shall not be greater than 1.5 nor less than 0.6 and may be determined by interpolation between consecutive construction types as listed above. Construction types are defined in the Appendix.

A = The total floor area in square metres (including all storeys, but excluding basements at least 50 percent below grade) in the building being considered.

For fire-resistive buildings, consider the two largest adjoining floors plus 50 percent of each of any floors immediately above them up to eight, when the vertical openings are inadequately protected. If the vertical openings and exterior vertical communications are properly protected (one hour rating), consider only the area of the largest floor plus 25 percent of each of the two immediately adjoining floors.

For one family and two family dwellings not exceeding two storeys in height, see **Note J**.

2. The value obtained in No. 1 may be reduced by as much as 25% for occupancies having a low contents fire hazard or may be increased by up to 25% surcharge for occupancies having a high fire hazard. Those may be classified as to contents as follows:

Non-Combustible	-25%	Free Burning	+15%
Limited Combustible	-15%	Rapid Burning	+25%
Combustible	No Charge		

As guide for determining low or high fire hazard occupancies, see the list in the Appendix. The fire flow determined shall not be less than 2,000 L/min,

3. The value obtained in No.2 above may be reduced by up to 50% for complete automatic sprinkler protection depending upon adequacy of the system. The credit for the system will be a maximum of 30% for an adequately designed system conforming to NFPA 13 and other NFPA sprinkler standards. Additional credit of up to 10% may be granted if the water supply is standard for both the system and fire department hose lines required. The percentage reduction made for an automatic sprinkler system will depend upon the extent to which the system is judged to reduce the possibility of fires spreading within and beyond the fire area. Normally this reduction will not be the maximum allowed without proper system supervision including water flow and control valve alarm service. Additional credit may be given of up to 10% for a fully supervised system.
4. To the value obtained in No. 2 above a percentage should be added for structures exposed within 45 metres by the fire area under consideration. This percentage shall depend upon the height, area, and construction of the building(s) being exposed, the separation, openings in the exposed building(s), the length and height of exposure, the provision of automatic sprinklers and/or outside sprinklers in the building(s) exposed, the occupancy of the exposed building(s), and the effect of hillside locations on the possible spread of fire.

The charge for any one side generally should not exceed the following limits for the separation:

Separation	Charge	Separation	Charge
0 to 3m	25%	20.1 to 30 m	10%
3.1 to 10m	20%	30.1 to 45m	5%
10.1 to 20m	15%		

The total percentage shall be the sum of the percentage for all sides, but shall not exceed 75%.

The fire flow shall not exceed 45,000 L/min nor be less than 2,000 L/min.

## Notes to Calculation

**Note A:** The guide is not expected to necessarily provide an adequate value for lumber yards, petroleum storage, refineries, grain elevators, and large chemical plants, but may indicate a minimum value for these hazards.

**Note B:** Judgment must be used for business, industrial, and other occupancies not specifically mentioned.

**Note C:** Consideration should be given to the configuration of the building(s) being considered and accessibility by the fire department.

**Note D:** Wood frame structures separated by less than 3 metres shall be considered as one fire area.

**Note E:** Fire Walls: - In determining floor areas, a fire wall that meets or exceeds the requirements of the current edition of the National Building Code of Canada (provided this necessitates a fire resistance rating of 2 or more hours) may be deemed to subdivide the building into more than one area or may, as a party wall, separate the building from an adjoining building.

Normally any unpierced party wall considered to form a boundary when determining floor areas may warrant up to a 10% exposure charge.

**Note F:** High one storey buildings: When a building is stated as 1=2, or more storeys, the number of storeys to be used in the formula depends upon the use being made of the building. For example, consider a 1=3 storey building. If the building is being used for high piled stock, or for rack storage, the building would probably be considered as 3 storeys and, in addition, an occupancy percentage increase may be warranted.

However, if the building is being used for steel fabrication and the extra height is provided only to facilitate movement of objects by a crane, the building would probably be considered as a one storey building and an occupancy credit percentage may be warranted.

**Note G:** If a building is exposed within 45 metres, normally some surcharge for exposure will be made.

**Note H:** Where wood shingle or shake roofs could contribute to spreading fires, add 2,000 L/min to 4,000 L/min in accordance with extent and condition.

**Note I:** Any non-combustible building is considered to warrant a 0.8 coefficient.

**Note J:** Dwellings: For groupings of detached one family and small two family dwellings not exceeding 2 stories in height, the following short method may be used. (For other residential buildings, the regular method should be used.)

Exposure distances	Suggested required fire flow	
	Wood Frame	Masonry or Brick
Less than 3m	See Note "D"	6,000 L/min
3 to 10m	4,000 L/min	4,000 L/min
10.1 to 30m	3,000 L/min	3,000 L/min
Over 30m	2,000 L/min	2,000 L/min

***If the buildings are contiguous, use a minimum of 8,000 L/min. Also consider Note H.***

## OUTLINE OF PROCEDURE

- A. Determine the type of construction.
- B. Determine the ground floor area.
- C. Determine the height in storeys.
- D. Using the fire flow formula, determine the required fire flow to the nearest 1,000 L/min.
- E. Determine the increase or decrease for occupancy and apply to the value obtained in D above. Do not round off the answer.
- F. Determine the decrease, if any, for automatic sprinkler protection. Do not round off the value.
- G. Determine the total increase for exposures, Do not round off the value.
- H. To the answer obtained in E, subtract the value obtained in F and add the value obtained in G.

The final figure is customarily rounded off to the nearest 1,000 L/min.

**Water Supply Design Criteria**

Design Parameter	Value
Residential Average Apartment	1.8 P/unit
Residential Average Daily Demand	280 L/d/P
Residential Maximum Daily Demand	9.5 x Average Daily *
Residential Maximum Hourly	1.5 x Maximum Daily *
Commercial Demand	2.5 L / m <sup>2</sup> / d
Commercial Maximum Daily Demand	1.5 x Average Daily
Commercial Maximum Hourly	1.8 x Maximum Daily
Minimum Watermain Size	150mm diameter
Minimum Depth of Cover	2.4m from top of watermain to finished grade
must remain within	275kPa and 552kPa (40-80 psi; 28-56m)
During fire flow operating pressure must not drop below	140kPa (20 psi; 14 m)
* Residential Max. Daily and Max. Hourly peaking factors per MOE Guidelines for Drinking-Water Systems Table 3-3 for 0 to 500 persons.	

# Chateau Laurier Hotel

## Domestic Demand

Type of Housing	Per / Unit	Units	Pop
Single Family	3.4	0	0
Semi-detached	2.7		0
Townhouse	2.7		0
Apartment			0
Bachelor	1.4		0
1 Bedroom	1.4	0	0
2 Bedroom	2.1	0	0
3 Bedroom	3.1	0	0
4 Bedroom	4.2	0	0

	Pop	Avg. Daily		Max Day		Peak Hour	
		m <sup>3</sup> /d	L/min	m <sup>3</sup> /d	L/min	m <sup>3</sup> /d	L/min
<b>Total Domestic Demand</b>	0	0.00	0.00	0.00	0.00	0.00	0.00

## Institutional / Commercial / Industrial Demand

			Avg. Daily		Max Day		Peak Hour	
Property Type	Unit Rate	Units	m <sup>3</sup> /d	L/min	m <sup>3</sup> /d	L/min	m <sup>3</sup> /d	L/min
Commercial floor space	2.5 L/m <sup>2</sup> /d	0	0.00	0.00	0.00	0.00	0.00	0.00
Office	75.0 L/9.3m <sup>2</sup> /d	0	0.00	0.00	0.00	0.00	0.00	0.00
Hotels	225.0 L/(bed-space-d)	189	42.53	29.53	63.79	44.30	114.82	79.73
Industrial -Light	35,000.0 L/gross ha/d							
Industrial -Heavy	55,000.0 L/gross ha/d							
<b>Total I/C/I Demand</b>			42.53	29.53	63.79	44.30	114.82	79.73

<b>Total Demand</b>	42.53	29.53	63.79	44.30	114.82	79.73
---------------------	-------	-------	-------	-------	--------	-------

**Water Demand and Boundary Conditions**

**Proposed Conditions**

Design Parameter	Anticipated Demand <sup>1</sup> (L/min)	Boundary Condition <sup>2</sup> (kPa)
Average Daily Demand	29.53	
Max Day + Fire Flow	13,044.30	
Peak Hour	79.73	
<sup>1</sup> ) Water demand calculation per Water Supply Guidelines. See Appendix B for detailed calculations. <sup>2</sup> ) Boundary conditions supplied by the City of Ottawa. See Appendix B for correspondence with the City.		

# FUS Fire Flow Calculations

Project: Chateau Laurier Hotel, Ottawa

Calculations Based on 1999 Publication "Water Supply for Public

Fire Protection " by Fire Underwriters' Survey (FUS)

Project Name: Chateau Laurier Hotel, Ottawa

Fire Flow Calculation #: 4

Date: January 14, 2019

Building Type/Description/Name:Hotel

Data input by: Zoran Mrdja, P.Eng.

Table A: Fire Underwriters Survey Determination of Required Fire Flow - Long Method

Step	Task	Term	Options	Multiplier Associated with Option	Choose:	Value Used	Unit	Total Fire Flow (L/min)			
1	Choose Frame Used for Construction of Unit	Coefficient related to type of construction (C)	Framing Material								
			Wood Frame	1.50	Fire resistive construction (>2 hrs)	0.60	m				
			Ordinary construction	1.00							
			Non-combustible construction	0.80							
			Fire resistive construction (< 2 hrs)	0.70							
			Fire resistive construction (> 2 hrs)	0.60							
2	Choose Type of Housing (if TH, Enter Number of Units Per TH Block)	Type of Housing	Floor Space Area								
			Single Family	1	Single Family	1	Units				
			Townhouse - indicate # of units	1							
			Other (Comm, Ind, etc.)	1							
2.2	# of Storeys	Number of Floors/ Storeys in the Unit (do not include basement):			6	1	Storeys				
3	Enter Ground Floor Area of One Unit	Enter Ground Floor Area (A) of One Unit Only :			137	12845	Area in Square Meters (m2)				
		Measurement Units	Square Feet (ft2)	0.093	Square Metres (m2)						
			Square Metres (m2)	1							
			Hectares (ha)	10000							
4	Obtain Required Fire Flow without Reductions	Required Fire Flow( without reductions or increases per FUS) (F = 220 * C * √A) Round to nearest 1000L/min						14,960			
5	Apply Factors Affecting Burning	Reductions/Increases Due to Factors Affecting Burning									
5.1	Choose Combustibility of Building Contents	Occupancy content hazard reduction or surcharge	Non-combustible	0.25	Non-combustible	-0.25	N/A	-3,740			
			Limited combustible	-0.15							
			Combustible	0.00							
			Free burning	0.15							
			Rapid burning	0.25							
5.2	Choose Reduction Due to Presence of Sprinklers	Sprinkler reduction	Complete Automatic Sprinkler Protection	-0.3	Complete Automatic Sprinkler Protection	-0.30	N/A	-4,488			
			None	0							
5.3	Choose Separation Distance Between Units	Exposure Distance Between Units	North Side	30.1m-45m	0.05	0.45	m	6,732			
			East Side	10.1-20.0 m	0.15						
			South Side	3.1-10.0 m	0.20						
			West Side	30.1m-45m	0.05						
6	Obtain Required Fire Flow, Duration & Volume	Total Required Fire Flow, rounded to nearest 1000 L/min, with max/min limits applied:						13,000			
		Total Required Fire Flow (above) in L/s:						217			
		Required Duration of Fire Flow (hrs)						2.00			
		Required Volume of Fire Flow (m³)						1560			

Note: The most current FUS document should be referenced before design to ensure that the above figures are consistent with the intent of the Guideline

Legend	
	Drop down menu - choose option, or enter value.
	No Information, No input required.

**Note: The structure is considered as non-combustible as separation walls are incorporated and the basement-garage is sprinklered.**

The most current FUS document should be referenced before design to ensure that the above figures are consistent with the intent of the Guideline.

The basement of the building will be used as a garage and it is recommended to be equipped with sprinkler system

## Pressure Drop Online-Calculator

---

### Calculation output

Flow medium:	Water 20 °C / liquid
Volume flow::	234 l/s
Weight density:	998.206 kg/m³
Dynamic Viscosity:	1001.61 10-6 kg/ms
Element of pipe:	circular
Dimensions of element:	Diameter of pipe D: 200 mm Length of pipe L: 30 m
Velocity of flow:	7.45 m/s
Reynolds number:	1484628
Velocity of flow 2:	-
Reynolds number 2:	-
Flow:	turbulent
Absolute roughness:	0.0015 mm
Pipe friction number:	0.01
Resistance coefficient:	1.67
Resist.coeff.branching pipe:	-
Press.drop branch.pipe:	-
Pressure drop:	461.51 mbar 0.46 bar

---

Note: The pressure drop was calculated by the online calculator of [www.pressure-drop.com](http://www.pressure-drop.com). We can not warrant the correctness of this software. The software is produced carefully. But no computer software is without bugs. Therefore the calculations are your own risk.


\*\*\*\*\*

**Do you know our software SF Pressure Drop 8.x for Excel?**

**Information: [www.pressure-drop.com](http://www.pressure-drop.com)**

\*\*\*\*\*

### Boundary Condition for Chateau Laurier



## **APPENDIX G**

### Sanitary Services Requirements

## SECTION 4

## SANITARY SEWER SYSTEMS

**4.4 DESIGN FLOWS**

Wherever possible, the design of sanitary sewers should be based on the ultimate sewage flows permitted by the zoning, expected from the tributary area (Contact the City Planning and Growth Management Department to obtain projected population and land use data).



The design of sanitary sewers must account for a number of flow contributions in determining an appropriate peak flow design capacity for sizing pipes and/or pumping facilities. It must be noted that this peak design capacity represents a combination of very high customer contribution and a very rare wet weather flow condition and that, most of the time, the facility will operate under significantly lower flow conditions. As an example, separated sanitary sewers usually operate within the typical dry weather flow range for 75% to 90% of the time in a typical year. As such, the design of sanitary collection systems (gravity sewers and pumping stations) must also account for typical flow conditions to provide due consideration to operational and maintenance issues.

The following sub-sections provide guidance for the calculation of design flows on the basis of:

- **Standard Peak Flow Design Parameters:** Applied for establishing peak design capacity (used for the design of sewers and pumping stations).
- **Operational Flow Parameters:** Derived from monitoring data and used for establishing the range of operational flows (used in sewer analysis and pumping station design).

Sanitary sewage flows are comprised of a number of flow contributions. These include waste discharges from residential, commercial, institutional, and industrial land uses, as well as extraneous non-waste flow components from such sources as groundwater infiltration and surface runoff.

Figures 4.1 and 4.2 illustrate, respectively, a typical dry weather flow and wet weather flow hydrograph measured on a separated sanitary sewer system. Various components of each flow hydrograph are labeled and illustrated on the figures.

**Figure 4.1 Dry Weather Flow Components****Figure 4.2 Wet Weather Flow Components**

#### 4.4.1 Calculation of Peak Design Flows

The formulae and parameters to be applied in the calculation of peak design flows (standard peak flow design parameters) for new or infill developments are illustrated in Figure 4.3 and described as follows:

**Figure 4.3 Peak Flow Design Parameters Summary**

<b>AVERAGE WASTEWATER FLOWS:</b>	
<b>Residential Average Flow:</b>	350 L/c/day
<b>Commercial Average Flow:</b>	50,000 L/gross ha/d
<b>Institutional Average Flow:</b>	50,000 L/gross ha/d
<b>Average Light Industrial Flow:</b>	35,000 L/gross ha/d
<b>Average Heavy Industrial Flow:</b>	55,000 L/gross ha/d
<b>PEAKING FACTORS:</b>	
<b>Residential Peak factor:</b>	Harmon Equation
	$P.F. = 1 + \left( \frac{14}{4 + \left( \frac{P}{1000} \right)^{\frac{1}{2}}} \right) * K$
	where: P=Population
	K=Correction Factor = 1
<b>Commercial Peak factor:</b>	1.5
<b>Institutional Peak factor:</b>	1.5
<b>Industrial Peak Factor:</b>	Per Figure in Appendix 4-B
<b>PEAK EXTRANEEOUS FLOWS: (design event)</b>	
<b>Infiltration Allowance:</b>	0.28 L/s/effective gross ha (for all areas)
<b><u>Less than 10 ha.</u></b>	
<b>Foundation Drain Allowance:</b>	5.0 L/s/gross ha (if necessary for existing partially separated and combined areas only)
<b><u>10 ha – 100 ha</u></b>	
<b>Foundation Drain Allowance:</b>	3.0 L/s/gross ha (if necessary for existing partially separated and combined areas only)
<b><u>Greater than 100 ha</u></b>	
<b>Foundation Drain Allowance:</b>	2.0 L/s/gross ha (if necessary for existing partially separated and combined areas only)

## SECTION 4

## SANITARY SEWER SYSTEMS

## 4.4.1.1 Domestic Flows

The preferred method is to utilize monitoring data. If monitoring data is unavailable use the average residential flow of 350 L/capita per day as noted in Figure 4.3. The peaking factor is derived from the Harmon Formula with the minimum permissible peaking factor being 2.0 and the maximum being 4.0.

## 4.4.1.2 Commercial and Institutional Flows

The sewage flows from commercial and institutional establishments vary greatly with the type of water-using facilities present in the development, the population using the facilities, the presence of water metering, the extent of extraneous flows entering the sewers, etc. If approved actual flow records are not available, a unit value of 50,000 L/gross ha/d (as outlined in Figure 4.3) should be used (exclusive of extraneous flows) at the functional design level (Master Planning & Servicing Studies).

For individual, commercial, and institutional uses, the sewage flow rates (rates are exclusive of extraneous flows) commonly used for design at the site plan level can be found in Appendix 4-A.

Furthermore, the plumbing code offers guidance with respect to water usage from fixtures.

The peaking factors applicable for sewage flows from commercial and institutional areas shall be 1.5 (as outlined in Figure 4.3) and applied to the average dry weather flow calculation.

A peak extraneous flow allowance for tributary areas related to commercial and institutional land uses is to be added.

## 4.4.1.3 Industrial Flows

Peak sewage flow rates from industrial areas vary greatly with the extent of the area, the type(s) of industry present, the provision of in-plant treatment or regulation of flows, the presence of cooling waters in the discharge, etc.

If the water usage of the proposed industry is known, such data should be used in the design of the system at the site plan application level. If the water usage for the proposed industry is not known, the following values should be used at the conceptual or functional design level (except for high water users - see Section 4.4.1.6):

- Average Light Industrial Flow: 35,000 L/gross ha/day
- Average Heavy Industrial Flow: 55,000 L/gross ha/day

## SECTION 4

## SANITARY SEWER SYSTEMS

The peaking factors applicable for sewage flows from Industrial Areas shall be based on the Figure provided in Appendix 4-B of the MOE sanitary sewer design guidelines and applied to the average dry weather flow calculation.

#### 4.4.1.4 Extraneous Flows New Areas

In computing the total peak flow rates for design of sanitary sewers, the designer shall include allowances to account for flow from extraneous sources.

A general allowance of 0.28 L/s/effective gross ha (as noted in Figure 4.3) shall be applied, irrespective of land use classification, to account for wet-weather inflow to maintenance holes (MH) located outside of sag areas and for infiltration into pipes and maintenance holes.

For MH's located in sag areas Appendix 7-A indicates the expected inflow through the cover vent holes for various depths of water. The designers can assume that the covers will not be opened during storm events. To minimize the inflow through the cover vent holes it is recommended that maintenance holes be located at high points. The sewer system should be analyzed for wet weather flow conditions to assess impacts of inflow through the cover vent holes.

Designers are to document all occurrences of maintenance hole placement where excess inflow is anticipated, quantify the inflow volume and assess the HGL elevation impacts against the system designed without the inflow volumes and report on the theoretical changes in pipe size etc. needed to mitigate the higher HGL potential.

Roof downspouts shall not be connected (either directly or indirectly) to sanitary sewers via foundation drains.

#### 4.4.1.5 Extraneous Flows from Existing Areas

The connection of foundation drains to sanitary sewer systems is not permitted; therefore, for new development areas, a specific allowance for foundation drain flow to sanitary sewers is not required. However, the designer is required to account for foundation drain flow when computing sanitary design flows from existing areas that may contain partially separated sewers. In the absence of specific monitored data, the following figures should be used in calculating design flows:

Less than 10 gross ha:	5.0 L/s/gross ha shall be used.
Between 10 and 100 gross ha:	3.0 L/s/gross ha shall be used.
Greater than 100 gross ha:	2.0 L/s/gross ha shall be used

#### 4.4.1.6 High Water Users

The foregoing guidelines do not apply to high-water-consumption land uses, which are those requiring excessive amounts of water over and above the

requirements for Heavy Industry. These users often include high-tech factories, meat packing plants, breweries, etc. In such cases, detailed analysis of the design requirements specific to each development proposal is required at the site plan application level.

#### 4.4.1.7 Total Peak Design Flows

The total peak design flow rates for a sanitary sewer shall be the sum of the peak dry weather flow rates as generated by population and land use for the design contributing area plus all extraneous flow allowances.

### 4.4.2 Monitored Flows

When determining the capacity of an existing sanitary sewer, the use of existing flow data, such as monitored flow, is permissible. The flow data and applicable parameters must be provided by the City prior to being used in any computation.

### 4.4.3 Range of Operational Flows

In addition to peak flow capacity requirements, the design of wastewater collection system components (including wastewater pumping stations) should consider the range of typical flow conditions that the system will be expected to accommodate at various stages and over the life cycle of the facility. Consideration of average daily flows, peak daily flows, annual events, and rare events will identify operational and maintenance shortcomings and provide valuable life-cycle costing information in the formation of interim servicing strategies.

These flows can be developed through the application of typical flow monitoring parameters that have been developed by the City of Ottawa. These parameters can be applied in a manner that closely resembles the sanitary sewer peak flow design criteria presented earlier in this section. The following provides an example of typical operational parameters that have been applied by the City of Ottawa, while Section 7.2.1.5 shows an example of an application for wastewater pumping station design. Monitored parameters are available for various areas within the City of Ottawa and should be reviewed with City Staff on a case-by-case basis. Figure 4.4 provides an example of operational flow parameters developed on the basis of flow monitoring data collected in the City of Ottawa.

**Wastewater Design Criteria**

Design Parameter	Value
Residential Average Apartment	1.8 P/unit
Average Daily Demand	280 L/cap/day
Peaking Factor	Harmon's Peaking Factor. Max 4.0, Min 2.0
Correction Factor (City of Ottawa Tech.Bulletin ISTB-2018-0	0.8
Commercial Space	28,000 L/ha/day
Infiltration and Inflow Allowance	0.33L/s/ha
Sanitary sewers are to be sized employing the Manning's Equation	$Q = (1/n)AR^{2/3}S^{1/2}$
Minimum Sewer Size	200mm diameter
Minimum Manning's 'n'	0.013
Minimum Depth of Cover	2.5m from crown of sewer to grade
Minimum Full Flowing Velocity	0.6m/s
Maximum Full Flowing Velocity	3.0m/s
<i>Extracted from Sections 4 and 6 of the City of Ottawa Sewer Design Guidelines, November 2012.</i>	

Sanitary Sewer Post Development Outflow

<b>Site Area</b>	<b>0.4 ha</b>
<b>Extraneous Flow Allowances</b>	
<b>Infiltration / Inflow</b>	<b>0.132 L/s</b>

**Domestic Contributions**

Unit Type	Unit Rate	Units	Pop
Single Family	3.4	0	0
Semi-detached and duplex	2.7		0
Duplex	2.3		0
Townhouse	2.7		0
Apartment			
Bachelor	1.4		0
1 Bedroom	1.4	0	0
2 Bedroom	2.1	0	0
3 Bedroom	3.1	0	0
4 Bedroom	4.2	0	0
<b>Total Population</b>			<b>0</b>
<b>Average Domestic Flow</b>			<b>0.00 L/s</b>
<b>Peaking Factor</b>			<b>3.8</b>
<b>Peak Domestic Flow</b>			<b>0.00 L/s</b>

**Institutional / Commercial / Industrial Contributions**

Property Type*	Unit Rate	No. of Units	Avg Wastewater (L/s)
Commercial	28,000 L/gross ha/d	0	0.00
Hotel with full housekeeping facilities per person	225 l/unit/day	189	0.49
Non resident staff, add per person	40 l/person/day	20	0.01
Institutional	28,000 L/gross ha/d	0	0.00
Industrial - Light**	35,000 L/gross ha/d	0	0.00
Industrial - Heavy**	55,000 L/gross ha/d	0	0.00
<b>Average I/C/I Flow</b>			<b>0.50</b>
<b>Peak Institutional / Commercial Flow*</b>			<b>0.50</b>
<b>Peak Industrial Flow**</b>			<b>0.00</b>
<b>Peak I/C/I Flow</b>			<b>0.5014</b>

<b>Total Estimated Average Dry Weather Flow Rate</b>	<b>0.50</b>
<b>Total Estimated Peak Dry Weather Flow Rate</b>	<b>0.50</b>
<b>Total Estimated Peak Wet Weather Flow Rate</b>	<b>0.63</b>

\*Ottawa TechBulletin ISTB-2018-01 Section 4.4.1 Page 4.5


\*\*Use Appendix 4B diagram

# Free Online Manning Pipe Flow Calculator

## Manning Formula Uniform Pipe Flow at Given Slope and Depth

Can you help me translate, program, or host these calculators? (./contact.php) [Hide this request]




Printable Title		
Printable Subtitle		
Set units: <input type="button" value="m"/> <input type="button" value="mm"/> <input type="button" value="ft"/> <input type="button" value="in"/>		Results
Pipe diameter, $d_0$	<input type="text" value="200"/> <input type="button" value="mm"/> <input type="button" value="v"/>	Flow, Q
Manning roughness, n ? ( <a href="http://www.engineeringtoolbox.com/mannings-roughness-d_799.html">http://www.engineeringtoolbox.com/mannings-roughness-d_799.html</a> )	<input type="text" value=".012"/>	Velocity, v
Pressure slope (possibly ? (./pressureslope.php) equal to pipe slope), $S_0$	<input type="text" value="1"/> <input type="button" value="% rise/run"/> <input type="button" value="v"/>	Velocity head, $h_v$
Percent of (or ratio to) full depth (100% or 1 if flowing full)	<input type="text" value="18"/> <input type="button" value="%"/> <input type="button" value="v"/>	Flow area
		Wetted perimeter
		Hydraulic radius
		Top width, T
		Froude number, F
		Shear stress (tractive force), tau



Please give us your valued words of suggestion or praise. Did this free calculator exceed your expectations in every way? (./contact.php) [Hide this request]

## **APPENDIX H**

### **Proposed Site Services Plan and New Sewers Plan and Profile**



EL. 58.97  
EL. 56.90  
PIT 4.9m x 9.1m x 3.4m DEEP INTO ROCK

PROFILE  
1:300 HORIZONTAL  
1:100 VERTICAL

THE LOCATION OF UTILITIES IS APPROXIMATE ONLY, AND THE EXACT LOCATION SHOULD BE DETERMINED BY CONSULTING THE MUNICIPAL AUTHORITIES AND UTILITY COMPANIES CONCERNED. THE CONTRACTOR SHALL PROVE THE LOCATION OF UTILITIES AND SHALL BE RESPONSIBLE FOR ADEQUATE PROTECTION FROM DAMAGE DURING CONSTRUCTION.

- GENERAL NOTES:
1. DIMENSIONS ARE SHOWN IN METRIC.
  2. CONTRACTOR IS RESPONSIBLE FOR LOCATING AND PROTECTING EXISTING UTILITIES.

200mm WATER SERVICE TABLE:

CHAINAGE	EXISTING ELEVATION	TOP OF WS TOP OF WM	DESCRIPTION
0+000	72.28	WS 69.78	New 200mm Water Service Connection to the Building
0+001.5	72.23	WS 69.71	New 200mm Water Valve
0+012.8	71.90	WS 69.66	Curb
0+020.6	72.00	WS 69.60 WM 69.48	New 200mm Water Service Connection to the 300mm Water Main

WS - WATER SERVICE  
WM - WATER MAIN



6	11/04/19	AS PER CITY REVIEW	BU
5	14/02/19	GENERAL REVISION	BU
4	18/07/18	AS PER CITY REVIEW	BU
3	19/01/18	AS PER CITY REVIEW	BU
2	20/07/17	AS PER DESIGNER REVISION	BU
1	08/06/17	AS PER CITY REVIEW	BU
No.	Date	Revision	By:

**REMISZ**  
Consulting Engineers Ltd.  
57 Auriga Dr. Suite 102  
Ottawa, ON, K2E 8B2  
tel.: (613) 225-1162  
fax: (613) 225-4529

Client  
LARCO INVESTMENTS LTD.

Project  
CHATEAU LAURIER EXPANSION  
1 RIDEAU STREET  
OTTAWA, ON


Drawing  
SERVICING PLAN  
AND PROFILE

Designed	BU	Date	08/06/17
Drawn	SL	Scale	1:250
Checked	BU	Sheet	2 OF 6
Project No.	2016-146	Dwg. No.	S-02


frame 790x505 mm

APPROX. EL. 71.95  
T.O. PAVEMENT  
T.O. ACCESS HATCH


APPROX. EL. 71.95  
T.O. PAVEMENT  
T.O. ACCESS HATCH




1  
1:60



2  
1:60



PLAN  
1:250



THE LOCATION OF UTILITIES IS APPROXIMATE ONLY, AND THE EXACT LOCATION SHOULD BE DETERMINED BY CONSULTING THE MUNICIPAL AUTHORITIES AND UTILITY COMPANIES CONCERNED. THE CONTRACTOR SHALL PROVE THE LOCATION OF UTILITIES AND SHALL BE RESPONSIBLE FOR ADEQUATE PROTECTION FROM DAMAGE DURING CONSTRUCTION.

#### GENERAL NOTES:

1. DIMENSIONS ARE SHOWN IN METRIC.
2. CONTRACTOR IS RESPONSIBLE FOR LOCATING AND PROTECTING EXISTING UTILITIES.
3. EXISTING MANHOLE DRAWINGS WERE PREPARED BY CIMA+.




5	14/02/19	GENERAL REVISION	BU
4	18/07/18	AS PER CITY REVIEW	BU
3	19/01/18	AS PER CITY REVIEW	BU
2	20/07/17	AS PER DESIGNER REVISION	BU
1	08/06/17	AS PER CITY REVIEW	BU
No.	Date	Revision	By:




57 Auriga Dr. Suite 102  
Ottawa, ON, K2E 8B2  
tel.: (613) 225-1162  
fax: (613) 225-4529

Client	LARCO INVESTMENTS LTD.		
Project	CHATEAU LAURIER EXPANSION 1 RIDEAU STREET OTTAWA, ON		
Drawing	SERVICING CONNECTION TO EXISTING MANHOLE		
Designed	BU	Date	08/06/17
Drawn	SL	Scale	AS SHOWN
Checked	BU	Sheet	3 OF 6
Project No.	2016-146	Dwg. No.	S-02.1

D07-12-16-0193




### CONNECTION WITHOUT VERTICAL RISER



### VERTICAL RISER

#### NOTES:

1. ALL DIAMETERS OF SERVICE CONNECTIONS TO FLEXIBLE MAIN SEWER SHALL BE MADE USING APPROVED TEE OR WYE FITTINGS.
2. SANITARY SERVICES TO BE 135mm AND STORM SERVICES TO BE 100mm FOR NEW RESIDENCES UNLESS SPECIFIED OTHERWISE. SERVICE PIPE AND RADIUS BENDS TO BE APPROVED CSA B182.2, SDR28 PRODUCTS UNLESS SPECIFIED OTHERWISE.
3. APPROVED CONTROLLED SETTLEMENT JOINTS OPTIONAL FOR SERVICE CONNECTIONS TO MAIN SEWERS UP TO 5m DEEP. WHERE APPROVED, CONNECTIONS TO SEWERS OVER 5m DEEP REQUIRE APPROVED CONTROLLED SETTLEMENT JOINTS.
4. CAP OR PLUG AT THE PROPERTY LINE SHALL BE ADEQUATELY BRACED TO WITHSTAND TESTING PRESSURE.
5. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SHOWN.




## **APPENDIX J**

### **Erosion and Sediment Control Plan**



www.remisz.com Frame.dwg - Jan. 2009



**GENERAL NOTES:**

1. THE CONTRACTOR SHALL IMPLEMENT BEST MANAGEMENT PRACTICES, TO PROVIDE FOR PROTECTION OF THE AREA DRAINAGE SYSTEM AND THE RECEIVING WATER COURSE, DURING CONSTRUCTION ACTIVITIES. THE CONTRACTOR ACKNOWLEDGES THAT FAILURE TO IMPLEMENT APPROPRIATE EROSION AND SEDIMENT CONTROL MEASURES MAY BE SUBJECT TO PENALTIES IMPOSED BY ANY APPLICABLE REGULATORY AGENCIES.
2. THIS PLAN IS TO BE CONSIDERED A LIVING DOCUMENT WHICH MAY BE MODIFIED IN THE EVENT THAT THE CONTROL MEASURES ARE INSUFFICIENT.
3. EROSION AND SEDIMENT CONTROL PLAN SHALL BE PERMANENTLY POSTED ON SITE AND MADE AVAILABLE FOR REVIEW BY INSPECTING AUTHORITY.

5	14/02/19	GENERAL REVISION	BU
4	18/07/18	AS PER CITY REVIEW	BU
3	19/01/18	AS PER CITY REVIEW	BU
2	20/07/17	AS PER DESIGNER REVISION	BU
1	08/06/17	AS PER CITY REVIEW	BU
No.	Date	Revision	By:

 **REMISZ**  
Consulting Engineers Ltd.

57 Auriga Dr. Suite 102  
Ottawa, ON, K2E 8B2  
tel.: (613) 225-1162  
fax: (613) 225-4529

Client

LARCO INVESTMENTS LTD.

Project

CHATEAU LAURIER EXPANSION  
1 RIDEAU STREET  
OTTAWA, ON

Drawing

EROSION AND SEDIMENT  
CONTROL PLAN

Designed	BU	Date	08/06/17
Drawn	SL	Scale	1:250
Checked	BU	Sheet	4 OF 6
Project No.	2016-146	Dwg. No.	S-03

D07-12-16-0193

## **APPENDIX K**

### **Pre-Consultations and Comments From Reviewing Agencies**


## Boris Uriev

---

**From:** Buchanan, Richard [Richard.Buchanan@ottawa.ca]  
**Sent:** Thursday, January 11, 2018 11:18 AM  
**To:** 'Dennis Jacobs'; Greg Remisz; Boris Uriev  
**Cc:** Hamlin, Allison; Art Phillips  
**Subject:** Storm and Sanitary Servicing

Hi Dennis

We followed up with our Asset Management group as to the option of doing a directional drill for each sanitary and storm service into the deep existing infrastructure (storm over 60 feet and Sanitary 100 feet deep) since this was how the US embassy was serviced. They had indicated that they would not support this approach. They did however indicate that they are working on a Manhole upgrade at the entrance to Majors Hill Park and would consider the option of connecting services to this structure to provide servicing. I included an Aerial photo of the manhole.



The extent of work proposed on the manhole is simply upgrades to meet access issues building codes. This would represent replacing ladders, platforms and other appurtenances. All works would be internal to the manhole short of replacing the manhole cover. They indicated that while Federal approval is required, due to its minimal works required, it would be a quick Federal Land Use Approval.

To accommodate your idea, they would need a high level servicing proposal/sketch with what you would need to service your development. I indicated that the service would need to go through Majors Hill Park and as such there would be a need to obtain approval from the NCC and define the required easement. The easement portion would be your responsibility to pursue with the NCC.

Please submit a plan/sketch of the proposed servicing of your site and include anticipated depth of directional drill (to determine elevation of entry of services into the existing manhole and indicate sizes of services. You may consider a force main verses gravity since the ability to provide necessary gradient could be a challenge and would result in a deep excavation around the pipe).

They would review and determine if it can be incorporated into their design. At this time, they indicated there would be no fee to review this but would be subject to review once you submit your servicing proposal.

**Richard Buchanan, CET**

Project Manager, Development Approvals  
Planning, Infrastructure and Economic Development Department  
Planning & Growth Management Branch  
City of Ottawa | Ville d'Ottawa  
☎ 613.580.2424 ext./poste 27801  
[ottawa.ca/planning](http://ottawa.ca/planning) / [ottawa.ca/urbanisme](http://ottawa.ca/urbanisme)

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

## Boris Uriev

---

---

**From:** Buchanan, Richard [<mailto:Richard.Buchanan@ottawa.ca>]  
**Sent:** Tuesday, January 16, 2018 10:32 AM  
**To:** 'Dennis Jacobs'  
**Cc:** Boris Uriev; Greg Remisz; Hamlin, Allison  
**Subject:** RE: Storm and Sanitary Servicing - Chateau Laurier

Hi Dennis

We have had an opportunity to review your consultants design and have the following questions/comments;

1. Confirm the size of proposed services. The sanitary service seems excessively large.
2. Have you considered each service being a forcemain? This would make the steel casing a lot smaller.
3. Proposed casing seems fairly large. Would recommend your consultant review with the intent of reducing size.

Based on your drawing, it is your intention to enter the existing manhole at a fairly deep point. It is obvious that there cannot be an open cut excavation around the manhole to make the connection, since the surrounding material is rock. All work will be done internally to the manhole. Ensure your contractor reviews this before bidding on project.

Once finalized, we will have our Asset Management team review and provide us with what the next steps will be. It is important to note that the easement across Majors Hill Park will be dependent on the casing size and once confirmed, you will need to start the formal process of obtaining the necessary easement.

**Richard Buchanan, CET**

Project Manager, Development Approvals  
Planning, Infrastructure and Economic Development Department  
Planning & Growth Management Branch  
City of Ottawa | Ville d'Ottawa  
☎ 613.580.2424 ext./poste 27801  
[ottawa.ca/planning](http://ottawa.ca/planning) / [ottawa.ca/urbanisme](http://ottawa.ca/urbanisme)

---

**From:** Dennis Jacobs [<mailto:djacobs@momentumplancom.ca>]  
**Sent:** Monday, January 15, 2018 10:19 AM  
**To:** Buchanan, Richard <[Richard.Buchanan@ottawa.ca](mailto:Richard.Buchanan@ottawa.ca)>  
**Cc:** Boris Uriev <[boris.uriiev@remisz.com](mailto:boris.uriiev@remisz.com)>; Greg Remisz <[greg.remisz@remisz.com](mailto:greg.remisz@remisz.com)>  
**Subject:** FW: Storm and Sanitary Servicing - Chateau Laurier

H Richard

Further to our discussion last week, here is the preliminary sketch for a connection to the manhole in the park. We will be submitting a revised servicing plan based on the new design for the hotel addition as part of the resubmission this week. This revised design will be incorporate this proposed connection.

Please let us know if you need anything further at this time. Thanks.

Dennis Jacobs MCIP, RPP  
Principal Planner  
Momentum - Planning & Communications  
1165 Greenlawn Crescent  
Ottawa ON K2C 1Z4  
Office: 613.729.3773  
Cell: 613.862.0799  
momentumplancom.ca



---

**From:** Boris Uriev [<mailto:boris.uriev@remisz.com>]  
**Sent:** Monday, January 15, 2018 9:45 AM  
**To:** Dennis Jacobs <[djacobs@momentumplancom.ca](mailto:djacobs@momentumplancom.ca)>  
**Cc:** Greg Remisz <[greg.remisz@remisz.com](mailto:greg.remisz@remisz.com)>; Art Phillips <[aphillips@larco.ca](mailto:aphillips@larco.ca)>  
**Subject:** RE: Storm and Sanitary Servicing

Dennis, good day!



Please find attached the requested proposal / drawing for storm and sanitary connections to Majors Hill Park manhole.

Regards,

Boris Uriev, M. Sc., P. Eng.


REMISZ Consulting Engineers Ltd  
57 Auriga Drive, Suite 102  
K2E 8B2, Ottawa, ON  
Phone: (613) 225-1162  
Fax: (613) 225-4529  
[bu@remisz.com](mailto:bu@remisz.com)





**TYPICAL LANDING AND LADDER DETAIL**  
SCALE 3/4" = 1' - 0"

- NOTES:
1. MAXIMUM DISTANCE BETWEEN LANDINGS TO BE 12 FEET.
  2. MANHOLE LADDERS & LANDINGS TO BE HOT DIP GALVANIZED




**SECT. 1-1  
SANITARY CLEANOUT DETAIL**

ELEVATION  
SCALE 1" = 1' - 0"


NOTE: LOCATE CLEANOUTS AT DROP-PIPE CONNECTIONS TO TUNNEL & AT 150' O.C. BETWEEN SHAFTS

NOTE: ALL STEEL FOR CLEANOUT & LANDING ASSEMBLIES TO BE HOT-DIP GALVANIZED




**SANITARY CLEANOUT DETAIL**

PLAN  
SCALE 1" = 1' - 0"




**ENTRANCE CHAMBER DETAIL (TYP.)**

SCALE 3/8" = 1' - 0"



**CONSTRUCTION JOINT DETAIL (TYP.)**

N.T.S.




**SANITARY CONNECTION FROM TUNNEL  
TO EXISTING INTERCEPTOR**

SCALE 1/4" = 1' - 0"




A.L.M.	ENTRANCE CHAMBER DETAIL AMENDED	14/7/70
By	Revisions	Date
NATIONAL CAPITAL COMMISSION		
CONFEDERATION SQUARE		
EAST BANK DEVELOPMENT		
STORM & SANITARY SEWER TUNNEL		
MISCELLANEOUS DETAILS		
DESIGN R.B.	CHECK A.J.W.	Scale: as shown
DRAWN R.B.	CHECK A.J.W.	Project No. C.N. 243-67
TRACING B.R.	DATE NOV./69	SHEET II
WYLLIE & UFNAL LTD.		
CONSULTING ENGINEERS		
Toronto	Hamilton	Ottawa





F21-a-2

F21-a-1

CITY OF OTTAWA ENGINEERING DEPARTMENT SEWER BRANCH	
<b>MACKENZIE AVENUE</b> <b>ST PATRICK TO RIDEAU</b>	
Scales - Hor. 1 in = 40 ft Vert. 1 in = 6 ft	
Commissioner of Works	Made by A.H.K.
Asst. Commissioner of Works	Checked by
Sewer Engineer	Survey - Book 138 P. 54
Designing Engineer	Levels - Book 138 P. 56
Date: March 18th 1935	
Drawing No. F-21a	





TOP OF GROUND ELEVATION	44.8	59.74	60.50	59.74	6.42	70.0	7.93	66.05	57.00	55.47	TOP OF GROUND ELEVATION
INVERT OF INTERCEPTOR	44.8	43.93	43.60	43.46	43.08	42.88	41.80	40.76	39.86	38.97	INVERT OF INTERCEPTOR
CHAINAGE	0+000	0+090.3	0+121.4	0+166.5	0+243.7	1+140.4	1+1915.6	3+1184.3	3+1941.1		CHAINAGE

NOTE:  
THE POSITION OF ALL POLE LINES, CONDUITS, WATERMANS, SEWERS AND OTHER UNDERGROUND AND OVERGROUND UTILITIES AND STRUCTURES IS NOT NECESSARILY SHOWN ON THE CONTRACT DRAWINGS, AND WHERE SHOWN, THE ACCURACY OF THE POSITION OF SUCH UTILITIES AND STRUCTURES IS NOT GUARANTEED BEFORE STARTING WORK, DETERMINE THE EXACT LOCATION OF ALL SUCH UTILITIES AND STRUCTURES AND ASSUME ALL LIABILITY FOR DAMAGE TO THEM.

ISSUED WITH DRAFT REPORT	JAN 16/90	GM
REVISION	DATE	BY

**Novatech**  
ENGINEERING CONSULTANTS LTD  
OTTAWA, ONTARIO

SCALE  
HORIZONTAL  
0 50 100 150 200  
VERTICAL  
0 10 20 30 40

**REGIONAL MUNICIPALITY OF OTTAWA - CARLETON**  
WORKS DEPARTMENT


**OTTAWA INTERCEPTOR SEWER**  
SCHEMATIC PLAN AND PROFILE

PROJECT NO. 8921  
FIELD BOOK  
DATE DEC/88  
DRAWING NO. 8921-1



NO.	REVISIONS	BY	DATE
5.	ISSUED FOR CONSTRUCTION	LPD	04/09/29
4.	ISSUED FOR TENDER	LPD	04/07/09
3.	RE-ISSUED FOR MOE APPROVAL	LPD	04/05/18
2.	ISSUED FOR MOE APPROVAL	LPD	04/04/21
1.	REVISED STORM SEWER	LPD	04/04/15

**NOTE:**  
The location of the utilities is approximate only, the exact location should be determined by consulting the municipal authorities and utility companies concerned.  
The contractor shall prove the location of utilities and shall be responsible for adequate protection from damage



STORM MANHOLE DATA					
NO.	STATION	OFFSET	TYPE	T/GRATE	ELEVATION
1	0+893.5	1.00 LT	OPSD-705.010	70.37	69.85-68.89
2	0+945.2	0.40 LT	OPSD-701.010	70.64	69.64-68.04
MH ADD	0+985.4	4.38 LT	OPSD-701.010		67.49
2A	0+995.8	0.20 RT	OPSD-701.010	69.48	68.47-67.00-67.01

STORM SEWER DATA					
SEWER	DIA.	TYPE	LENGTH	INVERT ELEVATION	DOWN STR.
MH 1 - MH 2	300	PVC SDR35	52.0	69.85-68.89	68.89-67.00
MH 2 - MH ADD	375	PVC SDR35	51.0	69.64-68.04	67.49-67.00
MH ADD - MH 2A	375	PVC SDR35	0.00	69.48-67.49	67.00-67.00

CATCH BASIN DATA					
NO.	STATION	OFFSET	TYPE	GRATE	ELEVATION
CB1	0+894.4	5.50 RT	OPSD-705.010	S22, S23	70.88
CB2	0+904.8	5.50 LT	OPSD-705.010	S22, S23	70.64
CB3	0+937.5	5.50 LT	OPSD-705.010	S22, S23	69.48
CB4	0+945.2	0.40 LT	OPSD-705.010	S22, S23	70.64
CB5	0+978.2	5.50 LT	OPSD-705.010	S22, S23	69.48
CB6	0+977.5	5.50 RT	OPSD-705.020	S22, S23	69.48

OFFSETS ARE FROM BASELINE TO FACE OF CURB FOR CATCH BASINS  
CURB INLET ELEV.

**NOVATECH ENGINEERING CONSULTANTS LTD.**  
ENGINEERS & PLANNERS

Suite 200, 240 Michael Cowpers Drive  
Kamato, Ontario, Canada  
K2M 1P6  
Telephone: (613) 254-9643  
Facsimile: (613) 254-5867  
Email: novatech@novatech-eng.com

NO.	REVISIONS	BY	DATE
5.	ISSUED FOR CONSTRUCTION	LPD	04/09/29
4.	ISSUED FOR TENDER	LPD	04/07/09
3.	ISSUED FOR MOE APPROVAL	LPD	04/05/18
2.	ISSUED FOR MOE APPROVAL	LPD	04/04/21
1.	REVISED STORM SEWER	LPD	04/04/15

**NOTE:**  
The location of the utilities is approximate only, the exact location should be determined by consulting the municipal authorities and utility companies concerned.  
The contractor shall prove the location of utilities and shall be responsible for adequate protection from damage.



NO.	REVISIONS	BY	DATE
5.	ISSUED FOR CONSTRUCTION	LPD	04/09/29
4.	ISSUED FOR TENDER	LPD	04/07/09
3.	ISSUED FOR MOE APPROVAL	LPD	04/05/18
2.	ISSUED FOR MOE APPROVAL	LPD	04/04/21
1.	REVISED STORM SEWER	LPD	04/04/15

**NOTE:**  
The location of the utilities is approximate only, the exact location should be determined by consulting the municipal authorities and utility companies concerned.  
The contractor shall prove the location of utilities and shall be responsible for adequate protection from damage.


**CONFEDERATION BOULEVARD**  
MacKenzie/Sussex South  
PHASE 1

**GRADING AND DRAINAGE PLAN**  
MacKENZIE AVENUE  
STATION 0+875 TO STATION 1+000


CONTRACT NO. RD-2520-16L  
DRAWING NO. 103184-GD4  
DATE: APRIL 2004  
SHEET NO. 13 OF 56



- NOTES AND SPECIFICATIONS:**
- GENERAL**
- THE ABANDONED WATERMAIN SHALL BE REMOVED DURING EXCAVATION OPERATION AND DISPOSED OF OFF-SITE. THE TRENCH SHALL BE BACKFILLED WITH ACCEPTABLE NATIVE MATERIAL AS DIRECTED BY THE SUB-ENGINEER WITH CONTRACT ADMINISTRATOR.
  - BORHOLE LOCATIONS ARE SHOWN IN PLAN. FOR FURTHER INFORMATION AND BORHOLE LOGS REFER TO GEOTECHNICAL REPORT DATED APRIL 5, 2004.
  - EXACT DEPTH OF UNDERGROUND UTILITY PLANT AND EQUIPMENT, AND ENCASMENT MATERIAL ARE UNKNOWN. THE CONTRACTOR IS TO TAKE NECESSARY PRECAUTIONS TO PROTECT EXISTING UTILITIES.
  - MANHOLES AND VALVE CHAMBERS ON ABANDONED SEWERS AND WATERMAINS TO BE REMOVED ENTIRELY AND THE SEWER/WATERMAIN TO BE PLUGGED WITH 20 MPa CONCRETE.
  - MAINTAIN TWO WAY TRAFFIC AT ALL TIMES. CONSTRUCTION IS TO BE STAGED AS DETAILED ELSEWHERE IN CONTRACT.
  - EXISTING TREES IN THE CONSTRUCTION ZONE AREA TO BE PRESERVED AND PROTECTED DURING THE CONSTRUCTION PERIOD.
  - LIMITS OF GRADING INDICATED MAY VARY DEPENDING ON FIELD CONDITIONS OR AS DIRECTED BY THE SUB-ENGINEER WITH CONTRACT ADMINISTRATOR.
  - WHERE AVAILABLE, EXISTING SERVICING INFORMATION TO PRIVATE PROPERTY HAS BEEN SHOWN.
  - EXCESSIVE LEVELS OF CHLORIDE ARE PRESENT IN AREAS THROUGHOUT THE CONTRACT. THEREFORE, THE PROTECTION OF STEEL IN CONCRETE IS REQUIRED.
  - PROFILE OF 150mm PERFORATED PIPE SUBRAIN AND BOTTOM OF TREE PIT DRAINAGE LAYERS TO BE ADJUSTED TO PROVIDE DRAINAGE OVER EXISTING SERVICE TUNNEL.
  - 150mm NON-PERFORATED PIPE TO BE USED FROM 2m UP STREAM OF SERVICE TUNNEL TO CB CONNECTION.
  - FOR DETAIL OF SERVICE TUNNEL INSULATION AND PROPOSED WORK SEE DRAWINGS ELSEWHERE IN CONTRACT.
  - GAS MAIN TO BE RELOCATED BY OTHERS PRIOR TO COMMENCEMENT OF CONFEDERATION BLVD. CONTRACT.
  - FOR LIMITS OF PERMANENT CONSTRUCTION AND DETAIL OF TEMPORARY PHASE 1 CONNECTION SEE DRAWING 103186-TPC.
- STORM AND SANITARY SEWERS**
- ALL STORM AND SANITARY SERVICES SHALL BE REPLACED TO PROPERTY LINE, OR FURTHER AS REQUIRED. TIE-IN LOCATION BEYOND PROPERTY LINE TO BE APPROVED BY SUB-ENGINEER WITH CONTRACT ADMINISTRATOR. WHERE STORM LATERALS ARE TO BE PLACED TO PROPERTY LINE, THEY SHALL BE CAPPED WITH A WATER TIGHT SEAL.
  - ALL CATCH BASINS TO HAVE A SUMP OF 0.9m (MIN.), UNLESS CATCH BASIN MODEL S27 IS SPECIFIED C/W 200mm LEAD. STORM MANHOLES TO HAVE 0.3m SUMP.
  - ALL SEWERS TO HAVE CLASS "B" BEDDING, AND APPROVED NATIVE BACKFILL MATERIAL. (REFER TO GEOTECHNICAL REPORT)
  - SUBRAIN OUTLETS INTO MANHOLES AND CATCH BASINS SHALL BE LOCATED TO SUIT FIELD CONDITIONS.
  - THE CONTRACTOR WILL BE REQUIRED TO LOCATE EXISTING SERVICES & UTILIZING DYE TESTING OR OTHER METHODS (TO THE SATISFACTION OF THE SUB-ENGINEER WITH CONTRACT ADMINISTRATOR), VERIFY THE EXISTING SERVICE PIPES STATUS. (ABANDONED OR IN USE)
- WATERMAIN**
- CURB STOPS TO BE INSTALLED 0.3m ON AND FROM BACK OF SIDEWALK OR AT ANOTHER LOCATION APPROVED BY ENGINEER.
  - ALL WATER SERVICES TO BE INSTALLED WITH 2.4 METRES OF COVER.
  - ALL FITTINGS REQUIRED FOR CONNECTIONS TO BE SUPPLIED BY THE CITY OF OTTAWA PER SECTION 4, F-7010.
  - EXISTING WATERMAIN TO BE ABANDONED DURING CONSTRUCTION. A TEMPORARY OVERLAND DISTRIBUTION SYSTEM WILL BE IMPLEMENTED AND MAINTAINED BY CITY OF OTTAWA FORCES.
  - ALL HYDRANTS AND VALVES AND OTHER APPURTENANCES TO BE REMOVED SHALL BE SALVAGED AND DELIVERED TO CITY OF OTTAWA YARD AT CLYDE AVENUE.
  - WATER SERVICES CROSSING NEW AND ABANDONED SEWERS SHALL BE INSTALLED UNDER THE SEWER PER W38.
  - ALL NEW CATCH BASINS AND MANHOLES CLOSER THAN 0.9m TO THE NEW WATERMAIN SHALL BE INSULATED PER W23.
  - CATHODIC PROTECTION REQUIRED FOR ALL FITTINGS & COMPONENTS PER W40 & W42.
  - WATERMAIN BEDDING IS TO BE AS PER W17.
  - ALL WATERMAIN MATERIALS AND CONSTRUCTION SHALL BE IN ACCORDANCE WITH THE LATEST EDITION OF THE CITY OF OTTAWA STANDARD SPECIFICATIONS AND STANDARD DRAWINGS.



D:\m\m\2003\103184\103184-GD4.dwg Layout:MAC-2 Updated: MAR 23, 2007 at 3:46pm by: ghr



REVISIONS / RÉVISIONS	DATE	BY
WATER - WATER DISTRIBUTION PLAN 2002	DEC 2002	SR
WATER REVISION APPLIED SUSSEX/YORK		
ENRIDGE - SUSSEX		
6" GAS ACTIVATED (PREV. ABANDONED)	FEB 2005	SR
07504032 - BUS PAD (DEC. 2004)		
CONCRETE PAD ADDED TO E. SIDE OF SUSSEX	APR 2007	DC
15322 - SUSSEX (DEC. 2011)		
SEWER, WATER, UTILITY & ROAD REVISED	AUG 2012	DC
BELL - 09-0679 (FEB 2011)		
BELL CONDUIT REVISED ON SUSSEX	AUG 2012	DC
R00130564-ROGERS (SEP 2013)		
H.H. AND CONDUIT ADDED TO YORK	NOV 2014	JM

LEGEND
Poles: Rogers, Bell, Hydro, Hydro One, Traffic, Utility
Poles w/ Light Std.: Bell, Hydro, Hydro-Bell, Traffic, Utility
Manholes-City: Sanitary, Storm, Water, Catchbasin, Generic
Manholes-Utility: Bell, Hydro, Traffic, Allstream, Atria
PWGSC, Group Telecom, Rogers, Street Lighting, OC Transpo
Catch Basins: Heavy Duty, Standard, Curb Inlet, CI for CBMH
Ditch Inlet, Rear Yard, Wing Wall
Pedestals: Allstream, Atria, Bell, Hydro, Gas, Group Telecom, Rogers, Telus, Videotron
Hand Holes: Allstream, Atria, Group Telecom, Hydro, Hydro One
Traffic, Street Lighting, OC Transpo
Bell: Bell Dip, Guy Wire, Bell Panel, Telephone Booth
Gas: Reducer, Meter, Valve, Regulator
Hydro: Thermocouple, Transformer, Tower
OC Transpo: Bus Shelter-No Power, Energized, Isolated
Rogers: Power Supply, Panel, Vault, Amplifier
Street Lighting: Light Standard, Disconnect
Streetscape: Decorative Light, Planter Box
Traffic: Connect Box, Disconnect Box, Ground Rod
Water: Reducer, Fire Hydrant, Water Valve, Meter, Wall Hydrant
Pipe, Duct, Conduit, Lateral
Culvert
Abandoned
Capped
Buried Cable
Property Line

**CAUTION/ATTENTION**

Although utility locations are established using the best available information, they cannot be guaranteed. Property lines were compiled from plans and documents recorded in the Land Registry System and are for indexing purposes only.

*Bien que l'emplacement des services publics soient établis en utilisant la meilleure information disponible, ils ne peuvent pas être garantis. Des lignes de propriété ont été compilées en utilisant des plans et des documents enregistrés dans le système de cadastre et sont pour l'indexation seulement.*

Department of Public Works and Services / Services et Travaux publics  
Infrastructure Services Branch / Direction des services d'infrastructure  
Infrastructure Management Division / Division de la gestion de l'infrastructure  
100 Constellation Cres., 6th Floor East / 6ème Étage Est, Ottawa, ON K2G 6J8

OTTAWA UTILITY COORDINATING COMMITTEE  
CENTRAL REGISTRY  
COMITÉ DE COORDINATION DES SERVICES PUBLICS D'OTTAWA  
ENREGISTREMENT CENTRAL

UCC  
CCSP

<b>N. SCHEPERS, P.Eng.</b> DCM, ISCIS	<b>W. NEWELL, P.Eng.</b> DIRECTOR, INFRASTRUCTURE SERVICES
<b>C. COLAIACOVO</b> MANAGER, BUSINESS & TECHNICAL SERVICES	<b>R. ZORGEL</b> COORDINATOR, INFORMATION CENTRE
PRODUCED BY: UCC MAPPING STAFF	SHEET NUMBER
SCALE: 1:250	<b>D-13-06</b>



REVISIONS / RÉVISIONS	DATE	BY
ENBRIDGE - 60-2891-04 (JAN 2003)	APR 2007	DC
4" GASMAIN ADDED TO MACKENZIE		
BELL - BELD307010 (NOV 2005)	APR 2007	DC
CONDUIT & PED. ADDED TO W. SIDE OF SUSSEX		
01504030 - BUS PAD (DEC 2004)	APR 2007	DC
CONCRETE PAD ADDED TO E. SIDE OF SUSSEX		
TELECOM OTTAWA TOL0706RG0V 2007	JUNE 2009	MH
TRENCH AND HHH INSTALLED SUSSEX GEORGE		
REVISION TOL070101 AUG 2007	MAY 2010	AJ
ATRIA ADDED ON GEORGE		
15322 - SUSSEX (DEC 2011)	AUG 2012	DC
SEWER, WATER, UTILITY & ROAD REVISED		
BELL CONDUIT REVISED ON SUSSEX	AUG 2012	DC
BELL - 08-0678 (FEB 2011)		
BELL CONDUIT ADDED	AUG 2012	ZB
12624 - MACKENZIE (MAY 2007)		
WATER / SEWERS APPLIED	AUG 2012	ZB
17100 - GEORGE (MAY 1982)		
WATER / SEWERS APPLIED	AUG 2012	ZB
HYDRO, BELL, ENBRIDGE, ROGERS, CITY SEWER, WATER, TRAFFIC, SL		
COMPILED/DIGITIZED FROM UTILITY/CITY DATA	FEB 2015	DC

**LEGEND**

Poles: Rogers, Bell, Hydro, Hydro One, Traffic, Utility	○ <sup>R</sup> ○ <sup>B</sup> ○ <sup>H</sup> ○ <sup>U</sup> ○ <sup>T</sup> ○ <sup>JP</sup>
Poles w/ Light Std.: Bell, Hydro, Hydro-Bell, Traffic, Utility	⊗ <sup>P</sup> ⊗ <sup>H</sup> ⊗ <sup>B</sup> ⊗ <sup>T</sup> ⊗ <sup>JP</sup>
Manholes-City: Sanitary, Storm, Water, Catchbasin, Generic	⊙ <sup>S</sup> ⊙ <sup>ST</sup> ⊙ <sup>W</sup> ⊙ <sup>CB</sup>
Manholes-Utility: Bell, Hydro, Traffic, Allstream, Atria	⊙ <sup>B</sup> ⊙ <sup>H</sup> ⊙ <sup>T</sup> ⊙ <sup>A</sup>
PWGSC, Group Telecom, Rogers, Street Lighting, OC Transpo	⊙ <sup>PT</sup> ⊙ <sup>GT</sup> ⊙ <sup>SL</sup> ⊙ <sup>OT</sup>
Catch Basins: Heavy Duty, Standard, Curb Inlet, CI for CBMH, Ditch Inlet, Rear Yard, Wing Wall	⊙ <sup>HD</sup> ⊙ <sup>ST</sup> ⊙ <sup>CI</sup> ⊙ <sup>CI</sup> ⊙ <sup>DI</sup> ⊙ <sup>RY</sup> ⊙ <sup>WW</sup>
Pedestals: Allstream, Atria, Bell, Hydro, Gas, Group Telecom, Rogers, Telus, Videotron	⊙ <sup>AS</sup> ⊙ <sup>AT</sup> ⊙ <sup>B</sup> ⊙ <sup>H</sup> ⊙ <sup>G</sup> ⊙ <sup>GT</sup> ⊙ <sup>R</sup> ⊙ <sup>T</sup> ⊙ <sup>V</sup>
Hand Holes: Allstream, Atria, Group Telecom, Hydro, Hydro One, Traffic, Street Lighting, OC Transpo	⊙ <sup>AS</sup> ⊙ <sup>AT</sup> ⊙ <sup>B</sup> ⊙ <sup>H</sup> ⊙ <sup>G</sup> ⊙ <sup>GT</sup> ⊙ <sup>R</sup> ⊙ <sup>T</sup> ⊙ <sup>V</sup>
Belt: Bell Dip, Guy Wire, Bell Panel, Telephone Booth	⊙ <sup>BD</sup> ⊙ <sup>GW</sup> ⊙ <sup>BP</sup> ⊙ <sup>TB</sup>
Gas: Reducer, Meter, Valve, Regulator	⊙ <sup>GR</sup>
Hydro: Thermocouple, Transformer, Tower	⊙ <sup>TC</sup> ⊙ <sup>TR</sup> ⊙ <sup>TW</sup>
OC Transpo: Bus Shelter-No Power, Energized, Isolated	⊙ <sup>BS</sup> ⊙ <sup>BS</sup> ⊙ <sup>BS</sup>
Rogers: Power Supply, Panel, Vault, Amplifier	⊙ <sup>PS</sup> ⊙ <sup>PA</sup> ⊙ <sup>VA</sup> ⊙ <sup>AM</sup>
Street Lighting: Light Standard, Disconnect	⊙ <sup>SL</sup> ⊙ <sup>SD</sup>
Streetscape: Decorative Light, Planter Box	⊙ <sup>DL</sup> ⊙ <sup>PB</sup>
Traffic: Connect Box, Disconnect Box, Ground Rod	⊙ <sup>CB</sup> ⊙ <sup>DCB</sup> ⊙ <sup>GR</sup>
Water: Reducer, Fire Hydrant, Water Valve, Meter, Wall Hydrant	⊙ <sup>WR</sup> ⊙ <sup>FH</sup> ⊙ <sup>WV</sup> ⊙ <sup>M</sup> ⊙ <sup>WH</sup>
Pipe, Duct, Conduit, Lateral	⊙ <sup>PDCL</sup>
Culvert	⊙ <sup>C</sup>
Abandoned	⊙ <sup>A</sup>
Capped	⊙ <sup>C</sup>
Buried Cable	⊙ <sup>BC</sup>
Property Line	⊙ <sup>PL</sup>

**CAUTION/ATTENTION**

Although utility locations are established using the best available information, they cannot be guaranteed. Property lines were compiled from plans and documents recorded in the Land Registry System and are for indexing purposes only.

*Bien que l'emplacement des services publics soient établis en utilisant la meilleure information disponible, ils ne peuvent pas être garantis. Des lignes de propriété ont été compilées en utilisant des plans et des documents enregistrés dans le système de cadastre et sont pour l'indexation seulement.*

Department of Public Works and Services / Services et Travaux publics  
Infrastructure Services Branch / Direction des services d'infrastructure  
Infrastructure Management Division / Division de la gestion de l'infrastructure  
100 Constellation Cres., 6th Floor East / 6ème Étage Est, Ottawa, ON K2G 6J8


OTTAWA UTILITY COORDINATING COMMITTEE  
CENTRAL REGISTRY  
COMITÉ DE COORDINATION DES SERVICES PUBLICS D'OTTAWA  
ENREGISTREMENT CENTRAL

UCC  
Ottawa  
CCSP  
COMITÉ DE COORDINATION DES SERVICES PUBLICS

<b>N. SCHEPERS, P.Eng.</b> DCM, ISCIS	<b>W. NEWELL, P. Eng.</b> DIRECTOR, INFRASTRUCTURE SERVICES
<b>C. COLAIACOVO</b> MANAGER, BUSINESS & TECHNICAL SERVICES	<b>R. ZORDEL</b> COORDINATOR, INFORMATION CENTRE
PRODUCED BY: UCC MAPPING STAFF	SHEET NUMBER

SCALE: 1:250

D-13-10



REVISIONS / RÉVISIONS	DATE	BY
14091 - MCKENZIE (SEPT. 2006)		
BELL CONDUIT ADDED & ABAND	APRIL 2007	DC
EMERGE - E004910 (JAN 2008)		
4" GAS MAIN ADDED TO MCKENZIE	APR 2007	DC
EMERGE - 60-4348-03 (FEB 2003)		
GAS MAIN ABAND & ADDED TO RIDEAU	APR 2007	DC
EMERGE - 60-1149923 (OCT 2005)		
GAS MAIN ABAND & ADDED TO RIDEAU	APR 2007	DC
REVISION A7169202 DEC 2008		
ADDED ATRIA ACROSS COLONEL BY	MAY 2010	AJ
J04226 - MCKENZIE (JUL 2012)		
BELL CONDUIT ADDED	AUG 2012	ZB
R06130142 ROGERS (MAY 2013)		
CONDUIT ADDED TO MCKENZIE	NOV 2014	JM
HYDRO/BELL/EMERGE/ROGERS CITY SEWER WATER TRAFFIC, &		
COMPILED/DIGITIZED FROM UTILITY/CITY DATA	JAN 2015	JM

LEGEND	
Poles: Rogers, Bell, Hydro, Hydro One, Traffic, Utility	○ <sup>RG</sup> ○ <sup>HB</sup> ○ <sup>HO</sup> ○ <sup>HT</sup> ○ <sup>HT</sup> ○ <sup>HT</sup> ○ <sup>HT</sup>
Poles w/ Light Std.: Bell, Hydro, Hydro-Bell, Traffic, Utility	⊗ <sup>B</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup>
Manholes-City: Sanitary, Storm, Water, Catchbasin, Generic	⊗ <sup>S</sup> ⊗ <sup>S</sup> ⊗ <sup>S</sup> ⊗ <sup>S</sup> ⊗ <sup>S</sup> ⊗ <sup>S</sup> ⊗ <sup>S</sup> ⊗ <sup>S</sup>
Manholes-Utility: Bell, Hydro, Traffic, Allstream, Atria, PWGSC, Group Telecom, Rogers, Street Lighting, OC Transpo	⊗ <sup>B</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup>
Catch Basins: Heavy Duty, Standard, Curb Inlet, CI for CBMH, Ditch Inlet, Rear Yard, Wing Wall	⊗ <sup>S</sup> ⊗ <sup>S</sup> ⊗ <sup>S</sup> ⊗ <sup>S</sup> ⊗ <sup>S</sup> ⊗ <sup>S</sup> ⊗ <sup>S</sup> ⊗ <sup>S</sup>
Pedestals: Allstream, Atria, Bell, Hydro, Gas, Group Telecom, Rogers, Telus, Videotron	⊗ <sup>B</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup>
Hand Holes: Allstream, Atria, Group Telecom, Hydro, Hydro One, Traffic, Street Lighting, OC Transpo	⊗ <sup>B</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup>
Bell: Bell Dip, Guy Wire, Bell Panel, Telephone Booth	⊗ <sup>B</sup> ⊗ <sup>B</sup> ⊗ <sup>B</sup> ⊗ <sup>B</sup> ⊗ <sup>B</sup> ⊗ <sup>B</sup> ⊗ <sup>B</sup> ⊗ <sup>B</sup>
Gas: Reducer, Meter, Valve, Regulator	⊗ <sup>G</sup> ⊗ <sup>G</sup> ⊗ <sup>G</sup> ⊗ <sup>G</sup> ⊗ <sup>G</sup> ⊗ <sup>G</sup> ⊗ <sup>G</sup> ⊗ <sup>G</sup>
Hydro: Thermocouple, Transformer, Tower	⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup> ⊗ <sup>H</sup>
OC Transpo: Bus Shelter-No Power, Energized, Isolated	⊗ <sup>OC</sup> ⊗ <sup>OC</sup> ⊗ <sup>OC</sup> ⊗ <sup>OC</sup> ⊗ <sup>OC</sup> ⊗ <sup>OC</sup> ⊗ <sup>OC</sup> ⊗ <sup>OC</sup>
Rogers: Power Supply, Panel, Vault, Amplifier	⊗ <sup>R</sup> ⊗ <sup>R</sup> ⊗ <sup>R</sup> ⊗ <sup>R</sup> ⊗ <sup>R</sup> ⊗ <sup>R</sup> ⊗ <sup>R</sup> ⊗ <sup>R</sup>
Street Lighting: Light Standard, Disconnect	⊗ <sup>SL</sup> ⊗ <sup>SL</sup> ⊗ <sup>SL</sup> ⊗ <sup>SL</sup> ⊗ <sup>SL</sup> ⊗ <sup>SL</sup> ⊗ <sup>SL</sup> ⊗ <sup>SL</sup>
Streetscape: Decorative Light, Planter Box	⊗ <sup>SC</sup> ⊗ <sup>SC</sup> ⊗ <sup>SC</sup> ⊗ <sup>SC</sup> ⊗ <sup>SC</sup> ⊗ <sup>SC</sup> ⊗ <sup>SC</sup> ⊗ <sup>SC</sup>
Traffic: Connect Box, Disconnect Box, Ground Rod	⊗ <sup>T</sup> ⊗ <sup>T</sup> ⊗ <sup>T</sup> ⊗ <sup>T</sup> ⊗ <sup>T</sup> ⊗ <sup>T</sup> ⊗ <sup>T</sup> ⊗ <sup>T</sup>
Water: Reducer, Fire Hydrant, Water Valve, Meter, Wall Hydrant	⊗ <sup>W</sup> ⊗ <sup>W</sup> ⊗ <sup>W</sup> ⊗ <sup>W</sup> ⊗ <sup>W</sup> ⊗ <sup>W</sup> ⊗ <sup>W</sup> ⊗ <sup>W</sup>
Pipe, Duct, Conduit, Lateral	⊗ <sup>P</sup> ⊗ <sup>P</sup> ⊗ <sup>P</sup> ⊗ <sup>P</sup> ⊗ <sup>P</sup> ⊗ <sup>P</sup> ⊗ <sup>P</sup> ⊗ <sup>P</sup>
Culvert	⊗ <sup>C</sup> ⊗ <sup>C</sup> ⊗ <sup>C</sup> ⊗ <sup>C</sup> ⊗ <sup>C</sup> ⊗ <sup>C</sup> ⊗ <sup>C</sup> ⊗ <sup>C</sup>
Abandoned	⊗ <sup>A</sup> ⊗ <sup>A</sup> ⊗ <sup>A</sup> ⊗ <sup>A</sup> ⊗ <sup>A</sup> ⊗ <sup>A</sup> ⊗ <sup>A</sup> ⊗ <sup>A</sup>
Capped	⊗ <sup>CA</sup> ⊗ <sup>CA</sup> ⊗ <sup>CA</sup> ⊗ <sup>CA</sup> ⊗ <sup>CA</sup> ⊗ <sup>CA</sup> ⊗ <sup>CA</sup> ⊗ <sup>CA</sup>
Buried Cable	⊗ <sup>BC</sup> ⊗ <sup>BC</sup> ⊗ <sup>BC</sup> ⊗ <sup>BC</sup> ⊗ <sup>BC</sup> ⊗ <sup>BC</sup> ⊗ <sup>BC</sup> ⊗ <sup>BC</sup>
Property Line	⊗ <sup>PL</sup> ⊗ <sup>PL</sup> ⊗ <sup>PL</sup> ⊗ <sup>PL</sup> ⊗ <sup>PL</sup> ⊗ <sup>PL</sup> ⊗ <sup>PL</sup> ⊗ <sup>PL</sup>

**CAUTION/ATTENTION**

Although utility locations are established using the best available information, they cannot be guaranteed. Property lines were compiled from plans and documents recorded in the Land Registry System and are for indexing purposes only.

*Bien que l'emplacement des services publics soient établis en utilisant la meilleure information disponible, ils ne peuvent pas être garantis. Des lignes de propriété ont été compilées en utilisant des plans et des documents enregistrés dans le système de cadastre et sont pour l'indexation seulement.*



Department of Public Works and Services / Services et Travaux publics  
Infrastructure Services Branch / Direction des services d'infrastructure  
Infrastructure Management Division / Division de la gestion de l'infrastructure  
100 Constellation Cres., 6th Floor East / 6ème Étage Est, Ottawa, ON K2G 6J8

OTTAWA UTILITY COORDINATING COMMITTEE  
CENTRAL REGISTRY  
COMITÉ DE COORDINATION DES SERVICES PUBLICS D'OTTAWA  
ENREGISTREMENT CENTRAL



N. SCHEPERS, P.Eng.  
DCM ISCS  
C. COLIAICOVO  
MANAGER, BUSINESS & TECHNICAL SERVICES  
PRODUCED BY: UCC MAPPING STAFF

W. NEWELL, P. Eng.  
DIRECTOR, INFRASTRUCTURE SERVICES  
R. ZORGEL  
COORDINATOR, INFORMATION CENTRE  
SHEET NUMBER  
D-13-14

SCALE: 1:250



NOTE: THE LOCATION OF UTILITIES IS APPROXIMATE ONLY, AND THE EXACT LOCATION SHOULD BE DETERMINED BY CONSULTING THE MUNICIPAL AUTHORITIES AND UTILITY COMPANIES CONCERNED. THE CONTRACTOR SHALL PROVE THE LOCATION OF UTILITIES AND SHALL BE RESPONSIBLE FOR ADEQUATE PROTECTION FROM DAMAGE DURING CONSTRUCTION.

"AS-BUILT" INFORMATION OBTAINED FROM R.O.C. RECORDS

BENCH MARK EL. 72.992  
NCC BRASS PLUG No.1603  
POINT No 2 OF PUBLIC WORKS CANADA SURVEY  
HORIZONTAL CONTROL MONUMENT

No	REVISION	BY	DATE
1	GENERAL REVISION	J.V.G.	22/10/97
2	BOREHOLE LOCATION	J.V.G.	01/04/98
3	R-4 VALVE CHAMBER	J.V.G.	16/04/98
4	WEST ARCH WM AND MACKENZIE VALVE CHAMBER	J.V.G.	11/06/98
5	ALIGNMENT AND VALVE CHAMBER	J.V.G.	29/06/98
6	AS BUILT-WATERMAIN ONLY	J.V.G.	18/08/99

PLAZA BRIDGE

SERVICE WATERMAINS REPLACEMENTS (200mm)

J. MILLER, P.ENG.  
Director of Engineering

D.C. MARETT, P.ENG.  
Manager Capital Ops Area Projects

DWG. No. B-024103-500



Sheet of 97-517

Des J.V.G. Cnk D.W.L.



Dwn. E.C. Cnk J.V.G.

Date SEPT.12, 1997

Scale 1:300



STA.	FITTING	INV.
2+000	305x305 TEE	67.21
2+004.9	305 V&C	67.32
2+006.5	305x203 REDUCER	67.38
2+007.1	203-45° BEND	67.36
2+008	203-45° BEND	67.41 (EX.WM)




"AS-BUILT" INFORMATION OBTAINED  
FROM R.O.C. RECORDS

BENCH MARK EL. 72.992  
NCC BRASS PLUG No.1603  
POINT No.2 OF PUBLIC WORKS CANADA SURVEY  
HORIZONTAL CONTROL MONUMENT



**McNEELY  
ENGINEERING  
CONSULTANTS LTD.**



[illegible]


SECTIONAL CHAIRS

**J. MILLER, P.ENG.**  
*Director of Engineering*

D.C. MARETT, P.ENG.  
Manager Capital Core Area Projects

Scale: 1:300







CURVE DATA #6  
 $\Delta_1 = 80^\circ 34' 14''$   
 $R = 100'$   
 $T = 84.762'$   
 $L_c = 140.622'$   
 $\Delta_2 = 23^\circ 59' 59''$   
 $R_2 = 124.786'$   
 $T_2 = 26.524'$   
 $L_{c2} = 54.167'$

CURVE DATA #7  
 $\Delta = 46^\circ 30' 40''$   
 $R = 500'$   
 $T = 214.874'$   
 $L_c = 405.886'$

PLAN  
 SCALE 1" = 100'



PROFILE SCALE  
 HORIZ. 1" = 100'  
 VERT. 1" = 20'



BOREHOLES ALONG RIDEAU CANAL

SCALE HORIZ. 1" = 100'  
 VERT. 1" = 20'



#### LEGEND FOR BOREHOLE DATA.

- GROUND SURFACE
- BEDROCK SURFACE
- BOTTOM OF HOLE
- LOST DRILL WATER AT ELEVATION
- RODS DROPPED 2" AT ELEVATION
- DRILLER REPORTED HOLE CAVING WHILE DRILLING AT ELEVATION
- MAXIMUM GROUND WATER LEVEL OF SEVERAL OVERNIGHT OBSERVATIONS, MAXIMUM WATER SURFACE AT ELEVATION OF BOTTOM OF HOLE, WHEN MAXIMUM WATER LEVEL OBSERVED, AT ELEVATION 153.1
- SINGLE GROUND WATER LEVEL OBSERVATION AFTER ALLOWING WATER TO SEEK ITS EQUILIBRIUM LEVEL OVERNIGHT; WATER SURFACE AT ELEVATION OF BOTTOM OF HOLE, WHEN WATER LEVEL OBSERVED WAS AT ELEVATION 153.1
- MAXIMUM GROUND WATER LEVEL OF SEVERAL OVERNIGHT OBSERVATIONS, MAXIMUM WATER SURFACE AT ELEVATION OF BOTTOM OF HOLE NOT SPECIFIED.

As-Built		Revisions		R.E.C. May 30 '63	
No.		By	Date		
<b>CITY OF OTTAWA</b> DEPARTMENT OF PLANNING AND WORKS SEWERAGE & DRAINAGE BRANCH <b>INTERCEPTOR AND OUTFALL SEWER PROJECT.</b> <b>CONTRACT No. 9</b> <b>INTERCEPTOR SEWER TUNNEL.</b> <b>PLAN &amp; PROFILE</b> <b>Sta. 62+80 to Sta. 87+00</b>					
DE LEUW CATHER & CO. OF CANADA LIMITED Consulting Engineers <i>Leon Marshall</i>			CITY OF OTTAWA <i>W. P. Keay</i> ENGINEER IN CHARGE SEWERAGE & DRAINAGE BRANCH <i>W. P. Keay</i> DIRECTOR OF PLANNING AND WORKS		
DESIGNED BY D.N./H.V.M.	DATE APRIL, 1961	SCALE AS SHOWN			
DRAWN BY A.G.Y.	SHEET 1 OF 15				
CHECKED BY H.V.M.					

# 1633-R MACKENZIE AVENUE

MACKENZIE AVENUE



Station	Existing Surface	Proposed Surface (Crown)	Type B Concrete (sewer)	Inverts (Exist & Prop. sewer)
975.00	71.50	71.50		
976.00	71.50	71.50		
977.00	71.50	71.50		
978.00	71.50	71.50		
979.00	71.50	71.50		
980.00	71.50	71.50		
981.00	71.50	71.50		
982.00	71.50	71.50		
983.00	71.50	71.50		
984.00	71.50	71.50		
985.00	71.50	71.50		
986.00	71.50	71.50		
987.00	71.50	71.50		
988.00	71.50	71.50		
989.00	71.50	71.50		
990.00	71.50	71.50		
991.00	71.50	71.50		
992.00	71.50	71.50		
993.00	71.50	71.50		
994.00	71.50	71.50		
995.00	71.50	71.50		
996.00	71.50	71.50		
997.00	71.50	71.50		
998.00	71.50	71.50		
999.00	71.50	71.50		
1000.00	71.50	71.50		

City Of Ottawa  
Department Of Physical Environment  
Engineering And Surveys Branch

**Notes:**

Utilities shown are taken from best available records. Contractor is requested to check with all utility companies before digging.

Soil information shown is not guaranteed and contractors are advised to collect additional soils information as deemed necessary.

Date of survey: April 19/81, Cross-sections Feb/80.

Reference bench mark: Top of Main Hydrant Mackenzie-St. Patrick Elev. 65.041.

**Notes (Sewer Construction Only)**

A minimum of 450 mm vertical clearance to be maintained between sewers and watermain where practical.

Borehole soil descriptions are not based on sieve analysis but on visual inspection only. Excavate where shown otherwise noted.

Soil information taken from:

- Existing sewers constructed in 1935, 1959, 1970.
- This plan supersedes in whole or in part plan no. P-21-9.
- Actual rock line recorded during construction of existing sewer.
- Registered plan no. 5-9-4770.
- For additional notes see Sheet No. 3.

**Legend:**

EXISTING	PROPOSED
STORM SEWER	STORM SEWER
SANITARY SEWER	SANITARY SEWER
STREET LINE	STREET LINE
LOT LINE	LOT LINE
ROADS & DRIVEWAYS	ROADS & DRIVEWAYS
Asphalt or Concrete	Asphalt or Concrete
Surface Treated	Surface Treated
WALLS	WALLS
Concrete or Asphalt	Concrete or Asphalt
Gravel, Chalk or Soil	Gravel, Chalk or Soil
DEPRESSED ACCESS	DEPRESSED ACCESS
On Curb	On Curb
On Sidewalk	On Sidewalk
WATERMAIN	WATERMAIN
GASMAIN & VALVE	GASMAIN & VALVE
BELL	BELL
HYDRO	HYDRO
TRAFFIC	TRAFFIC
ROSE ALARM	ROSE ALARM
CABLEVISION	CABLEVISION
STEAM LINE	STEAM LINE
HYDRANT	HYDRANT
WATER VALVE	WATER VALVE
STAND PIPE	STAND PIPE
WATER VALVE CHAMBER	WATER VALVE CHAMBER
SEWER TRAFFIC HYDRANT BELL	SEWER TRAFFIC HYDRANT BELL
TRAFFIC HANDICAP	TRAFFIC HANDICAP
GUARD RAIL	GUARD RAIL
RETAINING WALL	RETAINING WALL
FENCE	FENCE
HYDRO POLE	HYDRO POLE
HYDRO POLE & LIGHT	HYDRO POLE & LIGHT
BELL POLE	BELL POLE
TRAFFIC LIGHT	TRAFFIC LIGHT
LIGHT STANDARD	LIGHT STANDARD
TRAFFIC SIGN	TRAFFIC SIGN
STREET SIGN	STREET SIGN
CULVERT & DITCH	CULVERT & DITCH
STANDARD CATCH BASIN	STANDARD CATCH BASIN
HEAVY DUTY CATCH BASIN	HEAVY DUTY CATCH BASIN
CATCH BASIN TO BE REMOVED & REPLACED WITH STANDARD C.B.	CATCH BASIN TO BE REMOVED & REPLACED WITH STANDARD C.B.
HEAVY DUTY CATCH BASIN TO BE REPLACED WITH STANDARD C.B.	HEAVY DUTY CATCH BASIN TO BE REPLACED WITH STANDARD C.B.
HOUSE & CATCH BASIN CONNECTION	HOUSE & CATCH BASIN CONNECTION
HOUSE FROM RECORD	HOUSE FROM RECORD
RELOCATION	RELOCATION
REINFORCEMENT	REINFORCEMENT
SQUARE IRON BAR	SQUARE IRON BAR
STANDARD IRON BAR	STANDARD IRON BAR
ROUND IRON BAR	ROUND IRON BAR
TREE, SHRUB & HEDGE	TREE, SHRUB & HEDGE
BORERHOLE	BORERHOLE
ROCK	ROCK

\* DUPLEX SEWERS 400mm & ABOVE ARE SHOWN AS DOUBLE LINE TO SCALE, USING BAW LINE WEIGHT.

\* UTILITIES 4" DIA. AND ABANDONED, BELL PLANT SO MARKED MAY BECOME ACTIVE.

**Revisions:**

No.	Date	Description	Drawn By	Appr'd By
1	11/7/80	ORIGINAL - MACKENZIE AVENUE		
2	11/7/80	REVISION - MACKENZIE AVENUE		

Storm Sewer Designed By: \_\_\_\_\_ Date: \_\_\_\_\_

Sanitary Sewer Designed By: \_\_\_\_\_ Date: \_\_\_\_\_

Structural Checked By: \_\_\_\_\_ Date: \_\_\_\_\_

Hydro Checked By: \_\_\_\_\_ Date: \_\_\_\_\_

Survey By: \_\_\_\_\_ Date: \_\_\_\_\_

Drawn By: \_\_\_\_\_ Date: \_\_\_\_\_

Appr'd By: \_\_\_\_\_ Date: \_\_\_\_\_

Professional Engineer Seal

**Design And Construction Division**  
Engineering And Surveys Branch



C. Sim P. Eng. D.K. Donaldson P. Eng.

Branch Engineer

**MACKENZIE AVENUE**  
FROM STA. 9400.00 TO RIDEAU STREET

Sheet No. 1633-R

Scale: 1" = 20' HORIZ. 1" = 5' VERT.



City Of Ottawa  
Department Of Physical Environment  
Engineering And Surveys Branch

**Notes:**

- Utilities shown are taken from best available records. Contractor is requested to check with all utility companies before digging.
- Soil information shown is not guaranteed and contractors are advised to collect additional soils information as deemed necessary.
- Date of survey: Detail, Feb/80 May/80; Cross-sections Apr./80, Underground May/80.
- Reference bench mark: GBM Chateau Laurier Hotel (71.161)


See notes sheet 2.

**Notes (Sewer Construction Only)**





- A minimum of 460 mm vertical clearance to be maintained between sewers and watermains where practical.
- Borehole soil descriptions are not based on sieve analysis but on visual inspection only. Except where otherwise noted.
- Soil information taken from Johnston Drilling Co. Ltd. B.H. Report
- Existing sewers constructed in:
  - This plan supercedes (in whole or in part) plan no. H-20-a
  - Actual rock line recorded during construction of existing sewer.
  - Registered plan no.
- See notes: sheet 2

[illegible][illegible]

Storm Sewer Designed By JOHN BRADLEY	Date 4/1/82	Sanitary Sewer Designed By JOHN BRADLEY	Date 4/1/82
Structural Checked By Date <i>John M. Cote</i>			
Road Grade Designed By	Date	Checked By	Date
Survey Detail By R. VILL ENUEVE	Date	<i>M. Brown</i>	<i>2/2/82</i>
Drafting By <i>James</i>	Date	Checked By	Date
M. COTE	4/1/82	<i>J. J. Wells</i>	<i>Jan. 32</i>




Design And Construction Division  
Engineering And Surveys Branch

C. Sim P. Eng. Commissioner		D.K. Donaldson P. Branch Director	
			


EXISTING STORM & SANITARY SEWERS  
RIDEAU STREET  
FROM STA. 740.00 TO STA. 820.00

Contract No: 82-II R.A.P.	Survey Books: 2098-2107 2125	Scales: HOR. 1:200 VERT. 1:50	Plan No: 1660-F Sheet 5 of 6
------------------------------	------------------------------------	-------------------------------------	------------------------------------

# MACKENZIE AVENUE



# MACKENZIE AVENUE



## MACKENZIE AVENUE CYCLING FACILITY AND RESURFACING PROJECT

### GEOMETRY AND GENERAL LAYOUT MACKENZIE AVENUE STA. 1+070 TO STA. 1+370

W. R. NEWELL, P. ENG. J. MACDONALD, P. ENG.  
General Manager Senior Engineer  
Infrastructure Services Department Infrastructure Projects



Stantec Consulting Ltd.  
495-1131 Orléans Avenue  
Ottawa, ON Canada  
K2C 3S4  
Tel: 613-722-4420  
www.stantec.com



Contract No. ISD15-5168 Dwg. No. 011  
Sheet 11 of 44

Asset No.

Asset Group

Des. J.B. Chk'd. B.C.H.

Dwn. K.D.M. Chk'd. J.B.

Utility Circ. No. Index No.

Const. Inspector

Scale: HORIZONTAL 1:250

0m 2.5 5 10

NOTE: The location of utilities is approximate only, the exact location should be determined by consulting the municipal authorities and utility companies concerned. The contractor shall prove the location of utilities and shall be responsible for adequate protection from damage.

REVISIONS	No.	Description	By	Date (dd/mm/yyyy)
	1	ISSUED FOR DESIGN CIRCULATION	B.C.H.	22/12/2015
	2	ISSUED FOR MUNICIPAL CONSENT	B.C.H.	11/02/2016
	3	ISSUED FOR TENDER	B.C.H.	16/02/2016
	4	ISSUED FOR CONSTRUCTION	B.C.H.	05/04/2016

#### NOTES:



- ALL ROADWAY CO-ORDINATES AND RADII SHOWN ARE GIVEN AT EDGE OF PAVEMENT UNLESS OTHERWISE NOTED. WHERE SIDEWALKS INTERSECT CURBLINES, CO-ORDINATES ARE GIVEN AT EDGE OF PAVEMENT.
- CO-ORDINATES FOR SIDEWALKS INTERSECTING CURBLINES ARE GIVEN AT FACE OF CURB.

DRAWING FRAME: 700mm x 534mm City of Ottawa 2014

Drawing Number

2015-04-04 1:40 PM w:\active\103801\020\design\drawing\15-5184-015-020.dwg

# MACKENZIE AVENUE



## MACKENZIE AVENUE CYCLING FACILITY AND RESURFACING PROJECT



### GRADING AND DRAINAGE MACKENZIE AVENUE STA. 1+070 TO STA. 1+370

W. R. NEWELL, P. ENG. J. MACDONALD, P. ENG.  
General Manager Senior Engineer  
Infrastructure Services Department Infrastructure Projects



Stantec Consulting Ltd.  
400-1101 Ogle Avenue  
Ottawa, ON Canada  
K2G 3G4  
Tel: 613-722-4420  
www.stantec.com



Contract No.	ISD15-5168	Dwg. No.	015
Sheet	15 of 44	Asset No.	
Asset Group		Des.	J.B. Chk'd. B.C.H.
Dwn.	K.D.M.	Chk'd.	J.B.
Utility Circ. No.		Index No.	
Const. Inspector		Scale:	HORIZONTAL 1:250 0m 2.5 5 10

NOTE: The location of utilities is approximate only, the exact location should be determined by consulting the municipal authorities and utility companies concerned. The contractor shall prove the location of utilities and shall be responsible for adequate protection from damage.


Revisions	No.	Description	By	Date (dd/mm/yyyy)
	1	ISSUED FOR DESIGN CIRCULATION	B.C.H.	22/12/2015
	2	ISSUED FOR MUNICIPAL CONSENT	B.C.H.	11/02/2016
	3	ISSUED FOR TENDER	B.C.H.	16/02/2016
	4	ISSUED FOR CONSTRUCTION	B.C.H.	05/04/2016

#### CATCHBASIN & MAINTENANCE HOLE DATA

NO.	STATION	OFFSET (m)	TYPE		ELEVATION	
			Structure	Cover	Grate	Low Inv.
CB3	1+106	1.4 LT	705.010	S19	68.815	67.31
CB4	1+155	1.4 LT	705.010	S19	70.314	68.81
CB5	1+180	1.4 LT	705.010	S19	71.004	69.50

#### SEWER DATA

NO. to NO. (high to low)	SIZE (mm)	LENGTH (m)	CLASS	INVERTS	
				Inlet	Outlet
CB3 SEWER	200	1.5	SDR 35	67.31	67.16
CB4 SEWER	200	1.5	SDR 35	68.81	68.66
CB5 SEWER	200	1.5	SDR 35	69.50	69.44



MACKENZIE AVENUE  
CYCLING FACILITY AND  
RESURFACING PROJECT



**GEOMETRY AND  
GENERAL LAYOUT  
MACKENZIE AVENUE  
STA. 1+370 TO STA. 1+462.5**

Contract No.  
**ISD15-5168**

Dwg. No.  
**012**

Sheet 12 of 44

Asset No.

Asset Group

W. R. NEWELL, P. ENG.  
General Manager  
Infrastructure Services Department

J. MACDONALD, P. ENG.  
Senior Engineer  
Infrastructure Projects

Stantec Consulting Ltd.  
405 - 1331 Clyde Avenue  
Ottawa, ON Canada  
K2C 3K4  
Tel: 613 722 4420  
www.stantec.com

Des. J.B.

Chk'd. B.C.H.

Dwn. K.D.M.

Chk'd. J.B.

Utility Circ. No.

Index No.


Const. Inspector

Scale: HORIZONTAL 1:250  
0m 2.5 5 10

NOTE: The location of utilities is approximate only, the exact location should be determined by consulting the municipal authorities and utility companies concerned. The contractor shall prove the location of utilities and shall be responsible for adequate protection from damage.

REVISIONS	No.	Description	By	Date (dd/mm/yyyy)
	1	ISSUED FOR DESIGN CIRCULATION	B.C.H.	22/12/2015
	2	ISSUED FOR MUNICIPAL CONSENT	B.C.H.	11/02/2016
	3	ISSUED FOR TENDER	B.C.H.	16/02/2016
	4	ISSUED FOR CONSTRUCTION	B.C.H.	05/04/2016

- NOTES:
- ALL ROADWAY CO-ORDINATES AND RADII SHOWN ARE GIVEN AT EDGE OF PAVEMENT UNLESS OTHERWISE NOTED. WHERE SIDEWALKS INTERSECT CURBLINES, CO-ORDINATES ARE GIVEN AT EDGE OF PAVEMENT.
  - CO-ORDINATES FOR SIDEWALKS INTERSECTING CURBLINES ARE GIVEN AT FACE OF CURB.



MACKENZIE AVENUE  
CYCLING FACILITY AND  
RESURFACING PROJECT



GRADING AND DRAINAGE  
MACKENZIE AVENUE  
STA. 1+370 TO STA. 1+462.5

W. R. NEWELL, P. ENG.  
General Manager  
Infrastructure Services Department

J. MACDONALD, P. ENG.  
Senior Engineer  
Infrastructure Projects



Stantec Consulting Ltd.  
405 - 1331 Clyde Avenue  
Ottawa, ON Canada  
K2C 3K4  
Tel: 613-722-4420  
www.stantec.com



Des. J.B. Chk'd. B.C.H.

Dwn. K.D.M. Chk'd. J.B.

Utility Circ. No. Index No.

Const. Inspector

Scale: HORIZONTAL 1:250  
0m 2.5 5 10

NOTE: The location of utilities is approximate only, the exact location should be determined by consulting the municipal authorities and utility companies concerned. The contractor shall prove the location of utilities and shall be responsible for adequate protection from damage.

REVISIONS	No.	Description	By	Date (dd/mm/yyyy)
	1	ISSUED FOR DESIGN CIRCULATION	B.C.H.	22/12/2015
	2	ISSUED FOR MUNICIPAL CONSENT	B.C.H.	11/02/2016
	3	ISSUED FOR TENDER	B.C.H.	16/02/2016
	4	ISSUED FOR CONSTRUCTION	B.C.H.	05/04/2016

CATCHBASIN & MAINTENANCE HOLE DATA

NO.	STATION	OFFSET (m)	TYPE		ELEVATION	
			Structure	Cover	Grate	Low Inv.
CB6	1+380	1.7 LT	705.010	S19	70.20	68.70
CB7	1+383.6	8.0 RT	705.010	S19	70.112	68.91
CB8	1+422	8.8 RT	705.020	S22/S23 (2)	69.813	68.62
CB9	1+423	1.7 LT	705.010	S19	69.473	67.97

SEWER DATA

NO. to NO. (high to low)	SIZE (mm)	LENGTH (m)	CLASS	INVERTS	
				Inlet	Outlet
CB6 SEWER	200	1.0	SDR 35	68.70	68.67
CB7 EXIST.	200	2.5	SDR 35	68.91	68.58±
CB8 EXIST.	200	4.0	SDR 35	68.62	68.31±
CB9 SEWER	200	3.0	SDR 35	67.97	67.72

□ DENOTES INVERT GIVEN AT TOP OF RISER

# **APPENDIX L**

## Checklist

## 4. Development Servicing Study Checklist

The following section describes the checklist of the required content of servicing studies. It is expected that the proponent will address each one of the following items for the study to be deemed complete and ready for review by City of Ottawa Infrastructure Approvals staff.

The level of required detail in the Servicing Study will increase depending on the type of application. For example, for Official Plan amendments and re-zoning applications, the main issues will be to determine the capacity requirements for the proposed change in land use and confirm this against the existing capacity constraint, and to define the solutions, phasing of works and the financing of works to address the capacity constraint. For subdivisions and site plans, the above will be required with additional detailed information supporting the servicing within the development boundary.

### 4.1 General Content

- ☐ Executive Summary (for larger reports only).
- ☒ Date and revision number of the report.
- ☒ Location map and plan showing municipal address, boundary, and layout of proposed development.
- ☒ Plan showing the site and location of all existing services.
- ☐ Development statistics, land use, density, adherence to zoning and official plan, and reference to applicable subwatershed and watershed plans that provide context to which individual developments must adhere.
- ☒ Summary of Pre-consultation Meetings with City and other approval agencies.
- ☐ Reference and confirm conformance to higher level studies and reports (Master Servicing Studies, Environmental Assessments, Community Design Plans), or in the case where it is not in conformance, the proponent must provide justification and develop a defensible design criteria.
- ☒ Statement of objectives and servicing criteria.
- ☒ Identification of existing and proposed infrastructure available in the immediate area.

- ☐ Identification of Environmentally Significant Areas, watercourses and Municipal Drains potentially impacted by the proposed development (Reference can be made to the Natural Heritage Studies, if available).
- ☐ Concept level master grading plan to confirm existing and proposed grades in the development. This is required to confirm the feasibility of proposed stormwater management and drainage, soil removal and fill constraints, and potential impacts to neighboring properties. This is also required to confirm that the proposed grading will not impede existing major system flow paths.
- ☐ Identification of potential impacts of proposed piped services on private services (such as wells and septic fields on adjacent lands) and mitigation required to address potential impacts.
- ☐ Proposed phasing of the development, if applicable.
- ☐ Reference to geotechnical studies and recommendations concerning servicing.
- ☒ All preliminary and formal site plan submissions should have the following information:
  - ☒ Metric scale
  - ☒ North arrow (including construction North)
  - ☒ Key plan
  - ☒ Name and contact information of applicant and property owner
  - ☒ Property limits including bearings and dimensions
  - ☒ Existing and proposed structures and parking areas
  - ☒ Easements, road widening and rights-of-way
  - ☒ Adjacent street names

## 4.2 Development Servicing Report: Water

- ☐ Confirm consistency with Master Servicing Study, if available
- ☒ Availability of public infrastructure to service proposed development
- ☐ Identification of system constraints
- ☒ Identify boundary conditions
- ☒ Confirmation of adequate domestic supply and pressure

- ☒ Confirmation of adequate fire flow protection and confirmation that fire flow is calculated as per the Fire Underwriter's Survey. Output should show available fire flow at locations throughout the development.
- ☒ Provide a check of high pressures. If pressure is found to be high, an assessment is required to confirm the application of pressure reducing valves.
- ☐ Definition of phasing constraints. Hydraulic modeling is required to confirm servicing for all defined phases of the project including the ultimate design
- ☐ Address reliability requirements such as appropriate location of shut-off valves
- ☐ Check on the necessity of a pressure zone boundary modification.
- ☐ Reference to water supply analysis to show that major infrastructure is capable of delivering sufficient water for the proposed land use. This includes data that shows that the expected demands under average day, peak hour and fire flow conditions provide water within the required pressure range
- ☒ Description of the proposed water distribution network, including locations of proposed connections to the existing system, provisions for necessary looping, and appurtenances (valves, pressure reducing valves, valve chambers, and fire hydrants) including special metering provisions.
- ☐ Description of off-site required feeder mains, booster pumping stations, and other water infrastructure that will be ultimately required to service proposed development, including financing, interim facilities, and timing of implementation.
- ☒ Confirmation that water demands are calculated based on the City of Ottawa Design Guidelines.
- ☒ Provision of a model schematic showing the boundary conditions locations, streets, parcels, and building locations for reference.

### **4.3 Development Servicing Report: Wastewater**

- ☒ Summary of proposed design criteria (Note: Wet-weather flow criteria should not deviate from the City of Ottawa Sewer Design Guidelines. Monitored flow data from relatively new infrastructure cannot be used to justify capacity requirements for proposed infrastructure).
- ☐ Confirm consistency with Master Servicing Study and/or justifications for deviations.

- ☐ Consideration of local conditions that may contribute to extraneous flows that are higher than the recommended flows in the guidelines. This includes groundwater and soil conditions, and age and condition of sewers.
- ☒ Description of existing sanitary sewer available for discharge of wastewater from proposed development.
- ☐ Verify available capacity in downstream sanitary sewer and/or identification of upgrades necessary to service the proposed development. (Reference can be made to previously completed Master Servicing Study if applicable)
- ☒ Calculations related to dry-weather and wet-weather flow rates from the development in standard MOE sanitary sewer design table (Appendix 'C') format.
- ☒ Description of proposed sewer network including sewers, pumping stations, and forcemains.
- ☒ Discussion of previously identified environmental constraints and impact on servicing (environmental constraints are related to limitations imposed on the development in order to preserve the physical condition of watercourses, vegetation, soil cover, as well as protecting against water quantity and quality).
- ☐ Pumping stations: impacts of proposed development on existing pumping stations or requirements for new pumping station to service development.
- ☐ Forcemain capacity in terms of operational redundancy, surge pressure and maximum flow velocity.
- ☐ Identification and implementation of the emergency overflow from sanitary pumping stations in relation to the hydraulic grade line to protect against basement flooding.
- ☐ Special considerations such as contamination, corrosive environment etc.

#### **4.4 Development Servicing Report: Stormwater Checklist**

- ☒ Description of drainage outlets and downstream constraints including legality of outlets (i.e. municipal drain, right-of-way, watercourse, or private property)
- ☐ Analysis of available capacity in existing public infrastructure.
- ☒ A drawing showing the subject lands, its surroundings, the receiving watercourse, existing drainage patterns, and proposed drainage pattern.

- ☒ Water quantity control objective (e.g. controlling post-development peak flows to pre-development level for storm events ranging from the 2 or 5 year event (dependent on the receiving sewer design) to 100 year return period); if other objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into account long-term cumulative effects.
- ☐ Water Quality control objective (basic, normal or enhanced level of protection based on the sensitivities of the receiving watercourse) and storage requirements.
- ☒ Description of the stormwater management concept with facility locations and descriptions with references and supporting information.
- ☐ Set-back from private sewage disposal systems.
- ☐ Watercourse and hazard lands setbacks.
- ☐ Record of pre-consultation with the Ontario Ministry of Environment and the Conservation Authority that has jurisdiction on the affected watershed.
- ☐ Confirm consistency with sub-watershed and Master Servicing Study, if applicable study exists.
- ☒ Storage requirements (complete with calculations) and conveyance capacity for minor events (1:5 year return period) and major events (1:100 year return period).
- ☐ Identification of watercourses within the proposed development and how watercourses will be protected, or, if necessary, altered by the proposed development with applicable approvals.
- ☒ Calculate pre and post development peak flow rates including a description of existing site conditions and proposed impervious areas and drainage catchments in comparison to existing conditions.
- ☐ Any proposed diversion of drainage catchment areas from one outlet to another.
- ☐ Proposed minor and major systems including locations and sizes of stormwater trunk sewers, and stormwater management facilities.
- ☐ If quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100 year return period storm event.
- ☐ Identification of potential impacts to receiving watercourses

- ☐ Identification of municipal drains and related approval requirements.
- ☒ Descriptions of how the conveyance and storage capacity will be achieved for the development.
- ☒ 100 year flood levels and major flow routing to protect proposed development from flooding for establishing minimum building elevations (MBE) and overall grading.
- ☐ Inclusion of hydraulic analysis including hydraulic grade line elevations.
- ☒ Description of approach to erosion and sediment control during construction for the protection of receiving watercourse or drainage corridors.
- ☐ Identification of floodplains – proponent to obtain relevant floodplain information from the appropriate Conservation Authority. The proponent may be required to delineate floodplain elevations to the satisfaction of the Conservation Authority if such information is not available or if information does not match current conditions.
- ☐ Identification of fill constraints related to floodplain and geotechnical investigation.

## 4.5 Approval and Permit Requirements: Checklist

The Servicing Study shall provide a list of applicable permits and regulatory approvals necessary for the proposed development as well as the relevant issues affecting each approval. The approval and permitting shall include but not be limited to the following:

- ☐ Conservation Authority as the designated approval agency for modification of floodplain, potential impact on fish habitat, proposed works in or adjacent to a watercourse, cut/fill permits and Approval under Lakes and Rivers Improvement Act. The Conservation Authority is not the approval authority for the Lakes and Rivers Improvement Act. Where there are Conservation Authority regulations in place, approval under the Lakes and Rivers Improvement Act is not required, except in cases of dams as defined in the Act.
- ☐ Application for Certificate of Approval (CofA) under the Ontario Water Resources Act.
- ☐ Changes to Municipal Drains.
- ☐ Other permits (National Capital Commission, Parks Canada, Public Works and Government Services Canada, Ministry of Transportation etc.)

## 4.6 Conclusion Checklist

- ☒ Clearly stated conclusions and recommendations
- ☒ Comments received from review agencies including the City of Ottawa and information on how the comments were addressed. Final sign-off from the responsible reviewing agency.
- ☒ All draft and final reports shall be signed and stamped by a professional Engineer registered in Ontario

Bridges, Dams, Culverts

Retaining Walls

Falsework, Formwork, Temporary Structures

Parking Garages, Parking Lots

Sewage and Storm Water Management

Piles, Platforms

Condominiums, Apartments Buildings, Office Buildings

*PROFESSIONAL SERVICES PROVIDED WITH CARE,  
COMPETENCE AND INTEGRITY THAT DELIVER  
PRACTICAL SOLUTIONS TO COMPLEX PROBLEMS*

