

re: **Grading Plan Review**  
**Proposed Community Centre**  
**351 Sandhill Road - Ottawa**

to: Kanata Muslim Association - **Mr. Mehmood Shaikh** - [mehmoodshaikh@gmail.com](mailto:mehmoodshaikh@gmail.com)

to: EXP - **Mr. Alam Ansari** - [alam.ansari@exp.com](mailto:alam.ansari@exp.com)

date: November 19, 2018

file: PG4228-MEMO.02

---

Further to your request, Paterson Group (Paterson) prepared the current memorandum to provide a grading plan review for the proposed community centre development to be located at the aforementioned site. The following memorandum should be read in conjunction with our current report Paterson Group Report - PG4228-1 Revision 1 dated November 19, 2018.

## Grading Plan Review

Paterson reviewed the following grading plan prepared by EXP for the aforementioned development:

- Grading Plan - Phase 2 - Project No. OTT-00238504-A0 - Drawing No. GP-2, Revision 4 dated November 2, 2018

Based on the grading plan provided, the proposed grades are less than the permissible grade raise restriction of 2 m and are acceptable from a geotechnical perspective. Therefore, no lightweight fill is required for the proposed buildings from a geotechnical perspective.

We trust that this information satisfies your immediate requirements.

### Paterson Group Inc.



Colin Belcourt, P.Eng.



David J. Gilbert, P.Eng.

### Paterson Group Inc.

**Head Office and Laboratory**  
154 Colonnade Road South  
Ottawa - Ontario - K2E 7J5  
Tel: (613) 226-7381 Fax: (613) 226-6344

**Northern Office and Laboratory**  
63 Gibson Street  
North Bay - Ontario - P1B 8Z4  
Tel: (705) 472-5331 Fax: (705) 472-2334

**St. Lawrence Office**  
993 Princess Street - Suite 100  
Kingston - Ontario - K7L 1H3  
Tel: (613) 542-7381