

November 28, 2018

File No.: 18006

By Email: b.holzman@holzmanconsultants.com

City of Ottawa
Planning and Development
110 Laurier Ave. West
Ottawa, ON K1P 1J1

Attention: Ms. Amanda Marsh, Planner - Development Review

Via: Mr. Bill Holzman of Holzman Consultants Inc.

Reference: Site Plan Control Application - 351 Sandhill Road, Ottawa ON
File Number: D07-12-17-0119 - Site Lighting Control Letter

Dear Ms. Marsh:

This is to confirm the new site lighting package we have prepared for this project:

- a) Is designed using only fixtures that meet the criteria for Full Cut-Off (Sharp cut-off) Classification, as recognized by the Illuminating Engineering Society of North America (IESNA or IES) with the only exception is the feature lighting illuminating the pillars at the entrance porches (type CC light fixtures), and;
- b) Results in minimal light spillage onto adjacent properties, with less than 0.5 foot-candles spillage based on our calculations.

Yours truly,
ALFA+ PROJECT LEADERS INC.



Al Salah, P.Eng.
President

