

#### Engineering

Land / Site Development

Municipal Infrastructure

Environmental / Water Resources

Traffic / Transportation

Structural

Recreational

#### Planning

Land / Site Development

Planning Application Management

Municipal Planning Documents & Studies

Expert Witness (OMB)

Wireless Industry

## Landscape

Architecture

Urban Design & Streetscapes

Open Space, Parks & Recreation Planning

Community & Residential Developments

Commercial & Institutional Sites

Environmental Restoration



# Fernbank Crossing – Block 135

## **Servicing Design Brief**



SERVICING DESIGN BRIEF – BLOCK 135



Prepared By:

NOVATECH Suite 200, 240 Michael Cowpland Drive Ottawa, Ontario K2M 1P6

> March 22, 2019 Revised: June 12, 2019

Novatech File: 117089 Ref: R-2019-053



June 12, 2019

City of Ottawa Infrastructure Services and Community Sustainability 110 Laurier Avenue West, 4<sup>th</sup> Floor Ottawa, ON K1P 1J1

#### Attention: Mr. Eric Surprenant

Dear Mr. Surprenant:

Reference: Fernbank Crossing – Block 135 Servicing Design Brief Our File No.: 117089

Enclosed for your review and approval are two (2) copies of the Servicing Design Brief for the proposed development of Block 135 in the Fernbank Crossing Subdivision.

If you have any questions or comments, please do not hesitate to contact us.

Sincerely,

NOVATECH

- whi

Lucas Wilson, P.Eng. Project Coordinator

M:\2017\117089\DATA\REPORTS\SITE SERVICING\2019.06.12 SITE SERVICING.DOCX

## TABLE OF CONTENTS

1.0	INTRODUCTION	1
1.1 1.2	BACKGROUND	1 2
2.0	ROADWAYS	4
2.1 2.2 2.3	EXISTING CONDITIONS	4 4 4
3.0	GRADING	4
3.1 3.2 3.3	EXISTING CONDITIONS	4 5 5
4.0	EROSION AND SEDIMENT CONTROL	5
5.0	SANITARY SEWERS	6
5.1 5.2 5.3	EXISTING CONDITIONS	6 6 8
6.0	STORMWATER MANAGEMENT	8
6.1 6.2 6.3 6.3 6.4 6.4 6.4 6.4	EXISTING CONDITIONS8PROPOSED CONDITIONS82.1 Minor System Design102.2 Major System Design10HYDROLOGIC & HYDRAULIC MODELING10.3.1 Minor System11.3.2 Major System12RESULTS OF HYDROLOGIC/ HYDRAULIC ANALYSIS13.4.1 Minor System14.4.2 Major System14.4.3 Hydraulic Grade Line14	33800233344
7.0	WATER	6
7.1 7.2 7.3	EXISTING CONDITIONS	6 6 9
8.0	CONCLUSIONS AND RECOMMENDATIONS	D
Refer	ences	D

## List of Tables

- Table 2.1: Roadway Structure
- Table 5.1: Sanitary Sewer Design Parameters
- Table 6.1: Storm Sewer Design Parameters
- Table 6.2: Runoff Coefficients
- Table 6.3: Subcatchment Model Parameters
- Table 6.4: Inlet Control Devices & Design Flows
- Table 6.5: Overland Flow Results (100-year Event)
- Table 6.6: 100-year HGL Elevations
- Table 7.1: Watermain Design Criteria
- Table 7.2: Water Flow Summary
- Table 7.3: Summary of Hydraulic Model Results Maximum Day + Fire Flow
- Table 7.4: Summary of Hydraulic Model Results Peak Hour Demand
- Table 7.5: Summary of Hydraulic Model Results Maximum Pressure Check

## List of Figures

- Figure 1: Key Plan
- Figure 2: Site Plan
- Figure 3: Sanitary Sewer Network
- Figure 4: Storm Sewer Network
- Figure 5: Watermain Layout

## Appendices

Appendix A: Design Sheets Appendix B: SWM Calculations Appendix C: Drawings Appendix D: DSS Checklist RVCA Clearance

## 1.0 INTRODUCTION

#### 1.1 Background

The Abbott-Fernbank Lands are located within the new Fernbank Community on the north side of Fernbank Road west of Terry Fox Drive. **Figure 1** shows the location of the Fernbank Community, the Fernbank Crossing Subdivision, and Block 135.



Figure 1: Key Plan

The proposed site is approximately 1.26ha and will be bordered by Robert Grant Way and future residential lands to the west (CRT Developments Inc.), Cope Drive to the north, Shinny Avenue to the east, and Haliburton Heights to the south.

This Servicing Design Brief provides information on the considerations and approach by which Novatech has analyzed the existing site information for the Fernbank Crossing Subdivision, and details how the development lands will be serviced while meeting the City requirements and all other relevant regulations. This brief builds upon the recently completed works for the Fernbank Crossing Subdivision including the Servicing Design Brief – Phase 3 prepared by Novatech [1], the Fernbank Community Design Plan [2] prepared by Walker, Nott, Dragicevic Associates Limited, the Fernbank Master Servicing Study [3] prepared by Novatech, and the Fernbank Environmental Management Plan also prepared by Novatech [4].

This report should be read in conjunction with the following:

 Geotechnical Investigation, Fernbank Crossing Residential Subdivision, Block 135 Ottawa, Ontario prepared by Gemtec, dated March 20, 2019 (Project:64153.74). [5]

#### 1.2 Land Use

Block 135 will consist of six back-to-back townhome buildings (58 units total), two 12-unit buildings, two 10-unit buildings, one 8-unit building and one 6-unit building. The proposed Site Plan is shown below in **Figure 2**.



Figure 2: Site Plan

## 2.0 ROADWAYS

#### 2.1 Existing Conditions

Currently there is access to Block 135 via Cope Drive, Shinny Avenue and Haliburton Heights. Shinny Avenue and Haliburton Heights are classified as Local Roads and Cope Drive is classified as a Major Collector in the 2013 City of Ottawa Transportation Master Plan [6].

#### 2.2 **Proposed Conditions**

The development will be accessed from two entrances along Shinny Avenue, one entrance along Cope Drive and one entrance along Haliburton Heights. The site contains a series of 6.7m private roads.

#### 2.3 Roadway Design

Gemtec has prepared a Geotechnical Investigation report for the development (March 20<sup>th</sup>, 2019) that provides recommendations for roadway structure, servicing and foundations. The recommended roadway structure is as follows:

#### Table 2.1: Roadway Structure

Poodway Material Description	Pavement Structure
Roadway Material Description	Layer Thickness (mm)
Private Road	
Asphalt Wear Course: Superpave 12.5 (Class B)	40
Asphalt Binder Course: Superpave 19.0 (Class B)	60
Base: Granular A	150
Sub-Base: Granular B – Type II	<u>400</u>
Total	650

## 3.0 GRADING

#### 3.1 Existing Conditions

The existing site generally slopes to the northeast at approximately 2.5%. The maximum grade of approximately 106.49 metres in the southwest corner and a minimum elevation of approximately 103.50 metres in the northeast corner give a total elevation differential of approximately 3.00 metres across the site.

Geotechnical investigations were carried out by Gemtec [5], and bedrock was encountered approximately 0.60 to 4.3 metres below the existing ground surface.

## 3.2 **Proposed Conditions**

The design grades will tie into existing elevations along Robert Grant Way, Cope Drive, Haliburton Heights and the adjacent residential lands in Phase 3. For detailed grading refer to drawing 117089-GR.

The proposed grading will fall within these ranges:

- Landscaped Area: Minimum 2% Maximum 7%
- Rearyard Swales: Minimum 1.5% (1.0% with subdrain)
- Maximum Terracing Grade of 3H:1V

#### 3.3 Offsite Requirements

The proposed grading will not impede existing major system flow paths (See the grading plan drawing 117089-GR for detailed information).

## 4.0 EROSION AND SEDIMENT CONTROL

The following erosion and sediment control measures will be implemented during construction in accordance with the "Guidelines on Erosion and Sediment Control for Urban Construction Sites" (Government of Ontario, May 1987). Details are provided on the Grading Plan.

- A qualified inspector should conduct regular visits to ensure the contractor is working in accord with the drawings and that mitigation measures are implemented as specified.
- Terrafix Siltsoxx are to be placed under all new catchbasins and storm manhole covers.
- Pond 6 is now functional and will provide quality control of any sediment runoff that gets into the storm sewers.
- After complete build-out, all sewers are to be inspected and cleaned and all sediment and construction fencing is to be removed.

## 5.0 SANITARY SEWERS

## 5.1 Existing Conditions

An existing 200mm diameter sanitary sewer runs along Shinny Avenue, with an existing 200mm diameter cap located at both private entrances along Shinny Avenue.

#### 5.2 **Proposed Conditions**

The peak design flow parameters in **Table 5.1** have been used in the sewer capacity analysis.

Unit and population densities and all other design parameters are specified in the City of Ottawa Sewer Design Guidelines **[8]**.

Sanitary flow from Block 135 of the Fernbank Crossing Subdivision is proposed to connect into the downstream sewer system in Shinny Avenue. The sanitary sewer layout is shown on 117089-GP (**Appendix C**), and the design sheet is attached in **Appendix A**. The site (approx. 1.26ha) will outlet at MH 756 (south entrance) with a peak design flow of 1.5 L/s and outlet at MH 754 (north entrance) with a peak design flow of 1.3 L/s. The wastewater flow is routed through the Fernbank Crossing Subdivision and Blackstone Lands to the Fernbank Trunk, directing flow to the Hazeldean Pump Station.

Technical bulletin ISTB-2018-01 outlines recent changes to the sanitary sewer design criteria in the City of Ottawa. Existing infrastructure has been designed and constructed before the release of this bulletin, and for reasons of consistency we elected to maintain the same sanitary sewer design parameters used in the design of the existing sewers.

Parameter	Design Parameter
Town Unit Population	2.7 people/unit
Residential Flow Rate, Average Daily	350 L/cap/day
Residential Peaking Factor	Harmon Equation (min=2.0, max=4.0)
Infiltration Rate	0.28 L/s/ha
Minimum Pipe Size	200 mm
Minimum Velocity	0.6 m/s
Maximum Velocity	3.0 m/s

Table 5.1: Sanitary Sewer Design Parameters



Figure 3: Sanitary Sewer Network

## 5.3 Offsite Requirements

For the design of Phase 3 of Fernbank Crossing, an initial peak design flow of 3.5 L/s was used in the calculations for Block 135, which is higher than the calculated peak design flow of 2.8 L/s for the combined flows outletting to MH 754 and MH 756. Therefore, there will be sufficient capacity offsite to service the proposed development of Block 135.

## 6.0 STORMWATER MANAGEMENT

## 6.1 Existing Conditions

Existing 1200mm and 1350mm diameter storm sewers run along Shinny Avenue adjacent to the proposed development. These sewers outlet to an existing SWM Facility (Fernbank Pond 6) and have been sized to accommodate runoff from the proposed development of Block 135. An existing 600mm cap is located at the northern entrance and an existing 450mm cap is located at the southern entrance.

## 6.2 **Proposed Conditions**

Runoff from Block 135 will be routed to the storm sewer system in Shinny Avenue, where it will then be directed to a stormwater pond (Pond 6) that provides both quantity and quality control for the Fernbank Crossing development. The stormwater management facility outlets to the realigned Monahan Drain, which drains into the Monahan Constructed Wetlands Facility. **Figure 5** outlines the proposed storm sewer system layout, and how it will connect to the existing network along Shinny Avenue.

Technical Bulletin PIETB-2016-01 outlines recent changes to sewer design criteria in the City of Ottawa. We have incorporated these criteria, except for the minimum storm sewer sizing. The existing infrastructure was designed and constructed before the release of this bulletin, and for reasons of consistency we elected to maintain the minimum 5-year storm sewer sizing criteria. Our approach is conservative and will offer a slightly improved margin of safety against storm sewer back-up.

#### 6.2.1 Minor System Design

The storm sewers comprising the minor system have been designed based on the criteria outlined in the Ottawa Sewer Design Guidelines [8] using the principles of dual drainage. The design criteria used in sizing the storm sewers are summarized in **Table 6.1** and **Table 6.2**.

The proposed storm sewers have been designed using the Rational Method to convey peak flow associated with a 5-year rainfall event. The storm sewer design sheets are provided in **Appendix A**. The corresponding Storm Drainage Area Plan (Drawing 117089-STM) is provided in **Appendix C**.

The Phase 3 Stormwater Management Report **[10]** outlines that "inflows from all future development have been accounted for based on the 5-year peak flow". As such, all inlet control devices (ICDs) within Block 135 will be installed in all road catchbasins to limit inflows to the minor system during large (>1:5 year) storm events. Inlet control devices shall be CB lead plate-type and are to be sizes listed in Section 13.1.19 of the Ottawa Sewer Materials Specifications.



Figure 4: Storm Sewer Network

Parameter	Design Criteria
Private Roads	5 Year Return Period
Storm Sewer Design	Rational Method/AutoDesk Storm Analysis
IDF Rainfall Data	Ottawa Sewer Design Guidelines
Initial Time of Concentration (Tc)	10 min
Minimum Velocity	0.8 m/s
Maximum Velocity	3.0 m/s
Minimum Diameter	250 mm

#### Table 6.1: Storm Sewer Design Parameters

#### Table 6.2: Runoff Coefficients

Land Use	Runoff Coefficient
Hard Surface	0.90
Soft Surface	0.30

## 6.2.2 Major System Design

The site has been designed to convey runoff from storms that exceed the minor system capacity to Shinny Avenue. The roadway and parking areas have been graded to ensure that the 100-year peak overland flows are confined within the parking area at a maximum flow depth of 300mm.

## 6.3 Hydrologic & Hydraulic Modeling

The *City of Ottawa Sewer Design Guidelines* (October 2012) require hydrologic modeling for all dual drainage systems. The performance of the proposed storm drainage system for Block 135 was evaluated using the *Autodesk Storm and Sanitary Analysis* (SSA) hydrologic/hydraulic modeling software in order to maintain compatibility with the previously developed Phase 1-5 models (each of which were built in SSA).

The modeling files and model schematics are provided in **Appendix C**. For review purposes, a 'standalone' PCSWMM model of Block 135 has also been provided on CD included at the back of this report.

#### Design Storms

The hydrologic analysis was completed using the following synthetic design storms and historical storms. The IDF parameters used to generate the design storms were taken from the Sewer Design Guidelines **[8]**.

<u>4 Hour Chicago Storms</u>: 25mm 4-hr Chicago storm 2-year 4hr Chicago storm 5-year 4hr Chicago storm 100-year 4hr Chicago storm <u>12 Hour SCS Storms</u>: 2-year 12-hr SCS storm 5-year 24hr Chicago storm 100-year 24hr Chicago storm

The 4-hour Chicago distribution generates the highest peak flows for both the minor and major systems and was determined to be the critical storm distribution for the design of the storm drainage system.

The proposed drainage system has also been stress tested using a 4-hour Chicago design storm that has a 20% higher intensity and total volume compared to the 100-year event.

#### Model Development

The SSA model accounts for both minor and major system flows (*dual drainage*), including the routing of flows through the storm sewer network (*minor system*), and overland along the road network (*major system*). The results of the analysis were used to:

- Ensure no ponding in the rights-of-way following a 5-year event;
- Calculate the storm sewer hydraulic grade line for the 100-year storm event;
- Evaluate overland flow depths and ponding volumes in the rights-of-way during the 100year event; and
- Determine the total major and minor system runoff from the site to Pond 6.

The model is capable of accounting for both static and dynamic storage within the private roadways and parking areas, including the overland flow across all high points and capture/bypass curves for inlets on continuous grade. The 100-year flow depths computed by the model represent the total (static + dynamic) ponding depths at low points for areas in road sags, or the gutter flow depth where the inlets are on a continuous grade.

#### Storm Drainage Area Plan & Subcatchment Parameters

The Block 135 development has been divided into subcatchments based on the drainage areas tributary to each inlet of the proposed storm sewer system. The catchment areas are shown on the Storm Drainage Area Plan provided as drawing **117089-STM** in **Appendix C**.

The hydrologic parameters for each subcatchment were developed based on the Site Plan (**Figure 2**) and the Storm Drainage Area Plan specified above. Subcatchment parameters are outlined in **Table 6.3**.

Area ID	Catchment Area	Runoff Coefficient	Percent Impervious	No Depression	Flow Path Length	Equivalent Width	Average Slope
	(ha)	(C)	(%)	(%)	(m)	(m)	(%)
1	0.133	0.70	71%	37%	35.20	37.79	0.90%
2	0.220	0.74	77%	41%	25.40	86.60	1.00%
3a	0.187	0.77	81%	38%	38.60	48.44	0.85%
3b	0.066	0.65	64%	0%	9.41	70.12	0.85%
4a	0.266	0.74	77%	34%	38.50	69.10	0.90%
4b	0.041	0.63	61%	0%	7.92	51.75	0.90%
5	0.172	0.76	80%	54%	25.78	66.71	0.75%
6	0.149	0.70	71%	35%	29.27	50.91	0.70%
7	0.013	0.84	91%	0%	11.08	11.73	1.80%
8	0.012	0.84	91%	0%	10.35	11.60	2.00%

#### Table 6.3: Subcatchment Model Parameters

TOTAL: 1.26

#### Infiltration

Infiltration losses for all catchment areas were modeled using Horton's infiltration equation, which defines the infiltration capacity of the soil over the duration of a precipitation event using a decay function that ranges from an initial maximum infiltration rate to a minimum rate as the storm progresses. The default values for the Sewer Design Guidelines **[8]** were used for all catchments.

Horton's Equation:	Initial infiltration rate:	$f_{o} = 76.2 \text{ mm/hr}$
$f(t) = f_c + (f_o - f_c)e^{-k(t)}$	Final infiltration rate:	$f_{c} = 13.2 \text{ mm/hr}$
	Decay Coefficient:	k = 4.14/hr

#### Depression Storage

The default values for depression storage in the Sewer Design Guidelines **[8]** were used for all catchments. Residential rooftops were assumed to provide no depression storage.

- Depression Storage (pervious areas):
   4.67 mm
- Depression Storage (impervious areas): 1.57 mm

#### Equivalent Width

Equivalent Width' refers to the width of the sub-catchment flow path. This parameter is calculated as described in the Sewer Design Guidelines **[8]**, Section 5.4.5.6.

#### Impervious Values

Impervious (TIMP) values for each subcatchment area were calculated based on the proposed land use plan (Figure 2) and correspond to the Runoff Coefficients used in the Rational Method calculations using the equation:

$$\% imp = \frac{C - 0.2}{0.7}$$

#### 6.3.1 Minor System

Inflows to the storm sewer were modeled based on the characteristics of each inlet;

- For areas where catchbasins are located at low points (represented as junctions), inflows to the storm sewer are based on the ICD specified for the inlet and the maximum depth of ponding. Storage volumes within the right-of-way are based on the grading design.
- For areas where catchbasins are located on a continuous grade, the capture rate is based on the type of grate, the geometry of the road, and the approach flow. Rating curves for approach flow vs. capture rate were input into the model using the appropriate tables from the Ottawa Design Guidelines Sewer.
  - Design Chart 4.04: Gutter Flow Rate for Barrier Curb with Gutter.
  - Design Chart 4.06: Gutter Flow Rate for Mountable Curb with Gutter.
  - Design Chart 4.14: Inlet Capacity for Barrier Curb.
  - Design Chart 4.15: Inlet Capacity for Mountable Curb.
  - Appendix 7-A. Type S22 Curb Inlet Catchbasin with Cross Fall fixed at 3%

#### 6.3.2 Major System

The proposed road network was input into the SSA model to calculate the total inflow into the storm sewers (minor system), and to calculate the overland flows and flow depths within the rights-of-way (major system).

The roads are represented in the model as open channels. Model input includes:

- Right-of-way cross-sections;
- Length and slope of the road between each high and low point;
- The location of all storm inlets and whether the inlets are in a sag or on-grade.

The elevations used to define the road network are based on the gutter elevations, as opposed to the centerline of road elevations shown on the Grading Plans.

## 6.4 Results of Hydrologic/ Hydraulic Analysis

The model was used to evaluate the performance of the proposed storm drainage system for the Phase 5 lands and specifically to determine the 100-year hydraulic grade line. Both the SSA model and the stand-alone PCSWMM model have been provided on the attached CD at the back of this report.

#### 6.4.1 Minor System

The proposed inlet control devices (ICDs) have been sized to capture the approximate 5-year peak flow at each inlet to the storm sewer, as well as to reduce the 100-year HGL elevation in the storm sewers. Consequently, there will be little to no ponding within the rights-of-way during the 5-year event. The selection of ICDs takes into account the overland flow that bypasses catchbasins on-grade by providing additional capacity at the downstream inlets. The list of ICD sizes and performance is provided in **Table 6.4**.

		A			
Structure	Diameter 1	Max Head	Calculated 5-yr Capture Rate	5-yr Capture Rate**	Approach Flow**
	(mm)	(m)	(L/s)	(L/s)	(L/s)
CB50	108	1.35	29.19	28.80	30.05
CB51	152	1.32	57.34	50.56	51.18
CB52	83	1.36	17.32	13.44	14.64
CB53	152	1.32	57.34	44.88	45.32
CB54	83	1.36	17.32	8.44	9.01
CB55	178	1.31	78.25	78.47	79.76
CB56	152	1.32	57.34	22.45	41.11
CB57	127	1.34	40.22	32.38	33.14

Table 6.4:	Inlet Co	ontrol	Devices	&	Design	Flows
------------	----------	--------	---------	---	--------	-------

\*\*From PCSWMM Model, 5-year 4-hour Chicago storm distribution

The Rational Method design sheets (**Appendix B**) were used to calculate the required storm sewer sizes based on capturing the peak flow at each inlet to the storm sewer for a 5-year design return period.

#### 6.4.2 Major System

During the 100-year event, stormwater runoff that exceeds the available static storage within road sags will flow overland within the rights-of-way and/or defined drainage easements to Shinny Avenue. Major system network was evaluated using the model to ensure that the flow depths and velocities conform to City standards. The results of the 100-year modelling indicate that the overland flow depths on all streets will be less than 0.30m and major system flows will be confined to the rights-of-way. Generally, major system flow will be contained within the Block 135 development, for all storm events.

Othersetung	T/G	Max. Static (Spill D	: Ponding Depth)		100	)-yr Event (4hr)	)
Structure		Elev.	Depth	Elev.	Depth	Cascading	Cascade
	(m)	(m)	(m)	(m)	(m)	Flow?	Depth (m)
CB50	104.75	104.88	0.13	104.89	0.14	Y	0.01
CB51	104.40	104.50	0.10	104.51	0.11	Y	0.01
CB52	104.44	104.65	0.21	104.58	0.14	Ν	0.00
CB53	104.49	104.65	0.16	104.59	0.10	Ν	0.00
CB54	104.64	104.79	0.15	104.78	0.14	Ν	0.00
CB55	104.64	104.79	0.15	104.78	0.14	Ν	0.00
CB57	105.20	105.34	0.14	105.31	0.11	N	0.00

Table 6.5: Overland	<b>Flow Results</b>	(100-year Event)
---------------------	---------------------	------------------

An expanded table of the ponding depths at low points in the roadway (including the stress-test event) is provided in **Appendix B**. Based on these results, the proposed storm drainage system will not experience any adverse flooding even with a 20% increase to the 100-year event. These results are from the SSA model, however the stand-alone PCSWMM model gives very similar results.

#### 6.4.3 Hydraulic Grade Line

The Block 135 model has been integrated with the existing Fernbank Phase 1-5 SSA model. By integrating the models, the HGL elevations within the proposed Block 135 development and downstream in Phase 3 and along Cope Drive can be accurately determined.

The results of the HGL analysis were used to ensure that a minimum freeboard of 0.30m is provided between the 100-year HGL and the designed underside of footing elevations. The 100-year HGL elevations at each storm manhole with respect to the lowest adjacent underside of footing elevation are provided in **Table 6.6**.

Manhole ID	MH Invert Elevation	T/G Elevation	HGL Elevation - 100yr4hr	Design USF	Clearance (100yr)				
	(m)	(m)	(m)	(m)	(m)				
HGL - Block 13	HGL - Block 135								
MH01	101.42	104.53	102.10	103.72	1.62				
MH03	101.81	104.96	102.25	103.57	1.32				
MH05	102.19	105.11	102.13	103.57	1.44				
MH07	101.60	104.55	102.30	103.57	1.27				
MH09	101.99	104.88	102.67	103.77	1.10				
MH11	101.79	104.58	102.77	104.13	1.36				
MH13	102.13	104.78	102.78	104.13	1.35				
MH15	101.77	104.70	102.88	104.13	1.25				

Table 6.6: 100-year HGL Elevations

An expanded table showing the results of the stress test (100-year +20% event) and the HGL elevations for Phase 3 and Cope Drive is provided in **Appendix B**. The stress test indicates that the HGL elevations will be below the USF elevations for this event.

While the results in the table above are from the SSA model, the stand-alone PCSWMM model has been assigned outlet boundary conditions to give a close approximation of the results from the SSA model. 100-year boundary conditions are as follows:

- STM373 = 102.26m
- STM375 = 102.00m

These boundary conditions have also been provided in the 'Description' of each of the outfalls from the PCSWMM model for easy reference.

## 7.0 WATER

## 7.1 Existing Conditions

The proposed development is located inside the 3W Pressure Zone. An existing 300mm diameter watermain runs along Shinny Avenue and Haliburton Heights as well as an existing 200mm diameter watermain that runs along Cope Drive. Existing 200mm diameter caps are located at both private entrances off Shinny Avenue.

## 7.2 **Proposed Conditions**

Block 135 will be connected to the existing watermain network by way of four separate feed points. Two connections are proposed to the existing 200mm diameter caps located at the private entrances off Shinny Avenue, one connection to the 300mm diameter watermain in Haliburton Heights and one connection to the 200mm diameter watermain in Cope Drive.

Block 135 will be serviced by a combination of 150mm and 200mm diameter watermains and will provide sufficient capacity to maintain appropriate pressures and fire flows throughout the development. **Figure 5** provides a high level schematic of the proposed water distribution system.

The watermain boundary condition below was obtained from the City of Ottawa and has been included in **Appendix A**:

<u>Boundary Condition</u> – Located north of the Trans Canada Trail at the existing 300mm x 400mm diameter watermain connection (Shown in Figure 6 in **Appendix A**) Max Day + FF of 167 L/s = 152.9m Max Day + FF of 217 L/s = 151.2m Minimum Pressure during Peak Hour = 155.5m Max Pressure Check = 162.4m

City of Ottawa watermain design criteria and Fernbank Community Design Parameters are outlined in **Table 7.1**.



Figure 5: Watermain Layout

Design Parameter	Design Criteria
Town Population	2.7 people/unit
Residential Demand	350 L/c/d
Maximum Day Demand	2.5 x Average Day
Peak Hour Demand	2.2 x Maximum Day
Fire Demand	200, 233, 250 L/s
Maximum Pressure	690 kPa (100psi) unoccupied areas
Maximum Pressure	552 kPa (80psi) occupied areas outside of ROW
Minimum Pressure	275 kPa (40 psi) except during fire flow
Minimum Pressure	140 kPa (20 psi) fire flow conditions

#### Table 7.1: Watermain Design Criteria

#### Table 7.2: Water Flow Summary

	Units	Population	Average Day Demand (L/s)	Maximum Day Demand (L/s)	Peak Hour Demand (L/s)
Back-to-Back Towns	58	156.6	0.634	1.586	3.489
Total	58	156.6	0.634	1.586	3.489

Based on the fire underwriters survey, the fire flows were calculated as 200 L/s (building 5), 233 L/s (buildings 2 and 3) and 250 L/s (buildings 1, 4 and 6). Calculations are provided in **Appendix A**.

The proposed watermain was modeled using EPANET 2 (See 115049-GP for detailed watermain layout).

A summary of the model results are shown below in **Table 7.3**, **Table 7.4** and **Table 7.5**. Full model results are included in **Appendix A**.

Table 7.3: Summary	y of Hydraulic	Model Results	- Maximum D	ay + Fire Flow
	,,			

Operating Condition	Minimum Pressure
250 L/s at Building 1	230.54 kPa (CAP1)
233 L/s at Building 3	240.15 kPa (CAP4)
250 L/s at Building 4	213.76 kPa (CAP6)
250 L/s at Building 6	210.62 kPa (CAP6)

Operating Condition	Maximum Pressure	Minimum Pressure
3.489 L/s through system	500.31 kPa (T2)	489.13 kPa (CAP6)

Table 7.4: Summar	y of Hydrau	ic Model Results	- Peak Hour Demand

The hydraulic modeling summarized above highlights the maximum and minimum system pressures during Peak Hour conditions, and the minimum system pressures during the Maximum Day + Fire condition. Since the Maximum Day + Fire Flow pressures are above the minimum 140 kPa, and the Peak Hour Pressures onsite fall within the normal operating pressure range (345 kPa to 552 kPa) we conclude the proposed water design will adequately service the development.

Table 7.5: Summary	y of Hydraulic Mode	l Results – Maximum	<b>Pressure Check</b>
--------------------	---------------------	---------------------	-----------------------

Operating Condition	Maximum Pressure	Minimum Pressure					
0.634 L/s through system	560.15 kPa (CAP5, CAP6)	531.70 kPa (B6)					

The average day pressures at CAP1 through CAP4 are below or equal to 552 kPa. Average day pressures at CAP5 and CAP6 are slightly above 552 kPa and are both at 560.15 kPa. Since the average day pressures are modelled within the watermain and not the services to the units, lower pressures will be encountered at the upper levels. Pressures at the first floor were modelled at Buildings 4 and 5 (nodes B4 and B5) adjacent to CAP5 and CAP6. The average day pressures within the units at both B4 and B6 are below 552 KPa. We conclude that pressure reducing valves are not necessary to reduce the modelled pressures below 552 kPa within the watermain as the modelled average day pressures within the services to the units are within the required range.

#### 7.3 Offsite Requirements

As specified in the Fernbank Master Servicing Study **[3]**, additional firm pumping capacity at the Glen Cairn Pumping Station and one of the Zone 2W pumping stations is required to meet additional demands associated with the Fernbank Community. The timing of these upgrades is related to the overall rate of growth in the entire Zone 3W (Kanata and Stittsville area). Growth within the Fernbank Crossing Subdivision plays only a small part in determining when these upgrades are required; the City of Ottawa will determine when these water supply upgrades occur. No direct costs associated with the offsite upgrades are attributable to the developer.

## 8.0 CONCLUSIONS AND RECOMMENDATIONS

The report conclusions are as follows:

- 1) The servicing design generally conforms to the conclusions and recommendations outlined in the Fernbank Master Servicing Study and the Fernbank Environmental Management Plan both of which were approved by Council on June 24, 2009.
- 2) There is adequate capacity in the offsite infrastructure (sanitary, storm and water) to service Block 135, with note to the following:
  - a) Pond 6 is operational, and provides both quality and quantity control of stormwater runoff;
  - b) The water distribution network can adequately provide both domestic and fire suppression needs;
  - c) The Glen Carin Pumping Station (water distribution) will be upgraded by the City of Ottawa as-and-when required based on overall growth rates within the entire Zone 3W Area;
  - d) Wastewater is routed east through the Fernbank Crossing Subdivision and the Blackstone Lands to the Fernbank Trunk, directing flow to the Hazeldean Pump Station.
- 3) The proposed infrastructure (sanitary, storm and water) complies with City of Ottawa design standards.

This report is respectfully submitted for review and approval. Please contact the undersigned should you have questions or require additional information.

Sincerely,

#### NOVATECH

Prepared By:



Lucas Wilson, P.Eng. Project Coordinator Prepared By:



Kallie Auld, P.Eng. Project Coordinator | Water Resources

## References

- 1. "Fernbank Crossing Servicing Design Brief Phase 3, Novatech [July 13, 2015]
- 2. "Fernbank Community Design Plan, Walker, Nott, Dragicevic Associates Ltd. [June 24, 2009]
- 3. "Fernbank Master Servicing Study", Novatech Engineering Consultants Ltd. [June 24, 2009]
- **4.** "Fernbank Environmental Management Plan", Novatech Engineering Consultants Ltd. [June 24, 2009]
- **5.** "Geotechnical Investigation Fernbank Crossing Residential Subdivision Block 135, Ottawa, Ontario" Gemtec. [Report No. 64153.74, March 20, 2019]
- 6. "Transportation Master Plan", City of Ottawa [November 2013]
- 7. "Fernbank Transportation Master Plan", Delcan [June 24, 2009]
- 8. "Sewer Design Guidelines", Department of Public Works and Services, City of Ottawa [October 2012]
- **9.** "Standard Tender Documents, Material Specifications and Standard Detail Drawings" City of Ottawa, Department of Infrastructure Services and Community Sustainability [March, 2014]
- **10.** "Abbott-Fernbank Holdings Inc. Fernbank Crossing Phase 3 Stormwater Management Report", Novatech [July 13, 2015]

## **APPENDIX A: Design Sheets**

Storm Sewer Design Sheet (Rational Method) Sanitary Sewer Design Sheets Watermain Boundary Conditions and Correspondence Watermain Modelling Fire Flow Calculations Figure 6: Watermain Plan - Overview

## Fernbank Crossing (Block 135)- Storm Sewer Design Sheet (Traditional Rational Method)

LOC	CATION					-	AREA							FLOW	1			PROPOSED SEWER									
Location	From	To node	Park N' Ride Paramedic Post Medium Block	Hard Surface	Soft Surface	Singles Front Yards	Singles Rear Yard	Towns Front Yard	Towns Rear Yard	Total Area	Weighted Runoff Coefficient	Indivi 2.78 AR	Accum 2.78 AR	Time of Concentration	Rain Intensity (mm/hr) 5yr 10yr	Peak Flow	Total Peak Flow (Q)	Pipe	Size	Grade	Length	Capacity	Full Flow Velocity	Time of Flow	Q/Qfull	d/D	
			0.80	0.90	0.30	0.65	0.55	0.70	0.60	(ha)						(L/s)	(L/s)	Туре	(mm)	(%)	(m)	(l/s)	(m/s)	(min.)	(%)		
Phase 3																											
643	389	387				0.46				0.46	0.65	0.83	0.83	10.00	104.2	86.6	86.6	PVC	450	0.19	123.5	129.6	0.79	2.61	66.8%	0.666	
										0.00		0.00	0.00	10.00		0.0											
645	505	509						0.24		0.24	0.70	0.47	0.47	10.00	104.2	48.7	48.7	PVC	375	0.30	69.5	100.2	0.88	1.32	48.6%	0.552	
										0.00		0.00	0.00	10.00		0.0											
644	507	509						0.17		0.17	0.70	0.33	0.33	10.00	104.2	34.5	34.5	PVC	300	0.40	30.5	63.8	0.87	0.58	54.0%	0.590	
										0.00		0.00	0.00	10.00		0.0											
	509	CBMH15								0.00	0.00	0.00	0.80	11.32	97.7	78.0	78.0	PVC.	450	0.20	46 1	133.0	0.81	0.95	58.6%	0.616	
		- OBMITTO								0.00		0.00	0.00	11.32		0.0	1010			0.20	10.1	100.0	0.01	0.00	00.070	0.010	
622	CAR		1.78							1.78	0.80	3.96	3.96	10.00	104.2	412.5	412.5	CONC	750	0.20	5 5	626.1	1 20	0.07	64 90/	0.652	
033	CAP	CDIVITIO								0.00		0.00	0.00	10.00		0.0	412.5	CONC	750	0.30	5.5	030.1	1.59	0.07	04.0 %	0.055	
658, 659, 730,	0004145	0.07					0.18		0.45	0.63	0.59	1.03	5.78	12.27	93.6	541.1		00110		0.00	44.0	044.0	4.00	0.57	04.40/	0.050	
739	CBMH15	387								0.00		0.00	0.00	12.27		0.0	541.1	CONC	900	0.20	44.3	844.6	1.29	0.57	64.1%	0.653	
						0.43				0.43	0.65	0.78	7.39	12.84	91.3	674.4											
642	387	385				0110				0.00	0.00	0.00	0.00	12.84		0.0	674.4	CONC	900	0.20	51.8	844.6	1.29	0.67	79.8%	0.748	
	385	383								0.00	0.00	0.00	7.39	13.51	88.7	655.5	655 5	CONC	900	0.20	10.0	844.6	1 20	0.14	77.6%	0.735	
	303	303								0.00		0.00	0.00	13.51		0.0	055.5	CONC	300	0.20	10.3	044.0	1.23	0.14	11.078	0.735	
634	383	419							0.14	0.14	0.60	0.23	7.62	13.65	88.2	672.3	672.3	CONC	900	0.25	9.3	944.3	1.44	0.11	71.2%	0.697	
								0.20	0.12	0.00	0.68	0.00	0.00	13.65	07.0	0.0											
641	419	381						0.39	0.13	0.52	0.00	0.96	0.00	13.76	07.0	755.0	755.0	CONC	900	0.25	66.9	944.3	1.44	0.78	79.9%	0.748	
										0.00		0.00	0.00	10.70		0.0											
666	359	381				0.35				0.35	0.65	0.63	0.63	10.00	104.2	65.9	65.9	PVC	375	0.25	93.3	91.5	0.80	1.94	72.1%	0.704	
										0.00		0.00	0.00	10.00		0.0											
639	381	379								0.00	0.00	0.00	9.23	14.54	85.1	785.5	785.5	CONC	975	0.24	25.9	1145.4	1.49	0.29	68.6%	0.678	
										0.00		0.00	0.00	14.54		0.0											
627	379A	379	1.09							1.09	0.80	2.42	2.42	10.00	104.2	252.6	252.6	CONC	600	0.25	7.5	320.3	1.10	0.11	78.9%	0.742	
										0.00		0.00	0.00	10.00		0.0								••••			
667	270	277						0.35		0.35	0.70	0.68	12.34	14.83	84.1	1037.9	1027.0	CONC	1050	0.25	55.2	1424.4	1.50	0.59	72 00/	0.704	
007	379	5/1								0.00		0.00	0.00	14.83		0.0	1037.9	CONC	1050	0.25	55.5	1424.4	1.59	0.56	12.9%	0.704	
	400							0.16	0.18	0.34	0.65	0.61	0.61	10.00	104.2	63.7		51/0		1.00		100.0		a (a			
625, 638, 630	423	377								0.00		0.00	0.00	10.00		0.0	63.7	- 63.7	PVC	300	1.00	40.0	100.9	1.38	0.48	63.2%	0.647
								0.28		0.28	0.70	0.54	13 49	15 41	82.3	1110.2											
673	377	375						0.20		0.00	0.70	0.00	0.00	15.41		0.0	1110.2	CONC	1200	0.17	80.1	1677.0	1.44	0.93	66.2%	0.666	





## Fernbank Crossing (Block 135)- Storm Sewer Design Sheet (Traditional Rational Method)

LOC	CATION					A	REA							FLOW	1					PROPOSED SEWER							
Location	From node	To node	Park N' Ride Paramedic Post Medium Block	Hard Surface	Soft Surface	Singles Front Yards	Singles Rear Yard	Towns Front Yard	Towns Rear Yard	Total Area	Weighted Runoff Coefficient	Indivi 2.78 AR	Accum 2.78 AR	Time of Concentration	Rain Inte (mm/l 5yr	ensity ′hr) 10yr	Peak Flow	Total Peak Flow (Q)	Pipe	Size	Grade	Length	Capacity	Full Flow Velocity	Time of Flow	Q/Qfull	d/D
			0.80	0.90	0.30	0.65	0.55	0.70	0.60	(ha)							(L/s)	(L/s)	Туре	(mm)	(%)	(m)	(l/s)	(m/s)	(min.)	(%)	
Block 135 (South	n Outlet)																										
6	15	13		0.10	0.05					0.15	0.70	0.29 0.00	0.29	10.00 10.00	104.2		30.4 0.0	30.4	PVC	300	0.50	33.4	71.3	0.98	0.57	42.6%	0.512
	13	11								0.00	0.00	0.00	0.29	10.57	101.3		29.6	20.6	PV/C	375	0.30	0.0	100.2	0.88	0.10	20.5%	0.410
	15									0.00		0.00	0.00	10.57			0.0	29.0	FVC	575	0.50	9.9	100.2	0.00	0.15	29.57	0.419
5	11	9		0.13	0.04					0.17	0.76	0.36	0.65	10.76 10.76	100.4		65.3 0.0	65.3	PVC	375	0.85	25.8	168.6	1.48	0.29	38.7%	0.485
4	9	375		0.22	0.09					0.31 0.00	0.73	0.63	1.28 0.00	11.05 11.05	99.0		126.3 0.0	126.3	PVC	450	0.20	48.3	133.0	0.81	0.99	94.9%	0.853
674, 629	375	373						0.30	0.16	0.46	0.67	0.85 0.00	15.62 0.00	16.33 16.33	79.5		1241.5 0.0	1241.5	CONC	1200	0.18	110.5	1725.6	1.48	1.25	71.9%	0.697
Block 135 (North	Outlet)																										
3	7	5		0.19	0.07					0.26	0.74	0.53	0.53	10.00	104.2		55.6	55.6	PVC	375	0.30	33.0	100.2	0.88	0.63	55.5%	0.597
										0.00	0.00	0.00	0.00	10.00			0.0								0.00		
	5	1								0.00	0.00	0.00	0.53	10.63	101.0		53.9 0.0	53.9	PVC	450	0.25	10.0	148.7	0.91	0.18	36.2%	0.471
				0.09	0.04					0.13	0.70	0.25	0.25	10.00	104.2		26.2										
1	3	1								0.00	0.00	0.00	0.00	10.00	-		0.0	26.2	PVC	375	0.50	32.2	129.3	1.13	0.47	20.3%	0.345
_				0.16	0.06					0.22	0.74	0.45	1.24	10.81	100.1		123.7										
2	1	373								0.00	0.00	0.00	0.00	10.81			0.0	123.7	CONC	600	0.21	43.2	293.5	1.01	0.72	42.1%	0.512
723, 628	373	363						0.31	0.06	0.37	0.68	0.70	17.56	17.58	76.1		1335.5	1335.5	CONC	1350	0.20	58.9	2490.2	1.69	0.58	53.6%	0.584
										0.00	2/2/2/201/2	0.00		17.58			0.0						Project: Er	rnhank Cro	ccina	Plook 125	(117090)
Q = 2.70 AIR		WHERE :								Q = (1/11) A f	(2/3)30(1/2)		WIERE :		n = MANNI A = FLOW	ING COE AREA (m	/ FFICIENT O າ2)	F ROUGHNESS	6 (0.013)						issing - I	Desigr Checl Date: Jur	ned: LRW ked: MAB ne 7 2019







	AREA			R	ESIDEN	ITIAL		INF	ILTRATIC	)N					PI	IPE			
ID	From	То	Tow Units	ns Pop.	Accum. Pop.	Peak Factor	Peak Flow (I/s)	Total Area (ha)	Accum. Area (ha)	Infilt. Flow (I/s)	Total Flow (I/s)	Size (mm)	Slope (%)	Length (m)	Capacity (l/s)	Full Flow Vel. (m/s)	Actual Vel. (m/s)	Q/Q <sub>full</sub> (%)	d/D
North	Outlet																		
	14	12	10	27.0	27.0	4.0	0.4	0.19	0.19	0.1	0.5	200	0.75	38.0	29.6	0.91	0.28	1.7%	0.077
	12	8	0	0.0	27.0	4.0	0.4	0.06	0.25	0.1	0.5	200	1.50	42.7	41.9	1.29	0.37	1.2%	0.077
	10	8	10	27.0	27.0	4.0	0.4	0.16	0.16	0.0	0.5	200	1.50	38.0	41.9	1.29	0.37	1.2%	0.077
	8	2	1	2.7	56.7	4.0	0.9	0.01	0.42	0.1	1.0	200	1.50	9.9	41.9	1.29	0.47	2.5%	0.108
	6	4	6	16.2	16.2	4.0	0.3	0.12	0.12	0.0	0.3	200	0.75	42.9	29.6	0.91	0.24	1.0%	0.077
	4	2	0	0.0	16.2	4.0	0.3	0.02	0.14	0.0	0.3	200	1.50	36.5	41.9	1.29	0.31	0.7%	0.077
	2	754	0	0.0	72.9	4.0	1.2	0.04	0.60	0.2	1.3	200	0.32	43.7	19.4	0.60	0.29	7.0%	0.187
South	Outlet																		
	20	18	11	29.7	29.7	4.0	0.5	0.20	0.20	0.1	0.5	200	0.75	41.8	29.6	0.91	0.30	1.8%	0.077
	18	16	0	0.0	29.7	4.0	0.5	0.02	0.22	0.1	0.5	200	1.50	19.0	41.9	1.29	0.37	1.3%	0.077
	24	22	11	29.7	29.7	4.0	0.5	0.18	0.18	0.1	0.5	200	0.75	42.3	29.6	0.91	0.30	1.8%	0.077
	30	28	7	18.9	18.9	4.0	0.3	0.14	0.14	0.0	0.3	200	0.75	50.9	29.6	0.91	0.26	1.2%	0.077
	28	26	0	0.0	18.9	4.0	0.3	0.02	0.16	0.0	0.4	200	0.50	37.6	24.2	0.75	0.23	1.5%	0.077
	26	22	2	5.4	24.3	4.0	0.4	0.02	0.18	0.1	0.4	200	0.75	9.3	29.6	0.91	0.28	1.5%	0.077
	22	16	0	0.0	54.0	4.0	0.9	0.03	0.39	0.1	1.0	200	1.60	22.6	43.3	1.33	0.46	2.3%	0.108
	16	756	0	0.0	83.7	4.0	1.4	0.04	0.65	0.2	1.5	200	0.32	48.5	19.4	0.60	0.30	7.9%	0.202
Design Pa	ign Parameters: Population Density:														Projec	t: Block 13	35 (117089)		
Avg Flow/	Person =		350	l/day				ppl/unit	ur	nits/net	ha							Desi	gned: LRW
Comm./In	st. Flow =		35000	l/ha/da	у		Apartment	1.80		90								Che	cked: MAB
Infiltration	=		0.28	l/s/ha			Singles	3.40										Date: Ju	une 7, 2019
Pipe Fricti	ion n =		0.013				Towns	2.70		60									
Residentia	al Peaking	g Factor	= Harmon E	quation	(max 4, n	nin 2)													

## Fernbank Crossing, Block 135 - Sanitary Sewer Design Sheet





#### **Lucas Wilson**

From: Sent: To: Cc: Subject: Attachments: Surprenant, Eric <Eric.Surprenant@ottawa.ca> Friday, February 27, 2015 2:05 PM Lucas Wilson Mark Bissett RE: D07-16-09-0034 - Phase 3 Boundary Conditions at Fernbank-Abbott.docx

Lucas,

Please see my responses below.

Thanks

Eric S.

From: Lucas Wilson [mailto:l.wilson@novatech-eng.com]
Sent: February 25, 2015 11:27 AM
To: Surprenant, Eric
Cc: Mark Bissett
Subject: RE: D07-16-09-0034 - Phase 3

Eric – I had a couple questions regarding the comments for Fernbank Crossing – Phase 3.

- Comment #4 was asking for a table showing the HGL plus freeboard vs USF. Are you looking for a complete table of all USF's or is it possible to show an HGL plus Freeboard profile in Profile drawings? As long as it is clear and easy to reference on the profile drawings as it relates to HGL + freeboard and USF's, that will be acceptable.
- Comment #70 requested sidewalks along Haliburton and Slapshot adjacent the park lands, are both sidewalks required or is the switch along Haliburton adequate?
   Both streets require sidewalks, however the choice between a) and b) is available along Haliburton.

I'm also wondering on the status of the boundary conditions for the hydraulic analysis.

Thanks, Lucas Wilson | EIT, B.Eng.

## NOVATECH

**Engineers, Planners & Landscape Architects** | 200-240 Michael Cowpland Drive, Ottawa, ON K2M 1P6 Office 613.254.9643 x282 | Fax 613.254.5867 | Email <u>l.wilson@novatech-eng.com</u> *The information contained in this email message is confidential and is for exclusive use of the addressee.* 

From: Lucas Wilson Sent: February-24-15 1:02 PM To: eric.surprenant@ottawa.ca Cc: Mark Bissett Subject: D07-16-09-0034 - Phase 3, Revised Boundary Conditions **Eric** – As per our phone conversation, please find attached Water Demand for Fernbank Crossing and locations 1 & 2 for Boundary Conditions.

If you need any further information do not hesitate to contact me.

Thanks, Lucas Wilson | EIT, B.Eng.

## NOVATECH

**Engineers, Planners & Landscape Architects** | 200-240 Michael Cowpland Drive, Ottawa, ON K2M 1P6 Office 613.254.9643 x282 | Fax 613.254.5867 | Email <a href="https://wilson@novatech-eng.com">wilson@novatech-eng.com</a> The information contained in this email message is confidential and is for exclusive use of the addressee.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

## **BOUNDARY CONDITIONS**



## **Boundary Conditions For: Fernbank Crossing Block 135**

## Date of Boundary Conditions: 2019-Mar-18

#### **Provided Information:**

Scenario	Demand									
	L/min	L/s								
Average Daily Demand	38.0	0.6								
Maximum Daily Demand	95.2	1.6								
Peak Hour	209.3	3.5								
Fire Flow #1 Demand	15,000	250.0								

## Number Of Connections: 1

## Location:



## **BOUNDARY CONDITIONS**



#### **Results:**

#### Connection #: 1

Demand Scenario	Head (m)	Pressure <sup>1</sup> (psi)
Maximum HGL	161.3	84.9
Peak Hour	157.3	79.1
Max Day Plus Fire (15,000) L/min	155.3	76.4

#### <sup>1</sup>Elevation: **94.640 m**

#### Notes:

**1)** As per the Ontario Building Code in areas that may be occupied, the static pressure at any fixture shall not exceed 552 kPa (80 psi.) Pressure control measures to be considered are as follows, in order of preference:

- a) If possible, systems to be designed to residual pressures of 345 to 552 kPa (50 to 80 psi) in all occupied areas outside of the public right-of-way without special pressure control equipment.
- b) Pressure reducing valves to be installed immediately downstream of the isolation valve in the home/ building, located downstream of the meter so it is owner maintained.

2) City of Ottawa requires two connections to this subdivision from two different mains in order to provide uninterrupted water service to the subdivision in the event of required maintenance to one of the mains.

3) Click or tap here to enter text.

## **Disclaimer**

The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of watermains deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation. Fire Flow analysis is a reflection of available flow in the watermain; there may be additional restrictions that occur between the watermain and the hydrant that the model cannot take into account.

Fernbank Crossing - Block 135 Water Demand							
				Average Day	Maximum Day	Peak Hour	
	Area			Demand	Demand	Demand	
	(ha)	Units	Population	(L/s)	(L/s)	(L/s)	
Towns	N/A	58	157	0.634	1.586	3.489	
Total	0.00	58	157	0.634	1.586	3.489	

#### Water Demand Parameters

Towns	2.7	ppl/unit
Residential Demand	350	L/c/day
Residential Max Day	2.5	x Avg Day
Residential Peak Hour	2.2	x Max Day
Residential Fire Flow	200 - 250	L/s

## Fernbank Crossing (Block 135) - Watermain Demand

Node	Towns	Total Population	Average Day Residential Demand (L/s)	Maximum Day Residential Demand (L/s)	Peak Hour Residential Demand (L/s)
HYD1	0	0	0.000	0.000	0.000
HYD2	0	0	0.000	0.000	0.000
HYD3	0	0	0.000	0.000	0.000
HYD4	0	0	0.000	0.000	0.000
CAP1	6	16	0.066	0.164	0.361
CAP2	11	30	0.120	0.301	0.662
CAP3	10	27	0.109	0.273	0.602
CAP4	11	30	0.120	0.301	0.662
CAP5	13	35	0.142	0.355	0.782
CAP6	7	19	0.077	0.191	0.421
T1	0	0	0.000	0.000	0.000
T2	0	0	0.000	0.000	0.000
Т3	0	0	0.000	0.000	0.000
T4	0	0	0.000	0.000	0.000
Т5	0	0	0.000	0.000	0.000
Total	58	157	0.634	1.586	3.489
Water Demand Param	eters				
Singles	3.4	ppl/unit	Residential Max Day	2.5	x Avg Day
Towns	2.7	ppl/unit	Residential Peak Hour	2.2	x Max Day
Residential Demand	350	L/c/day	Residential Fire Flow	200 - 250	L/s


Elevation Node IDDemand ILPSHead rosPressure PressurePressure paiNode ID104.820155.6850.86498.9472.31June HYD2104.660155.6250.83498.6472.32June HYD3104.770155.6750.29493.3471.55June HYD3105.750.36155.6750.29493.3471.90June CAP1105.150.36155.6850.59496.2971.90June CAP3104.920.66155.6250.59496.2971.90June CAP3105.070.666155.6250.36494.0371.65June CAP5105.240.78155.6550.36494.0371.90June CAP5105.710.42155.6749.86498.1370.94June T1104.650155.6150.03494.0372.35June T3104.750155.6550.85498.8472.35June T4104.650155.6850.83498.6472.32June T5156.320155.5750.25492.9571.50June T6104.850155.6850.83498.6472.32June T6104.850155.6850.83498.6472.32June T5157.3-84.5271.50155.7492.9571.50June T6104.850155.6850.83498.6472.32June T6	Network Table - Nodes - (P	Peak Hour)						
Node ID   m   LPS   m   m   m   RPa   psi     June HYD1   104.82   0   155.68   50.96   499.94   72.36     June HYD3   104.77   0   155.67   50.29   493.34   71.55     June HYD3   104.77   0   155.57   50.29   493.34   71.55     June CAP1   105.15   0.36   155.68   50.53   496.29   72.32     June CAP2   105.03   0.66   155.61   50.69   496.29   71.90     June CAP3   104.97   0.66   155.61   50.33   495.70   71.90     June CAP5   105.71   0.42   155.67   49.86   498.13   70.94     June T1   104.65   0   155.67   50.92   498.84   72.35     June T3   104.75   0   155.6   50.83   498.44   72.34     June T4   104.65   0   155.67   50.25   492.95   71.50     June		Elevation	Demand	Head	Pressure	Pressure	Pressure	
June HYD1   104.82   0   155.68   50.86   498.94   72.36     June HYD2   104.66   0   155.62   50.96   499.92   72.51     June HYD3   104.77   0   155.65   50.83   499.64   72.32     June HYD4   105.28   0   155.57   50.29   493.34   71.55     June CAP1   105.03   0.66   155.68   50.59   496.29   71.90     June CAP2   105.07   0.66   155.61   50.69   497.27   72.52     June CAP5   105.24   0.76   155.65   50.36   498.94   72.34     June CAP5   105.71   0.42   155.65   50.87   498.84   72.32     June T2   104.61   0   155.65   50.84   498.74   72.34     June T3   104.75   0   155.65   50.84   498.64   72.32     June T4   104.85   0   155.65   50.85   498.64   72.34     Jun	Node ID	m	LPS	m	m	kPa	psi	
June HYD2   104.66   0   155.62   50.96   499.92   72.51     June HYD3   104.77   0   155.6   50.83   498.64   72.32     June HYD4   105.28   0   155.57   50.29   493.34   71.55     June CAP1   105.15   0.36   155.62   50.53   496.70   71.90     June CAP2   105.03   0.66   155.61   50.69   497.27   72.12     June CAP3   104.92   0.6   155.61   50.69   496.30   71.90     June CAP4   105.07   0.66   155.61   50.36   494.03   71.65     June CAP5   105.24   0.778   155.6   50.36   498.43   70.94     June T1   104.65   0   155.65   50.98   498.74   72.35     June T3   104.75   0   155.65   50.85   498.64   72.32     June T4   104.76   0   155.65   50.83   498.64   72.32     Jun	Junc HYD1	104.82	0	155.68	50.86	498.94	72.36	
June HYD3   104.77   0   155.6   50.83   448.64   72.32     June HYD4   105.28   0   155.57   50.29   493.34   71.55     June CAP1   105.15   0.36   155.68   50.53   495.70   71.90     June CAP2   105.03   0.66   155.61   50.69   497.27   72.12     June CAP3   104.92   0.6   155.66   50.53   495.70   71.90     June CAP4   105.71   0.42   155.57   49.86   489.13   70.94     June TA   104.65   0   155.62   50.97   500.02   72.52     June T2   104.61   0   155.65   50.85   498.84   72.35     June T3   104.75   0   155.65   50.84   498.74   72.34     June T5   105.32   0   155.68   50.83   498.64   72.32     June T6   104.85   0   155.68   50.83   498.64   72.32     Resvr RES	Junc HYD2	104.66	0	155.62	50.96	499.92	72.51	
June YD4   105.28   0   155.57   50.29   493.34   71.55     Junc CAP1   105.15   0.36   155.68   50.53   495.70   71.90     Junc CAP2   105.03   0.66   155.62   50.59   496.29   71.92     Junc CAP3   104.92   0.6   155.61   50.69   497.27   72.12     Junc CAP4   105.07   0.66   155.6   50.36   494.03   71.95     Junc CAP6   105.71   0.42   155.57   49.86   489.13   70.94     Junc T1   104.65   0   155.66   50.85   498.84   72.35     Junc T3   104.75   0   155.66   50.85   498.84   72.32     Junc T6   104.85   0   155.68   50.83   498.64   72.32     Junc T6   104.85   0   155.68   50.83   498.64   72.32     Junc T6   104.85   0   155.68   50.83   496.64   72.32     Pipe P1<	Junc HYD3	104.77	0	155.6	50.83	498.64	72.32	
Junc CAP1   105,15   0.36   155,68   50,53   496,70   71,90     Junc CAP2   105,03   0.66   155,62   50,59   496,29   71,90     Junc CAP3   104,92   0.6   155,61   50,69   497,27   72,12     Junc CAP4   105,07   0.66   155,6   50,53   495,70   71,90     Junc CAP5   105,24   0.78   155,67   49,86   489,13   70,94     Junc T1   104,65   0   155,62   50,97   500,02   72,52     Junc T2   104,61   0   155,65   50,85   498,84   72,35     Junc T3   104,75   0   155,65   50,85   498,84   72,34     Junc T6   104,85   0   155,68   50,83   498,64   72,32     Junc T6   104,85   0   155,68   50,83   498,64   72,32     Junc T6   104,85   0   155,68   50,83   498,64   72,32     Junc T6 </td <td>Junc HYD4</td> <td>105.28</td> <td>0</td> <td>155.57</td> <td>50.29</td> <td>493.34</td> <td>71.55</td> <td></td>	Junc HYD4	105.28	0	155.57	50.29	493.34	71.55	
Junc CAP2   105.03   0.66   155.62   50.59   496.29   71.88     Junc CAP3   104.92   0.6   155.61   50.69   497.27   72.12     Junc CAP4   105.07   0.66   155.6   50.36   494.03   71.65     Junc CAP5   105.24   0.78   155.67   49.86   489.13   70.94     Junc T1   104.65   0   155.61   51   500.31   72.56     Junc T2   104.61   0   155.61   51   500.31   72.35     Junc T3   104.76   0   155.67   50.85   498.84   72.35     Junc T6   105.32   0   155.57   50.25   492.95   71.50     Junc T6   104.85   0   155.68   50.83   498.64   72.32     Junc T6   104.85   0   155.68   50.83   498.64   72.32     Pior P1   17   204   110   0.36   0.01   0.00   0.05     Pipe P1	Junc CAP1	105.15	0.36	155.68	50.53	495.70	71.90	
Junc CAP3   104.92   0.6   155.61   50.69   497.27   72.12     Junc CAP4   105.07   0.66   155.6   50.33   495.70   71.90     Junc CAP5   105.24   0.78   155.6   50.36   494.03   71.65     Junc CAP6   105.71   0.42   155.57   49.86   489.13   70.94     Junc T1   104.65   0   155.62   50.97   500.02   72.52     Junc T3   104.75   0   155.6   50.85   498.44   72.35     Junc T4   104.76   0   155.6   50.85   498.74   72.34     Junc T5   105.32   0   155.68   50.83   496.46   72.32     Junc T6   104.85   0   155.68   50.83   496.44   72.32     Junc T5   157.3   -84.52   157.3   0   0.00   0.00     Lorgt   mm   mm   LPS   m/s   m/s/m   Friction     Junc T5   157.	Junc CAP2	105.03	0.66	155.62	50.59	496.29	71.98	
Junc CAP4   105.07   0.66   155.6   50.53   495.70   71.90     Junc CAP5   105.24   0.78   155.6   50.36   494.03   71.65     Junc CAP6   105.71   0.42   155.67   49.86   489.13   70.94     Junc T1   104.65   0   155.62   50.97   500.02   72.52     Junc T2   104.61   0   155.61   51   500.31   72.56     Junc T3   104.75   0   155.6   50.85   498.84   72.35     Junc T6   105.32   0   155.68   50.83   498.64   72.32     Junc T6   104.85   0   155.68   50.83   498.64   72.32     Junc T6   104.85   0   155.68   50.83   498.64   72.32     Junc T6   104.85   0   155.68   50.83   498.64   72.32     Resvr RES1   157.3   -84.52   157.3   0   0.00   0.00     Pipe P1 <td< td=""><td>Junc CAP3</td><td>104.92</td><td>0.6</td><td>155.61</td><td>50.69</td><td>497.27</td><td>72.12</td><td></td></td<>	Junc CAP3	104.92	0.6	155.61	50.69	497.27	72.12	
Junc CAP5   105.24   0.78   155.6   50.36   494.03   71.65     Junc CAP6   105.71   0.42   155.57   49.86   489.13   70.94     Junc T1   104.65   0   155.62   50.97   500.02   72.52     Junc T3   104.75   0   155.66   50.85   498.84   72.35     Junc T4   104.76   0   155.66   50.85   498.84   72.34     Junc T5   105.32   0   155.66   50.83   498.64   72.32     Junc T6   104.85   0   155.68   50.83   498.64   72.32     Resvr RES1   157.3   -84.52   157.3   0   0.00   0.00     Network Table - Links - (Peak Hour)   m   mm   LPS   m/s   m/km   Factor     Pipe P1   17   204   110   0.36   0.01   0.00   0.064     Pipe P3   56   204   110   5.57   0.17   0.27   0.038	Junc CAP4	105.07	0.66	155.6	50.53	495.70	71.90	
Junc CAP6   105.71   0.42   155.57   49.86   489.13   70.94     Junc T1   104.65   0   155.62   50.97   500.02   72.52     Junc T2   104.61   0   155.61   51   500.31   72.56     Junc T3   104.75   0   155.6   50.84   498.74   72.34     Junc T4   104.76   0   155.65   50.84   498.74   72.34     Junc T5   105.32   0   155.68   50.83   498.64   72.32     Resvr RES1   157.3   -84.52   157.3   0   0.00   0.00     Network Table - Links - (Peak Hour)   mmm   LPS   m/s   m/km   Fiction     Link ID   m   mm   LPS   m/s   m/km   Factor     Pipe P1   17   204   110   0.36   0.01   0.00   0.054     Pipe P3   56   204   110   5.57   0.17   0.27   0.038     Pipe P4	Junc CAP5	105.24	0.78	155.6	50.36	494.03	71.65	
Junc T1 104.65 0 155.62 50.97 500.02 72.52   Junc T2 104.61 0 155.61 51 500.31 72.56   Junc T3 104.75 0 155.6 50.85 498.84 72.35   Junc T4 104.76 0 155.6 50.84 498.74 72.34   Junc T5 105.32 0 155.68 50.83 498.64 72.32   Junc T6 104.85 0 155.68 50.83 498.64 72.32   Resvr RES1 157.3 -84.52 157.3 0 0.00 0.00   Network Table - Links - (Peak Hour) m mm LPS m/s m/s Friction   Link ID m mm mm LPS m/s m/s Factor   Pipe P1 17 204 110 0.36 0.01 0.00 0.064   Pipe P3 56 204 110 5.57 0.17 0.22 0.038   Pipe P4 42 155 100 0.66 0.04 0.02	Junc CAP6	105.71	0.42	155.57	49.86	489.13	70.94	
Junc T2   104.61   0   155.61   51   500.31   72.56     Junc T3   104.75   0   155.6   50.85   498.84   72.35     Junc T4   104.76   0   155.6   50.84   498.74   72.34     Junc T5   105.32   0   155.67   50.25   492.95   71.50     Junc T6   104.85   0   155.68   50.83   498.64   72.32     Resvr RES1   157.3   -84.52   157.3   0   0.00   0.00     Network Table - Links - (Peak Hour)   m   mm   LPS   m/s   m/km   Factor     Pipe P1   17   204   110   0.36   0.01   0.00   0.054     Pipe P2   30   155   100   0.36   0.02   0.01   0.064     Pipe P3   56   204   110   5.57   0.17   0.22   0.038     Pipe P5   8   204   110   4.91   0.15   0.22   0.038 </td <td>Junc T1</td> <td>104.65</td> <td>0</td> <td>155.62</td> <td>50.97</td> <td>500.02</td> <td>72.52</td> <td></td>	Junc T1	104.65	0	155.62	50.97	500.02	72.52	
Junc T3   104.75   0   155.6   50.85   498.84   72.35     Junc T4   104.76   0   155.6   50.84   498.74   72.34     Junc T5   105.32   0   155.67   50.25   492.95   71.50     Junc T6   104.85   0   155.68   50.83   498.64   72.32     Resvr RES1   157.3   -84.52   157.3   0   0.00   0.00     Network Table - Links - (Peak Hour)   Length   Diameter   Roughness   Flow   Velocity   Headloss   Friction     Link ID   m   mm   LPS   m/s   m/km   Factor     Pipe P1   17   204   110   0.36   0.01   0.00   0.054     Pipe P3   56   204   110   5.57   0.17   0.27   0.038     Pipe P4   42   155   100   0.66   0.04   0.02   0.059     Pipe P5   8   204   110   4.91   0.15 <td>Junc T2</td> <td>104.61</td> <td>0</td> <td>155.61</td> <td>51</td> <td>500.31</td> <td>72.56</td> <td></td>	Junc T2	104.61	0	155.61	51	500.31	72.56	
Junc T4   104.76   0   155.6   50.84   498.74   72.34     Junc T5   105.32   0   155.57   50.25   492.95   71.50     Junc T6   104.85   0   155.68   50.83   498.64   72.32     Resvr RES1   157.3   -84.52   157.3   0   0.00   0.00     Network Table - Links - (Peak Hour)   Length   Diameter   Roughness   Flow   Velocity   Headloss   Friction     Link ID   m   mm   LPS   m/s   m/km   Factor     Pipe P1   17   204   110   0.36   0.01   0.00   0.054     Pipe P2   30   155   100   0.36   0.02   0.01   0.064     Pipe P3   56   204   110   5.57   0.17   0.27   0.038     Pipe P6   33   204   110   4.91   0.15   0.22   0.038     Pipe P8   35   204   110   4.31	Junc T3	104.75	0	155.6	50.85	498.84	72.35	
Junc T5   105.32   0   155.57   50.25   492.95   71.50     Junc T6   104.85   0   155.68   50.83   498.64   72.32     Resvr RES1   157.3   -84.52   157.3   0   0.00   0.00     Network Table - Links - (Peak Hour)   Length   Diameter   Roughness   Flow   Velocity   Headloss   Friction     Link ID   m   mm   LPS   m/s   m/km   Factor     Pipe P1   17   204   110   0.36   0.01   0.00   0.054     Pipe P2   30   155   100   0.36   0.02   0.01   0.064     Pipe P3   56   204   110   5.57   0.17   0.27   0.038     Pipe P6   33   204   110   4.91   0.15   0.22   0.038     Pipe P7   41   155   100   0.66   0.04   0.02   0.059     Pipe P8   35   204   110 <td< td=""><td>Junc T4</td><td>104.76</td><td>0</td><td>155.6</td><td>50.84</td><td>498.74</td><td>72.34</td><td></td></td<>	Junc T4	104.76	0	155.6	50.84	498.74	72.34	
Junc T6   104.85   0   155.68   50.83   498.64   72.32     Resvr RES1   157.3   -84.52   157.3   0   0.00   0.00     Network Table - Links - (Peak Hour)   Length   Diameter   Roughness   Flow   Velocity   Headloss   Friction     Link ID   m   mm   LPS   m/s   m/km   Factor     Pipe P1   17   204   110   0.36   0.01   0.00   0.054     Pipe P2   30   155   100   0.36   0.02   0.01   0.064     Pipe P3   56   204   110   5.57   0.17   0.27   0.038     Pipe P4   42   155   100   0.66   0.04   0.02   0.059     Pipe P5   8   204   110   4.91   0.15   0.22   0.038     Pipe P6   33   204   110   4.31   0.13   0.17   0.39     Pipe P7   41   155   100	Junc T5	105.32	0	155.57	50.25	492.95	71.50	
Resvr RES1   157.3   -84.52   157.3   0   0.00   0.00     Network Table - Links - (Peak Hour)   Length   Diameter   Roughness   Flow   Velocity   Headloss   Friction     Link ID   m   mm   LPS   m/s   m/s   m/s   Friction     Pipe P1   17   204   110   0.36   0.01   0.00   0.054     Pipe P2   30   155   100   0.36   0.02   0.01   0.064     Pipe P3   56   204   110   5.57   0.17   0.27   0.038     Pipe P4   42   155   100   0.66   0.04   0.02   0.059     Pipe P5   8   204   110   4.91   0.15   0.22   0.038     Pipe P7   411   155   100   0.66   0.03   0.02   0.069     Pipe P9   3   204   110   4.31   0.13   0.17   0.39     Pipe P10   44	Junc T6	104.85	0	155.68	50.83	498.64	72.32	
Network Table - Links - (Peak Hour)   Length   Diameter   Roughness   Flow   Velocity   Headloss   Friction     Link ID   m   mm   LPS   m/s   m/s   Friction     Pipe P1   17   204   110   0.36   0.01   0.00   0.054     Pipe P2   30   155   100   0.36   0.02   0.01   0.064     Pipe P3   56   204   110   5.57   0.17   0.27   0.038     Pipe P4   42   155   100   0.66   0.04   0.02   0.059     Pipe P5   8   204   110   4.91   0.15   0.22   0.038     Pipe P6   33   204   110   4.91   0.15   0.22   0.038     Pipe P7   411   155   100   0.60   0.03   0.02   0.069     Pipe P9   3   204   110   4.31   0.13   0.17   0.039     Pipe P10   44   <	Resvr RES1	157.3	-84.52	157.3	0	0.00	0.00	
LengthDiameterRoughnessFlowVelocityHeadlossFrictionLink IDmmmLPSm/sm/kmFactorPipe P1172041100.360.010.000.054Pipe P2301551000.360.020.010.064Pipe P3562041105.570.170.270.038Pipe P4421551000.660.040.020.059Pipe P582041104.910.150.220.038Pipe P6332041104.910.150.220.039Pipe P7411551000.660.030.020.069Pipe P8352041104.310.130.170.039Pipe P932041104.310.130.170.039Pipe P11252041103.650.110.120.040Pipe P13611551000.660.040.020.059	Network Table - Links - (Pe	eak Hour)						
Link IDmmmLPSm/sm/kmFactorPipe P1172041100.360.010.000.054Pipe P2301551000.360.020.010.064Pipe P3562041105.570.170.270.038Pipe P4421551000.660.040.020.059Pipe P582041104.910.150.220.038Pipe P6332041104.910.150.220.038Pipe P7411551000.600.030.020.069Pipe P8352041104.310.130.170.039Pipe P932041104.310.130.170.039Pipe P10441551000.660.040.020.059Pipe P11252041103.650.110.120.040Pipe P13611551000.780.090.080.041		Length	Diameter	Roughness	Flow	Velocity	Headloss	Friction
Pipe P1172041100.360.010.000.054Pipe P2301551000.360.020.010.064Pipe P3562041105.570.170.270.038Pipe P4421551000.660.040.020.059Pipe P582041104.910.150.220.038Pipe P6332041104.910.150.220.038Pipe P7411551000.600.030.020.069Pipe P8352041104.310.130.170.039Pipe P932041104.310.130.170.039Pipe P10441551000.660.040.020.059Pipe P11252041103.650.110.120.040Pipe P13611551000.780.090.080.041	Link ID	m	mm	•	LPS	m/s	m/km	Factor
Pipe P2301551000.360.020.010.064Pipe P3562041105.570.170.270.038Pipe P4421551000.660.040.020.059Pipe P582041104.910.150.220.038Pipe P6332041104.910.150.220.038Pipe P7411551000.600.030.020.060Pipe P8352041104.310.130.170.039Pipe P932041104.310.130.170.039Pipe P10441551000.660.040.020.059Pipe P11252041103.650.110.120.040Pipe P12492041102.870.090.080.041Pipe P13611551000.780.040.030.058	Pipe P1	17	204	110	0.36	0.01	0.00	0.054
Pipe P3562041105.570.170.270.038Pipe P4421551000.660.040.020.059Pipe P582041104.910.150.220.038Pipe P6332041104.910.150.220.038Pipe P7411551000.600.030.020.060Pipe P8352041104.310.130.170.039Pipe P932041104.310.130.170.039Pipe P10441551000.660.040.020.059Pipe P11252041103.650.110.120.040Pipe P12492041102.870.090.080.041	Pipe P2	30	155	100	0.36	0.02	0.01	0.064
Pipe P4421551000.660.040.020.059Pipe P582041104.910.150.220.038Pipe P6332041104.910.150.220.038Pipe P7411551000.600.030.020.069Pipe P8352041104.310.130.170.039Pipe P932041104.310.130.170.039Pipe P10441551000.660.040.020.059Pipe P11252041103.650.110.120.040Pipe P13611551000.780.040.030.058	Pipe P3	56	204	110	5.57	0.17	0.27	0.038
Pipe P582041104.910.150.220.038Pipe P6332041104.910.150.220.038Pipe P7411551000.600.030.020.60Pipe P8352041104.310.130.170.039Pipe P932041104.310.130.170.039Pipe P10441551000.660.040.020.059Pipe P11252041103.650.110.120.040Pipe P13611551000.780.090.080.041	Pipe P4	42	155	100	0.66	0.04	0.02	0.059
Pipe P6332041104.910.150.220.038Pipe P7411551000.600.030.020.060Pipe P8352041104.310.130.170.039Pipe P932041104.310.130.170.039Pipe P10441551000.660.040.020.059Pipe P11252041103.650.110.120.040Pipe P12492041102.870.090.080.041Pipe P13611551000.780.040.030.058	Pipe P5	8	204	110	4.91	0.15	0.22	0.038
Pipe P7411551000.600.030.020.060Pipe P8352041104.310.130.170.039Pipe P932041104.310.130.170.039Pipe P10441551000.660.040.020.059Pipe P11252041103.650.110.120.040Pipe P12492041102.870.090.080.041Pipe P13611551000.780.040.030.58	Pipe P6	33	204	110	4.91	0.15	0.22	0.038
Pipe P8352041104.310.130.170.039Pipe P932041104.310.130.170.039Pipe P10441551000.660.040.020.059Pipe P11252041103.650.110.120.040Pipe P12492041102.870.090.080.041Pipe P13611551000.780.040.030.58	Pipe P7	41	155	100	0.60	0.03	0.02	0.060
Pipe P9   3   204   110   4.31   0.13   0.17   0.039     Pipe P10   44   155   100   0.66   0.04   0.02   0.059     Pipe P11   25   204   110   3.65   0.11   0.12   0.040     Pipe P12   49   204   110   2.87   0.09   0.08   0.041     Pipe P13   61   155   100   0.78   0.04   0.03   0.058	Pipe P8	35	204	110	4.31	0.13	0.17	0.039
Pipe P10   44   155   100   0.66   0.04   0.02   0.059     Pipe P11   25   204   110   3.65   0.11   0.12   0.040     Pipe P12   49   204   110   2.87   0.09   0.08   0.041     Pipe P13   61   155   100   0.78   0.04   0.03   0.058	Pipe P9	3	204	110	4.31	0.13	0.17	0.039
Pipe P11   25   204   110   3.65   0.11   0.12   0.040     Pipe P12   49   204   110   2.87   0.09   0.08   0.041     Pipe P13   61   155   100   0.78   0.04   0.03   0.058	Pipe P10	44	155	100	0.66	0.04	0.02	0.059
Pipe P12   49   204   110   2.87   0.09   0.08   0.041     Pipe P13   61   155   100   0.78   0.04   0.03   0.058	Pipe P11	25	204	110	3.65	0.11	0.12	0.040
Pipe P13 61 155 100 0.78 0.04 0.03 0.058	Pipe P12	49	204	110	2.87	0.09	0.08	0.041
······································	Pipe P13	61	155	100	0.78	0.04	0.03	0.058
Pipe P14 25 204 110 -0.42 0.01 0.00 0.054	Pipe P14	25	204	110	-0.42	0.01	0.00	0.054
Pipe P15 38 155 100 0.42 0.02 0.01 0.064	Pipe P15	38	155	100	0.42	0.02	0.01	0.064



Network Table - Nodes -	(Max Pressure Chec	k)					
	Elevation	Demand	Head	Pressure	Pressure	Pressure	
Node ID	m	LPS	m	m	kPa	psi	
Junc HYD1	104.82	0	161.21	56.39	553.19	80.23	
Junc HYD2	104.66	0	161.21	56.55	554.76	80.46	
Junc HYD3	104.77	0	161.21	56.44	553.68	80.30	
Junc HYD4	105.28	0	161.21	55.93	548.67	79.58	
Junc B4	106.5	0.01	161.2	54.7	536.61	77.83	
Junc B6	107	0.01	161.2	54.2	531.70	77.12	
Junc CAP1	105.15	0.07	161.21	56.06	549.95	79.76	
Junc CAP2	105.03	0.12	161.21	56.18	551.13	79.93	
Junc CAP3	104.92	0.11	161.21	56.29	552.20	80.09	
Junc CAP4	105.07	0.12	161.21	56.14	550.73	79.88	
Junc CAP5	105.24	0.13	161.21	55.97	560.15	81.24	
Junc CAP6	105.71	0.07	161.21	55.5	560.15	81.24	
Junc T1	104.65	0	161.21	56.56	554.85	80.47	
Junc T2	104.61	0	161.21	56.6	555.25	80.53	
Junc T3	104.75	0	161.21	56.46	553.87	80.33	
Junc T4	104.76	0	161.21	56.45	553.77	80.32	
Junc T5	105.32	0	161.21	55.89	559.07	81.09	
Junc T6	104.85	0	161.21	56.36	552.89	80.19	
Resvr RES1	161.3	-17.45	161.3	0	0.00	0.00	
Network Table - Links - (	Max Pressure Check	x)					
	Length	Diameter	Roughness	Flow	Velocity	Headloss	Friction
Link ID	m	mm		LPS	m/s	m/km	Factor
Pipe P1	17	204	110	0.07	0.00	0.00	0.000
Pipe P2	30	155	100	0.07	0.00	0.00	0.000
Pipe P3	56	204	110	1.13	0.03	0.01	0.048
Pipe P4	42	155	100	0.12	0.01	0.00	0.067
Pipe P5	8	204	110	1.01	0.03	0.01	0.049
Pipe P6	33	204	110	1.01	0.03	0.01	0.047
Pipe P7	41	155	100	0.11	0.01	0.00	0.083
Pipe P8	35	204	110	0.90	0.03	0.01	0.050
Pipe P9	3	204	110	0.90	0.03	0.01	0.033
Pipe P10	44	155	100	0.12	0.01	0.00	0.095
Pipe P11	25	204	110	0.78	0.02	0.01	0.052
Pipe P12	49	204	110	0.63	0.02	0.00	0.054
Pipe P13	61	155	100	0.15	0.01	0.00	0.071
Pipe P14	25	204	110	-0.09	0.00	0.00	0.000
Pipe P15	38	155	100	0.09	0.00	0.00	0.137
Pipe P16	16	19	100	-0.01	0.04	0.33	0.083
Pipe P17	16	19	100	-0.01	0.04	0.33	0.083



#### Network Table - Nodes - (Fire Flow Summary)

Fire	Flow	Μ	Minimum Pressure			
LOCATION	Flow (L/s)	Pressure (kPa)	Pressure (PSI)	Node		
B1	250	230.54	33.44	CAP1		
B3	233	240.15	34.83	CAP4		
B4	250	213.76	31.00	CAP6		
B6	250	210.62	30.55	CAP6		



Network Table - Links (Max Day + FF 'Bldg 1')

Network Table - Nodes	(Max Day + FF 'Bldg 1')					
	Elevation	Demand	Head	Pressure	Pressure	Pressure
Node ID	m	LPS	m	m	kPa	psi
Junc HYD1	104.82	95	128.65	23.83	233.77	33.91
Junc HYD2	104.66	95	130.47	25.81	253.20	36.72
Junc HYD3	104.77	0	131.08	26.31	258.10	37.43
Junc HYD4	105.28	0	131.83	26.55	260.46	37.78
Junc HYD36	104.46	60.14	131.9	27.44	269.19	39.04
Junc CAP1	105.15	0.16	128.65	23.5	230.54	33.44
Junc CAP2	105.03	0.3	130.63	25.6	251.14	36.42
Junc CAP3	104.92	0.27	130.77	25.85	253.59	36.78
Junc CAP4	105.07	0.3	131.11	26.04	255.45	37.05
Junc CAP5	105.24	0.35	131.34	26.1	256.04	37.14
Junc CAP6	105.71	0.19	131.83	26.12	256.24	37.16
Junc T1	104.65	0	130.63	25.98	254.86	36.96
Junc T2	104.61	0	130.77	26.16	256.63	37.22
Junc T3	104.75	0	131.11	26.36	258.59	37.51
Junc T4	104.76	0	131.34	26.58	260.75	37.82
Junc T5	105.32	0	131.83	26.51	260.06	37.72
Junc T6	104.85	0	129.52	24.67	242.01	35.10
Resvr RES1	155.3	-289.2	155.3	0	0.00	0.00

	Length	Diameter	Roughness	Flow	Velocity	Headloss	Friction
Link ID	m	mm		LPS	m/s	m/km	Factor
Pipe P1	17	204	110	-95.16	2.91	52.27	0.025
Pipe P2	30	155	100	0.16	0.01	0.00	0.076
Pipe P3	56	204	110	58.65	1.79	21.33	0.027
Pipe P4	42	155	100	0.30	0.02	0.01	0.067
Pipe P5	8	204	110	58.34	1.79	21.12	0.027
Pipe P6	33	204	110	-36.66	1.12	8.93	0.028
Pipe P7	41	155	100	0.27	0.01	0.00	0.066
Pipe P8	35	204	110	36.93	1.13	9.06	0.028
Pipe P9	3	204	110	36.93	1.13	9.05	0.028
Pipe P10	44	155	100	0.30	0.02	0.01	0.066
Pipe P11	25	204	110	37.23	1.14	9.19	0.028
Pipe P12	49	204	110	37.58	1.15	9.36	0.028
Pipe P13	61	155	100	0.35	0.02	0.01	0.065
Pipe P14	25	204	110	0.19	0.01	0.00	0.087
Pipe P15	95	155	100	0.19	0.01	0.00	0.070



letwork Table - Nodes (Max Day + FF 'Bldg 3')								
	Elevation	Demand	Head	Pressure	Pressure	Pressure		
Node ID	m	LPS	m	m	kPa	psi		
Junc HYD1	104.82	0	135.13	30.31	297.34	43.13		
Junc HYD2	104.66	95	129.46	24.8	243.29	35.29		
Junc HYD3	104.77	95	129.41	24.64	241.72	35.06		
Junc HYD4	105.28	0	132.84	27.56	270.36	39.21		
Junc HYD38	104.54	43.11	132.35	27.81	272.82	39.57		
Junc CAP1	105.15	0.16	135.13	29.98	294.10	42.66		
Junc CAP2	105.03	0.3	129.95	24.92	244.47	35.46		
Junc CAP3	104.92	0.27	129.43	24.51	240.44	34.87		
Junc CAP4	105.07	0.3	129.55	24.48	240.15	34.83		
Junc CAP5	105.24	0.35	130.62	25.38	248.98	36.11		
Junc CAP6	105.71	0.19	132.84	27.13	266.15	38.60		
Junc T1	104.65	0	129.95	25.3	248.19	36.00		
Junc T2	104.61	0	129.43	24.82	243.48	35.31		
Junc T3	104.75	0	129.55	24.8	243.29	35.29		
Junc T4	104.76	0	130.63	25.87	253.78	36.81		
Junc T5	105.32	0	132.84	27.52	269.97	39.16		
Junc T6	104.85	0	135.13	30.28	297.05	43.08		
Resvr RES1	155.3	-272.2	155.3	0	0.00	0.00		
Network Table - Links (Max Day + FF 'Bldg 3')								

	Length	Diameter	Roughness	Flow	Velocity	Headloss	Friction
Link ID	m	mm		LPS	m/s	m/km	Factor
Pipe P1	17	204	110	-0.16	0.01	0.00	0.089
Pipe P2	30	155	100	0.16	0.01	0.00	0.063
Pipe P3	56	204	110	105.03	3.21	62.76	0.024
Pipe P4	42	155	100	0.30	0.02	0.01	0.067
Pipe P5	8	204	110	104.73	3.20	62.42	0.024
Pipe P6	33	204	110	9.73	0.30	0.77	0.035
Pipe P7	41	155	100	0.27	0.01	0.00	0.069
Pipe P8	35	204	110	-9.46	0.29	0.73	0.035
Pipe P9	3	204	110	85.54	2.62	42.91	0.025
Pipe P10	44	155	100	0.30	0.02	0.01	0.066
Pipe P11	25	204	110	85.84	2.63	43.19	0.025
Pipe P12	49	204	110	86.20	2.64	43.52	0.025
Pipe P13	61	155	100	0.35	0.02	0.01	0.065
Pipe P14	25	204	110	0.19	0.01	0.00	0.087
Pipe P15	95	155	100	0.19	0.01	0.00	0.070



Network Table - Nodes (M	lax Day + FF 'Bldg 4')							
	Elevation	Demand	Head	Pressure	Pressure	Pressure		
Node ID	m	LPS	m	m	kPa	psi		
Junc HYD1	104.82	0	132.74	27.92	273.90	39.73		
Junc HYD2	104.66	0	129.71	25.05	245.74	35.64		
Junc HYD3	104.77	95	128.44	23.67	232.20	33.68		
Junc HYD4	105.28	95	127.5	22.22	217.98	31.62		
Junc HYD38	104.54	60.11	128.5	23.96	235.05	34.09		
Junc CAP1	105.15	0.16	132.74	27.59	270.66	39.26		
Junc CAP2	105.03	0.3	129.86	24.83	243.58	35.33		
Junc CAP3	104.92	0.27	129.09	24.17	237.11	34.39		
Junc CAP4	105.07	0.3	128.48	23.41	229.65	33.31		
Junc CAP5	105.24	0.35	128.75	23.51	230.63	33.45		
Junc CAP6	105.71	0.19	127.5	21.79	213.76	31.00		
Junc T1	104.65	0	129.86	25.21	247.31	35.87		
Junc T2	104.61	0	129.09	24.48	240.15	34.83		
Junc T3	104.75	0	128.48	23.73	232.79	33.76		
Junc T4	104.76	0	128.75	23.99	235.34	34.13		
Junc T5	105.32	0	128.81	23.49	230.44	33.42		
Junc T6	104.85	0	132.74	27.89	273.60	39.68		
Resvr RES1	155.3	-289.2	155.3	0	0.00	0.00		
Network Table - Links (Max Day + FF 'Bidg 4')								

	Length	Diameter	Roughness	Flow	Velocity	Headloss	Friction
Link ID	m	mm		LPS	m/s	m/km	Factor
Pipe P1	17	204	110	-0.16	0.01	0.00	0.089
Pipe P2	30	155	100	0.16	0.01	0.00	0.063
Pipe P3	56	204	110	54.99	1.68	18.93	0.027
Pipe P4	42	155	100	0.30	0.02	0.01	0.067
Pipe P5	8	204	110	54.69	1.67	18.74	0.027
Pipe P6	33	204	110	54.69	1.67	18.74	0.027
Pipe P7	41	155	100	0.27	0.01	0.00	0.066
Pipe P8	35	204	110	-54.42	1.66	18.57	0.027
Pipe P9	3	204	110	40.58	1.24	10.78	0.028
Pipe P10	44	155	100	0.30	0.02	0.01	0.066
Pipe P11	25	204	110	40.88	1.25	10.93	0.028
Pipe P12	49	204	110	41.24	1.26	11.11	0.028
Pipe P13	61	155	100	0.35	0.02	0.01	0.065
Pipe P14	25	204	110	95.19	2.91	52.30	0.025
Pipe P15	95	155	100	0.19	0.01	0.00	0.073



Network Table - Nodes	s (Max Day + FF 'Bldg 6')					
	Elevation	Demand	Head	Pressure	Pressure	Pressure
Node ID	m	LPS	m	m	kPa	psi
Junc HYD1	104.82	0	132.76	27.94	274.09	39.75
Junc HYD2	104.66	0	129.77	25.11	246.33	35.73
Junc HYD3	104.77	95	128.5	23.73	232.79	33.76
Junc HYD4	105.28	95	127.18	21.9	214.84	31.16
Junc HYD43	104.97	60	128.83	23.86	234.07	33.95
Junc CAP1	105.15	0.16	132.76	27.61	270.85	39.28
Junc CAP2	105.03	0.3	129.91	24.88	244.07	35.40
Junc CAP3	104.92	0.27	129.15	24.23	237.70	34.47
Junc CAP4	105.07	0.3	128.54	23.47	230.24	33.39
Junc CAP5	105.24	0.35	128.82	23.58	231.32	33.55
Junc CAP6	105.71	0.19	127.18	21.47	210.62	30.55
Junc T1	104.65	0	129.91	25.26	247.80	35.94
Junc T2	104.61	0	129.15	24.54	240.74	34.92
Junc T3	104.75	0	128.54	23.79	233.38	33.85
Junc T4	104.76	0	128.82	24.06	236.03	34.23
Junc T5	105.32	0	128.49	23.17	227.30	32.97
Junc T6	104.85	0	132.76	27.91	273.80	39.71
Resvr RES1	155.3	-289.2	155.3	0	0.00	0.00

Network Table - Links (Max Day + FF 'Bldg 6')								
	Length	Diameter	Roughness	Flow	Velocity	Headloss	Friction	
Link ID	m	mm		LPS	m/s	m/km	Factor	
Pipe P1	17	204	110	-0.16	0.01	0.00	0.089	
Pipe P2	30	155	100	0.16	0.01	0.00	0.076	
Pipe P3	56	204	110	54.74	1.67	18.77	0.027	
Pipe P4	42	155	100	0.30	0.02	0.01	0.067	
Pipe P5	8	204	110	54.44	1.67	18.58	0.027	
Pipe P6	33	204	110	54.44	1.67	18.58	0.027	
Pipe P7	41	155	100	0.27	0.01	0.00	0.066	
Pipe P8	35	204	110	-54.16	1.66	18.41	0.027	
Pipe P9	3	204	110	40.84	1.25	10.91	0.028	
Pipe P10	44	155	100	0.30	0.02	0.01	0.068	
Pipe P11	25	204	110	41.14	1.26	11.06	0.028	
Pipe P12	49	204	110	41.49	1.27	11.24	0.028	
Pipe P13	61	155	100	0.35	0.02	0.01	0.065	
Pipe P14	25	204	110	95.19	2.91	52.30	0.025	
Pipe P15	95	155	100	0.19	0.01	0.00	0.070	



As per 1999 Fire Underwriter's Survey Guidelines

Novatech Project #: 117089 Project Name: Block 135 Date: 3/22/2019 Input By: Lucas Wilson Reviewed By: Project Manager



Engineers, Planners & Landscape Architects

Input by User

Legend

No Information or Input Required

Building Description: Back-2-Back Towns (Bldg 1)

						Total Fire			
Step			Input		Value Used	Flow			
						(L/min)			
		Base Fire Flov	N						
	Construction Ma	terial		Mult	iplier				
	Coefficient	Wood frame	Yes	1.5					
1	related to type	Ordinary construction		1					
-	of construction	Non-combustible construction		0.8	1.5				
	C	Modified Fire resistive construction (2 hrs)		0.6					
		Fire resistive construction (> 3 hrs)		0.6					
Floor Area									
		Building Footprint (m <sup>2</sup> )	600						
	Α	Number of Floors/Storeys	3						
2		Area of structure considered (m <sup>2</sup> )			1,800				
	-	Base fire flow without reductions				14 000			
	•	$F = 220 C (A)^{0.5}$				14,000			
Reductions or Surcharges									
	Occupancy haza	/Surcharge							
3 (1)		Non-combustible		-25%					
		Limited combustible	Yes	-15%					
	(1)	Combustible		0%	-15%	11,900			
		Free burning		15%					
		Rapid burning		25%					
	Sprinkler Reduct	tion		Redu	iction				
		Adequately Designed System (NFPA 13)		-30%					
4	(0)	Standard Water Supply		-10%		0			
	(2)	Fully Supervised System		-10%		U			
			Cum	ulative Total	0%				
	Exposure Surcha	arge (cumulative %)			Surcharge				
		North Side	> 45.1m		0%				
_		East Side	10.1 - 20 m		15%				
5	(3)	South Side	20.1 - 30 m		10%	2,975			
		West Side	> 45.1m		0%				
			Cum	ulative Total	25%				
		Results							
	Total Required Fire Flow, rounded to pearest 10001 /min								
6	(1) + (2) + (3)			or	_/	250			
		(2,000 L/min < Fire Flow < 45,000 L/min)		or	USGPM	3,963			
						-,			
7	Storage Volume	Required Duration of Fire Flow (hours)			Hours	3			
, 		Required Volume of Fire Flow (m <sup>3</sup> )			m <sup>3</sup>	2700			

As per 1999 Fire Underwriter's Survey Guidelines

Novatech Project #: 117089 Project Name: Block 135 Date: 3/22/2019 Input By: Lucas Wilson Reviewed By: Project Manager



Engineers, Planners & Landscape Architects

Legend

Input by User No Information or Input Required

Building Description: Back-2-Back Towns (Bldg 3)

						Total Fire	
Step			Input		Value Used	Flow	
						(L/min)	
Base Fire Flow							
	Construction Ma	terial		Mult	iplier		
	Coefficient	Wood frame	Yes	1.5			
1	related to type	Ordinary construction		1			
-	of construction	Non-combustible construction		0.8	1.5		
	С	Modified Fire resistive construction (2 hrs)		0.6			
		Fire resistive construction (> 3 hrs)		0.6			
	Floor Area						
		Building Footprint (m <sup>2</sup> )	545				
•	Α	Number of Floors/Storeys	3				
2		Area of structure considered (m <sup>2</sup> )			1,635		
	F	Base fire flow without reductions				13 000	
	•	$F = 220 C (A)^{0.5}$				.0,000	
Reductions or Surcharges							
	Occupancy haza	rd reduction or surcharge		Reduction	/Surcharge		
		Non-combustible		-25%			
3		Limited combustible	Yes	-15%			
-	(1)	Combustible		0%	-15%	11,050	
		Free burning		15%			
		Rapid burning		25%			
	Sprinkler Reduct	ion		Redu	iction		
		Adequately Designed System (NFPA 13)		-30%			
4	(2)	Standard Water Supply		-10%		0	
	(2)	Fully Supervised System		-10%		0	
			Cum	ulative Total	0%		
	Exposure Surcha	arge (cumulative %)			Surcharge		
		North Side	20.1 - 30 m		10%		
F		East Side	20.1 - 30 m		10%		
5	(3)	South Side	20.1 - 30 m		10%	3,315	
		West Side	> 45.1m		0%		
	C				30%		
		Results					
		Total Required Fire Flow, rounded to nea	rest 1000L/mir	ı	L/min	14.000	
6	(1) + (2) + (3)	• •		or	L/s	233	
		(2,000 L/min < Fire Flow < 45,000 L/min)		or	USGPM	3,699	
		Poquired Duration of Fire Flow (bours)			Houro	2	
7	Storage Volume					ى مەرمە	
		Required Volume of Fire Flow (m <sup>°</sup> )	m~	2520			

As per 1999 Fire Underwriter's Survey Guidelines

Novatech Project #: 117089 Project Name: Block 135 Date: 3/22/2019 Input By: Lucas Wilson Reviewed By: Project Manager



Engineers, Planners & Landscape Architects

Legend

Input by User No Information or Input Required

Building Description: Back-2-Back Towns (Bldg 5 + 6)

			lanut			Total Fire		
Step			Input		Value Used	Flow		
						(L/min)		
Base Fire Flow								
	Construction Ma	terial		Mult	iplier			
	Coefficient	Wood frame	Yes	1.5				
1	related to type	Ordinary construction		1				
	of construction	Non-combustible construction		0.8	1.5			
	С	Modified Fire resistive construction (2 hrs)		0.6				
	-	Fire resistive construction (> 3 hrs)		0.6				
	Floor Area							
		Building Footprint (m <sup>2</sup> )	600					
•	Α	Number of Floors/Storeys	3					
2		Area of structure considered (m <sup>2</sup> )			1,800			
	F	Base fire flow without reductions				14 000		
	•	$F = 220 C (A)^{0.5}$				14,000		
Reductions or Surcharges								
	Occupancy haza	rd reduction or surcharge		Reduction	Surcharge			
		Non-combustible		-25%				
3		Limited combustible	Yes	-15%				
Ů	(1)	Combustible		0%	-15%	11,900		
		Free burning		15%		,		
		Rapid burning		25%				
	Sprinkler Reduct	ion		Redu	ction			
		Adequately Designed System (NFPA 13)		-30%				
4	(2)	Standard Water Supply		-10%		0		
	(2)	Fully Supervised System		-10%		U		
			Cum	ulative Total	0%			
	Exposure Surcha	arge (cumulative %)			Surcharge			
	-	North Side	20.1 - 30 m		10%			
-		East Side	20.1 - 30 m		10%			
Э	(3)	South Side	20.1 - 30 m		10%	3,570		
		West Side	> 45.1m		0%			
			Cum	ulative Total	30%			
		Results						
		Total Required Fire Flow, rounded to nea	rest 1000L/mir	า	L/min	15.000		
6	(1) + (2) + (3)	· · · · · · · · · · · · · · · · · · ·		or		250		
		(2,000 L/min < Fire Flow < 45,000 L/min)		or	USGPM	3,963		
						· · · · · · · · · · · · · · · · · · ·		
7	Storage Volume	Required Duration of Fire Flow (hours)			Hours	3		
, otorage volume		Required Volume of Fire Flow (m <sup>3</sup> )	m <sup>3</sup>	2700				

As per 1999 Fire Underwriter's Survey Guidelines

Novatech Project #: 117089 Project Name: Block 135 Date: 3/22/2019 Input By: Lucas Wilson Reviewed By: Project Manager



Engineers, Planners & Landscape Architects

Legend

Input by User No Information or Input Required

Building Description: Back-2-Back Towns (Bldg 5)

						Total Fire		
Step			Input		Value Used	Flow		
						(L/min)		
Base Fire Flow								
	Construction Ma	terial		Mult	iplier			
	Coefficient	Wood frame	Yes	1.5				
1	related to type	Ordinary construction		1				
	of construction	Non-combustible construction		0.8	1.5			
	С	Modified Fire resistive construction (2 hrs)		0.6				
		Fire resistive construction (> 3 hrs)		0.6				
	Floor Area							
		Building Footprint (m <sup>2</sup> )	325					
	Α	Number of Floors/Storeys	3					
2		Area of structure considered (m <sup>2</sup> )			975			
	F	Base fire flow without reductions				10 000		
	•	$F = 220 C (A)^{0.5}$				10,000		
Reductions or Surcharges								
	Occupancy haza	rd reduction or surcharge		Reduction	/Surcharge			
		Non-combustible		-25%				
3		Limited combustible	Yes	-15%				
-	(1)	Combustible		0%	-15%	8,500		
		Free burning		15%				
		Rapid burning		25%				
	Sprinkler Reduct	ion		Redu	ction			
		Adequately Designed System (NFPA 13)		-30%				
4	(2)	Standard Water Supply		-10%		0		
	(2)	Fully Supervised System		-10%		U		
			Cum	ulative Total	0%			
	Exposure Surcha	arge (cumulative %)			Surcharge			
		North Side	10.1 - 20 m		15%			
F		East Side	0 - 3 m		25%			
5	(3)	South Side	30.1- 45 m		5%	3,825		
		West Side	> 45.1m		0%			
	Cum				45%			
		Results						
		Total Required Fire Flow, rounded to near	est 1000L/mir	ı	L/min	12,000		
6	(1) + (2) + (3)			or	L/s	200		
		(2,000 L/MIN < FIRE FIOW < 45,000 L/MIN)		or	USGPM	3,170		
		Required Duration of Fire Flow (hours)			Hours	2.5		
7	Storage Volume	Required Volume of Fire Flow (m <sup>3</sup> )			m <sup>3</sup>	1800		
						1000		

As per 1999 Fire Underwriter's Survey Guidelines

Novatech Project #: 117089 Project Name: Block 135 Date: 3/22/2019 Input By: Lucas Wilson Reviewed By: Project Manager



Engineers, Planners & Landscape Architects

Legend

Input by User No Information or Input Required

Building Description: Back-2-Back Towns (Bldg 6)

Cton			luurut		Volue Heed	Total Fire
Step			Input		value Used	FIOW
						(Ľ/ШП)
		Base Fire Flov	N			
	Construction Ma	terial		Mult	iplier	
	Coefficient	Wood frame	Yes	1.5		
1	related to type	Ordinary construction		1		
	of construction	Non-combustible construction		0.8	1.5	
	С	Modified Fire resistive construction (2 hrs)		0.6		
	-	Fire resistive construction (> 3 hrs)		0.6		
	Floor Area					
		Building Footprint (m <sup>2</sup> )	425			
-	Α	Number of Floors/Storeys	3			
2		Area of structure considered (m <sup>2</sup> )			1,275	
	F	Base fire flow without reductions				12 000
	•	$F = 220 C (A)^{0.5}$				12,000
Reductions or Surcharges						
	Occupancy haza	rd reduction or surcharge		Reduction	/Surcharge	
	3	Non-combustible		-25%		
3		Limited combustible	Yes	-15%		
-	(1)	Combustible		0%	-15%	10,200
		Free burning		15%		
		Rapid burning		25%		
	Sprinkler Reduct	tion		Redu	iction	
		Adequately Designed System (NFPA 13)		-30%		
4	(2)	Standard Water Supply		-10%		0
	(2)	Fully Supervised System		-10%		U
			Cum	ulative Total	0%	
	Exposure Surch	arge (cumulative %)			Surcharge	
	-	North Side	20.1 - 30 m		10%	
-		East Side	10.1 - 20 m		15%	
Э	(3)	South Side	30.1- 45 m		5%	5,100
		West Side	3.1 - 10 m		20%	
			Cum	ulative Total	50%	
		Results				
		Total Required Fire Flow, rounded to near	rest 1000L/mir	1	L/min	15.000
6	(1) + (2) + (3)	· · · · · · · · · · · · · · · · · · ·		or	l/s	250
		(2,000 L/min < Fire Flow < 45,000 L/min)		or	USGPM	3,963
		Poquired Duration of Fire Flow (hours)			Hours	2
7	Storage Volume					ა 0700
. ctorage relation		Required Volume of Fire Flow (m <sup>3</sup> )	m	2700		



#### APPENDIX B

SWM Calculations



		ICD Size & Inlet Rate						
Structure	tructure Diameter 1		Calculated 5-yr Capture Rate	5-yr Capture Rate**	Flow**			
	(1111)	(111)		(L/S)	(L/S)			
CB50	108	1.35	29.19	28.80	30.05			
CB51	152	1.32	57.34	50.56	51.18			
CB52	83	1.36	17.32	13.44	14.64			
CB53	152	1.32	57.34	44.88	45.32			
CB54	83	1.36	17.32	8.44	9.01			
CB55	178	1.31	78.25	78.47	79.76			
CB56	152	1.32	57.34	22.45	41.11			
CB57	127	1.34	40.22	32.38	33.14			

\*Diameter 2 only specified where catchbasins are not interconnected

\*\*From PCSWMM Model, 5-year 4-hour Chicago storm distribution

#### Fernbank Crossing - Block 135 ICD Rating Curves





#### Fernbank Crossing - Block 135 Catchbasin (On-Grade) with ICD Curves





#### Curb Inlet Catchbasins on Continuous Grade

Depth vs. Captured Flow Curve

A standard depth vs. captured flow curve for catch basins on a continuous grade was provided to Novatech by City staff for use in a dual-drainage model of an existing residential neighbourhood. This standard curve was derived using the inlet curves in Appendix 7A of the Ottawa Sewer Design Guidelines.

Novatech reviewed the methodology used to create this standard curve (described below) and determined that it was suitable for general use in other dual-drainage models.

- MTO Design Chart 4.04 provides the relationship between the gutter flow rate (Qt) and flow spread (T) for Barrier Curb.

- MTO Design Chart 4.12 provides the relationship between flow spread (T) and flow depth (D).

- The relationship between the gutter flow rate ( $Q_1$ ) and flow depth (D) was determined for different road slopes using the above charts and Manning's equation (refer to pages 58-60 of the MTO Drainage Management Manual – Part 2);

- The relationship between approach flow ( $Q_t$ ) and captured flow ( $Q_c$ ) was determined for different road slopes using the design chart for Barrier Curb with Gutter (Appendix 7-A.2).

- Using the above information, a family of curves was developed to characterize the relationship between flow depth and captured flow for curb inlet catchbasins on different road slopes. The results of this exercise can be summarized as follows:

- For a given flow depth, the gutter flow rate  $(Q_t)$  increases as the road slope increases.

- The capture efficiency  $({\rm Q}_{\rm c})$  of curb inlet catchbasins decrease as the road slope increases.

- The net result is that the relationship between flow depth and capture rate is largely independent of road slope: While approach flow vs. captured flow ( $Q_t$  vs.  $Q_c$ ) varies significantly with road grade, flow depth vs. captured flow (D vs.  $Q_c$ ) does not.

Since there was very little difference in the flow depth vs. captured flow curves for different road slopes, this family of curves was averaged to create a single standard curve for use in dual-drainage models.

Inlet Control Devices

The standard depth vs. capture flow curve was modified to account for the installation of ICDs in curb inlet catchbasins on continuous grade. Separate inlet curves were created for each standard ICD orifice size by capping the inlet rate on the depth vs. capture flow curve at the maximum flow rate through the ICD at a head of 1.2m (depth from centerline of CB lead to top of CICB frame).

#### Fernbank Crossing - Block 135 HGL Elevations

Manhole ID	MH Invert Elevation	T/G Elevation	HGL Elevation - 100yr4hr	HGL Elevation - 100yr4hr+20%	Design USF	Clearance (100yr)	Clearance (100yr+20%)
	(m)	(m)	(m)	(m)	(m)	(m)	(m)
HGL - Block 135							
MH01	101.42	104.53	102.10	102.11	103.72	1.62	1.61
MH03	101.81	104.96	102.25	102.25	103.57	1.32	1.32
MH05	102.19	105.11	102.13	102.14	103.57	1.44	1.43
MH07	101.60	104.55	102.30	102.30	103.57	1.27	1.27
MH09	101.99	104.88	102.67	102.70	103.77	1.10	1.07
MH11	101.79	104.58	102.77	102.81	104.13	1.36	1.32
MH13	102.13	104.78	102.78	102.82	104.13	1.35	1.31
MH15	101.77	104.70	102.88	102.91	104.13	1.25	1.22
HGL - Phase 3							
343	98.71	103.09	100.62	100.76	101.36	0.74	0.60
345	101.15	104.26	101.47	101.47	102.24	0.77	0.77
347	98.78	103.46	101.08	101.24	101.68	0.60	0.44
349	100.46	104.47	101.38	101.55	102.47	1.09	0.92
351	99.23	104.05	101.33	101.48	102.05	0.72	0.57
353	101.12	104.86	101.47	101.63	102.71	1.24	1.08
357	101.60	104.65	102.28	102.31	102.85	0.57	0.54
359	102.24	105.24	102.80	102.57	103.25	0.45	0.68
373	101.88	104.40	101.92	101.99	102.75	0.83	0.76
375	101.22	104.76	102.17	102.22	103.04	0.87	0.82
377	101.37	104.98	102.30	102.34	103.17	0.87	0.83
379	101.66	104.99	102.49	102.53	103.07	0.58	0.54
381	101.80	105.14	102.60	102.63	103.18	0.58	0.55
383	102.06	105.23	102.85	102.87	103.61	0.76	0.74
385	102.08	105.26	102.92	102.94	103.61	0.69	0.67
387	102.19	105.17	103.02	103.05	103.44	0.42	0.39
389	102.87	105.46	103.16	103.17	103.64	0.48	0.47
391	100.71	103.19	102.44	102.46	-	-	-
393	101.13	103.91	101.47	101.47	101.88	0.41	0.41
395	98.90	103.18	100.76	100.90	101.44	0.68	0.54
397	100.09	103.94	101.39	101.55	102.05	0.66	0.50
399	100.71	104.22	101.46	101.63	102.34	0.88	0.71
417	99.89	103.87	101.40	101.56	102.12	0.72	0.56
419	102.04	104.86	102.77	102.79	103.30	0.53	0.51



#### Fernbank Crossing - Block 135 HGL Elevations

Manhole ID	MH Invert Elevation	T/G Elevation	HGL Elevation - 100yr4hr	HGL Elevation - 100yr4hr+20%	Design USF	Clearance (100yr)	Clearance (100yr+20%)
	(m)	(m)	(m)	(m)	(m)	(m)	(m)
HGL - Cope Drive	e						
301	96.94	101.51	98.90	98.95	99.86	0.96	0.91
335	96.66	101.86	99.27	99.34	100.05	0.78	0.71
337	96.79	102.14	99.54	99.62	100.30	0.76	0.68
339	96.90	102.43	99.77	99.87	100.55	0.78	0.68
341	97.32	102.85	100.20	100.32	101.23	1.03	0.91
361	99.03	103.65	101.01	101.18	101.87	0.86	0.69
363	100.40	104.46	101.62	101.74	102.41	0.79	0.67
365	101.02	104.46	101.95	101.97	102.50	0.55	0.53
367	101.34	104.59	102.08	102.09	102.67	0.59	0.58
369	101.59	104.55	102.18	102.19	102.77	0.59	0.58
371	102.04	104.86	102.54	102.54	102.95	0.41	0.41
391	100.71	104.40	102.44	102.46	-	-	-
M97	96.25	101.00	98.47	98.49	99.86	1.39	1.37
M98	95.80	100.75	98.16	98.17	99.86	1.70	1.69



#### Fernbank Crossing - Block 135 Ponding in Road Calculations

Chrusting	T/G	Max. Stati (Spill I	c Ponding Depth)		2-yr	Event (4hr)			5-yr	Event (4hr)			100-у	r Event (4hr)			100-yr Ev	ent (+20%) (4	nr)
Structure		Elev.	Depth	Elev.	Depth	Cascading	Cascade	Elev.	Depth	Cascading	Cascade	Elev.	Depth	Cascading	Cascade	Elev.	Depth	Cascading	Cascade
	(m)	(m)	(m)	(m)	(m)	Flow?	Depth (m)	(m)	(m)	Flow?	Depth (m)	(m)	(m)	Flow?	Depth (m)	(m)	(m)	Flow?	Depth (m)
CB50	104.75	104.88	0.13	104.04	0.00	N	0.00	104.71	0.00	N	0.00	104.89	0.14	Y	0.01	104.90	0.15	Y	0.02
CB51	104.40	104.50	0.10	103.60	0.00	N	0.00	104.10	0.00	N	0.00	104.51	0.11	Y	0.01	104.54	0.14	Y	0.04
CB52	104.44	104.65	0.21	103.45	0.00	N	0.00	103.90	0.00	N	0.00	104.58	0.14	Ν	0.00	104.62	0.18	N	0.00
CB53	104.49	104.65	0.16	103.58	0.00	N	0.00	104.52	0.03	N	0.00	104.59	0.10	N	0.00	104.62	0.13	N	0.00
CB54	104.64	104.79	0.15	103.41	0.00	N	0.00	103.60	0.00	N	0.00	104.78	0.14	N	0.00	104.83	0.19	Y	0.04
CB55	104.64	104.79	0.15	103.99	0.00	N	0.00	104.65	0.01	N	0.00	104.78	0.14	N	0.00	104.83	0.19	Y	0.04
CB57	105.20	105.34	0.14	104.28	0.00	N	0.00	104.73	0.00	N	0.00	105.31	0.11	N	0.00	105.35	0.15	Y	0.01



Engineers, Planners & Landscape Architects

#### Fernbank Crossing - Block 135 Roadway Cross-Sections



Mountable Cu Distance	urb and Gutter Elevation
0	0.18
0.99	0.15
1	0.07
8	0
8.01	0.08
9	0.11



Mountable Cu	urb and Gutter
Distance	Elevation
0	0.11
0.99	0.08
1	0
8	0.07
8.01	0.15
9	0.18





Mountable Cu Distance	urb and Gutter Elevation
0	0.17
0.99	0.14
1	0.06
4	0.12
10	0
10.01	0.08
11	0.11





Mountable Curb and Gutter					
Distance	Elevation				
0	0.17				
0.99	0.14				
1	0.06				
4	0.12				



Mountable Curb and Gutter						
Distance Elevatio						
0	0.12					
6	0					
6.01	0.08					
7	0.11					







Mountable Curb and Gutter							
Distance	Elevation						
0	0.11						
0.99	0.08						
1	0						
4.5	0.07						



Mountable Curb and Gutter						
Distance	Elevation					
0	0.07					
3.5	0					
3.51	0.08					
4.5	0.11					



#### Fernbank Crossing - Block 135 Roadway Cross-Sections



Mountable Curb and Gutter Distance Elevation							
0	0.11						
0.99	0.08						
1	0						
4.5	0.07						
8	0						
8.01	0.08						
9	0.11						



#### Fernbank Crossing - Block 135 Standalone Model Schematic - PCSWMM





## Legend

#### Junctions

- Visible
- Manholes
- Catchbasin
- Highpoint
- Outfalls

#### Conduits

- Visible
- Roadways
- Orifices
- Outlets
- Subcatchments
- Background







## STORAGE NODE

#### Fernbank Crossing - Block 135 Overall Model Schematic (SSA)





#### Fernbank Crossing - Block 135 Schematic 1 (SSA)





#### Fernbank Crossing - Block 135 Schematic 1 (SSA)





#### Fernbank Crossing - Block 135 Design Storm Time Series Data 4-hour Chicago Design Storms



C25mr	C25mm-4.stm C2-4.stm		C5-4	.stm	
Duration	Intensity	Duration	Intensity	Duration	Intensity
min	mm/hr	min	mm/hr	min	mm/hr
0:00	0	0:00	0	0:00	0
0:10	1.34	0:10	1.98	0:10	2.49
0:20	1.49	0:20	2.23	0:20	2.77
0:30	1.69	0:30	2.58	0:30	3.14
0:40	1.96	0:40	3.06	0:40	3.62
0:50	2.33	0:50	3.81	0:50	4.31
1:00	2.91	1:00	5.1	1:00	5.37
1:10	3.91	1:10	7.91	1:10	7.19
1:20	6.1	1:20	19.04	1:20	11.14
1:30	14.53	1:30	76.81	1:30	26.25
1:40	58.72	1:40	23.64	1:40	104.19
1:50	17.11	1:50	11.91	1:50	30.86
2:00	8.32	2:00	7.98	2:00	15.15
2:10	5.5	2:10	6.03	2:10	10.07
2:20	4.13	2:20	4.87	2:20	7.58
2:30	3.32	2:30	4.1	2:30	6.11
2:40	2.79	2:40	3.55	2:40	5.14
2:50	2.41	2:50	3.14	2:50	4.45
3:00	2.12	3:00	2.82	3:00	3.93
3:10	1.9	3:10	2.57	3:10	3.53
3:20	1.73	3:20	2.35	3:20	3.21
3:30	1.58	3:30	2.18	3:30	2.94
3:40	1.46	3:40	2.03	3:40	2.72
3:50	1.36	3:50	1.9	3:50	2.53
4:00	1.27	4:00	1.79	4:00	2.37

#### Fernbank Crossing - Block 135 Design Storm Time Series Data 4-hour Chicago Design Storms



C100-4.stm		C100-4+	C100-4+20%.stm			
Duration	Intensity	Duration	Intensity			
min	mm/hr	min	mm/hr			
0:00	0	0:00	0			
0:10	4.07	0:10	4.88			
0:20	4.54	0:20	5.45			
0:30	5.14	0:40	7.14			
0:40	5.95	0:50	8.51			
0:50	7.09	1:00	10.62			
1:00	8.85	1:10	14.28			
1:10	11.9	1:20	22.25			
1:20	18.54	1:30	53.03			
1:30	44.19	1:40	214.27			
1:40	178.56	1:50	62.45			
1:50	52.04	2:00	30.37			
2:00	25.31	2:10	20.08			
2:10	16.73	2:20	15.07			
2:20	12.56	2:30	12.11			
2:30	10.09	2:40	10.16			
2:40	8.47	2:50	8.78			
2:50	7.32	3:00	7.75			
3:00	6.46	3:10	6.95			
3:10	5.79	3:20	6.3			
3:20	5.25	3:30	5.78			
3:30	4.82	3:40	5.34			
3:40	4.45	3:50	4.97			
3:50	4.14	4:00	4.66			
4:00	3.88					

#### Fernbank Crossing - Block 135 Design Storm Time Series Data SCS Design Storms



S2-12	2.stm	S5-12	2.stm	S100-	12.stm
Duration	Intensity	Duration	Intensity	Duration	Intensity
min	mm/hr	min	mm/hr	min	mm/hr
0:00	0.00	0:00	0	0:00	0
0:30	1.27	0:30	1.69	0:30	2.82
1:00	0.59	1:00	0.79	1:00	1.31
1:30	1.10	1:30	1.46	1:30	2.44
2:00	1.10	2:00	1.46	2:00	2.44
2:30	1.44	2:30	1.91	2:30	3.19
3:00	1.27	3:00	1.69	3:00	2.82
3:30	1.69	3:30	2.25	3:30	3.76
4:00	1.69	4:00	2.25	4:00	3.76
4:30	2.29	4:30	3.03	4:30	5.07
5:00	2.88	5:00	3.82	5:00	6.39
5:30	4.57	5:30	6.07	5:30	10.14
6:00	36.24	6:00	48.08	6:00	80.38
6:30	9.23	6:30	12.25	6:30	20.47
7:00	4.06	7:00	5.39	7:00	9.01
7:30	2.71	7:30	3.59	7:30	6.01
8:00	2.37	8:00	3.15	8:00	5.26
8:30	1.86	8:30	2.47	8:30	4.13
9:00	1.95	9:00	2.58	9:00	4.32
9:30	1.27	9:30	1.69	9:30	2.82
10:00	1.02	10:00	1.35	10:00	2.25
10:30	1.44	10:30	1.91	10:30	3.19
11:00	0.93	11:00	1.24	11:00	2.07
11:30	0.85	11:30	1.12	11:30	1.88
12:00	0.85	12:00	1.12	12:00	1.88

#### Fernbank Crossing - Block 135 Design Storm Time Series Data SCS Design Storms



S2-24	4.stm	S5-2	4.stm	S100-3	24.stm
Duration	Intensity	Duration	Intensity	Duration	Intensity
min	mm/hr	min	mm/hr	min	mm/hr
0:00	0	0:00	0	0:00	0
1:00	0.72	1:00	0.44	1:00	0.6
2:00	0.34	2:00	0.44	2:00	0.75
3:00	0.63	3:00	0.81	3:00	1.39
4:00	0.63	4:00	0.81	4:00	1.39
5:00	0.81	5:00	1.06	5:00	1.81
6:00	0.72	6:00	0.94	6:00	1.6
7:00	0.96	7:00	1.25	7:00	2.13
8:00	0.96	8:00	1.25	8:00	2.13
9:00	1.3	9:00	1.68	9:00	2.88
10:00	1.63	10:00	2.12	10:00	3.63
11:00	2.59	11:00	3.37	11:00	5.76
12:00	20.55	12:00	26.71	12:00	45.69
13:00	5.23	13:00	6.8	13:00	11.64
14:00	2.3	14:00	2.99	14:00	5.12
15:00	1.54	15:00	2	15:00	3.42
16:00	1.34	16:00	1.75	16:00	2.99
17:00	1.06	17:00	1.37	17:00	2.35
18:00	1.11	18:00	1.44	18:00	2.46
19:00	0.72	19:00	0.94	19:00	1.6
20:00	0.58	20:00	0.75	20:00	1.28
21:00	0.81	21:00	1.06	21:00	1.81
22:00	0.53	22:00	0.68	22:00	1.17
23:00	0.48	23:00	0.63	23:00	1.07
0:00	0.48	0:00	0.63	0:00	1.07

#### **APPENDIX C: Drawings**

117089-GP 117089-GR 117089-STM 108180-19-SAN 108180-19-STM



STM MANHOLE TABLE							
MANHOLE ID	SIZE (mm)	T/G ELEV (m)	INVERT (m)	PIPE DIAMETER (mm)			
1	1500Ø	104.49	NE=101.72 S=101.87 NW=101.94	NE=600 S=450 NW=375			
3	1200Ø	104.56	SE=102.11 SW=103.24	SE=375 SW=200			
5	1200Ø	104.55	N=101.89 SE=101.96	N=450 SE=375			
7	1200Ø	104.53	NW=102.06 S=103.06 NE=102.95	NW=375 S=200 NE=200			
9	1200Ø	104.70	NE=102.07 SE=102.14 NW=103.16	NE=450 SE=375 NW=200			
11	1200Ø	105.04	NW=102.36 E=102.42	NW=375 E=375			
13	1200Ø	105.09	W=102.45 SE=102.51	W=375 SE=300			
15	1200Ø	105.41	NW=102.68 SW=103.73	NW=300 SW=200			

SAN MANHOLE TABLE						
MANHOLE ID	SIZE (mm)	T/G ELEV (m)	INVERT (m)	PIPE DIAMET (mm)		
2	1200Ø	104.49	NE=100.43 S=100.73 NW=100.73	NE=200 S=200 NW=200		
4	1200Ø	104.93	SE=101.28 SW=101.54	SE=200 SW=200		
6	1200Ø	105.16	NE=101.86	NE=200		
8	1200Ø	104.60	N=100.88 SW=101.16 SE=100.94	N=200 SW=200 SE=200		
10	1200Ø	105.00	NE=101.73	NE=200		
12	1200Ø	104.63	NW=101.58 SW=101.64	NW=200 SW=200		
14	1200Ø	104.90	NE=101.92	NE=200		
16	1200Ø	104.72	NE=100.85 SE=101.40 NW=101.40	NE=200 SE=200 NW=200		
18	1200Ø	104.76	SE=101.68 SW=101.70	SE=200 SW=200		
20	1200Ø	105.13	NE=102.01	NE=200		
22	1200Ø	105.00	NW=101.77 E=101.83 SW=101.83	NW=200 E=200 SW=200		
24	1200Ø	105.27	NE=102.15	NE=200		
26	1200Ø	105.22	W=101.90 SE=101.96	W=200 SE=200		
28	1200Ø	105.40	SW=102.21 NW=102.15	SW=200 NW=200		
30	1200Ø	105.59	NE=102.59	NE=200		

WA				WATERMAIN TABLE			WATERMAIN TABLE										
ROBERT GRANT AVENUE		F/G ELEVATION	TOP OF WATERMAIN	COVER	DESCRIPTION	Station	F/G ELEVATION	TOP OF WATERMAIN	COVER	DESCRIPTION	Station	F/G ELEVATION	TOP OF WATERMAIN	COVER	DESCRIPTION		
			1+000.00	104.48	102.08	2.40	CONNECT TO EXISTING	2+000.00	104.91	102.51	2.40	CONNECT TO EXISTING	5+000.00	104.76	102.36	2.40	200X150 TEE
1+025.00 104.48		104.48	102.08	2.40	-	2+001.07	104.89	102.49	2.40	45° HORIZONTAL BEND	5+025.00	104.85	102.45	2.40	-		
1+031.85 104.51		104.51	102.11	2.40	45° HORIZONTAL BEND	2+002.59	104.85	102.45	2.40	45° HORIZONTAL BEND	5+044.04	105.07	105.07	0.00	CAP AND THRUST BLOCK		
			1+040.19	104.63	102.23	2.40	45° HORIZONTAL BEND	2+004.59	104.82	102.42	2.40	HYD1					
			1+043.19	104.66	102.26	2.40	200X150 TEE	2+006.59	104.81	102.41	2.40	REDUCER					
			1+048.75	104.66	102.26	2.40	HYD2	2+025.00	104.98	102.58	2.40	-		,	WATERMA	IN TAB	l F
			1+050.00	104.65	102.25	2.40	-	2+034.09	105.15	102.75	2.40	CAP AND THRUST BLOCK		5/0			<b></b>
			1+075.00	104.55	102.15	2.40	-	-					Station	ELEVATION	WATERMAIN	COVER	DESCRIPTION
			1+081.90	104.62	102.22	2.40	200X150 TEE						6+000.00	104.76	102.36	2.40	200X150 TEE
SEW	ER CROSSIN	G TABLE	1+099.60	104.79	102.39	2.40	VB1		l l	WATERMA	N TAB	LE	6+012.31	104.95	102.55	2.40	45° HORIZONTAL BEND
			1+116.92	104.77	102.37	2.40	HYD3		5/0				6+015.09	104.87	102.47	2.40	22.5° VERTICAL BEND
LOCATION	ELEVATIONS	CLEARANCE	1+120.15	104.76	102.36	2.40	200X150 TEE	Station	ELEVATION	WATERMAIN	COVER	DESCRIPTION	6+016.67	104.87	103.12	1.75	22.5° VERTICAL BEND
C1	STM INV=101.72 SAN OBV=100.96	0.76m	1+122.76	104.74	102.34	2.40	11° HORIZONTAL BEND	3+000.00	104.66	102.26	2.40	200X150 TEE	6+018.17	104.88	103.12	1.76	45° HORIZONTAL BEND
C2	STM INV=101.97	0.58m	1+125.00	104.73	102.33	2.40	-	3+002.34	104.70	102.30	2.40	22.5° VERTICAL BEND	6+021.76	104.88	103.12	1.76	22.5° VERTICAL BEND
	SAN OBV=101.39	0.0011	1+136.43	104.74	102.34	2.40	22.5° VERTICAL BEND	3+003.50	104.70	102.79	1.91	22.5° VERTICAL BEND	6+023.32	104.88	102.48	2.40	22.5° VERTICAL BEND
C3	STM INV=102.07 SAN OBV=101.63	0.44m	1+138.12	104.77	103.04	1.73	22.5° VERTICAL BEND	3+006.06	104.65	102.79	1.86	45° HORIZONTAL BEND	6+025.00	104.88	102.48	2.40	-
C4	STM INV=102.35	0.31m	1+139.62	104.77	103.04	1.73	11° HORIZONTAL BEND	3+007.56	104.66	102.79	1.87	22.5° VERTICAL BEND	6+050.00	105.07	102.67	2.40	-
	0/11/02/01/02:04		1+141.92	104.75	103.04	1.71	22.5° VERTICAL BEND	3+008.83	104.66	102.26	2.40	22.5° VERTICAL BEND	6+061.37	105.24	102.84	2.40	CAP AND THRUST BLOCK
			1+143.61	104.74	102.34	2.40	22.5° VERTICAL BEND	3+011.74	104.65	102.25	2.40	45° HORIZONTAL BEND					
			1+145.17	104.76	102.36	2.40	200X150 TEE	3+025.00	104.77	102.37	2.40	-					
			1+150.00	104.78	102.38	2.40	-	3+042.92	105.03	102.63	2.40	CAP AND TRUST BLOCK			WATERMA	IN TAR	IF
			1+175.00	104.87	102.47	2.40	-					·					
			1+180.20	104.77	102.37	2.40	CONNECT TO EXISTING						Station	F/G ELEVATION	TOP OF WATERMAIN	COVER	DESCRIPTION
										WATERMA	IN TAB	IF	7+000.00	105.30	102.90	2.40	200x150 TEE
	CATC	HRASIN TARI	F										7+012.00	105.37	102.97	2.40	W3

	CATCHBASIN TABLE									
CB No.	T/G ELEVATION	INVERT	ICD DIA.	ICD TYPE	ICD RELEASE RATE (L/s)					
50	104.75	103.35	108mm	ORIFICE	28.80					
51	104.40	103.00	152mm	ORIFICE	50.56					
52	104.44	103.04	83mm	ORIFICE	13.44					
53	104.49	103.09	152mm	ORIFICE	44.88					
54	104.64	103.24	83mm	ORIFICE	8.44					
55	104.64	103.24	178mm	ORIFICE	78.47					
56	104.83	103.43	152mm	ORIFICE	22.45					
57	105.20	103.80	127mm	ORIFICE	32.38					

NOTE THE POSITION OF ALL POLE LINES, CONDUITS,

WATERMAINS, SEWERS AND OTHER UNDERGROUND AND OVERGROUND UTILITIES AND

STRUCTURES IS NOT NECESSARILY SHOWN ON

THE CONTRACT DRAWINGS, AND WHERE SHOWN,

THE ACCURACY OF THE POSITION OF SUCH

UTILITIES AND STRUCTURES IS NOT GUARANTEED. BEFORE STARTING WORK, DETERMINE THE EXACT

LOCATION OF ALL SUCH UTILITIES AND

STRUCTURES AND ASSUME ALL LIABILITY FOR DAMAGE TO THEM.

WATERMAIN TABLE						
Station	F/G ELEVATION	TOP OF WATERMAIN	COVER	DESCRIPTION		
4+000.00	104.62	102.22	2.40	200X150 TEE		
4+025.00	104.71	102.31	2.40	-		
4+041.20	104.92	102.52	2.40	CAP AND THRUST BLOCK		

WATERMAIN TABLE						
Station   F/G ELEVATION   TOP OF WATERMAIN   COVER   DESCRIPTION						
7+000.00	105.30	102.90	2.40	200x150 TEE		
7+012.00	105.37	102.97	2.40	W3		
7+013.85	105.33	102.93	2.40	45° HORIZONTAL BEND		
7+016.85	105.31	102.91	2.40	45° HORIZONTAL BEND		
7+024.91	105.28	102.88	2.40	HYD4		
7+026.91	105.30	102.90	2.40	REDUCER		
7+050.00	105.45	103.05	2.40	-		
7+062.94	105.70	103.30	2.40	CAP AND THRUST BLOCK		

				SCALE	DESIGN	FOR REVI	EW ONLY		
				1:400		PROFESSIONAL	PROFESSIONAL	ΝΟΛΤΞΟΗ	FERNBANK CR
					DRAWN DTD	L. R. WILSON 100160065	MA. BISSETT EF	Engineers, Planners & Landscape Architects Suite 200, 240 Michael Cowpland Drive Ottawa, Ontario, Canada K2M 1P6	
2.	REVISED PER CITY COMMENTS	JUN 12/19	MAB	1:400 0 4 8 12 16	CHECKED MAB		Boundary Contraction	Telephone   (613) 254-9643     Facsimile   (613) 254-5867	GENERAL PL
1.	SITE PLAN SUBMISSION	MAR 22/19	MAB			CE OF ON	ACE OF ON	website www.novatech-eng.com	

SANITARY SEWER	WATERMAIN CURB FACE	DRIVEWAY		SERVICES PER SC11.3 (TYP.)	CURB		
		DRIVEWAY			19mm D COPPEI SERVIC	IA. TYPE 'K' R WATER E DRIVEWAY	
		CURB STOP		135mm DIA. PVC SDR 28 SANITARY SERVICE (TYP.) AT 1.0% (MIN)		DRIVEWAY	
			SERVIC				

BACK TO BACK TOWNHOUSE (SLAB ON GRADE)



# ĦD BLOCK 135-KEY PLAN

# LEGEND

	SANITARY MANHOLE, SEWER & DIRECTION OF FLOW	нүр - <b>∲—⊗—</b>	HYDRANT C/W VAL
	STORM MANHOLE, SEWER & DIRECTION OF FLOW	æ	CAP AND THRUST
<u>30</u> 0mmØ	WATERMAIN AND DIAMETER	►	REDUCER
<sup>∨B</sup> ⊗	VALVE & VALVE BOX	95	ROAD CATCHBASII
W3 ම	GATE VALVE CHAMBER PER W3	96	ROAD CATCHBASII
- <u>87</u> T	T-CONNECTION AND THRUST BLOCK	•	SINGLE SERVICE L
-124-	11.25° BEND AND THRUST BLOCK	$\bigtriangledown$	DOUBLE SERVICE
-	22.5° BEND AND THRUST BLOCK		

45° BEND AND THRUST BLOCK

# GENERAL NOTES:

- 1. DIMENSIONS AND LAYOUT INFORMATION SHALL BE CONFIRMED PRIOR TO COMMENCEMENT OF CONSTRUCTION. 2. THE ORIGINAL TOPOGRAPHY AND GROUND ELEVATIONS, SERVICING AND SURVEY INFORMATION SHOWN ON THIS PLAN ARE SUPPLIED FOR INFORMATION PURPOSES ONLY. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO VERIFY THE ACCURACY OF ALL INFORMATION OBTAINED FROM THIS PLAN.
- 3. CO-ORDINATE AND SCHEDULE ALL WORK WITH OTHER TRADES AND CONTRACTORS.
- 4. BEFORE COMMENCING CONSTRUCTION, PROVIDE PROOF OF COMPREHENSIVE ALL RISK AND OPERATIONAL LIABILITY INSURANCE INCLUDING BLASTING. INSURANCE POLICY TO NAME THE OWNER, ENGINEER AND THE CITY AS CO-INSURED. 5. CONNECT TO EXISTING SYSTEMS AS DETAILED, INCLUDING ALL RESTORATION WORK NECESSARY TO REINSTATE SURFACES TO
- EXISTING CONDITIONS OR BETTER. 6. DETERMINE THE EXACT LOCATION, SIZE, MATERIAL AND ELEVATION OF ALL EXISTING UTILITIES PRIOR TO COMMENCING CONSTRUCTION. PROTECT AND ASSUME RESPONSIBILITY FOR ALL EXISTING UTILITIES WHETHER OR NOT SHOWN ON THESE
- DRAWINGS. 7. OBTAIN AND PAY FOR ALL NECESSARY PERMITS AND APPROVALS BEFORE COMMENCING CONSTRUCTION.
- 8. RESTORE ALL TRENCHES AND SURFACE FEATURES TO EXISTING CONDITIONS OR BETTER AND TO THE SATISFACTION OF MUNICIPAL AUTHORITIES.
- 9. REMOVE FROM SITE ALL EXCESS EXCAVATED MATERIAL UNLESS OTHERWISE INSTRUCTED BY THE ENGINEER. EXCAVATE AND REMOVE FROM SITE ALL ORGANIC MATERIAL AND DEBRIS UNLESS OTHERWISE INSTRUCTED BY THE ENGINEER. 10. ALL ELEVATIONS ARE GEODETIC AND UTILIZE METRIC UNITS.
- 11. REFER TO GEOTECHNICAL INVESTIGATION PROJECT: 64153.74 (MARCH 20, 2019), PREPARED BY GEMTEC FOR SUBSURFACE
- CONDITIONS AND CONSTRUCTION RECOMMENDATIONS. 12. PERFORATED PIPE SUB-DRAINS TO BE PROVIDED AT SUBGRADE LEVEL EXTENDING FROM THE ROADSIDE CATCHBASIN FOR A DISTANCE OF 3.0m, PARALLEL TO THE CURB IN TWO DIRECTIONS.

# SEWER NOTES:

۱.	SPECIFICATIONS:		
	ITEM	SPEC. No.	REFERENCE
	CATCHBASIN (600x600mm)	705.010	OPSD
	STORM / SANITARY MANHOLE (1200Ø)	701.010	OPSD
	ROADSIDE CB, FRAME & COVER	S2 & S19	CITY of OTTAWA
	STORM / SANITARY MH FRAME & COVER	S24.1 / S24 & S25	CITY of OTTAWA
	STORM SEWER	PVC DR 35 OR CONC.	(CLASS SPECIFIED ON PROFILE
	SANITARY SEWER	PVC DR 35	
	CATCHBASIN LEAD	PVC DR 35	

- CLEARANCE BETWEEN PIPE AND INSULATION.
- 3. SERVICES ARE TO BE CONSTRUCTED TO PROPERTY LINE AT MINIMUM SLOPE OF 1.0% (2.0% IS PREFERRED).
- DENSITY. THE USE OF CLEAR CRUSHED STONE AS A BEDDING LAYER SHALL NOT BE PERMITTED.
- 5. SEWER SERVICE CONNECTIONS PER CITY OF OTTAWA DETAILS S11 AND S11.1. 6. THE SITE SERVICING CONTRACTOR SHALL PERFORM FIELD TESTS FOR QUALITY CONTROL OF ALL SANITARY SEWERS. LEAKAGE TESTING SHALL BE COMPLETED IN ACCORDANCE WITH OPSS 410.07.16 AND 407.07.24. DYE TESTING IS TO BE COMPLETED ON ALL SANITARY SERVICES TO CONFIRM PROPER CONNECTION TO THE SANITARY SEWER MAIN. THE FIELD TESTS SHALL BE PERFORMED IN THE PRESENCE OF THE ENGINEER.
- 7. STORM MANHOLES AND CBMHS SHALL HAVE 300mm SUMPS UNLESS OTHERWISE INDICATED. 8. CONTRACTOR TO TELEVISE (CCTV) ALL PROPOSED SEWERS, 200mmØ OR GREATER PRIOR TO CONNECTING THE PROPOSED SEWERS. UPON COMPLETION OF CONTRACT, THE CONTRACTOR IS RESPONSIBLE TO FLUSH AND CLEAN ALL SEWERS & APPURTENANCES.

# WATERMAIN NOTES

1.	GENERAL:		
	ITEM	DETAIL. No.	REFERENCE
	WATERMAIN TRENCHING	W17	CITY OF OTTAW
	THERMAL INSULATION IN SHALLOW TRENCHES	W22	CITY OF OTTAW
	WATERMAIN CROSSING BELOW SEWER / OVER SEWER	W25 / W25.2	CITY OF OTTAW
S			

- MAIN SHALL BE PVC DR 18 IN ACCORDANCE WITH MATERIAL SPECIFICATION MW-18.1, UNLESS OTHERWISE INDICATED, COMPLETE WITH TRACING WIRE AND CATHODIC PROTECTION.
- AND SPECIFICATIONS. EXCAVATION, INSTALLATION, BACKFILL AND RESTORATION OF ALL WATERMAINS BY THE CONTRACTOR. CONNECTIONS AND SHUT-OFFS AT THE MAIN AND CHLORINATION OF THE WATER SYSTEM SHALL BE PERFORMED BY CITY
- OFFICIALS. 4. WATERMAIN SHALL BE MINIMUM 2.4m DEPTH BELOW GRADE UNLESS OTHERWISE INDICATED.
- 5. PROVIDE MINIMUM 0.25m CLEARANCE BETWEEN OUTSIDE OF PIPES AT ALL CROSSINGS.
- 6. WATER LATERAL AND SERVICE POST IS TO BE CONSTRUCTED 1.0m FROM BACK OF CURB.



LAN OF SERVICES




S				
1				
0 3	MAB	JUN 12/19	REVISED PER CITY COMMENTS	2.
	MAB	MAR 22/19	SITE PLAN SUBMISSION	1.
	BY	DATE	REVISION	No.







100 YEAR PONDING						
PONDING ID	STRUCTURE	MAX PONDING DEPTH (m)	MAX PONDING ELEVATION (m)			
P1	189-190	0.16	105.70			
P2	191-192	0.07	105.58			
P3	192-193	0.13	104.50			
P4	195	0.11	103.93			
1	00 YEAR P	ONDING + 2	20%			
1 PONDING ID	00 YEAR P	ONDING + 2 MAX PONDING DEPTH (m)	20% MAX PONDING ELEVATION (m)			
1 PONDING ID P1	00 YEAR P STRUCTURE 189-190	ONDING + 2 MAX PONDING DEPTH (m) 0.17	MAX PONDING ELEVATION (m) 105.71			
1 PONDING ID P1 P2	00 YEAR P STRUCTURE 189-190 191-192	ONDING + 2 MAX PONDING DEPTH (m) 0.17 0.17	MAX PONDING ELEVATION (m) 105.71 105.68			
1 PONDING ID P1 P2 P3	00 YEAR P STRUCTURE 189-190 191-192 193-194	ONDING + 2 MAX PONDING DEPTH (m) 0.17 0.17 0.19	20% MAX PONDING ELEVATION (m) 105.71 105.68 104.56			

	REAR YARD PONDING						
PONDING ID	STRUCTURE	MAX 100 YEAR PONDING DEPTH (m)	MAX 100 YEAR PONDING ELEVATION (m)	MAX 100 YEAR +20% PONDING DEPTH (m)	MAX 100 YEAR + 20% PONDING ELEVATION (m)		
P5	LCB31	0.30	105.92	0.30	105.92		
P6	LCB30	0.30	105.83	0.30	105.83		
P7	RYCB11	0.30	105.44	0.30	105.44		
P8	LCB25	0.30	105.12	0.30	105.12		
P9	LCB34	0.20	104.47	0.20	104.47		
P10	LCB35	0.20	104.36	0.20	104.36		

Appendix D:

DSS Checklist RVCA Clearance

4.1 General Content	Addressed (Y/N/NA)	Comments
Executive Summary (for larger reports only).	N/A	
Date and revision number of the report.	Y	
Location map and plan showing municipal address,	Y	Refer to Report Figures
Plan showing the site and location of all existing services	v	Pofor to Grading and Sonvicing Plans
Development statistics land use density adherance to	1	Refer to Grading and Servicing Flans
zoning and official plan, and reference to applicable		
subwatershed and watershed plans that provide context	Y	Refer to Site Plan
to which individual developments must adhere.		
Summary of Pre-consultation Meetings with City and	v	
other approval agencies.	T	
Reference and confirm conformance to higher level		
studies and reports (Master Servicing Studies,		
Environmental Assessments, Community Design Plans),	Y	
or in the case where it is not in conformance, the		
proponent must provide justification and develop a		
defendable design criteria.		
Statement of objectives and servicing criteria.	Y	Refer to Sections: 5.0 Sanitary Sewers, 6.0 Stormwater
Identification of existing and proposed infrastructure	V	Management, 7.0 Water
available in the immediate area.	Ŷ	
Identification of Environmentally Significant Areas,		
watercourses and Municipal Drains potentially impacted		
by the proposed development (Reference can be made	N/A	
to the Natural Heritage Studies, if available).		
Concept level master grading plan to confirm existing		
and proposed grades in the development. This is		
required to confirm the feasibility of proposed		
stormwater management and drainage, soil removal and	v	Refer to Grading Plan and Stormwater Management
fill constraints, and potential impacts to neighboring	T	Plan
properties. This is also required to confirm that the		
proposed grading will not impede existing major system		
flow paths.		

4.1 General Content	Addressed (Y/N/NA)	Comments
Identification of potential impacts of proposed piped		
services on private services (such as wells and septic	NI/A	
fields on adjacent lands) and mitigation required to	N/A	
address potential impacts.		
Proposed phasing of the development, if applicable.	N/A	
Reference to geotechnical studies and recommendations	v	Pofor to Soction 2.0 Grading
concerning servicing.	T	
All preliminary and formal site plan submissions should		
have the following information:		
Metric scale	Y	
North arrow (including construction	Y	
Key plan	Y	
Name and contact information of applicant and property owner	Y	
Property limits including bearings and dimensions	Y	
Existing and proposed structures and parking areas	Y	
Easements, road widening and rights-of-	Y	
Adjacent street names	Y	

4.2 Water	Addressed (Y/N/NA)	Comments
Confirm consistency with Master Servicing Study, if available.	Y	
Availability of public infrastructure to service proposed development.	Y	Refer to Sections: 5.0 Sanitary Sewers, 6.0 Stormwater
Identification of system constraints.	N/A	Management, 7.0 Water
Identify boundary conditions.	Y	Provided by City of Ottawa
Confirmation of adequate domestic supply and pressure.	Y	Refer to Appendix A
Confirmation of adequate fire flow protection and confirmation that fire flow is calculated as per the Fire Underwriter's Survey. Output should show available fire flow at locations throughout the development.	Y	Refer to Appendix A
Provide a check of high pressures. If pressure is found to be high, an assessment is required to confirm the application of pressure reducing valves.	Y	Refer to Appendix A
Definition of phasing constraints. Hydraulic modeling is required to confirm servicing for all defined phases of the project including the ultimate design.	N/A	
Address reliability requirements such as appropriate location of shut-off valves.	Y	
Check on the necessity of a pressure zone boundary modification.	N/A	
Reference to water supply analysis to show that major infrastructure is capable of delivering sufficient water for the proposed land use. This includes data that shows that the expected demands under average day, peak hour and fire flow conditions provide water within the required pressure range.	Y	Refer to Section 7.0 Water
Description of the proposed water distribution network, including locations of proposed connections to the existing system, provisions for necessary looping, and appurtenances (valves, pressure reducing valves, valve chambers, and fire hydrants) including special metering provisions.	Y	Refer to Section 7.0 Water
Description of off-site required feedermains, booster pumping stations, and other water infrastructure that will be ultimately required to service proposed development, including financing, interim facilities, and timing of implementation.	N/A	
Confirmation that water demands are calculated based on the City of Ottawa Design Guidelines.	Y	Refer to Section 7.0 Water
Provision of a model schematic showing the boundary conditions locations, streets, parcels, and building locations for reference.	N/A	

4.3 Wastewater	Addressed (Y/N/NA)	Comments
Summary of proposed design criteria (Note: Wet- weather flow criteria should not deviate from the City of Ottawa Sewer Design Guidelines. Monitored flow data from relatively new infrastructure cannot be used to justify capacity requirements for proposed infrastructure).	Y	Refer to Section 5.0 Sanitary Sewers
Confirm consistency with Master Servicing Study and/or justifications for deviations.	N/A	
Consideration of local conditions that may contribute to extraneous flows that are higher than the recommended flows in the guidelines. This includes groundwater and soil conditions, and age and condition of sewers.	N/A	
Description of existing sanitary sewer available for discharge of wastewater from proposed development.	Y	Refer to Section 5.0 Sanitary Sewers
Verify available capacity in downstream sanitary sewer and/or identification of upgrades necessary to service the proposed development. (Reference can be made to previously completed Master Servicing Study if applicable)	У	Refer to Appendix A
Calculations related to dry-weather and wet-weather flow rates from the development in standard MOE sanitary sewer design table (Appendix 'C') format.	N/A	
Description of proposed sewer network including sewers, pumping stations, and forcemains.	Y	Refer to Section 5.0 Sanitary Sewers
Discussion of previously identified environmental constraints and impact on servicing (environmental constraints are related to limitations imposed on the development in order to preserve the physical condition of watercourses, vegetation, soil cover, as well as protecting against water quantity and quality).	N/A	
Pumping stations: impacts of proposed development on existing pumping stations or requirements for new pumping station to service development.	N/A	
Forcemain capacity in terms of operational redundancy, surge pressure and maximum flow velocity.	N/A	
Identification and implementation of the emergency overflow from sanitary pumping stations in relation to the hydraulic grade line to protect against basement flooding.	N/A	
Special considerations such as contamination, corrosive environment etc.	N/A	

4.4 Stormwater	Addressed (Y/N/NA)	Comments
Description of drainage outlets and downstream constraints including legality of outlet (i.e. municipal drain, right-of-way, watercourse, or private property).	Y	Refer to Section 6.0 Stormwater Management
Analysis of the available capacity in existing public infrastructure.	Y	Refer to Appendix A
A drawing showing the subject lands, its surroundings, the receiving watercourse, existing drainage patterns and proposed drainage patterns.	Y	Refer to Storm Drainage Area Plan (117089-STM)
Water quantity control objective (e.g. controlling post- development peak flows to pre-development level for storm events ranging from the 2 or 5 year event (dependent on the receiving sewer design) to 100 year return period); if other objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into account long-term cumulative effects.	Y	Refer to Section 6.0 Stormwater Management
Water Quality control objective (basic, normal or enhanced level of protection based on the sensitivities of the receiving watercourse) and storage requirements.	Y	Refer to Section 6.0 Stormwater Management
Description of stormwater management concept with facility locations and descriptions with references and supporting information.	Y	Refer to Section 6.0 Stormwater Management
Set-back from private sewage disposal systems.	N/A	
Watercourse and hazard lands setbacks.	N/A	
Record of pre-consultation with the Ontario Ministry of Environment and the Conservation Authority that has jurisdiction on the affected watershed.	N/A	
Confirm consistency with sub-watershed and Master Servicing Study, if applicable study exists.	N/A	
Storage requirements (complete with calcs) and conveyance capacity for 5 yr and 100 yr events.	Y	Refer to Appendix B
Identification of watercourse within the proposed development and how watercourses will be protected, or, if necessary, altered by the proposed development with applicable approvals.	N/A	
Calculate pre and post development peak flow rates including a description of existing site conditions and proposed impervious areas and drainage catchments in comparison to existing conditions.	Y	Refer to Appendix B
Any proposed diversion of drainage catchment areas from one outlet to another.	N/A	
Proposed minor and major systems including locations and sizes of stormwater trunk sewers, and SWM	N/A	
If quantity control is not proposed, demonstration that downstream system has adequate capacity for the post- development flows up to and including the 100-year return period storm event.	N/A	

4.4 Stormwater	Addressed (Y/N/NA)	Comments
Identification of potential impacts to receiving	N/A	
Identification of municipal drains and related approval requirements.	N/A	
Description of how the conveyance and storage capacity will be achieved for the development.	Y	Refer to Section 6.0 Stormwater Management
100 year flood levels and major flow routing to protect proposed development from flooding for establishing minimum building elevations (MBE) and overall grading.	Y	Refer to Grading Plan and Storm Drainage Area Plan
Inclusion of hydraulic analysis including HGL elevations.	N/A	
Description of approach to erosion and sediment control during construction for the protection of receiving watercourse or drainage corridors.	Y	Refer to Section 4.0 Erosion Sediment Control
Identification of floodplains – proponent to obtain relevant floodplain information from the appropriate Conservation Authority. The proponent may be required to delineate floodplain elevations to the satisfaction of the Conservation Authority if such information is not available or if information does not match current conditions.	N/A	
Identification of fill constrains related to floodplain and geotechnical investigation.	N/A	

4.5 Approval and Permit Requirements	Addressed (Y/N/NA)	Comments
Conservation Authority as the designated approval agency for modification of floodplain, potential impact on fish habitat, proposed works in or adjacent to a watercourse, cut/fill permits and Approval under Lakes and Rivers Improvement Act. The Conservation Authority is not the approval authority for the Lakes and Rivers Improvement Act. Where there are Conservation Authority regulations in place, approval under the Lakes and Rivers Improvement Act is not required, except in cases of dams as defined in the Act.	N/A	
Application for Certificate of Approval (CofA) under the Ontario Water Resources Act.	N/A	
Changes to Municipal Drains.	N/A	
Other permits (National Capital Commission, Parks Canada, Public Works and Government Services Canada, Ministry of Transportation etc.)	N/A	

4.6 Conclusion	Addressed (Y/N/NA)	Comments
Clearly stated conclusions and recommendations.	Y	Refer to Section 8.0 Conclusions and Recommendations
Comments received from review agencies including the City of Ottawa and information on how the comments were addressed. Final sign-off from the responsible reviewing agency.	Y	
All draft and final reports shall be signed and stamped by a professional Engineer registered in Ontario.	Y	

also agrees to note the locations of all Community Mail Boxes within the development, and to notify affected homeowners of any established easements granted to Canada Post to permit access to the Community Mail Box.

- d. The developer will provide a suitable and safe temporary site for a Community Mail Box until curbs, sidewalks and final grading are completed at the permanent Community Mail Box locations. Canada Post will provide mail delivery to new residents as soon as the homes are occupied.
- e. The developer agrees to provide the following for each Community Mail Box site and to include these requirements on the appropriate servicing plans:
  - i. Any required walkway across the boulevard, per municipal standards
  - ii. Any required curb depressions for wheelchair access, with an opening of at least two meters (consult Canada Post for detailed specifications)

#### **Rideau Valley Conservation Authority (RVCA)**

1. The RVCA has reviewed the above noted Site Plan Control application for 6 back to back townhouse blocks and have no objections provided that the site servicing report is implemented for quality control protection (run off captured by Pond 6) as part of the Site Plan Agreement.

Please provide a resubmission that addresses each of the comments or issues listed above. Please include 6 copies of all revised drawings and 2 copies of revised reports. A cover letter must also be included that states how each provided comment was addressed in the resubmission. Please co-ordinate the numbering of each resubmission comment or issue, with the above noted comment number. All addenda or revisions to any studies and plans, must be accompanied by a PDF copy, either by USB or e-mail.

Please contact me at <u>Kathy.Rygus@ottawa.ca</u> or at 613-580-2424 ext. 28318 if you have any questions regarding design, site plan or landscaping comments. Please contact Project Manager Eric Surprenant directly for questions regarding engineering comments at or at 613-580-2424, Ext.27794

Sincerely,

Kathy Rygus, Planner Development Review West Planning, Infrastructure and Economic Development Department