



**City of Ottawa**  
Development Review  
110 Laurier Avenue West, 4<sup>th</sup> Floor  
Ottawa, Ontario, K1P 1J1

Date: June 17<sup>th</sup>, 2019

**Attention:** **Anne Wang, Planner II**  
City of Ottawa DRRS

Phone: (613) 580-2424

**CC:** Bryan Bonell

**Re:** **Site Plan Control Application**  
**Application for Site Plan Control for 2037 McGee Side Road**  
**Highland Park Funeral Home**

---

Dear Anne,

This Letter will confirm the exterior lighting on the building, exterior parking lot light fixtures and parking lot poles, proposed for this project, meet the criteria for full cut-off classification as recognized by the IESNA. The resulting light spillage onto adjacent properties is below the maximum allowable spillage 5.0 LUX (0.5 FC) by City of Ottawa Standards, and is below the maximum allowable spillage 0.5 LUX (0.05 FC) by MTO standards along MTO right of way.

Yours truly,

A handwritten signature in blue ink, appearing to read 'C. McGuire'.

---

Carmen McGuire, Senior Electrical Consultant Manager  
[Carmen.McGuire@wsp.com](mailto:Carmen.McGuire@wsp.com)  
613-292-4005

WSP Canada Inc.