

TECHNICAL MEMORANDUM

DATE: JUNE 17, 2019

TO: MURRAY CHOWN

FROM: CARA RUDDLE

RE: 300-306 ELMGROVE AVENUE – SITE SERVICING BRIEF

Novatech has been retained to review the Adequacy of Existing Services for the Zoning By-law Amendment and the Site Plan application of the four properties at 300-306 Elmgrove Avenue in the City of Ottawa. Refer to **Figure 1** – Key plan for the site location. The construction of four triplex buildings is currently underway on the subject properties. The triplex buildings were originally designed to have three two-bedroom units. The current proposal is to establish a fourth two-bedroom unit in the basement of the triplex. This would convert the use of the buildings from a triplex to a four-unit low rise apartment building. Refer to **Figure 2** for the proposed Site Plan.

The purpose of this technical memorandum is to review the water, sanitary and storm servicing requirements for the proposed additional units. The memo will provide an analysis of the existing infrastructure surrounding the site to ensure there is adequate capacity for the additional units.

WATER SERVICING


There is an existing 152mm diameter watermain in Elmgrove Avenue that currently services the subject site. Refer to **Figure 3** for details on the existing servicing information. The domestic water demands for the proposed 4-unit apartment buildings were calculated and provided to the City of Ottawa to obtain boundary conditions to confirm serviceability. The domestic water demand calculations are based on a theoretical population for the proposed apartment units based on criteria provided in the City of Ottawa Water Design Guidelines. The water demand calculations, boundary conditions and watermain analysis calculations for the existing public infrastructure are provided in **Appendix A**. The results of the hydraulic analysis are summarized below in **Table 1**.

Table1: Water Analysis Results Summary

Condition	Water Demand	Min/Max Allowable Operating Pressures	Limits of Design Operating Pressures
High Pressure	0.14 L/s	80 psi (Max)	72.6 psi
Peak Hour	0.75 L/s	40 psi (Min)	63.8 psi

The required fire flow was calculated to be 8,000 L/min using the Fire Underwriter’s Survey (FUS) method and is based on 3-storey above ground wood frame construction. Refer to **Appendix A** for a copy of the FUS fire flow calculations. There are three existing fire hydrants within the vicinity of the proposed development which will provide fire protection, one on Elmgrove Avenue and two on Winona Ave. Refer to **Figure 3** for the existing hydrant locations. Boundary conditions were


Figure 1 Keyplan



April 26, 2019

1:5,000

 Property Parcels



City of Ottawa

Figure 2 Proposed Site Plan




April 26, 2019

Addresses

 Property Parcels

1:750



City of Ottawa

Figure 3 Existing Services




April 26, 2019

- Addresses
- Property Parcels
- Upstream Invert / Radier amont
- Sanitary Pipe Details / Détails de la conduite de réseau d'égout domestique**
- Sewer Fittings / Raccords**
- Cap / bouchon
- Tee / raccord en T

- Sanitary Manholes / Regards d'égout domestique
- Sanitary Pipes / Conduites d'égout domestique**
- - Private / Branchement privé
- - Public / Branchement public
- Sanitary Pump Stations and Treatment Plants / Installations d'infrastructure**
- - Sanitary Pump Station / Station de pompage des eaux usées
- - Wastewater Treatment Plant / Usine d'épuration des eaux usées

- Upstream Invert / Radier amont
- Downstream Invert / Radier aval
- Storm Pipe Details / Détails de la conduite d'eaux pluviales**
- - Catch Basins / Puitsards
- - Storm Inlets / Prises d'entrée des eaux pluviales
- - Storm Outlets / Prises de sortie des eaux pluviales
- - Storm Manholes / Regards de conduites d'eaux pluviales



City of Ottawa

requested for fire protection from the existing 150mm diameter watermain on Elmgrove Avenue. The City indicated that there is only 60 L/s of available flow at a pressure of 20 psi. The low flow available at this location is due to a dead end watermain that supplies minimal properties and the existing hydrant on Elmgrove Ave.

The fire flow required for the proposed development as indicated previously is 8,000 L/min based on the FUS guidelines. As per the City of Ottawa Technical Bulletin ISTB-2018-02 Appendix I, the aggregate fire flow of all contributing fire hydrants within 150m of the site should not be less than the required fire flow. In the case of the proposed development there are three class AA (blue top) hydrants within 150m of site. The total combined aggregate flow from the three existing hydrants as per Table 1 in the ISTB-2018-02 technical bulletin would allow for a total fire flow of 13,300 L/min.

The results of the water analysis show there is adequate flow and pressure in the existing 152mm watermain in Elmgrove Avenue to meet the required domestic and fire flow demands for the proposed additional units.

SANITARY SERVICING

There is an existing 300mm and 375mm diameter sanitary sewer in Elmgrove Avenue that currently services the subject site. Refer to **Figure 3 Existing Services**. The peak sanitary flow from the original four triplex buildings was calculated to be 0.29 L/s. The increase in peak sanitary flow from the additional basement unit in each building was calculated to be 0.09 L/s for a total peak flow of 0.38 L/s. The sanitary flow calculations are based on criteria provided in the City of Ottawa Sewer Design Guidelines. Refer to **Appendix B** for detailed calculations.

According to the sanitary sewer information provided on the GeoOttawa website, the existing 300mm diameter sanitary sewer in Elmgrove Avenue has a slope 0.73% which has a theoretical capacity of 82.5 L/s. The existing 375mm diameter sanitary sewer in Elmgrove Avenue has a slope of 0.16% which has a theoretical capacity of 70.1 L/s. The addition of a two-bedroom unit in each building increases the peak sanitary flows by only 0.09 L/s. Therefore, the additional flows will have a negligible impact on the existing sewer.

STORM SERVICING AND STORMWATER MANAGEMENT

There is an existing 525mm diameter storm sewer in Elmgrove Avenue that currently services the subject properties. Refer to **Figure 3 Existing Services**. The surface drainage from the site sheet drains towards the existing catchbasin fronting the development in Elmgrove Avenue. The foundation drainage from the proposed building is connected to the Elmgrove Avenue storm sewer.

Stormwater management (quantity and quality control of stormwater) is not required by the City of Ottawa for the proposed development. The addition of a basement unit will not increase storm drainage for the proposed development. Therefore, there are no concerns for storm servicing and there will be no adverse impacts on the existing infrastructure.

CONCLUSION

Based on the foregoing, the existing sanitary sewer, storm sewer and watermain infrastructure can adequately service the proposed additional units at 300-306 Elmgrove Avenue.

NOVATECH

Prepared by:



Cara Ruddle, P.Eng
Senior Project Manager | Land Development

List of Appendices:

- Appendix A: Water Calculations
- Appendix B: Sanitary Sewer Calculations

APPENDIX A
Water Calculations

Table 1 Water Demand						
Node	Residential Population			Residential Demand (L/s)		
	Units		Total Population	Avg Day	Max. Daily	Peak Hour
Units	POP					
Proposed Development	16	34	34	0.14	0.34	0.75

Design Parameters:

- 2 Bed Apartment 2.1 pop/unit
- Section 4.0 Ottawa Sewer Design Guidelines
- Average Domestic Flow 350 L/day
- Peaking Factors: Table 3-3 Moe Guideline
- Max. Daily Demand:
- Residential 2.5 x Avg Day
- Peak Hourly Demand:
- Residential 2.2 x Max Day

FUS - Fire Flow Calculations

As per 1999 Fire Underwriter's Survey Guidelines



Engineers, Planners & Landscape Architects

Novatech #: 117210

Project Name: 300-306 Elmgrove Ave.

Date: April 26/ 2019

Input By: Matt Hrehoriak

Legend

Input by User

No Information or Input Required

Building Description: 3 Storey above ground 4 Unit apartment

Step		Choose	Multiplier Options	Value Used	Total Fire Flow (L/min)	
Required Fire Flow						
1	Construction Material					
	Coefficient related to type of construction C	Wood frame	Yes	1.5	1.5	
		Ordinary construction		1		
		Non-combustible construction		0.8		
		Fire resistive construction (< 3 hrs)		0.7		
Fire resistive construction (> 3 hrs)			0.6			
2	Floor Area					
	A	Gross Floor Area (m ²)	115		345	
		Number of Floors/Storeys	3			
Area of structure considered (m ²)						
F	Base fire flow without reductions				6,000	
	F = 220 C (A)^{0.5}					
Reductions or Surcharges						
3	Occupancy hazard reduction or surcharge					
	(1)	Non-combustible	Yes	-25%	-25%	4,500
		Limited combustible		-15%		
		Combustible		0%		
		Free burning		15%		
Rapid burning			25%			
4	Sprinkler Reduction					
	(2)	Adequately Designed System (NFPA 13)	No	-30%	0	
		Standard Water Supply	No	-10%		
		Fully Supervised System	No	-10%		
Cumulative Total				0%		
5	Exposure surcharge (cumulative (%))					
	(3)	North Side	10.1 - 20 m		15%	3,375
		East Side	0 - 3 m		25%	
		South Side	10.1 - 20 m		15%	
		West Side	0 - 3 m		25%	
Cumulative Total				75%		
(1) + (2) + (3)	Total Required fire Flow, rounded to nearest 1000L/min				8,000	
	(2,000 L/min < Fire Flow < 45,000 L/min)			or	L/s	133
				or	USGPM	2,114
	Required Duration of Fire Flow (hours)				Hours	2
Required Volume of Fire Flow (m ³)				m ³	960	

Matthew Hrehoriak

From: Wessel, Shawn <shawn.wessel@ottawa.ca>
Sent: Tuesday, April 30, 2019 8:48 AM
To: Matthew Hrehoriak
Subject: RE: 300-306 Elmgrove Boundary Condition Request
Attachments: 300-306 Elmgrove April 2019.pdf

Good morning Mr. Hrehoriak.

As per your request, please find the boundary conditions for your site as per below:

The following are boundary conditions, HGL, for hydraulic analysis at 300-306 Elmgrove (zone 1W) assumed to be connected to the 152mm on Elmgrove (see attached PDF for location).

Minimum HGL = 108.8m

Maximum HGL = 115.0m

Available Flow @20psi = 60L/s, assuming a ground elevation of 62.9m

These are for current conditions and are based on computer model simulation.

Disclaimer: The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of watermains deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation.

If you require additional information or clarification, please do not hesitate to contact me anytime.

Thank you

Regards,

Shawn Wessel, A.Sc.T.,rcji

Project Manager - Infrastructure Approvals

Gestionnaire de projet – Approbation des demandes d’infrastructures

Development Review Central Branch | Direction de l’examen des projets d’aménagement, Centrale
Planning, Infrastructure and Economic Development Department | Direction générale de la planification
de l’infrastructure et du développement économique

City of Ottawa | Ville d’Ottawa

110 Laurier Ave. W. | 110, avenue Laurier Ouest, Ottawa ON K1P 1J1

(613) 580 2424 Ext. | Poste 33017

Int. Mail Code | Code de Courrier Interne 01-14

shawn.wessel@ottawa.ca

From: Wessel, Shawn
Sent: April 26, 2019 2:30 PM
To: 'Matthew Hrehoriak' <m.hrehoriak@novatech-eng.com>
Subject: RE: 300-306 Elmgrove Boundary Condition Request

Thank you for your email Mr. Hrehoriak.

I will pass on your request to our Water Distribution Dept. for their comments.

If you require additional information or clarification, please do not hesitate to contact me anytime.

Thank you

Regards,

Shawn Wessel, A.Sc.T.,rcji
Project Manager - Infrastructure Approvals
Gestionnaire de projet – Approbation des demandes d’infrastructures

Development Review Central Branch | Direction de l'examen des projets d'aménagement, Centrale
Planning, Infrastructure and Economic Development Department | Direction générale de la planification
de l'infrastructure et du développement économique
City of Ottawa | Ville d'Ottawa
110 Laurier Ave. W. | 110, avenue Laurier Ouest, Ottawa ON K1P 1J1
(613) 580 2424 Ext. | Poste 33017
Int. Mail Code | Code de Courrier Interne 01-14
shawn.wessel@ottawa.ca

From: Matthew Hrehoriak <m.hrehoriak@novatech-eng.com>
Sent: April 26, 2019 11:54 AM
To: Wessel, Shawn <shawn.wessel@ottawa.ca>
Subject: 300-306 Elmgrove Boundary Condition Request

CAUTION: This email originated from an External Sender. Please do not click links or open attachments unless you recognize the source.

ATTENTION : Ce courriel provient d'un expéditeur externe. Ne cliquez sur aucun lien et n'ouvrez pas de pièce jointe, excepté si vous connaissez l'expéditeur.

Hi Shawn,

Please find below water demand information for the proposed development at 300-306 Elmgrove Avenue. Also, attached is a key plan showing the site location. Please provide boundary conditions for the existing watermain infrastructure highlighted on the attached plan so we can confirm the existing infrastructure has capacity for the proposed development.

Water Demands proposed development:

AVG DAY = 0.14L/s

MAX DAY = 0.34 L/s

PEAK HOUR = 0.75 L/s

MAX DAY + FIRE =133.34 L/s

Thanks.

Matthew Hrehorik, P.Eng., Project Engineer | Land Development Engineering

NOVATECH Engineers, Planners & Landscape Architects

240 Michael Cowpland Drive, Suite 200, Ottawa, ON, K2M 1P6 | Tel: 613.254.9643 x 273 | Fax: 613.254.5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

CALCULATED WATER DEMANDS:

PROPOSED DEVELOPMENT (4-4UNIT APRTMENT BUILDINGS)

AVERAGE DAY = 0.14 L/s
MAXIMUM DAY = 0.34 L/s
PEAK HOUR = 0.75 L/s

CITY OF OTTAWA BOUNDARY CONDITIONS:

BOUNDARY CONDITIONS BASED ON (ZONE 1W) CONNECTION TO 150mm DIA. WATERMAIN ON ELMGROVE AVE.

MINIMUM HGL = 108.8 m
MAXIMUM HGL = 115.0 m

WATERMAIN ANALYSIS:

ELMGROVE AVE WATERMAIN CONNECTIONS

AVERAGE GROUND ELEVATION = 63.95 m

HIGH PRESSURE TEST = MAX HGL - AVG GROUND ELEV x 1.42197 PSI/m < 80 PSI

HIGH PRESSURE = 72.6 PSI

LOW PRESSURE TEST = MIN HGL - AVG GROUND ELEV x 1.42197 PSI/m > 40 PSI

LOW PRESSURE = 63.8 PSI

THE EXISTING 150mm DIAMETER WATERMAIN IN ELMGROVE AVENUE PASSES THE DOMESTIC DEMAND ANALYSIS TESTS, THEREFORE THERE IS CAPACITY IN THE EXISTING INFRASTRUCTURE FOR THE PROPOSED ADDITION.

APPENDIX B
Sanitary Sewer Calculations

PROPOSED 4 4-UNIT APARTMENT BUILDINGS

NUMBER OF 2 BDR UNITS	16
PERSONS PER 2 BDR UNIT	2.1
TOTAL POPULATION	34
AVERAGE DAILY FLOW	280 L/c/day
PEAK FACTOR (HARMON FORMULA)	3.48
PEAK SANITARY FLOW	0.38 L/s

ORIGIANL 4 TRIPLEX BUILDINGS

NUMBER OF 2 BDR UNITS	12
PERSONS PER 2 BDR UNIT	2.1
TOTAL POPULATION	26
AVERAGE DAILY FLOW	280 L/c/day
PEAK FACTOR (HARMON FORMULA)	3.49
PEAK SANITARY FLOW	0.29 L/s