



ROOF DRAIN TABLE: AREA R-1 (ROOF DRAINS 1 to 7)

AREA ID	ROOF DRAIN No. (WATTS MODEL)	ROOF DRAIN OPENING SETTING	1.5 YEAR RELEASE RATE	APPROX. 5 YR PONDING DEPTH	1:100 YEAR RELEASE RATE	APPROX. 100 YR PONDING DEPTH
R-1	RD 1 (RD-100-A-ADJ)	1/2 EXPOSED	0.95 L/s	11 cm	1.10 L/s	14 cm
R-1	RD 2 (RD-100-A-ADJ)	1/2 EXPOSED	0.95 L/s	11 cm	1.10 L/s	14 cm
R-1	RD 3 (RD-100-A-ADJ)	1/2 EXPOSED	0.95 L/s	11 cm	1.26 L/s	15 cm
R-1	RD 4 (RD-100-A-ADJ)	1/2 EXPOSED	0.95 L/s	10 cm	1.10 L/s	13 cm
R-1	RD 5 (RD-100-A-ADJ)	1/2 EXPOSED	0.95 L/s	10 cm	1.10 L/s	13 cm
R-1	RD 6 (RD-100-A-ADJ)	1/2 EXPOSED	0.95 L/s	11 cm	1.26 L/s	14 cm
R-1	RD 7 (RD-100-A-ADJ)	1/2 EXPOSED	0.95 L/s	11 cm	1.26 L/s	14 cm

\* REFER TO THE 'DEVELOPMENT SERVICING STUDY AND STORMWATER MANAGEMENT REPORT' (R-2018-158) PREPARED BY NOVATECH FOR DRAINAGE AREA IDENTIFIERS AND STORMWATER MANAGEMENT DETAILS.

\*\* ALL CONTROLLED FLOW ROOF DRAINS FOR THE PROPOSED BUILDING TO BE WATTS ADJUSTABLE ACCUTROL® ROOF DRAINS.

