Servicing Report

Commercial Plaza 5100 Kanata Avenue



Value through service and commitment

Table of Contents

1.0	Introd	uction	1
	1.1	Site Description and Background	1
	1.2	Proposed Development	3
	1.3	Existing Infrastructure	3
	1.4	Permits and Approvals	3
	1.5	Engineering Drawings	4
2.0	Water	Servicing	4
	2.1	Design Criteria	4
	2.2	System Pressures	4
	2.3	Water Demands	5
	2.4	Simulation of Fire Flows	5
	2.5	Proposed Watermain Servicing, Pipe Sizing and Roughness Coefficients	6
	2.6	Hydraulic Boundary Conditions	6
	2.7	Simulation Results	7
		2.7.1 Peak Hour Demand	7
		2.7.2 Maximum Day Demand plus Fire Flow	7
		2.7.3 High Pressure Check	7
	2.8	Internal Pumping	8
	2.9	Summary and Conclusions	8
3.0	Sanita	ary Servicing	8
	3.1	Background	8
	3.2	Design Criteria	8
	3.3	Proposed Sanitary Servicing	9
4.0	3.4	Summary and Conclusions	9
4.0	Storm	water Servicing	10
	4.1	Background	10
	4.2	Storm Criteria	.11
	4.3	Proposed Stormwater Servicing and SWM Strategy	.12
		4.3.1 Uπ-Site Runoπ and Allowable Minor System Release Rate	.12
		4.3.2 Roottop Controls	.13
		4.3.3 Inlet Control Devices (ICDS)	.14
		4.3.4 Uncontrolled Flow	.10
		4.3.5 Summary of Proposed Restricted Flows, Uncontrolled Flows, and	ג די
		Storage	.17
		4.3.0 Overland Flow	. 17
	4 4	4.3.7 Water Quality	. 17
F 0	4.4	Summary and Conclusions	. 17
0.0		union	. IŎ 10
0.0	COUCI	นธเบเา	. 19

List of Tables

Table 1.2:	Building Footprint Areas	.3
Table 2.3:	Calculated Water Demands	5
Table 2.5:	PVC Watermain Pipe Diameters and Roughness Coefficients	6
Table 2.6:	Hydraulic Boundary Conditions	7

Table 3.2:	Wastewater Servicing Design Criteria.	9
Table 4.1:	Minor System Flow Allocation	11
Table 4.2:	Storm Servicing Design Criteria	11
Table 4.3.1:	Off-Site Peak Flow Comparison	12
Table 4.3.2:	Rooftop Storage and Release Characteristics	14
Table 4.3.3:	ICD and Storage Volume Characteristics	16
Table 4.3.4:	Flow and Storage Results	17

List of Appendices

APPENDX' A1' APPENDX 'A2' APPENDIX 'A3' APPENDIX 'B'	Block 111 Site Servicing Plan (S1) (prepared by JLR, 2016) MOE Environmental Compliance Approval City of Ottawa Development Servicing Checklist Hydraulic Network Analysis (HNA)
APPENDIX 'B1'	Water Demands
APPENDIX 'B2'	FUS Calculations
APPENDIX 'B3'	Overall Schematic
APPENDIX 'B4'	Hydraulic Boundary Conditions
APPENDIX 'B5'	Peak Hour Simulation Results
APPENDIX 'B6'	Maximum Day Plus Fire Flow Simulation Results
APPENDIX 'B7'	Maximum Pressure Check
APPENDIX 'C1'	Sanitary Sewer Walden Village Subdivision Design Documents and
	Block 111 Sepitery Sewer Design Sheet (Propered by ILP, 2016)
APPENDIX 'C3'	Sanitary Sewer Hawthorn Retirement Residence (Prepared by SCS
	Consulting group. 2016)
APPENDIX 'C4'	Commercial Plaza Sanitary Sewer Design Sheet
APPENDIX 'D1'	Storm Sewer Walden Village Subdivision Design Documents and Drawings (prepared by IBI, 2001)
APPENDIX 'D2'	Block 111 Storm Sewer Design Sheet (prepared by JLR, 2016)
APPENDIX 'D3'	Hawthorn Retirement Residence Storm Sewer Design (Prepared by SCS Group, 2016)
APPENDIX 'D4'	Commercial Plaza Stormwater Management Calculations
APPENDIX 'D5'	Commercial Plaza Storm Sewer Design Sheet
APPENDIX 'D6'	ZURN Control-Flo Roof Drainage System Technical Manual
APPENDIX 'D7'	SWMHYMO Results
APPENDIX 'D8'	Water Quality Memorandum
APPENDIX 'D9'	E-mail Correspondance – Maintenance

1.0 Introduction

Urbandale Corporation (Urbandale) has retained the services of J.L. Richards & Associates Limited (JLR) to proceed with the detailed design of municipal infrastructure for the development of their Commercial Plaza located at 5100 Kanata Avenue in the Kanata Lakes Community in the City of Ottawa (City).

This Site Servicing Report outlines the design objectives and criteria, servicing constraints and strategies for developing the subject lands with water, wastewater and stormwater services in accordance with the 2001 Walden Village Subdivision Design completed by IBI Group (formerly Cumming Cockburn Limited (CCL)) and the September 2016 Servicing Report for Block 111 prepared by JLR, as well as the City of Ottawa Sewer Design Guidelines (2012) and associated Technical Bulletins. This Report also includes strategies and solutions for implementing erosion and sedimentation control measures throughout construction.

1.1 Site Description and Background

The 1.65 ha property is situated in the northeastern quadrant of the Kanata Avenue and Goulbourn Forced Road intersection in the Kanata Lakes Community. The site is bounded by Goulbourn Forced Road to the west, Kanata Avenue (formerly Castlefrank Road) to the south, the existing Walden Village residential subdivision to the east and a retirement residence site to the north, as shown on Figure 1 - Location Plan.

In the 2001 Walden Village Subdivision Design completed by IBI Group (formerly CCL), the subject site was identified as being part of Block 115, which in 2016 was sub-divided into two separate parcels. The northern portion of the former Block 115 (\pm 1.70 ha) is owned by Hawthorn Retirement Group and is being developed as a retirement residence. The southern portion of the former Block 115 (\pm 1.65 ha), the subject property, is owned by Urbandale Corporation who is proposing to develop a Commercial Plaza.

Wastewater and stormwater generated within the proposed Commercial Plaza was accounted for in the sanitary and storm sewer design for the adjacent Walden Village Subdivision. Peak flows were allocated for the subject site to the Bryant Street (formerly Davenport Street) sanitary and storm sewers at the intersection with Broughton Street. Furthermore, the Beaver Pond Stormwater Management Facility was assigned to be the dedicated stormwater outlet for the subject site.

In 2017, the Ministry of the Environment, Conservation and Parks (MECP) and the City granted approvals for the construction of shared storm and sanitary sewers to service both the Hawthorn retirement residence and the Urbandale commercial site. The shared storm and sanitary sewers extend from the southern limit of the retirement residence site and outlet to existing Bryant Street storm and sanitary sewers via the future residential Block 110 to the north of the retirement residence and via Broughton Street, respectively, as shown on the Site Servicing Plan provided in Appendix 'A1'.



PLOT DATE: November 9, 2017 2:47:54 PM

1.2 **Proposed Development**

The proposed Commercial Plaza includes five (5) buildings identified 'A' through 'E'. The footprint areas of each building are as follows:

Building	Footprint Area (m²)
A	405
В	954
С	848
D	1060
Ш	530

Table 1.2: Building	g Footprint Areas
---------------------	-------------------

The site also includes a six (6) meter wide landscape block totaling 0.07 ha located along the eastern property limit adjacent to the Walden Village subdivision.

1.3 Existing Infrastructure

The following existing infrastructure is within the vicinity of the site:

<u>Watermain</u>

- Existing 600 mm diameter watermain on Kanata Avenue along the southern frontage of the Commercial Plaza.
- Existing 400 mm diameter watermain on Goulbourn Forced Road on the western side of the Commercial Plaza.

Sanitary

• Existing 200 mm PVC sanitary sewer located to the north of the Commercial Plaza within the retirement residence site, ± 17 m from the eastern property limit.

<u>Storm</u>

• Existing 600 mm concrete storm sewer located to the north of the Commercial Plaza within the retirement residence site, ± 15 m from the eastern property limit.

1.4 **Permits and Approvals**

An MECP ECA was granted in 2017 for the existing shared sanitary and storm sewers designed to service both the retirement residence and the subject commercial site. Refer to Appendix 'A2' for a copy of the MECP ECA No.4070-AN9PJ2, dated June 15, 2017. Given that the proposed Commercial Plaza will be privately owned and operated, it is anticipated that no additional ECA will be required for the proposed private sewer works.

The City of Ottawa Development Servicing Study Checklist has been included in Appendix 'A3' which provides all the details associated with this development and the approval and permit requirements.

1.5 Engineering Drawings

Engineering Drawings have been prepared in support of the development of the Commercial Plaza. The following four (4) drawings are included at the back of the Report:

- Site Servicing Plan (Drawing S1);
- Grading Plan (Drawing G1);
- Ponding Plan (Drawing SWM); and
- Erosion and Sediment Control Plan (Drawing ESC).

2.0 Water Servicing

2.1 Design Criteria

A Hydraulic Network Analysis (HNA) was completed for the proposed Commercial Plaza to confirm that the proposed watermain distribution system identified on the Site Servicing Plan (Drawing S1) can provide adequate supply while complying with both the City of Ottawa Design Guidelines for Water Distribution (July 2010) and Technical Bulletins ISDTB-2014-02 and ISTB-2018-02. These documents have been referred to in this section as the Design Guidelines, TB-2014-02, and TB-2018-02 respectively. The Design Guidelines require that a water supply system be designed to satisfy the following demand criteria:

- maximum day demand plus fire flow; and
- maximum hourly demand (peak hour demand).

2.2 System Pressures

Section 4.2.2 of the Design Guidelines requires that new development additions to the public water distribution system be designed such that the minimum and maximum water pressures, as well as flow rates, conform to the following:

- i. Under maximum hourly demand conditions (peak hour), the pressures shall not fall below 276 kPa (40 psi).
- ii. During periods of simultaneous maximum day and fire flow demand, the residual pressure at any point in the distribution system shall not be less than 140 kPa (20 psi).
- iii. In accordance with the Ontario Code & Guide for Plumbing, the static pressure at any fixture shall not exceed 552 kPa (80 psi) in areas that may be occupied.
- iv. The maximum pressure at any point in the distribution system shall not exceed 689 kPa (100 psi) in unoccupied areas.

v. Feedermains, which have been provided primarily for the purpose of redundancy, shall meet, at a minimum, the basic day plus fire flow demand. This criterion is irrelevant to this HNA as there are no feedermains proposed.

The HNA was carried out to fulfill the above watermain pressure and demand objectives.

2.3 Water Demands

To assess the performance of the proposed water distribution system (refer to Drawing S1 at the back of the Report for system layout), the above-noted water demand scenarios were developed and evaluated against the pressure criteria listed in Section 2.2 using the WaterCAD® software platform. The total average day demand for the commercial site was calculated based on a daily commercial consumption rate of 25,000 L/ha/day, as per the Design Guidelines, and occurring over a 12-hour business day. The individual building demands were then assigned to each of the five (5) proposed buildings by distributing the total site area on a proportional building footprint area basis, and multiplying the area distribution factor by the total average day demand. Once calculated, the average day demands were used to compute both maximum day and peak hour demands using a peaking factor of 1.5 and 1.8, respectively, as prescribed in the Design Guidelines for commercial development. Based on the above, a water consumption of 37,500 L/ha/day and 67,500 L/ha/day was simulated for the maximum day demand and peak hour demand, respectively. Table 2.3 summarizes the water demands associated with each of the proposed commercial buildings. Refer to Appendix 'B1' for the water demand calculations.

BLDG	Average Day Demand (L/s)	Maximum Day Demand (L/s)	Peak Hourly Demand (L/s)
А	0.10	0.15	0.27
В	0.23	0.35	0.63
С	0.21	0.31	0.56
D	0.25	0.37	0.67
E	0.13	0.19	0.34
TOTAL	0.92	1.37	2.47

Table 2.3: Calculated Water Demands

2.4 Simulation of Fire Flows

Various guidelines are used throughout North America to establish fire flow requirements for different types of buildings. The Guidelines entitled "Water Supply for Public Fire Protection (1999)" developed by the Fire Underwriters Survey (FUS) govern fire flow protection requirements in the City of Ottawa. In addition, fire flow requirements used in this HNA have been calculated in accordance with TB-2014-02 and TB-2018-02. Fire flow requirements were calculated for each of the proposed buildings. It was assumed that each building will consist of a single storey and that Buildings A, B and D will have sprinkler protection. It was also assumed that Buildings A and E will have wood frame construction. Based on the calculations, it was

found that the governing fire flow requirement is 9,000 L/min (150 L/s) at Building E. This fire flow was used conservatively as the targeted requirement for the entire site. Refer to Appendix 'B2' for the FUS calculations and for a copy of the letter from the Mechanical Engineer regarding the fire suppression system.

2.5 **Proposed Watermain Servicing, Pipe Sizing and Roughness Coefficients**

The proposed watermain layout for the Commercial Plaza is shown on the Site Servicing Plan (Drawing S1 at the back of the Report). Water will be supplied to the site by a 200 mm diameter connection to the existing 400 mm diameter watermain along Goulbourn Forced Road. It should be noted that this connection is proposed and supersedes the watermain service connection previously proposed and shown on the September 2016 Site Servicing Plan provided in Appendix 'A1'. Water supply to the proposed buildings will be provided by an on-site 150 mm diameter watermain loop, with a 150 mm diameter water service for Buildings A, B, C, and D, and a 50 mm diameter water service for Building E. Fire flow requirements will be achieved by one (1) proposed on-site hydrant supplemented by three (3) existing hydrants – one (1) on Goulbourn Forced Road and two (2) on Kanata Avenue. It should be noted that Junctions J-9, J-10, J-11, J-12 and J-13 were set to the finished floor elevations of Buildings A, B, C, D and E, respectively. Refer to Appendix 'B3' for the overall schematic of the WaterCAD® model.

Watermain roughness coefficients were set based on the recommended Hazen-Williams friction factors presented in Section 4.2.12 of the Design Guidelines and the internal pipe diameters were modelled based on Section 4.3.5 of the Design Guidelines, as summarized in Table 2.5.

Nominal diameter of Watermain	Internal Diameter	C-Factor	
50 mm	50 mm	100	
150 mm	155 mm	100	
200 mm	204 mm	110	

 Table 2.5: PVC Watermain Pipe Diameters and Roughness Coefficients

2.6 Hydraulic Boundary Conditions

The HNA was carried out based on hydraulic boundary conditions provided by the City under various water demands (refer to Appendix 'B4' for a copy of the e-mail correspondence). It is noted that a fire flow requirement of 11,000 L/min (183 L/s) was specified in the request for hydraulic boundary conditions due to unknown building specifics at the time. Since the governing fire flow requirement of 9,000 L/min is less than what was used to generate the boundary conditions, the maximum day plus fire flow simulation results are considered to be conservative.

Boundary conditions received from the City are summarized in Table 2.6 below.

Water Demands	Goulbourn Forced Road HGL (m)		
Peak Hour	157.8		
Maximum Day + Fire Flow	151.7		
High Pressure Check	162.3		

Table 2.6: Hydraulic Boundary Conditions

2.7 Simulation Results

2.7.1 Peak Hour Demand

The proposed water distribution system as depicted on Drawing S1 was simulated under the peak hour demand based on the water demand summarized in Table 2.3 and the hydraulic boundary condition presented in Table 2.6.

The simulation results show a minimum residual pressure of 486 kPa (70.5 psi) at Junction J-9 (i.e., Building A) under the peak hour demand, exceeding the minimum operating pressure of 276 kPa (40 psi) as recommended in the Design Guidelines (refer to Appendix 'B5' for WaterCAD® simulation schematic and results).

2.7.2 Maximum Day Demand plus Fire Flow

Section 4.2.2.3 of the Design Guidelines requires that the water distribution system satisfy the maximum day demand combined with the FUS fire flow requirement, as presented in Appendix 'B2'. The fire flow simulation was carried out by allowing WaterCAD® to calculate the available fire flow that can be drawn from a hydrant without allowing any part of the system to experience pressures less than 140 kPa (20 psi).

The proposed servicing as depicted on Drawing S1 was simulated under the maximum day demand based on the water demand summarized in Table 2.3 and the hydraulic boundary condition presented in Table 2.6. A fire flow requirement of 150 L/s was targeted for the entire site.

The simulation results indicate that a minimum fire flow of 173 L/s is available at Hydrant H-4 (on-site hydrant) while fulfilling the maximum day demand. Consequently, the distribution system can deliver fire flows in excess of 150 L/s (refer to Appendix 'B6' for WaterCAD® simulation schematic and results).

2.7.3 High Pressure Check

The Design Guidelines require that a high pressure check (maximum hydraulic grade elevation) be performed on the proposed system to ensure that the maximum pressure constraint of 552 kPa (80 psi) as per the Ontario Code & Guide for Plumbing is not exceeded. To generate the highest pressure, the demand at all Junctions was set to zero (0).

The simulation results show a maximum residual pressure of 540 kPa (78.3 psi) at Junction J-3 (near Building D) under the maximum pressure scenario, which is less than the maximum pressure constraint of 552 kPa (80 psi) as recommended in the Design Guidelines (refer to Appendix 'B7' for WaterCAD® simulation schematic and results).

2.8 Internal Pumping

Simulation results have shown that there is no requirement to provide internal pumping during domestic usage as the minimum pressure of 276 kPa (40 psi) is exceeded for all of the proposed fixtures at ground level. In terms of pumping requirements for the sprinkler system, it will be the responsibility of the certified fire protection specialist to recommend whether this system is required.

2.9 Summary and Conclusions

Based on the above simulation results, it is recommended that the water distribution system shown on the Site Servicing Plan (Drawing S1) be implemented to provide potable water for domestic and fire flow usages for the proposed Commercial Plaza.

3.0 Sanitary Servicing

3.1 Background

Wastewater flows generated by the proposed Commercial Plaza were accounted for in the overall sanitary sewer design of the Walden Village Subdivision completed by IBI Group (formerly CCL) in 2001. The Commercial Plaza was identified at the time of the Walden Village subdivision design as being part of Block 115, with an area of 3.23 ha (refer to the Walden Village Sanitary Drainage Area Plan Drawing 501 in Appendix 'C1'). This 3.23 ha commercial area was designed to be tributary to sanitary maintenance hole 38A (SAN MH38A), located at the intersection of Broughton Street and Bryant Street (formerly Davenport Street).

In 2017, approvals were granted by the MECP and the City for an alternate sanitary sewer outlet for the former Block 115, which now consists of the retirement residence site and the proposed Commercial Plaza. As outlined in JLR's 2016 Site Servicing Report and as shown on the Site Servicing Plan provided in Appendix 'A1', wastewater flows from the commercial site will outlet to SAN MH4A located at the southern limit of the retirement residence, and will be conveyed northerly across the retirement residence site, via a shared 200 mm diameter sanitary sewer, to existing SAN MH 37A located on Broughton Street. From existing SAN MH37A, wastewater is then conveyed northerly along Broughton Street to SAN MH38A, the original outlet for the site designated in the Walden Village subdivision design. As part of the updated 2016 design, the proposed Commercial Plaza was allocated a peak flow of 1.76 L/s, as indicated in the May 2016 Sanitary Sewer Design Sheets provided in Appendices 'C2' and 'C3'.

3.2 Design Criteria

The sanitary sewers for the proposed Commercial Plaza were designed based on the City of Ottawa Sewer Design Guidelines (October 2012) and associated Technical Bulletins. Key design parameters have been summarized in Table 3.2 below:

Design Criteria	Design Value	Reference	
Commercial average flow	28,000 L/gross ha/day	Technical Bulletin ISTB-2018-01	
Commercial peaking factor	1.5	City Section 4.4.1	
Infiltration flow	0.33 L/s/effective gross ha	Technical Bulletin ISTB-2018-01	
Minimum velocity	0.6 m/s	City Section 6.1.2.2	
Maximum velocity	3.0 m/s	City Section 6.1.2.2	
Manning Roughness Coefficient (for smooth wall pipes)	0.013	City Section 6.1.8.2	
Minimum allowable slopes	Varies City Table 6.2 Section 6.1.2.2		

Table 3.2:	Wastewater	Servicing	Design	Criteria
------------	------------	-----------	--------	----------

3.3 Proposed Sanitary Servicing

It is proposed to collect and convey wastewater flows generated within the Commercial Plaza site via a 200 mm diameter sanitary sewer collection system that will outlet to the existing SAN MH 4A located at the northern limit of the Commercial Plaza, ± 17 m from the eastern property limit. A Sanitary Sewer Design Sheet was prepared for the proposed sewer system and is presented in Appendix 'C4'. A peak flow of 2.06 L/s was calculated for the Commercial Plaza based on the parameters described in Table 3.2 and assuming that the plaza is in operation 12 hours per day.

It is noted that the calculated peak flow for the Commercial Plaza is approximately 0.3 L/s greater than that allocated for the site in the 2016 design. This is due to a slight change in total tributary area as well as the assumption of the 12 hours per day of operation. Although JLR does not have the residual capacities of all existing downstream sanitary sewers on record, it would appear that the existing downstream sanitary sewers within the retirement residence site and in the Walden Village Subdivision have the residual capacity to accommodate the additional 0.3 L/s wastewater flow (refer to Sanitary Sewer Design Sheets for existing sewers provided in Appendices 'C2' and 'C3').

3.4 Summary and Conclusions

Based on the above servicing details and the Sanitary Sewer Design Sheet provided in Appendix 'C4', it is recommended that sanitary sewers shown on Drawing S1 (at the back of the Report) be implemented to provide sanitary servicing for the Commercial Plaza.

4.0 Stormwater Servicing

4.1 Background

Stormwater Management (SWM) for the Commercial Plaza was accounted for in the overall storm sewer design of the Walden Village Subdivision. The drainage area associated with the subject site was identified as being part of Block 115 within the Site Stormwater Management Plan (SSMP-WV), prepared by IBI, dated October 2001 (refer to Drawing No. 500 in Appendix 'D1'). The SWM for the Walden Village subdivision follows the dual drainage principle; the minor storm sewer system captures and conveys runoff during frequent storm events with up to a 1:5 year recurrence, while the major overland system conveys excess runoff generated from severe storm events that are not captured by the minor system and up to a 1:100 year recurrence.

The IBI Storm Sewer Design Sheet (provided in Appendix 'D1') indicates that runoff from the former Block 115 is to be conveyed to existing storm maintenance hole 38 (ST MH 38) located at the intersection of Broughton Street and Bryant Street (formerly Davenport Street). From ST MH 38, stormwater is conveyed by the existing 900 mm diameter storm sewer system along Bryant Street, then northerly through existing storm sewers, and ultimately outlets to the Kanata Lakes Beaver Pond Stormwater Management Facility, herein referred to as the Beaver Pond, via a sediment forebay at Cecil Walden Ridge. The Beaver Pond is a wet pond facility that provides stormwater quality treatment before discharging into the Kizell Drain. It should be noted that runoff generated by the proposed landscape block located to the east of the Commercial Plaza was allocated to the rear yards of single family home lots fronting onto Weaver Crescent and to Kanata Avenue (former Castlefrank Road), as shown on the Storm Drainage Plan Drawing No. 500 in Appendix 'D1'.

The SSMP-WV Report also indicated that runoff in excess of the allowable minor system release rate of the former Block 115 is to be contained on-site up to and including the 1:100 year storm event. Alternatively, excess runoff could be conveyed overland across Goulbourn Forced Road to the Beaver Pond (as indicated on Drawing 500 in Appendix 'D1').

In 2017, approvals were granted by the City and the MECP for the construction of shared storm sewers to service the retirement site and proposed commercial site which, combined, make up the former Block 115. This included an 825 mm diameter storm sewer along the length of the future residential Block 110 located to the north of the retirement residence site and a 600 mm diameter storm sewer extending between the northern to southern property limits of the retirement residence site, as shown on the Site Servicing Plan provided in Appendix 'A1' and in the Storm Sewer Design Sheet provided in Appendix 'D2'.

With the severance of former Block 115, the allowable minor system release rate of 289.1 L/s allocated to the existing Bryant Street storm sewer had to be shared amongst two properties. The Block 115 allowable release rate (289.1 L/s) was based on a drainage area of 3.23 ha, a C-Factor of 0.60 and an intensity of 53.66 mm/hr as shown in the Storm Sewer Design Sheet and Drawing 500 provided in Appendix 'D1'.

Q = 2.78CIA = 2.78 (0.60) (53.66 mm/hr) (3.23 ha) = 289.1 L/s

The release rate for the Commercial Plaza was achieved on a weighted area and runoff coefficient basis, as outlined in the Block 111 Site Servicing Report prepared by JLR dated

September 2016. An allowable minor system release rate of 139.7 L/s was, therefore, allocated for the proposed Commercial Plaza as summarized in the table below.

Former Block 115	Area (ha)	C-Factor	AxC	Qrest. (L/s)
Institutional Site				
(retirement residence)	1.70	0.77	1.309	149.4
Commercial Site				
(commercial plaza)	1.53	0.80	1.224	139.7
Total	3.23		2.533	289.1

Table 4.1: Minor System Flow Allocation

4.2 Storm Criteria

Storm servicing developed for the proposed Commercial Plaza was designed in accordance with the following stormwater criteria, which has been approved by the City and the MECP as part of the development of the Hawthorn Retirement Group retirement residence site:

- Storm runoff outletting to the existing Bryant Street sewer is to be limited to the allocated peak flow of 139.7 L/s.
- Runoff in excess of allocated minor system release rate and up to the 1:100 year recurrence shall be retained on site.
- Major overland flow in excess of the 1:100 year recurrence is to be conveyed to Goulbourn Forced Road.
- Quality control for the site is to be provided by the Beaver Pond.

Furthermore, the detailed SWM design was carried out in accordance with the design criteria prescribed in the City of Ottawa Sewer Design Guidelines (2012) and associated Technical Bulletins, as summarized in the table below.

Table 4.2: Storm Servicing Design Criteria

General Design Criteria

Storm sewers sized to accommodate the 1:2 year peak flows calculated with the Rational Method and the City of Ottawa Intensity-Duration-Frequency (IDF) curves.

Storm sewers designed based on an inlet time of ten (10) minutes, as per the Technical Bulletin ISDTB-2012-4.

The 1:100 year peak flows to be detained on-site by means of on-site storage designed to limit the total outflows to the allowable release rate.

Minimum swale grades at 1.5% (with lower grades, a sub-drain must be provided).

Minimum roadway profile grades at 0.5%.

Maximum 0.35 m street/parking lot ponding depth.

Provide measures to ensure that site preparation and construction is in accordance with the current Best Management Practices for Erosion and Sediment Control.

4.3 **Proposed Stormwater Servicing and SWM Strategy**

The proposed storm servicing strategy for the subject site includes both uncontrolled off-site runoff and captured minor system runoff. The uncontrolled off-site runoff includes drainage from some of the perimeter landscaped areas along the north, south and western property limits of the Commercial Plaza, as well as the landscaped block to the east. The controlled captured minor system flows include runoff from the remainder of the site (i.e., access lanes, paved parking areas, landscaped areas, and building roofs). Runoff from these areas will be directed to catch basins and roof drains (with or without flow restrictors) and will outlet to the storm sewer system. Refer to the Project Drawings (at the back of the Report) for inlet control devices (ICD) and roof drain information, grading, drainage and ponding areas, overland flow route and outlet details.

4.3.1 Off-Site Runoff and Allowable Minor System Release Rate

Due to site grading constraints, some of the narrow landscaped strips along the northern property limit (the retirement residence), Kanata Avenue and Goulbourn Forced Road will drain off-site as major overland flow. Additionally, the landscaped block to the east of the Commercial Plaza will drain off-site as overland flow towards the rear yards of the Walden Village subdivision. Table 4.3.1 below provides a comparison between the off-site overland peak flows allocated for the site as part of the Walden Village and retirement residence detailed design versus the off-site overland peak flows proposed as part of the Commercial Plaza development, refer to detailed calculations provided in Appendix 'D4'.

	Allocated		Proposed	
Off-site Outlet	Area	Peak Flow (1:5 year)	Area	Peak Flow (1:5 year)
Retirement Residence (1)	0.03 ha	5.39 L/s	0.034 ha	4.40 L/s
Kanata Avenue ⁽²⁾	0.07 ha	4.06 L/s	0.022 ha	2.29 L/s
Goulbourn Forced Road	N/A	N/A	0.028 ha	2.23 L/s
Walden Village Residential Rear Yards ⁽²⁾	0.12 ha	19.12 L/s	0.062 ha	5.76 L/s
Notes				

Table 4.3.1: Off-Site Peak Flow Comparison

 Refer to Retirement Residence Storm Drainage Plan prepared by SCS Consulting Ltd. dated August 17th 2016, provided in Appendix 'D3'.

(2) Refer to Walden Village Storm Drainage Plan Drawing No. 500 provided in Appendix 'D1'.

As summarized in the table above, off-site drainage areas and peak flows are generally less than those allocated for the site, with the exception of the overland flow to Goulbourn Forced Road. Based on the SSMP-WV, there was no uncontrolled flow allocated to Goulbourn Forced Road. To compensate for this additional flow, it is proposed to reduce the allowable minor system release rate of 139.7 L/s for the site by subtracting the 1:5 year peak flow discharging overland to Goulbourn Forced Road. Therefore, a revised restricted minor system release rate of 137.47 L/s (139.7 L/s – 2.23 L/s) has been used as the design target for the Commercial Plaza.

The allowable minor system release rate of 137.47 L/s will be achieved through the use of controlled rooftop drains and ICDs combined with surface storage, as depicted on the ponding plan (Drawing SMW) and underground pipe storage. With the exception of the underground pipe storage, the storm sewer system presented on Site Servicing Plan (Drawing S1) was sized to accommodate peak flows generated during the 1:2 year storm event as shown in the Storm Sewer Design Sheet in Appendix 'D5'. The minimum 1:2 year capture is consistent with Technical Bulletin PIEDTB-2016-01.

4.3.2 Rooftop Controls

Stormwater runoff generated from building rooftops will be controlled by the implementation of restricted roof drain systems on Buildings B, C and D. Rooftop storage (i.e., ponding) will, therefore be provided for Buildings B, C and D. Given the smaller footprint area of Buildings A and E, it is assumed that these building roofs would be slanted and, therefore, would not accommodate rooftop storage.

Given that municipal servicing is being carried out prior to the detailed design of the buildings, rooftop control charts were used to determine appropriate roof drain release rates based on commercially available products. The Zurn Control-Flo rooftop drainage system (Model Z 105 5, single notch) was used to assess viable restricted flow rates (refer to Appendix 'D6'). It was assumed that all of the buildings (i.e., B, C, and D) will have an effective ponding area of at least 80 percent of the total roof area with a maximum ponding depth of 5" (127 mm). Further, it was assumed that all roofs would be sloped towards each of the rooftop drains.

Table 4.3.2 presents the restricted release rates and ponding details for each of the three (3) buildings as well as the 1:100 year release rates for Buildings A and E. Additional roof drain calculations are provided in Appendix 'D4'. At the time of detailed design of the buildings, the Mechanical Engineer is to comply with the maximum allowable release rate and the minimum storage volume requirements for each building as indicated in Table 4.3.2. However, the Mechanical Engineer can use any manufacturer or other combination of roof drains, as long as the specified release rates are not exceeded and minimum storage volume requirements are fulfilled. Appendix 'B2' includes a letter from the Mechanical Engineer stating that the roof system will be designed in accordance with the requirements of clause 7.4.10.4 of the Ontario Building Code.

Building	Max. Release Rate (1:100 year) (L/s)	Min. Storage Requirement (1:100 year) (m ³)	Storage Volume Provided ⁽¹⁾ (m³)
А	20.10	0	N/A
В	7.74	29.74	32.17
С	6.45	27.47	28.79
D	7.74	34.85	35.90
E	26.30	0	N/A
Notes:			

Table 4 3 2	Roofton	Storage	and Release	Characteristics
1 abie 4.J.Z.	Roonop	Slurage	and neiease	Gilaracteristics

(1) Based on 80% effective roof ponding area and max ponding depth of 127 mm for a sloped roof. (2) Maximum release rate for Buildings A and E based on the 1:100 year unrestricted peak flow.

4.3.3 Inlet Control Devices (ICDs)

In addition to the aforementioned rooftop restrictors, the allowable minor system release rate will be met using five (5) ICDs in parking lot catch basins and storm maintenance holes. Details associated with each ICD, catchment area and storage requirements are as follows:

ICD No. 53

As shown on Drawing SWM, the ICD at MH530 controls numerous catchment areas that amount to an overall area of 0.689 ha. Within this catchment, there are six (6) above ground storage cells, as depicted on Drawing SWM, with storage volumes of 23.57 m³, 5.85 m³, 3.38 m³, 2.23 m³, 25.18 m³ and 1.61 m³. Based on high level Modified Rational Method calculations (Appendix 'D4'), it was determined that the above-ground storage volume of 61.82 m³ was insufficient to contain runoff generated during the 1:100 year storm event. Consequently, it is proposed to oversize specific sewers to supplement the surface storage. Four (4) pipe reaches were oversized as follows:

- 1050 mm diameter sewer for pipe reaches MH510-MH511, MH511-MH520 and • MH520-MH530;
- 750 mm diameter sewer for the catch basin lead spanning between CBMH510-• MH511.

The storage volume in the oversized maintenance holes was also accounted for in the calculations. The aforementioned above-ground storage of 61.82 m³ was, therefore, supplemented with underground storage of 88.28 m³ and 62.26 m³ for the oversized sewers and maintenance holes, respectively.

Given that approximately 29% of the overall storage volume is at the surface, the use of the Modified Rational Method may underestimate the storage volume requirements. Consequently, the SWMHYMO software platform was used to assess storage volume requirements for this catchment. A rating was first developed at various stages that

estimated the outflows at various elevations, which are dictated by the ICD, and associated incremental storage volumes were assessed. The various storage volumes consisting of 61.82 m³ (above ground), 88.28 m³ (oversized sewers) and 62.26 m³ (oversized maintenance holes) were incorporated in the outflow-storage relationship. Appendix 'D7' (see Model 1) provides the details associated with the rating curve used in SWMHYMO. Runoff for this 0.689 ha area was generated using a single lumped catchment with a total C-Factor of 0.85 estimated from the weighted average of runoff coefficients for each sub catchment area.

Results of this simulation (Appendix 'D7' – Model 1) have shown that the overall storage volume of 212.36 m³ is sufficient to contain the 3 hour Chicago Design Storm event while releasing a maximum outflow of 74.0 L/s. The simulation results show that 211.90 m³ of the 212.36 m³ will be the maximum storage used during the 1:100 year storm event.

ICD No. 52

The ICD at CB 552 controls one catchment area totaling 0.085 ha. The catchment area has one surface storage cell as depicted on Drawing SWM which provides 35.70 m³ of storage. Based on the assigned ICD release rate of 4.0 L/s, the Modified Rational Method calculations (Appendix 'D4') show that the minimum storage volume requirement of 28.98 m³ generated during the 1:100 year storm event can be contained within the designed ponding area.

ICD No. 71

The ICD at CBMH 571 controls two (2) catchment areas totaling 0.333 ha. Within these catchment areas, there are two surface storage cells which provide 71.97 m³ and 26.44 m³ of storage. Based on the assigned ICD release rate of 18.0 L/s, the surface storage cells provide insufficient storage to contain the 1:100 year storm event. Consequently, an oversized 975 mm diameter catch basin lead is proposed between CBMH 570 and CBMH 571 to provide underground storage to supplement the surface storage provided.

The aforementioned above-ground storage of 98.41 m³ was, therefore, supplemented with underground storage of 30.85 m³ and 17.63 m³ for the oversized sewer and maintenance holes, respectively. Given that a significant volume of storage will be provided underground, the SWMHYMO software platform was used to assess storage volume requirements for this catchment (Refer to Appendix 'D7' - Model 3). Runoff for this 0.333 ha area was generated using a single lumped catchment with a total C-Factor of 0.83 estimated from the weighted average of runoff coefficients for each sub catchment area.

Results of this simulation (Appendix 'D7' – Model 3) have shown that the overall storage volume of 146.89 m³ is sufficient to contain the 3 hour Chicago Design Storm event while releasing a maximum outflow of 18.0 L/s. The simulation results show that 138.40 m³ of the 146.89 m³ will be the maximum storage used during the 1:100 year storm event.

ICD No. 72

The ICD at CBMH 572 controls one (1) catchment area totaling 0.053 ha. The catchment area has one (1) surface storage cell as depicted on Drawing SWM which provides 9.28 m³ of storage. Based on the assigned ICD release rate of 4.0 L/s, the Modified Rational Method calculations (Appendix 'D4') show that the minimum storage volume requirement of 5.43 m³ generated during the 1:100 year storm event can be contained within the designed ponding area.

ICD No. 80

The ICD at CB 580 controls one catchment area totaling 0.050 ha. The catchment area has one (1) surface storage cell as depicted on Drawing SWM which provides 4.35 m³ of storage. Based on the assigned ICD release rate of 13.0 L/s, the Modified Rational Method calculations (Appendix 'D4') show that the minimum storage volume requirement of 2.18 m³ generated during the 1:100 year storm event can be contained within the designed ponding area.

Table 4.3.3 below summarizes the aforementioned specific release rates and storage volumes associated with each ICD, refer to Appendix 'D4' for detailed Modified Rational Method calculations and Appendix 'D7' for SWMHYMO results.

ICD No.	Restricted Release Rate	ICD Type	STO _{REQ} (1:100 year)	Surface Storage Provided (m ³)	Underground Storage Provided (m ³)	Total Storage Provided (m³)
50	74.0	Custom ICD	044 00(2)	01.00		040.00
53	74.0	131 mm Ø	211.90(2)	61.82	150.54	212.30
52	4.0	50 VHV-1	28.98(1)	37.70	0	37.70
71	18.0	Custom ICD 66 mm Ø	138.40 ⁽²⁾	98.41	48.48	146.89
72	4.0	50 VHV-1	5.43(1)	9.28	0	9.28
80	13.0	100 VHV-1	2.18(1)	4.35	0	4.35
Total	113.0		386.89	211.56	199.02	410.58
	Notes: (1) Storage Requirement as per Modified Rational Method Calculations in Appendix 'D4' (2) Storage Requirement as per SWMHYMO results provided in Appendix 'D7' (3) As per SWMHYMO model provided in Appendix 'D7'					

Table 4.3.3: ICD and Storage Volume Characteristics

4.3.4 Uncontrolled Flow

CB 573 controls one (1) catchment area totaling 0.008 ha. Based on the total area, the Modified Rational Method calculations (Appendix 'D4') estimated a total 1:100 year peak flow of 2.11 L/s at CB 573.

4.3.5 Summary of Proposed Restricted Flows, Uncontrolled Flows, and Storage

The above stormwater flow determinations show that, with the implementation of ICDs and roof drains, the design provides sufficient storage onsite to attenuate peak flows to meet the 137.47 L/s minor system release rate criterion. The maximum peak flows and storage results are summarized in Table 4.3.4 below. As indicated in the Table below, the Commercial Plaza will release a maximum of 137.04 L/s to the existing downstream storm sewer system.

Flow Component	Flow Rate (L/s)	Max. Storage Requirement (m ³)	Storage Provided (m³)
Rooftop (controlled)	21.93	92.06	96.86
ICDs	113.0	388.46	410.58
Uncontrolled	2.11	N/A	N/A
Total	137.04	497.06	533.50

Table 4.3.4:	Flow	and	Storage	Results
	1 1011	ana	otorago	Resource

4.3.6 Overland Flow

A major overland flow route was designed for the site to outlet to Goulbourn Forced Road for storm events in excess of the 1:100 year event, in accordance with the criteria described in Section 4.2. Refer to the Grading Plan (Drawing G1) at the back of the Report for details.

4.3.7 Water Quality

Stormwater runoff from the Commercial Plaza is to be conveyed by both minor and major drainage systems to the Kizell Drain via Beaver Pond. This end-of-pipe facility was designed to provide stormwater quality control for the Commercial Plaza. Appendix 'D8' provides the details associated with the water quality treatment provided by the Kizell Drain and Beaver Pond. Consequently, there are no additional water quality measures proposed for the site servicing.

4.4 Summary and Conclusions

The storm and stormwater management solution presented in this Site Servicing Report was found to fulfill the water quantity criteria presented in Section 4.3.1. The calculated off-site overland flows and the restricted minor system flows were designed to be less than those allocated for the site as part of the Walden Village detailed design. Furthermore, the site has been designed with adequate surface and underground pipe storage to contain stormwater onsite up to the 1:100 year event. It is, therefore, recommended that the stormwater servicing shown on the Site Servicing Plan (Drawing S1) be implemented to provide adequate stormwater management for the Commercial Plaza.

5.0 Erosion and Sediment Control

During construction of the proposed site, appropriate erosion and sedimentation control measures, as outlined in the Ontario Ministry of Natural Resources (MNR) Guidelines on Erosion and Sediment Control for Urban Construction Sites, should be implemented to trap sediment on site.

As a minimum, the following erosion and sedimentation control measures are proposed, as shown on Drawing ESC:

- supply and installation of a silt fence barrier, as per OPSD 219.110;
- supply and installation of filter fabric between the frame and cover of catch basins and maintenance holes adjacent to the project area during construction, to prevent sediment from entering the existing sewer system. The filter fabric is to be inspected regularly and corrected as required;
- stockpiling of material during construction is to be located along flat areas away from drainage paths. For material placed on sloped areas, stockpiles are to be enclosed with a silt fence to protect watercourses;
- all catch basins are to be equipped with sumps, inspected frequently, and cleaned as required;
- sandbags are to be placed blocking part of the sewer pipe in the connecting storm maintenance holes to eliminate construction debris from entering the existing storm sewer system. The sandbags are to be removed after the proposed storm sewers have been fully cleaned.

The proposed erosion control measures shall conform to the following documents:

- "Guidelines on Erosion and Sediment Control for Urban Construction Sites" published by Ontario Ministries of Natural Resources, Environment, Municipal Affairs, and Transportation & Communication, Association of Construction Authorities of Ontario and Urban Development Institute, Ontario, May 1987.
- "MTO Drainage Manual", Chapter F: "Erosion of Materials and Sediment Control", Ministry of Transportation & Communications, 1985.
- "Erosion and Sediment Control" Training Manual by Ministry of Environment, Spring 1998.
- Applicable Regulations and Guidelines of the Ministry of Natural Resources.

6.0 Conclusion

This Servicing Report and the associated Drawings describe the servicing solutions to provide municipal services for the proposed Commercial Plaza at 5100 Kanata Avenue, in accordance with the City of Ottawa Design Guidelines. Construction details are to be in accordance with Local and Provincial design standards. It is recommended that this Servicing Report be reviewed with the intent of providing approval to permit the Owner to proceed with the presented servicing.

This report has been prepared for the exclusive use of Urbandale Corporation, for the stated purpose, for the named facility. Its discussions and conclusions are summary in nature and cannot be properly used, interpreted or extended to other purposes without a detailed understanding and discussions with the client as to its mandated purpose, scope and limitations. This report was prepared for the sole benefit and use of Urbandale Corporation and may not be used or relied on by any other party without the express written consent of J.L. Richards & Associates Limited.

This report is copyright protected and may not be reproduced or used, other than by Urbandale Corporation for the stated purpose, without the express written consent of J.L. Richards & Associates Limited.

J.L. RICHARDS & ASSOCIATES LIMITED

Prepared by:



Annie Williams, P.Eng.

Reviewed by:



Lucie Dalrymple, P.Eng.

Appendix A1

Block 111 Site Servicing Plan (S1) (Prepared by JLR, 2016)

GENERAL NOTES

- 1. ALL MATERIALS, SERVICES AND CONSTRUCTION METHODS TO BE IN ACCORDANCE WITH THE CITY OF OTTAWA CURRENT STANDARDS AND SPECIFICATIONS.
- 2. ALL DIMENSIONS SHOWN ON PLANS ARE IN METRES UNLESS OTHERWISE NOTED.
- 3. UNLESS OTHERWISE NOTED, DIMENSIONS FROM STREET LINE ARE TO THE CENTRELINE OF SEWER OR MANHOLE.
- 4. THE INSIDE DIAMETER OF PIPES ARE REFERRED TO IN PLAN VIEW AND THE OUTSIDE DIAMETER OF CONCRETE PIPES ARE DRAWN IN PROFILE VIEW.
- THE CONTRACTOR IS RESPONSIBLE TO DETERMINE THE EXACT LOCATION, SIZE, MATERIAL AND ELEVATION OF ALL SERVICES AND UTILITIES PRIOR TO CONSTRUCTION AND SHALL PROTECT AND ASSURE RESPONSIBILITY FOR ALL UTILITIES WHETHER OR NOT SHOWN ON THIS DRAWING.
- THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL EXCAVATION, BACKFILL, REINSTATEMENT OF ALL AREAS DISTURBED DURING CONSTRUCTION AND ALL ASSOCIATED WORKS TO THE SATISFACTION OF THE ENGINEER AND THE CITY OF OTTAWA.
- THE CONTRACTOR SHALL BE RESPONSIBLE TO DETERMINE, VIA EXCAVATION, THE EXACT LOCATION AND ELEVATION OF THE EXISTING WATERMAINS, SEWERS AND UNDERGROUND STRUCTURES AS REQUIRED FOR ALL CONNECTIONS, RELOCATIONS AND BLANKINGS.
- 8. EXCAVATION FOR THE INSTALLATION OF SERVICES ALONG OR IN PROXIMITY OF A BUILDING OR A STRUCTURE IS TO BE CONTAINED WITHIN A TRENCH BOX WIDTH AND IS TO ENSURE NO CONFLICT WITH ANY FUTURE FOOTINGS. SELECT SUBGRADE MATERIAL, COMPACTED TO 100% SPD TO 1.0m BELOW EXISTING GRADE FOR FULL TRENCH WIDTH OF DISTURBED AREA SHALL BE USED FOR BACKFILL, INCLUDING ALONG ANY SEWERS AND WATERMAINS ADJACENT TO A BUILDING OR OTHER STRUCTURE.

WATERMAIN NOTES

- EXISTING WATERMAIN INFORMATION SHOWN ON PLANS IS BASED ON BEST CURRENT INFORMATION. CONTRACTOR TO VERIFY EXACT LOCATION OF WATERMAIN AND APPURTENANCES. REPORT ANY DISCREPANCIES TO ENGINEER.
- 10. EXCAVATION, INSTALLATION, BACKFILL AND RESTORATION OF ALL WATERMAINS BY CONTRACTOR. NO WATERMAIN SITE WORK IS TO COMMENCE UNLESS THE CITY OF OTTAWA WATER WORKS INSPECTOR AND/OR CONSULTANT ARE PRESENT ON SITE TO WITNESS WORK.
- 11. WATERMAIN AND WATER SERVICE TO HAVE A MINIMUM OF 2.4 METERS OF COVER. INSULATION TO BE BE PROVIDED WHERE MINIMUM COVER CANNOT BE PROVIDED. WATERMAIN TO BE INSTALLED TO DEPTHS SHOWN ON PLANS.
- 12. WATERMAIN THRUST BLOCKS TO BE CONSTRUCTED PER CITY OF OTTAWA DETAILS W25.3 AND W25.4. THRUST BLOCKS ARE REQUIRED AT ALL BENDS, TEES, PLUGS, DEAD END CAPS, VALVES, REDUCERS OR OTHER FITTINGS WHERE CHANGES OCCUR IN PIPE DIAMETER OR DIRECTION ALL IN ACCORDANCE WITH CURRENT CITY OF OTTAWA STANDARDS AND SPECIFICATIONS.

SANITARY & STORM SEWER NOTES

- 13. SANITARY & STORM SEWERS TO BE REINFORCED CONCRETE, PVC, OR CITY APPROVED EQUIVALENT.
- 14. SANITARY & STORM SEWERS WITH LESS THAN 2.0m COVER SHALL BE INSULATED.

BLOCK 240

15. SANITARY & STORM MAINTENANCE HOLES TO BE CONCRETE PER OPSD 701.010 TO 701.013.

GRADING NOTES:

16. MATCH EXISTING ELEVATIONS AT ALL EXTERIOR PROPERTY LINES. ENSURE POSITIVE DRAINAGE TOWARD A SUITABLE OUTLET WHETHER INDICATED OR NOT.

Gaupe







Appendix A2

MOE Environmental Compliance Approval



Ministry of the Environment and Climate Change Ministère de l'Environnement et de l'Action en matière de changement climatique

ENVIRONMENTAL COMPLIANCE APPROVAL

NUMBER 4070-AN9PJ2 Issue Date: June 15, 2017

Urbandale Corporation 2193 Arch Street Ottawa, Ontario K1G 2H5

Site Location: 5100 Kanata Avenue and 130 Goulbourn Forced Road City of Ottawa

You have applied under section 20.2 of Part II.1 of the <u>Environmental Protection Act</u>, R.S.O. 1990, c. E. 19 (Environmental Protection Act) for approval of:

the construction stormwater and wastewater infrastructure to service the 1.7 hectare Hawthorn Retirement Group Residence at 130 Goulbourn Forced Road, as well as the 1.5 hectare Urbandale Corporation future commercial site at 5100 Kanata Avenue, in the City of Ottawa, consisting of;

Storm sewers running along the east side of the property at 130 Goulbourn Forced Road, from approximately 180 m south of Bryant Street, and then along 91 Broughton Street (Block 110) from approximately 105 m south of Bryant Street to Bryant Street, discharging through a 250 mm pipe to existing storm sewers on Bryant Street;

Sanitary sewers running along the east side of the property at 130 Goulbourn Forced Road, from approximately 180 m south of Bryant Street, and then along Broughton Street from approximately 105 m south of Bryant Street to approximately 72 m south of Bryant Street, discharging to existing sanitary sewers on Broughton Street;

Sanitary sewers on Bryant Street from Block 110, discharging to existing sanitary sewers on Bryant Street;

including erosion/sedimentation control measures during construction and all other controls and appurtenances essential for the proper operation of the aforementioned Works;

all in accordance with the submitted application and supporting documents listed in Schedule "A" forming part of this Approval.

For the purpose of this environmental compliance approval, the following definitions apply:

"Approval" means this entire document and any schedules attached to it, and the application;

"Director" means a person appointed by the Minister pursuant to section 5 of the EPA for the purposes of Part II.1 of the EPA;

"District Manager" means the District Manager of the appropriate local District Office of the Ministry, where the Works are geographically located;

"EPA" means the Environmental Protection Act, R.S.O. 1990, c.E.19, as amended;

"Ministry" means the ministry of the government of Ontario responsible for the EPA and OWRA and includes all officials, employees or other persons acting on its behalf;

"Owner" means Urbandale Corporation, and includes its successors and assignees;

"OWRA" means the Ontario Water Resources Act, R.S.O. 1990, c. O.40, as amended;

"Works" means the sewage works described in the Owner's application, and this Approval.

You are hereby notified that this environmental compliance approval is issued to you subject to the terms and conditions outlined below:

TERMS AND CONDITIONS

1. <u>GENERAL CONDITIONS</u>

- (1) The Owner shall ensure that any person authorized to carry out work on or operate any aspect of the Works is notified of this Approval and the conditions herein and shall take all reasonable measures to ensure any such person complies with the same.
- (2) Except as otherwise provided by these Conditions, the Owner shall design, build, install, operate and maintain the Works in accordance with the description given in this Approval, and the application for approval of the Works.
- (3) Where there is a conflict between a provision of any document in the schedule referred to in this Approval and the conditions of this Approval, the conditions in this Approval shall take precedence, and where there is a conflict between the documents in the schedule, the document bearing the most recent date shall prevail.
- (4) Where there is a conflict between the documents listed in Schedule 'A' and the application,

the application shall take precedence unless it is clear that the purpose of the document was to amend the application.

(5) The conditions of this Approval are severable. If any condition of this Approval, or the application of any requirement of this Approval to any circumstance, is held invalid or unenforceable, the application of such condition to other circumstances and the remainder of this Approval shall not be affected thereby.

2. <u>EXPIRY OF APPROVAL</u>

- (1) This Approval will cease to apply to those parts of the Work which have not been constructed within five (5) years of the date of this Approval.
- (2) In the event that completion and commissioning of any portion of the Works is anticipated to be delayed beyond the specified expiry period, the Owner shall submit an application of extension to the expiry period, at least twelve (12) months prior to the end of the period. The application for extension shall include the reason(s) for the delay, whether there is any design change(s) and a review of whether the standards applicable at the time of Approval of the Works are still applicable at the time of request for extension, to ensure the ongoing protection of the environment.

3. <u>CHANGE OF OWNER</u>

- (1) The Owner shall notify the District Manager and the Director, in writing, of any of the following changes within thirty (30) days of the change occurring:
 - (a) change of Owner;
 - (b) change of address of the Owner;
 - (c) change of partners where the Owner is or at any time becomes a partnership, and a copy of the most recent declaration filed under the <u>Business Names Act</u>, R.S.O. 1990, c.B17 shall be included in the notification to the District Manager; or
 - (d) change of name of the corporation where the Owner is or at any time becomes a corporation, and a copy of the most current information filed under the <u>Corporations</u> <u>Information Act</u>, R.S.O. 1990, c. C39 shall be included in the notification to the District Manager.
- (2) In the event of any change in ownership of the Works, other than a change to a successor municipality, the Owner shall notify in writing the succeeding owner of the existence of this Approval, and a copy of such notice shall be forwarded to the District Manager and the Director.
- (3) The Owner shall ensure that all communications made pursuant to this condition refer to the

number at the top of this Approval.

(4) Notwithstanding any other requirements in this Approval, upon transfer of the ownership or assumption of the Works to a municipality if applicable, any reference to the District Manager shall be replaced with the Water Supervisor.

4. **OPERATION AND MAINTENANCE**

(1) If applicable, any proposed storm sewers or other stormwater conveyance in this Approval can be constructed but not operated until the proposed stormwater management facilities in this Approval or any other Approval that are designed to service the storm sewers or other stormwater conveyance are in operation.

Schedule "A"

Application for Environmental Compliance Approval for Municipal and Private Sewage Works, dated January 4, 2017 and received on April 26, 2017, submitted by Urbandale Corporation;

Pipe Data Sheet, prepared by J.L. Richards & Associates Limited;

<u>Block 111 – 5100 Kanata Avenue – Servicing Report</u>, dated September 2015 prepared by J.L. Richards & Associates Limited;

Engineering Drawings: Urbandale Corporation – Block 111, dated October 2016, prepared by J.L. Richards & Associates Limited; and

E-mail from Hilary MacKay of .L. Richards & Associates Limited to the MOECC, dated June 13, 2017;

The reasons for the imposition of these terms and conditions are as follows:

- 1. Condition 1 is imposed to ensure that the Works are constructed and operated in the manner in which they were described and upon which approval was granted. This condition is also included to emphasize the precedence of conditions in the Approval and the practice that the Approval is based on the most current document, if several conflicting documents are submitted for review.
- 2. Condition 2 is included to ensure that, when the Works are constructed, the Works will meet the standards that apply at the time of construction to ensure the ongoing protection of the environment.
- 3. Condition 3 is included to ensure that the Ministry records are kept accurate and current with respect to approved Works and to ensure that subsequent owners of the Works are made aware of the Approval and continue to operate the Works in compliance with it.
- 4. Condition 4 is included to prevent the operation of stormwater pipes and other conveyance until such time that their required associated stormwater management Works are also constructed.

In accordance with Section 139 of the Environmental Protection Act, you may by written Notice served upon me and the Environmental Review Tribunal within 15 days after receipt of this Notice, require a hearing by the Tribunal. Section 142 of the Environmental Protection Act provides that the Notice requiring the hearing shall state:

- a. The portions of the environmental compliance approval or each term or condition in the environmental compliance approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The Notice should also include:

- 1. The name of the appellant;
- 2. The address of the appellant;
- 3. The environmental compliance approval number;
- 4. The date of the environmental compliance approval;
- 5. The name of the Director, and;
- 6. The municipality or municipalities within which the project is to be engaged in.

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

		The Director appointed for the purposes of
The Secretary*		Part II.1 of the Environmental Protection Act
Environmental Review Tribunal		Ministry of the Environment and
655 Bay Street, Suite 1500	AND	Climate Change
Toronto, Ontario		135 St. Clair Avenue West, 1st Floor
M5G 1E5		Toronto, Ontario
		M4V 1P5

* Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349, Fax: (416) 326-5370 or www.ert.gov.on.ca

The above noted activity is approved under s.20.3 of Part II.1 of the Environmental Protection Act.

DATED AT TORONTO this 15th day of June, 2017

Gregory Zimmer, P.Eng. Director appointed for the purposes of Part II.1 of the *Environmental Protection Act*

EC/

c: District Manager, MOECC Ottawa Hilary MacKay, P.Eng., J.L. Richards & Associates Limited

Appendix A3

City of Ottawa Development Servicing Checklist

UBANDALE COMMERCIAL PLAZA 5100 KANATA AVENUE

DEVELOPMENT SERVICING STUDY CHECKLIST

REFERENCED STUDIES AND REPORTS	REFERENCE
Servicing Study, Commercial Plaza 5100 Kanata Avenue, prepared by J.L. Richards & Associates Limited dated March 21, 2018	SSR

4.1	GENERAL CONTENT	REFERENCE
	Executive Summary (for larger reports only).	N/A
	Date and revision number of the report.	SSR (Title Page)
	Location map and plan showing municipal address, boundary, and layout of proposed development.	SSR (Figure 1)
	Plan showing the site and location of all existing services.	Site Servicing Plan (S1)
	Development statistics, land use, density, adherence to zoning and official plan, and reference to applicable subwatershed and watershed plans that provide context to which individual developments must adhere.	N/A
	Summary of Pre-consultation Meetings with City and other approval agencies.	
	Reference and confirm conformance to higher level studies and reports (Master Servicing Studies, Environmental Assessments, Community Design Plans), or in the case where it is not in conformance, the proponent must provide justification and develop a defendable design criteria.	SSR (Section 1.1)
	Statement of objectives and servicing criteria.	SSR (Sect. 1.0; 2.1; 2.2; 2.3; 3.2; 4.2)
	Identification of existing and proposed infrastructure available in the immediate area.	SSR (Sect. 1.1; 1.3;)
	Identification of Environmentally Significant Areas, watercourses and Municipal Drains potentially impacted by the proposed development (Reference can be made to the Natural Heritage Studies, if available).	N/A
	Concept level master grading plan to confirm existing and proposed grades in the development. This is required to confirm the feasibility of proposed stormwater management and drainage, soil removal and fill constraints, and potential impacts to neighbouring properties. This is also required to confirm that the proposed grading will not impede existing major system flow paths.	Grading Plan (G1)
	Identification of potential impacts of proposed piped services on private services (such as wells and septic fields on adjacent lands) and mitigation required to address potential impacts.	N/A

Proposed phasing of the development, if applicable.	N/A
Reference to geotechnical studies and recommendations concerning servicing.	Site Servicing Plan (S1)
 All preliminary and formal site plan submissions should have the following information: Metric scale North arrow (including construction North) Key plan Name and contact information of applicant and property owner Property limits, including bearings and dimensions Existing and proposed structures and parking areas Easements, road widening and rights-of-way Adjacent street names 	All Drawings

4.2	DEVELOPMENT SERVICING REPORT: WATER	REFERENCE
	Confirm consistency with Master Servicing Study, if available.	N/A
	Availability of public infrastructure to service proposed development.	Site Servicing Plan (S1)
\boxtimes	Identification of system constraints.	SSR (Sect.1.1; 1.3)
\boxtimes	Identify boundary conditions.	SSR (Sect. 2.6; Table 2.6; Appendix B4)
\square	Confirmation of adequate domestic supply and pressure.	SSR (Sect. 2.7.1; Appendix B5;)
	Confirmation of adequate fire flow protection and confirmation that fire flow is calculated as per the Fire Underwriter's Survey. Output should show available fire flow at locations throughout the development.	SSR (Sect. 2.7.2; Appendix B6)
	Provide a check of high pressures. If pressure is found to be high, an assessment is required to confirm the application of pressure reducing valves.	SSR (Sect. 2.7.3; Appendix B7)
	Definition of phasing constraints. Hydraulic modelling is required to confirm servicing for all defined phases of the project, including the ultimate design.	SSR (Sect. 2.7)
	Address reliability requirements, such as appropriate location of shutoff valves.	Site Servicing Plan (S1)
	Check on the necessity of a pressure zone boundary modification.	SSR (Sect. 2.7)
	Reference to water supply analysis to show that major infrastructure is capable of delivering sufficient water for the proposed land use. This includes data that shows that the expected demands under average day, peak hour and fire flow conditions provide water within the required pressure range.	SSR (Sect 2.7.1; 2.7.2; 2.7.5; Appendices B5, B6; B7)
Description of the proposed water distribution network, including locations of proposed connections to the existing system, provisions for necessary looping, and appurtenances (valves, pressure reducing valves, valve chambers, and fire hydrants), including special metering provisions.	SSR (Sect. 2.9) Site Servicing Plan (S1)	
--	--	
Description of off-site required feedermains, booster pumping stations, and other water infrastructure that will be ultimately required to service proposed development, including financing, interim facilities, and timing of implementation.	N/A	
Confirmation that water demands are calculated based on the City of Ottawa Design Guidelines.	SSR (Sect. 2.3; Appendix B1)	
Provision of a model schematic showing the boundary conditions locations, streets, parcels, and building locations for reference.	Site Servicing Plan (S1), SSR Appendix B3	

4.3	DEVELOPMENT SERVICING REPORT: WASTEWATER	REFERENCE	
	Summary of proposed design criteria (Note: Wet weather flow criteria should not deviate from the City of Ottawa Sewer Design Guidelines. Monitored flow data from relatively new infrastructure cannot be used to justify capacity requirements for proposed infrastructure).	SSR (Sect. 3.2)	
	Confirm consistency with Master Servicing Study and/or justifications for deviations.	N/A	
	Consideration of local conditions that may contribute to extraneous flows that are higher than the recommended flows in the Guidelines. This includes groundwater and soil conditions, and age and condition of sewers.	N/A	
	Description of existing sanitary sewer available for discharge of wastewater from proposed development.	SSR (Sect. 1.3; 3.1)	
	Verify available capacity in downstream sanitary sewer and/or identification of upgrades necessary to service the proposed development. (Reference can be made to previously completed Master Servicing Study if applicable.)	SSR (Sect. 3.3)	
	Calculations related to dry weather and wet weather flow rates from the development in standard MOE sanitary sewer design table (Appendix 'C') format.	N/A	
	Description of proposed sewer network, including sewers, pumping stations and forcemains.	SSR (Sect. 3.4) Site Servicing Plan (S1)	
	Discussion of previously identified environmental constraints and impact on servicing (environmental constraints are related to limitations imposed on the development in order to preserve the physical condition of watercourses, vegetation, soil cover, as well as protecting against water quantity and quality).	N/A	

Pumping stations: impacts of proposed development on existing pumping stations or requirements for new pumping station to service development.	N/A
Forcemain capacity in terms of operational redundancy, surge pressure and maximum flow velocity.	N/A
Identification and implementation of the emergency overflow from sanitary pumping stations in relation to the hydraulic grade line to protect against basement flooding.	N/A
Special considerations, such as contamination, corrosive environment, etc.	N/A

4.4	DEVELOPMENT SERVICING REPORT: STORMWATER	REFERENCE
	Description of Drainage outlets and downstream constraints, including legality of outlets (i.e., municipal drain, right-of-way, watercourse, or private property).	SSR (Sect. 4.1)
	Analysis of available capacity in existing public infrastructure.	SSR (Sect. 4.1)
	A Drawing showing the subject lands, its surroundings, the receiving watercourse, existing drainage patterns, and proposed drainage pattern.	SSR (Figure 1) Site Servicing Plan (S1)
	Water quantity control objective (e.g. controlling post-development peak flows to pre-development level for storm events ranging from the 2 or 5 year event (dependent on the receiving sewer design) to 100 year return period); if other objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into account long-term cumulative effects.	SSR (4.3; Appendix D3,D4)
	Water Quality control objective (basic, normal or enhanced level of protection based on the sensitivities of the receiving watercourse) and storage requirements.	SSR (Sect. 4.2)
	Description of the stormwater management concept with facility locations and descriptions with references and supporting information.	SSR (Sect. 4.3)
	Setback from private sewage disposal systems.	N/A
	Watercourse and hazard lands setbacks.	N/A
	Record of pre-consultation with the Ontario Ministry of Environment and the Conservation Authority that has jurisdiction on the affected watershed.	SSR (Sect. 1.4; Appendix A2)
	Confirm consistency with subwatershed and Master Servicing Study, if applicable study exists.	N/A

Storage requirements (complete with calculations) and conveyance capacity for minor events (1:5 year return period) and major events (1:100 year return period).	SSR (Sect.4.3; Appendices D3 & D4)
Identification of watercourses within the proposed development and how watercourses will be protected, or, if necessary, altered by the proposed development with applicable approvals.	N/A
Calculate pre- and post-development peak flow rates, including a description of existing site conditions and proposed impervious areas and drainage catchments in comparison to existing conditions.	SSR (Sect. 4.1; 4.3; Appendices D3 & D4)
Any proposed diversion of drainage catchment areas from one outlet to another.	N/A
Proposed minor and major systems, including locations and sizes of stormwater trunk sewers, and stormwater management facilities.	SSR (Sect. 4.4) Site Servicing Plan (S1)
If quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100-year return period storm event.	N/A
Identification of potential impacts to receiving watercourses.	N/A
Identification of municipal drains and related approval requirements.	N/A
Description of how the conveyance and storage capacity will be achieved for the development.	SSR (Sect 4.3; 4.4)
100 year flood levels and major flow routing to protect proposed development from flooding for establishing minimum building elevations (MBE) and overall grading.	SSR (Sect 4.3) Site Servicing Plan (S1)
Inclusion of hydraulic analysis, including hydraulic grade line elevations.	
Description of approach to erosion and sediment control during construction for the protection of receiving watercourse or drainage corridors.	SSR (Sect. 5.0) Erosion & Sediment Control Plan (ESC)
Identification of floodplains – proponent to obtain relevant floodplain information from the appropriate Conservation Authority. The proponent may be required to delineate floodplain elevations to the satisfaction of the Conservation Authority if such information is not available or if information does not match current conditions.	N/A
Identification of fill constraints related to floodplain and geotechnical investigation.	N/A

4.5 APPROVAL AND PERMIT REQUIREMENTS REFERENCE	
--	--

The Servicing Study shall provide a list of applicable permits and regulatory approvals necessary for the proposed development, as well as the relevant issues affecting such approval. The approval and permitting shall include but not be limited to the following: \square Conservation Authority as the designated approval agency for modification N/A of floodplain, potential impact on fish habitat, proposed works in or adjacent to a watercourse, cut/fill permits and Approval under Lakes and Rivers Improvement Act. The Conservation Authority is not the approval authority for the Lakes and Rivers Improvement Act. Where there are Conservation Authority regulations in place, approval under the Lakes and Rivers Improvement Act is not required, except in cases of dams, as defined in the Act. \boxtimes Application for Environmental Compliance Approval (ECA) under the N/A Ontario Water Resources Act. Changes to Municipal drains. N/A Other permits (National Capital Commission, Parks Canada, Public Works N/A and Government Services Canada, Ministry of Transportation, etc.).

4.6	CONCLUSION CHECKLIST	REFERENCE
\boxtimes	Clearly stated conclusions and recommendations.	SSR (Sect. 2.9; 3.4; 4.4)
	Comments received from review agencies, including the City of Ottawa and information on how the comments were addressed. Final sign-off from the responsible reviewing agency.	
	All draft and final reports shall be signed and stamped by a Professional Engineer registered in Ontario.	SSR (Section 5.0)

Hydraulic Network Analysis (Water Distribution System)

Water Demands

COMMERCIAL PLAZA 5100 Kanata Avenue

	BLDG FOOTPRINT	BLDG AREA	AREA DISTRIBUTION	JUNCTION ID	DEMAND (L/s)		
BUILDING ID	(m2)	DISTRIBUTION (ha) FACTO	FACTOR		Avg Day	Max Day	Peak Hour
А	405	0.17	0.11	J-9	0.10	0.15	0.27
В	970	0.40	0.25	J-10	0.23	0.35	0.63
С	875	0.36	0.23	J-11	0.21	0.31	0.56
D	1,050	0.43	0.27	J-12	0.25	0.37	0.67
E	530	0.22	0.14	J-13	0.13	0.19	0.34
TOTAL	3,830	1.58	1.00		0.92	1.37	2.47

Commercial Consumption				
Total Site Area	1.58	ha		
Average Day Demand	25,000	L/ha/day		
Maximum Day Demand (1.5 x Avg Day)	37,500	L/ha/day		
Peak Hour Demand (1.8 x Max Day)	67,500	L/ha/day		

*NOTE - A 12 hour business day was assumed.

FUS Calculations

November 5th, 2019

VIA Email

City of Ottawa Planning, Transit and the Environment 110 Laurier Avenue West Ottawa, ON, K1P 1J1

Attention: Stream Shen Planner II Development Review - West Re: File Number: D07-12-18-0063 5100 Kanata Avenue Site Plan Control Application

In response to your letter of comments to Urbandale Corporation dated October 15th, 2019 we wish to comment as follows:

Engineering:

C2 Response: The sprinkler system installed within the building will meet NFPA 13 requirements and be supervised.

C3 Response: The roof drains and scuppers will be installed to meet the requirements of Section 7.4.10.4 (2)(c) to (e) and (3).

If you have any further questions or require any further clarification, please contact me at your earliest convenience.

Yours Truly,

JRP Engineering

Michael Karakolis, P.Eng



FUS Fire Flow Calculations - BLDG A

5100 Kanata Ave - Commercial Plaza

Step	Parameter	Value		Note
Α	Type of Construction	Wood Frame		
	Coefficient (C)	1.5		_
В	Ground Floor Area	405	m²	
с	Height in storeys	1	storeys	
	Total Floor Area	405	m ²	_
D	Fire Flow Formula	F=220C√A		
	Fire Flow	6641	L/min	
	Rounded Fire Flow	7000	L/min	Flow rounded to nearest 1000 I /min
F	Occupancy Class	Combustible	2,	
-	Occupancy Charge	0%		
	Occupancy Increase or	075		
	Decrease	0		
	Fire Flow	7000	L/min	No rounding applied.
F	Sprinkler Protection	Automatic Fully Supervised		0 11
	Sprinkler Credit	-50%		_
	Decrease for Sprinkler	-3500	L/min	_
G	North Side Exposure		-,	
-	Exposing Wall	Wood Frame		
	Exposed Wall:	Wood Frame		
	Length of Exposed Wall	21.0	m	
	Height of Exposed Wall:	1	storevs	
	Length-Height Factor	21.0	m-storeys	
	Senaration Distance	23.5	m	
	North Side Exposure	25.5		
	Charge	8%		
	East Side Exposure			_
	Exposing Wall:	Wood Frame		
	Exposed Wall:	Wood Frame		
	Length of Exposed Wall:	0.0	m	
	Height of Exposed Wall:	0	storeys	
	Length-Height Factor	0.0	m-storeys	
	Separation Distance	100	, m	
	East Side Exposure Charge	0%		_
	South Side Exposure			_
	Exposing Wall:	Wood Frame		
	Exposing Wall:	Wood Frame		
	Exposed Wall.		m	
	Length of Exposed Wall:	0.0	storours	
	Longth Lloight Faster	9	storeys	
	Length-Height Factor	0.0	m-storeys	
	South Side Exposure	100	111	_
	Charge	0%		
	West Side Exposure			_
	Exposing Wall:	Wood Frame		
	Exposed Wall:	Wood Frame		
	Length of Exposed Wall	16.0	m	
	Height of Exposed Wall	2	storevs	
	Length-Height Factor	32.0	m-storevs	
	Separation Distance	45	m	
	West Side Exposure			—
	Charge	5%		
	Total Exposure Charge	13%		The total exposure charge is below the maximum value of 75%.
	Increase for Exposures	910	L/min	
н	Fire Flow	4410	L/min	
	Rounded Fire Flow	4000	L/min	Flow rounded to nearest 1000 L/min.
	Required Fire Flow		_,	The City of Ottawa's cap does not apply since this is a
City Cap	(RFF)	4000	L/min	commercial building.
		67	L/S	

Fire Underwriters Survey (FUS) Fire Flow Calculations

FUS Fire Flow Calculations - BLDG B

5100 Kanata Ave - Commercial Plaza

Step	Parameter	Value		Note
А	Type of Construction	Non-combustible		
	Coefficient (C)	0.8		
В	Ground Floor Area	970	m²	
с	Height in storeys	1	storeys	
	Total Floor Area	970	m ²	
D	Fire Flow Formula	F=220C√A		
	Fire Flow	5481	L/min	
	Rounded Fire Flow	5000	, L/min	Flow rounded to nearest 1000 L/min.
F	Occupancy Class	Combustible	,	
-	Occupancy Charge	0%	_	
	Occupancy Increase or			
	Decrease	0		
	Fire Flow	5000	L/min	No rounding applied.
F	Sprinkler Protection	Automatic Fully Supervised		
	Sprinkler Credit	-50%		—
	Decrease for Sprinkler	-2500	L/min	—
G	North Side Exposure		•	
	Exposing Wall:	Non-combustible		
	Exposed Wall:	Non-combustible		
	Length of Exposed Wall:	20.0	m	
	Height of Exposed Wall	1	storevs	
	Length-Height Factor	20.0	m-storevs	
	Separation Distance	22	m	
	North Side Exposure			—
	Charge	8%		
	East Side Exposure			
	Exposing Wall:	Non-combustible		
	Exposed Wall:	Wood Frame		
	Length of Exposed Wall:	54.0	m	
	Height of Exposed Wall:	2	storeys	
	Length-Height Factor	108.0	m-storeys	
	Separation Distance	22.5	m	
	East Side Exposure Charge	10%		_
	South Side Exposure			—
	Exposing Wall:	Non-combustible		
	Exposed Wall:	Non-combustible		
	Length of Exposed Wall	0.0	m	
	Height of Exposed Wall:	0	storevs	
	Length-Height Factor	0.0	m-storeys	
	Senaration Distance	100	m	
	South Side Exposure	100		—
	Charge	0%		
	West Side Exposure			_
	Exposing Wall:	Non-combustible		
	Exposed Wall:	Wood Frame		
	Length of Exposed Wall:	18.0	m	
	Height of Exposed Wall:	1	storeys	
	Length-Height Factor	18.0	m-storeys	
	Separation Distance	65	m	
	West Side Exposure	00/		_
	Charge	U%		
	Total Exposure Charge	18%		The total exposure charge is below the maximum value of 75%.
. <u></u>	Increase for Exposures	900	L/min	
н	Fire Flow	3400	L/min	
	Rounded Fire Flow	3000	L/min	Flow rounded to nearest 1000 L/min.
City Can	Required Fire Flow	3000	L/min	The City of Ottawa's cap does not apply since this is a
, c up	(RFF)	50	_,	commercial building.

Fire Underwriters Survey (FUS) Fire Flow Calculations

FUS Fire Flow Calculations - BLDG C

5100 Kanata Ave - Commercial Plaza

Step	Parameter	Value		Note
Α	Type of Construction	Non-combustible		
	Coefficient (C)	0.8		_
В	Ground Floor Area	875	m²	
С	Height in storeys	1	storeys	
	Total Floor Area	875	m²	=
D	Fire Flow Formula	F=220C√A		
	Fire Flow	5206	L/min	
	Rounded Fire Flow	5000	L/min	Flow rounded to nearest 1000 L/min.
E	Occupancy Class	Combustible	,	
	Occupancy Charge	0%		
	Occupancy Increase or	0		
	Decrease	0		
	Fire Flow	5000	L/min	No rounding applied.
F	Sprinkler Protection	None		_
	Sprinkler Credit	0%		
	Decrease for Sprinkler	0	L/min	
G	North Side Exposure			
	Exposing Wall:	Non-combustible		
	Exposed Wall:	Wood Frame		
	Length of Exposed Wall:	49.0	m	
	Height of Exposed Wall:	1	storeys	
	Length-Height Factor	49.0	m-storeys	
	Separation Distance	7.8	m	
	North Side Exposure	199/		=
	Charge	18%		_
	East Side Exposure			
	Exposing Wall:	Non-combustible		
	Exposed Wall:	Wood Frame		
	Length of Exposed Wall:	20.0	m	
	Height of Exposed Wall:	2	storeys	
	Length-Height Factor	40.0	m-storeys	
	Separation Distance	33.5	m	_
	East Side Exposure Charge	5%		
	South Side Exposure			_
	Exposing Wall:	Non-combustible		
	Exposed Wall:	Non-combustible		
	Length of Exposed Wall:	20.0	m	
	Height of Exposed Wall:	1	storeys	
	Length-Height Factor	20.0	m-storeys	
	Separation Distance	22	m	
	South Side Exposure	8%		_
	Charge	070		_
	West Side Exposure			
	Exposing Wall:	Non-combustible		
	Exposed Wall:	Non-combustible		
	Length of Exposed Wall:	20.0	m	
	Height of Exposed Wall:	1	storeys	
	Length-Height Factor	20.0	m-storeys	
	Separation Distance	27	m	_
	west Side Exposure Charge	8%		
	Total Exposure Charge	39%		 The total exposure charge is below the maximum value of 75%.
	Increase for Exposures	1950	L/min	
н	Fire Flow	6950	L/min	
	Rounded Fire Flow	7000	L/min	Flow rounded to nearest 1000 L/min.
City Cap	Required Fire Flow (RFF)	7000	L/min	The City of Ottawa's cap does not apply since this is a commercial building.
	<u>, 1</u>	117	L/s	

Fire Underwriters Survey (FUS) Fire Flow Calculations

FUS Fire Flow Calculations - BLDG D

5100 Kanata Ave - Commercial Plaza

Step	Parameter	Value		Note
Α	Type of Construction	Non-combustible		
	Coefficient (C)	0.8		
В	Ground Floor Area	1050	m ²	
с	Height in storeys	1	storeys	
	Total Floor Area	1050	m ²	—
D	Fire Flow Formula	F=220C√A		
	Fire Flow	5703	L/min	
	Rounded Fire Flow	6000	L/min	Flow rounded to nearest 1000 L/min.
E	Occupancy Class	Combustible		
	Occupancy Charge	0%	_	
	Occupancy Increase or	0		
	Decrease	U		
	Fire Flow	6000	L/min	No rounding applied.
F	Sprinkler Protection	Automatic Fully Supervised		
	Sprinkler Credit	-50%		
	Decrease for Sprinkler	-3000	L/min	
G	North Side Exposure			
	Exposing Wall:	Non-combustible		
	Exposed Wall:	Non-combustible		
	Length of Exposed Wall:	53.0	m	
	Height of Exposed Wall:	3	storeys	
	Length-Height Factor	159.0	m-storeys	
	Separation Distance	25	m	
	North Side Exposure	10%		—
	Charge	10%		
	East Side Exposure			
	Exposing Wall:	Non-combustible		
	Exposed Wall:	Non-combustible		
	Length of Exposed Wall:	20.0	m	
	Height of Exposed Wall:	1	storeys	
	Length-Height Factor	20.0	m-storeys	
	Separation Distance	27	m	
	East Side Exposure Charge	8%		
	South Side Exposure			—
	Exposing Wall:	Non-combustible		
	Exposed Wall:	Wood Frame		
	Length of Exposed Wall:	26.5	m	
	Height of Exposed Wall:	1	storeys	
	Length-Height Factor	26.5	m-storeys	
	Separation Distance	34	m	
	South Side Exposure	F0/		_
	Charge	370		_
	West Side Exposure			
	Exposing Wall:	Non-combustible		
	Exposed Wall:	Wood Frame		
	Length of Exposed Wall:	20.0	m	
	Height of Exposed Wall:	2	storeys	
	Length-Height Factor	40.0	m-storeys	
	Separation Distance	35	m	
	West Side Exposure Charge	5%		
	Total Exposure Charge	28%		The total exposure charge is below the maximum value
	Increase for Exposures	1680	L/min	
н	Fire Flow	4680	L/min	
	Rounded Fire Flow	5000	L/min	Flow rounded to nearest 1000 L/min.
City Cap	Required Fire Flow	5000	L/min	The City of Ottawa's cap does not apply since this is a
-	<u>(NFF)</u>	83	L/s	

Fire Underwriters Survey (FUS) Fire Flow Calculations

FUS Fire Flow Calculations - BLDG E

5100 Kanata Ave - Commercial Plaza

Step	Parameter	Value		Note
Α	Type of Construction	Wood Frame		
	Coefficient (C)	1.5		_
В	Ground Floor Area	530	m²	
С	Height in storeys	1	storeys	
	Total Floor Area	530	m ²	
D	Fire Flow Formula	F=220C√A		
	Fire Flow	7597	L/min	
	Rounded Fire Flow	8000	L/min	Flow rounded to nearest 1000 L/min.
E	Occupancy Class	Combustible		
	Occupancy Charge	0%		
	Occupancy Increase or	0		
	Decrease	0		
	Fire Flow	8000	L/min	No rounding applied.
F	Sprinkler Protection	None		_
	Sprinkler Credit	0%		_
	Decrease for Sprinkler	0	L/min	
G	North Side Exposure			
	Exposing Wall:	Wood Frame		
	Exposed Wall:	Wood Frame		
	Length of Exposed Wall:	26.5	m	
	Height of Exposed Wall:	1	storeys	
	Length-Height Factor	26.5	m-storeys	
	Separation Distance	34	m	_
	North Side Exposure	5%		
	Charge			_
	Eust Side Exposure	Wood Frame		
	Exposing Wall:	Wood Frame		
	Length of Exposed Wall:		m	
	Height of Exposed Wall:	0.0	storeys	
	Length-Height Factor	0.0	m-storeys	
	Senaration Distance	100	m	
	East Side Exposure Charge	200		_
	Courth Cida European			_
	South Side Exposure	Mood Frame		
	Exposing Wall.	Wood Frame		
	Exposed Wall.	wood Frame		
	Length of Exposed Wall:	21:0	storous	
	Height of Exposed Wall.	1	storeys	
	Length-Height Factor	21.0	m	
	South Side Exposure	23.5		_
	Charge	8%		
	West Side Exposure			—
	Exposing Wall:	Wood Frame		
	Exposed Wall:	Wood Frame		
	Length of Exposed Wall:	20.0	m	
	Height of Exposed Wall:	2	storeys	
	Length-Height Factor	40.0	m-storeys	
	Separation Distance	40	m	_
	West Side Exposure Charge	5%		
	Total Exposure Charge	18%		The total exposure charge is below the maximum value
	Increase for Exposures	1440	L/min	
н	Fire Flow	9440	L/min	
	Rounded Fire Flow	9000	L/min	Flow rounded to nearest 1000 L/min.
City Cap	Required Fire Flow (RFF)	9000	L/min	The City of Ottawa's cap does not apply since this is a commercial building.
	<u>, </u>	150	L/s	

Fire Underwriters Survey (FUS) Fire Flow Calculations

Overall Schematic



Hydraulic Boundary Conditions

5100 Kanata Avenue Boundary Conditions

Information Provided:

Date provided: October 2017

	Demand					
Scenario	L/min	L/s				
Average Daily Demand	52.8	0.9				
Maximum Daily Demand	79.2	1.3				
Peak Hour	142.8	2.4				
Fire Flow Demand	11000	183.3				

Location:



Results:

Connection 1 - Goulbourn Forced Rd

Demand Scenario	Head (m)	Pressure ¹ (psi)
Maximum HGL	162.3	83.6
Peak Hour	157.8	77.2
Max Day plus Fire (11,000 l/min)	151.7	68.5

¹ Ground Elevation = 103.5 m

Notes:

- 1) As per the Ontario Building Code in areas that may be occupied, the static pressure at any fixture shall not exceed 552 kPa (80 psi.) Pressure control measures to be considered are as follows, in order of preference:
 - a) If possible, systems to be designed to residual pressures of 345 to 552 kPa (50 to 80 psi) in all occupied areas outside of the public right-of-way without special pressure control equipment.
 - b) Pressure reducing valves to be installed immediately downstream of the isolation valve in the home/ building, located downstream of the meter so it is owner maintained.

Disclaimer

The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of watermains deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation. Fire Flow analysis is a reflection of available flow in the watermain; there may be additional restrictions that occur between the watermain and the hydrant that the model cannot take into account.

Peak Hour Simulation Results

Commercial Plaza - 5100 Kanata Avenue Peak Hour Demand



Commercial Plaza - 5100 Kanata Avenue

Peak Hour Demand

Junction Table

Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
J-9	108.15	0.27	157.79	486
J-14	107.95	0.00	157.80	488
J-13	107.82	0.34	157.77	489
J-15	107.80	0.00	157.80	489
J-11	107.72	0.56	157.79	490
J-12	107.72	0.67	157.79	490
J-10	107.67	0.63	157.79	491
J-6	107.49	0.00	157.79	492
J-1	107.42	0.00	157.80	493
J-5	107.38	0.00	157.79	493
J-17	107.32	0.00	157.79	494
J-7	107.30	0.00	157.79	494
J-4	107.29	0.00	157.79	494
J-16	107.29	0.00	157.80	494
J-2	107.28	0.00	157.80	494
J-18	107.22	0.00	157.80	495
J-3	107.16	0.00	157.79	496

Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 WaterCAD CONNECT Edition Update 2 [10.02.00.43] Page 1 of 1

Commercial Plaza - 5100 Kanata Avenue

Peak Hour Demand

Pipe Table

Label	Length (Scaled) (m)	Diameter (mm)	Material	Hazen-Williams C	Hydraulic Grade (Start) (m)	Hydraulic Grade (Stop) (m)	Velocity (m/s)	Flow (L/s)
P-1	51.3	204	PVC	110.0	157.80	157.80	0.08	2.47
P-2	9.3	155	PVC	100.0	157.80	157.79	0.07	1.41
P-4	5.8	155	PVC	100.0	157.79	157.79	0.01	0.18
P-5	70.6	155	PVC	100.0	157.79	157.79	0.02	-0.45
P-6	30.7	155	PVC	100.0	157.79	157.79	0.04	-0.72
P-7	20.9	155	PVC	100.0	157.79	157.80	0.06	-1.06
P-8	19.8	204	PVC	110.0	157.80	157.80	0.08	-2.47
P-10	30.7	155	PVC	100.0	157.79	157.79	0.01	0.27
P-11	4.5	155	PVC	100.0	157.79	157.79	0.03	0.63
P-12	33.3	155	PVC	100.0	157.79	157.79	0.03	0.56
P-13	33.4	155	PVC	100.0	157.79	157.79	0.04	0.67
P-14	11.9	50	PVC	100.0	157.79	157.77	0.17	0.34
P-15	95.1	393	PVC	120.0	157.80	157.80	0.00	0.00
P-16	24.9	600	PVC	120.0	157.80	157.80	0.00	0.00
P-17	93.8	600	PVC	120.0	157.80	157.80	0.00	0.00
P-18	3.8	155	PVC	100.0	157.80	157.80	0.00	0.00
P-19	10.9	155	PVC	100.0	157.80	157.80	0.00	0.00
P-20	5.7	155	PVC	100.0	157.80	157.80	0.00	0.00
P-21	28.5	155	PVC	100.0	157.79	157.79	0.04	0.74
P-22	35.9	155	PVC	100.0	157.79	157.79	0.04	0.74
P-23	6.6	155	PVC	100.0	157.79	157.79	0.00	0.00
P-24	91.8	393	PVC	120.0	157.80	157.80	0.02	2.47

Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 WaterCAD CONNECT Edition Update 2 [10.02.00.43] Page 1 of 1

Maximum Day Plus Fire Flow Simulation Results

Commercial Plaza - 5100 Kanata Avenue Maximum Day Demand + Fire Flow



Commercial Plaza - 5100 Kanata Avenue

Maximum Day Demand + Fire Flow

Label	Satisfies Fire Flow Constraints?	Fire Flow (Needed) (L/s)	Fire Flow (Available) (L/s)	Flow (Total Needed) (L/s)	Flow (Total Available) (L/s)	Pressure (Residual Lower Limit) (kPa)	Pressure (Calculated Residual) (kPa)	Junction w/ Minimum Pressure (System)	Is Fire Flow Run Balanced?
H-4	True	150.00	173.87	150.00	173.87	140	140	J-17	True
H-2	True	150.00	330.35	150.00	330.35	140	140	J-14	True
H-3	True	150.00	443.59	150.00	443.59	140	140	H-2	True
H-1	True	150.00	500.00	150.00	500.00	140	206	J-9	True

Fire Flow Table

23405-003_KNLCommercialBlock111_Nov2019.wtg 11/1/2019

Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 WaterCAD CONNECT Edition Update 2 [10.02.00.43] Page 1 of 1

Maximum Pressure Check

Commercial Plaza - 5100 Kanata Avenue Maximum Pressure Junction Table



Commercial Plaza - 5100 Kanata Avenue

Maximum Pressure

Junction Table

Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
J-9	108.15	0.00	162.30	530
J-14	107.95	0.00	162.30	532
J-13	107.82	0.00	162.30	533
J-15	107.80	0.00	162.30	533
J-11	107.72	0.00	162.30	534
J-12	107.72	0.00	162.30	534
J-10	107.67	0.00	162.30	535
J-6	107.49	0.00	162.30	536
J-1	107.42	0.00	162.30	537
J-5	107.38	0.00	162.30	537
J-17	107.32	0.00	162.30	538
J-7	107.30	0.00	162.30	538
J-4	107.29	0.00	162.30	538
J-16	107.29	0.00	162.30	538
J-2	107.28	0.00	162.30	538
J-18	107.22	0.00	162.30	539
J-3	107.16	0.00	162.30	540

23405-003_KNLCommercialBlock111_Nov2019.wtg 11/1/2019 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 WaterCAD CONNECT Edition Update 2 [10.02.00.43] Page 1 of 1

Commercial Plaza - 5100 Kanata Avenue

Maximum Pressure

Pipe Table

Label	Length (Scaled) (m)	Diameter (mm)	Material	Hazen-Williams C	Hydraulic Grade (Start) (m)	Hydraulic Grade (Stop) (m)	Velocity (m/s)	Flow (L/s)
P-1	51.3	204	PVC	110.0	162.30	162.30	0.00	0.00
P-2	9.3	155	PVC	100.0	162.30	162.30	0.00	0.00
P-4	5.8	155	PVC	100.0	162.30	162.30	0.00	0.00
P-5	70.6	155	PVC	100.0	162.30	162.30	0.00	0.00
P-6	30.7	155	PVC	100.0	162.30	162.30	0.00	0.00
P-7	20.9	155	PVC	100.0	162.30	162.30	0.00	0.00
P-8	19.8	204	PVC	110.0	162.30	162.30	0.00	0.00
P-10	30.7	155	PVC	100.0	162.30	162.30	0.00	0.00
P-11	4.5	155	PVC	100.0	162.30	162.30	0.00	0.00
P-12	33.3	155	PVC	100.0	162.30	162.30	0.00	0.00
P-13	33.4	155	PVC	100.0	162.30	162.30	0.00	0.00
P-14	11.9	50	PVC	100.0	162.30	162.30	0.00	0.00
P-15	95.1	393	PVC	120.0	162.30	162.30	0.00	0.00
P-16	24.9	600	PVC	120.0	162.30	162.30	0.00	0.00
P-17	93.8	600	PVC	120.0	162.30	162.30	0.00	0.00
P-18	3.8	155	PVC	100.0	162.30	162.30	0.00	0.00
P-19	10.9	155	PVC	100.0	162.30	162.30	0.00	0.00
P-20	5.7	155	PVC	100.0	162.30	162.30	0.00	0.00
P-21	28.5	155	PVC	100.0	162.30	162.30	0.00	0.00
P-22	35.9	155	PVC	100.0	162.30	162.30	0.00	0.00
P-23	6.6	155	PVC	100.0	162.30	162.30	0.00	0.00
P-24	91.8	393	PVC	120.0	162.30	162.30	0.00	0.00

Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 WaterCAD CONNECT Edition Update 2 [10.02.00.43] Page 1 of 1

Appendix C1

Sanitary Sewer Walden Village Subdivision Design Documents and Drawings (Prepared by IBI, 2001)

CUMMING COCKBURN LIMITED 1770 WOODWARD DRIVE OTTAWA, ONTARIO K2C OP8

۴

ŕ

SANITARY SEWER DESIGN SHEET

PROJECT : KANATA LAKES WALDEN VILLAGE DEVELOPER : KNL DEVELOPMENTS FILE: 3302-LD DATE: MAY 2001 DESIGN: LE

LOCA	TION		INDIV	IDUAL	CUMUL	ATIVE				PR	OPOSE	DSEW	ER			
	FROM	то	POPLN.	AREA	POPLN.	AREA	PEAK	POPLN	INFILT	PEAK	CAPACITY	VELOCITY	LGTH.	PIPE	GRADE	AVAIL.
STREET							FACT.	FLOW	FLOW	FLOW						CAP.
	МН	MH		(Ha)		(Ha)	(M)	(1/s)	(l/s)	(l/s)	l/s	m/s	(m)	(mm)	%	(%)
BYRANT	32A	33A	20	0.36	64	1.58	4.00	1.05	0.44	1.49	48.38	1.49	36.0	200	2.00	96.92%
BYRANT	33A	34A	24	0.49	88	2.07	4.00	1.44	0.58	2.02	36.68	1.13	74.0	200	1.15	94.49%
BROUGHTON	34A	35A	8	0.15	308	6.67	4 00	5.05	1 87	6.92	36.69	0.72	24.5	250	0.25	01 140/
BROUGHTON	35A	36A	8	0.23	316	6.90	4.00	5.18	1.93	7.11	36.69	0.72	44.0	250	0.35	80 62%
BROUGHTON	36A	38A	8	0.22	324	7.12	4.00	5.31	1.99	7.30	36.69	0.72	39.0	250	0.35	80.10%
BROUGHTON	37A	38A	16	0.39	16	0.39	4.00	0.26	0.11	0.37	26.49	0.82	67.0	200	0.60	98.60%
				www.commenter												
DAVENPORT	Future	38A	Comm.	3.23		3.16	1.50	2.84	0.88	3.72						
DAVENPORT	Future	38A	1028	2.57	1028	5.73	4.00	16.86	1.60	21.30						
	204	20.4			1070											
DAVENPORT	38A	39A	8	0.28	1376	13.52	3.71	20.93	3.79	27.56	36.69	0.72	70,0	250	0.35	24.86%
DAVENPORT	39A	40A	64	0.90	1440	14.42	3.69	21.79	4.04	28.67	36.69	0.72	121.0	250	0.35	21.84%
DAVENPORT	40A	EX.	4	0.09	1444	14.51	3.69	21.85	4.06	28.75	59.69	0.82	5.0	300	0.35	51.82%
								-								
1																
												n				

Where Q = average daily per capita flow (350 l/cap.d.)

I = Unit of peak extraneous flow (0.28 l/sec/ha)

M = Peaking factor

Q(p) = Peak population flow (I/s)

Q(i) = peak extraneous flow (I/s)

Population = 4.0 per single family (SF) residential unit Commercial and School - Average flow 50,000 l/ha/day with

511010

Coeff. of friction (n 0.013

SPECIFY

PAGE 2 OF 2



LEGEND :

POPULATION @ 4 P.P.U. AREA IN HECTARES

32	
0.81	

KNL DEVELOPMENTS INC.	PROJ. No. 3302-LD CONT. No
	DATED FEBRUARY'01
WALDEN VILLAGE	DWG. No.
SANITARY DRAINAGE AREA PLAN	501

Appendix C2

Block 111 Sanitary Sewer Design Sheet (prepared by JLR, 2016)



BLOCK 111 5100 Kanata Avenue URBANDALE CORPORATION CITY OF OTTAWA JLR No. 23405-01

SING. HOUSING	3.4	pers/unit	q =	275	L/cap/day
MULT. HOUSING	2.7	pers/unit	l =	0.280	L/s/ha
Manning's Coeff. N =	0.01	3	Comm.	50000	L/ha/day

_						RESIDENT	IAL			COMMER	ICAL/INST	ITUTIONAL	4		_						_							
	мць	lumbor	I	NUMBER OF U	UNITS	CUMU	LATIVE	PEAKING	POPUL.		CUMM.	COMM.	PEAK EXTR.	PEAK DES.			SEWER DA	TA		RESIDUAL		UPST	REAM			DOWNST	EAM	
STREET	IVI.11. I	Anninger	SIN	IG. MULT.	AREA	POPUL.	AREA	FACTOR	FLOW	AREA	AREA	FLOW	FLOW	FLOW	DIA.	SLOPE	CAPAC.	VEL.	LENGTH	CAP.	Center	Obvert	Invert	Cover	Center	Obvert Obver	i Invert	Cover
	FROM	то			ha	peop.	ha		l/s	ha	ha	l/s	l/s	l/s	mm	%	l/s	m/s	m	l/s	Line				Line	Drop		
Future Commercial Site		Stub1								1.53	1.53	1.33	0.43	1.76														
Institutional Site		Stub1				157	1.70	4.00	2.00				0.48	2.48														
Broughton Street	Stub1	EX. 37A				157	1.70	4.00	2.00		1.53	1.33	0.91	4.24	200	0.41	21.9	0.68	32.00	17.67	107.19	104.05	103.85	3.14	107.23	103.92	103.72	3.31
																									Ex.37A OB	8V/INV (N): 103.92	103.72	
Block 110	Stub2	EX. 38A				1028	2.57	4.00	16.86		0.00	0.00	0.72	17.58	250	0.25	31.0	0.61	11.00	13.44	107.10	99.75	99.50	7.35	106.99	99.72	99.47	7.27
																									Ex.38A OB	8V/INV (E): 99.72	99.47	
																					Legend:							
																						= sanitary	peak flow as	s per Sanita	ry Sewer De	sign Sheet for Ottaw	a Retirement	
																						Residence	prepared b	y SCS Cons	sulting Group	Ltd. dated May 201	ز	
																						= Block 11	0 residentia	l lands sanit	tary peak flow	w as per Walden Villa	ge Sanitary	
																						Sewer Des	sign Sheet p	repared by	IBI (formerly	CCL), dated May 20	J1	

SANITARY SEWER DESIGN SHEET

Designed	bv:	H.M
Designed	by.	1 1.101

Reviewed by: L.D.

Dated: May 2016

Appendix C3

Sanitary Sewer Hawthorn Retirement Residence (Prepared by SCS Group, 2016)
Minimum Dia. = Mannings "n"= Minimum Velocity =	200 0.013 0.6	mm m/s							SAN 130 City	Goull of Ot	Y SEW bourn ttawa	/ER DE Forced	SIGN SH Road	IEET							Y.			
Minimum Grade = Avg. Domestic Flow = Infiltration = Max. Peaking Factor= Min. Peaking Factor= Maximum Velocity =	0.4 275 0.28 4.0 2.0 3	% I/c/d I/s/ha m/s																Project: Project No Date: Designed NOMINAL	o: by: PIPE SIZE	USED		130 Goulbo 1698 06/05/2016 I.K.	ourn Forcec	d Road
					RES	IDENTIAL				COMMER	CIAL/INDU	STRIAL/INS	TITUTIONAL			FLOW	CALCULATIO	ONS				PI	PE DATA	
STREET	FROM	то		ACC.					ACC.		ACC.	EQUIV.	FLOW	ACC.	INFILTRATION	TOTAL	PEAKING	RES.	СОММ.	TOTAL			Q	v
	мн	мн	AREA	AREA	UNITS	DENISTY	DENSITY	POP	RES.	AREA	AREA	POP.	RATE	EQUIV.	27.0004.004	ACC.	FACTOR	FLOW	FLOW	FLOW	DIA.	SLOPE	FULL	FULL
			(ha)	(ha)	(#)	(P/ha)	(P/unit)		POP.	(ha)	(ha)	(p/ha)	(l/s/ha)	POP.	(l/s)	POP.		(l/s)	(l/s)	(I/s)	(mm)	(%)	(l/s)	(m/s)
Commercial	SITE	MH4A	0	0	0			0	0	1.53	1.53	0	0.868056	0	0.43	0	4.00	0.0	1.3	1.8	200	0.50	23.2	0.74
0	MH4A	МНЗА	0	0	0			0	0	0.29	1.82	0	0	0	0.51	0	4.00	0.0	1.3	1.8	200	0.39	20.5	0.65
0	МНЗА	MH2A	0	0	0			0	0	0	1.82	0	0	0	0.51	0	4.00	0.0	1.3	1.8	200	0.41	21.0	0.67
Retirement Residence	BLDG	MH2A	1.45	1.45	0	108.275		156.999	157	0	0	0	0.22425	0	0.41	156.999	4.00	2.0	0.0	2.4	200	1.00	32.8	1.04

Appendix C4

Commercial Plaza Sanitary Sewer Design Sheet



Urbandale Commercial Plaza 5100 Kanata Ave. JLR No. 23405-003.1

Commercial Flow = 28,000 L / ha / day* Comm. Peaking Factor = 1.5 Infiltration = 0.33 L / s / ha Manning's Coeff. N = 0.013 Per SCS consulting group retirement residence design dated August 2016 Building Service Laterals

*Assuming 12 hrs/day operation

		INSTITUT	IONAL / CON	IMERICAL	I	NFILTRATIO	N																
M.I	H. #		CUMM.	PEAK**		CUMM.	PEAK	PEAK DES.			SEWER DATA	A		RESIDUAL		UPST	REAM			[DOWNSTREA	М	
		AREA	AREA	FLOW	AREA	AREA	EXTR.	l/s	DIA.	SLOPE	CAPAC.	VEL.	LENGTH	CAP.	Center	Obvert	Invert	Cover	Center	Obvert	Obvert	Invert	Cover
FROM	TO	ha	ha	l/s	ha	ha	l/s		mm	%	l/s	m/s	m	l/s	Line				Line	Drop			<u> </u>
																							I
																							I
Building A	MH 10	0.34	0.34	0.33	0.34	0.34	0.11	0.45	150	3.00	27.5	1.51	5.4	27.08	108.15	105.87	105.72	2.28	107.86	0.00	105.71	105.56	2.15
MH 10	MH 20		0.34	0.33	0.00	0.34	0.11	0.45	200	1.00	34.2	1.06	51.1	33.77	107.86	105.71	105.50	2.15	107.31		105.20	104.99	2.11
																							I
Building E	MH 20	0.32	0.32	0.31	0.32	0.32	0.11	0.42	150	3.00	27.5	1.51	9.0	27.11	107.82	105.52	105.37	2.30	107.31	0.05	105.25	105.10	2.06
																							I
MH 20	MH 30		0.67	0.65	0.00	0.67	0.22	0.87	200	0.35	20.2	0.62	25.1	19.38	107.31	105.20	104.99	2.11	107.39	0.06	105.11	104.91	2.28
MH30	MH 40		0.67	0.65	0.00	0.67	0.22	0.87	200	0.35	20.2	0.62	16.6	19.38	107.39	105.05	104.85	2.34	107.23	0.03	104.99	104.79	2.24
																							I
Building D	MH 50	0.63	0.63	0.61	0.63	0.63	0.21	0.82	150	3.00	27.5	1.51	9.9	26.68	107.72	105.42	105.27	2.30	107.27	0.02	105.12	104.97	2.15
MH 50	MH 40		0.63	0.61	0.00	0.63	0.21	0.82	200	0.37	20.7	0.64	21.8	19.90	107.27	105.10	104.90	2.17	107.23	0.06	105.02	104.82	2.21
																							L
MH 40	MH 70		1.30	1.26	0.00	1.30	0.43	1.69	200	0.35	20.2	0.62	65.6	18.55	107.23	104.96	104.76	2.27	107.25	0.06	104.73	104.53	2.52
																							I
Building B	MH 70	0.22	0.22	0.21	0.22	0.22	0.07	0.28	150	3.00	27.5	1.51	9.6	27.22	107.67	105.37	105.22	2.30	107.25	0.41	105.08	104.93	2.17
																							I
MH 70	EX. MH 4A		1.52	1.47	0.00	1.52	0.50	1.97	200	0.35	20.2	0.62	36.6	18.27	107.25	104.67	104.47	2.58	106.81		104.54	104.34	2.27
																							L
Building C	EX. MH 4A	0.14	0.14	0.13	0.14	0.14	0.04	0.18	150	5.72	38.0	2.08	11.8	37.82	107.72	105.42	105.27	2.30	106.81	0.20	104.75	104.59	2.06
																							1
EX. MH 4A	MH EX.		1.65	1.60	0.00	1.65	0.54	2.15	200	0.39	21.4	0.66			106.81	104.54	104.34						
																							1

** 12 hrs/day operation assumed , Peak flow = 28 000 l/ha/day x Cumulative Area x Peaking Factor x 24hrs/12rs/(86,400 s/day)

SANITARY SEWER DESIGN SHEET

Designed by:	R.M.	
Checked by:	A.W.	
Date:	March 2019	

Storm Sewer Walden Village Subdivision Design Documents and Drawings (prepared by IBI, 2001)

CUMMING COCKBURN LIMITED 1770 WOODWARD DRIVE

C =

Runoff Coefficient

STORM SEWER DESIGN SHEET

OTTAWA, ONTARIO K2C OP8

PROJECT : KANATA LAKES WALDEN VILLAGE

DEVELOPER : KNL DEVELOPMENTS

FILE: 3302-LD

DATE: MAY 2001

DESIGN: LE

LOCATION AREA (Ha.) RAINFALL SEWER DATA STREET FROM TO C= C= C= INDIV. ACCUM. INLET TIME TOTAL I PK. FLOW LENGTH PIPE SLOPE CAP. VEL. AVAIL. MH MH 0.40 0.55 0.20 2.78AC 2.78AC (min.) IN PIPE (mm/Hr) (1/s)(M) (mm) (%) (1/s)(M/s) CAP. (%) BYRANT 32 33 0.36 0.40 1.80 20.60 0.32 20.91 65.92 118.66 37.0 300 2.00 142.65 1.96 16.82% BYRANT 33 34 0.49 0.54 2.34 20.91 0.82 21.74 65.19 152.54 73.0 375 0.85 168.62 1.48 9.53% BROUGHTON 34 35 0.15 0.17 7.52 25.99 0.29 26.28 55.67 418.64 22.5 675 0.30 480.21 1.30 12.82% BROUGHTON 35 36 0.23 0.33 0.53 8.05 26.28 0.55 26.83 55.23 444.60 43.0 675 0.30 480.21 1.30 7.41% BROUGHTON 36 38 0.22 0.24 8.29 26.83 0.51 27.34 54.40 450,98 40.0 675 0.30 480.21 1.30 6.09% BROUGHTON 37 38 0.36 0.40 0.40 20.00 1.00 21.00 67.35 26.94 64.0 300 0.60 78.15 1.07 65.53% C= 0.60 DAVENPORT Future 38 5.80 9.67 9.67 DAVENPORT 38 39 0.28 0.31 18.67 27.34 0.70 28.04 53.66 1,001.8 71.0 900 0.35 1,117.0 1.70 10.31% DAVENPORT 39 40 0.90 1.00 19.67 28,04 1.20 29.23 52.68 1,036.2 122.0 900 0.35 1,117.0 1.70 7.24% DAVENPORT 40 EX. 0.09 0.10 19.77 29.23 0.05 29.28 51.11 1,010.4 5.0 900 0.35 1,117.0 1.70 9.54% PROFESSION AL LICENSE 20 Q = 2.78AIC, where: Q = Peak Flow in Litres per Second (I/s) INCER L. MERTON A = Area in Hectares (ha.) Rainfall Intensity in Millimeters per Hour (mm/hr) I =

BOUNCE OF ONTARIO



LEGEND :



AREA IN HECTARES RUN OFF COEFFICIENT



DIRECTION OF MAJOR SYSTEM

KNL DEVELOPMENTS INC.	PROJ. NO. 3302–LD CONT. NO. DATED FEBRUARY'01
WALDEN VILLAGE	DWG. No.
STORM DRAINAGE AREA PLAN	500

Block 111 Storm Sewer Design Sheet (prepared by JLR, 2016)



BLOCK 111 5110 Kanata Avenue URBANDALE CORPORATION CITY OF OTTAWA JLR NO. 23405-01

Mar	nning's Coefficient n =	0.013	
	IDF CURVE =	5	year

				DRAINA	GE AREA	S		In Pipe	5 YR	PEAK FLC	OW COMPU	TATION			SEWER DAT	A		Residual		UPS'	TREAM			D	OWNSTRE	AM	
	M.H. N	umber			Total	Cum.	Inlet	Flow		Cum.	5 Yr	Peak	Pipe					Capacity									
STREET			0.75	0.80	Area	Area	Time	Time	2.78AR	2.78AR	Intensity	Flow	Dia	Slope	Q full	V full	Length	$Q_{cap} Q_{d}$	Center	Obvert	Invert	Cover	Center	Drop	Obvert	Invert	Cover
	FROM	то			(ha)	(ha)	(min.)	(min.)			(mm/hr)	(L/s)	(mm)	(%)	(L/s)	(m/s)	(m)	(L/s)	Line				Line				
																									ļ		
Block 111 (Institutional & Commercial Sites)		Stub			3.18	3.18	13.31	0.02	6.42	6.42	89.43	575.00															
							13.33																				
Block 110	Stub	104A			0.00	3.18	13.33	0.15	0.00	6.42	89.43	575.00	750	0.34	677.2	1.48	13.60	102.2	107.09	101.49	100.73	5.60	107.00		101.45	100.68	5.55
Block 110	104A	104	1.00		1.00	4.18	13.49	0.88	2.09	8.51	88.79	756.00	825	0.38	923.1	1.67	88.50	167.1	107.00	101.45	100.61	5.55	107.00	0.06	101.11	100.27	5.89
Broughton Street	104	EX38	1.57		1.57	5.75	14.37	0.13	3.27	11.78	85.66	1009.08	900	0.39	1179.4	1.80	14.30	170.3	107.00	101.05	100.14	5.95	106.99		100.99	100.08	6.00
							14.50																		ĺ		
																							EX.38 OB	V/INV (E.)	100.99	100.08	
																			Legend:								
																				- 1.5 yr stor	m neak flow	as ner Storm		Sheet for O	Ittawa Rotiror	nont Rosidon	100

STORM SEWER DESIGN SHEET 1: 5 YEAR

Designed by: H.M.

Checked by: L.D.

Date: Sept 2016

1:5 yr storm peak flow as per Storm Sewer Design Sheet for Ottawa Retirement Resid prepared by SCS Consulting Group Ltd. dated May 2016

= Block 110 residential lands as per Walden Village Storm Drainage Area Plan prepared by CCL Dated May 25, 2002

Hawthorn Retirement Residence Storm Sewer Design (Prepared by SCS Group, 2016)



					A COMPANY OF A COMPANY OF A COMPANY										A REAL PROPERTY AND A REAL PROPERTY		and the first sector of the first sector of			
						Storm Se	ewer Desi	gn Shee	et											
Rainfall Intensity =	- 4j	A	-			130 Goull	oourn For	ced Roa	ad											
		(Tc+B)^c																		
	5-YEAR		100-YEAR													Project:	130 Goulbor	urn Forced Ro	ad	
A=	998.071	Ú.	0													Project No:	1698			
B=	6.053	3	0													Date:	06-May-16			
C=		l I	0													Designed by:	I.K.			
Starting Tc =	10) min																		
						- 1/5	- 1/5	- VD			00111	1.4001114								T
			5-YR	5-YR	5-YR	5-YR	5-YR	5-YR	сомм.	сомм.	сомм.	ACCUM.	lotal							
STREET	FROM	то	AREA	RUNOFF	"AR"	ACCUM.	RAINFALL	ACCUM.	AREA	FLOW	FLOW	COMM.	Flow	LENGTH	SLOPE	PIPE	FULL FLOW	FULL FLOW	TIME OF	ACC. TIME OF
	MH	МН	(ha)	COEFFICIENT		"AR"	INTENSITY (mm/br)	FLOW (m ³ /s)	(ha)	RATE	(m ³ /s)	FLOW (m ³ /s)	(m ³ /s)	(m)	(%)	DIAMETER	(m3/s)	VELOCITY (m/s)	(min)	(min)
Site	CB1	CBMH1	(na)	0.61	0.04	0.04	104 19	0.011	(na)	(/s/na)	0.000	0,000	0.011	21.10	0.62	200	0.026	0.822	0.428	10.42
One			0.00	0.01	0.04	0.04	104.19	0.011	0.000	0.000	0.000	0.000	0.011	21.10	0.02	200	0.020	0.022	0.120	
Site	CB2	CBMH2	0.12	0.72	0.09	0.09	104.19	0.025	0.000	0.000	0.000	0.000	0.025	17.60	0.80	200	0.029	0.934	0.314	10.31
Site	CBMH2	CBMH1	0.06	0.78	0.05	0.13	102.56	0.038	0.000	0.000	0.000	0.000	0.038	14.40	0.63	250	0.047	0.962	0.250	10.56
Site	CB3	CBMH1	0.07	0.67	0.05	0.05	104.19	0.014	0.000	0.000	0.000	0.000	0.014	0.80	1.00	200	0.033	1.044	0.013	10.01
Site	CB4	CBMH1	0.11	0.78	0.09	0.09	104.19	0.025	0.000	0.000	0.000	0.000	0.025	0.70	2.00	200	0.046	1.476	0.008	10.00
Sito	CBMH1	CBMH3	0.05	0.67	0.03	0.34	101 31	0.005	0.000	0.000	0.000	0.000	0.095	59.80	0.50	450	0.201	1 268	0.786	11 35
Site	CBMH3	CBMH4	0.03	0.62	0.03	0.40	97.56	0.110	0.000	0.000	0.000	0.000	0.110	23.10	0.52	450	0.205	1.293	0.298	11.64
0.10	- CDINING	0.0.00		0.01	0.07	0.10	01100		0.000											
Site	CB5	CBMH4	0.09	0.67	0.06	0.06	104.19	0.017	0.000	0.000	0.000	0.000	0.017	17.80	2.02	200	0.047	1.484	0.200	10.20
Site	CB6	CBMH4	0.05	0.78	0.04	0.04	104.19	0.011	0.000	0.000	0.000	0.000	0.011	1.10	2.00	200	0.046	1.476	0.012	10.01
Site	CB7	CBMH4	0.09	0.54	0.05	0.05	104.19	0.014	0.000	0.000	0.000	0.000	0.014	0.80	2.00	200	0.046	1.476	0.009	10.00
Site	CBMH4	MH5	0.04	0.87	0.03	0.59	96.23	0.157	0.000	0.000	0.000	0.000	0.157	48.50	0.60	450	0.221	1.389	0.582	12.230
Cito	CDO	MUE	0.05	0.62	0.02	0.02	104.10	0.000	0.000	0.000	0.000	0.000	0.000	2 70	2.00	200	0.046	1 476	0.042	10.04
Site	CBO		0.05	0.63	0.03	0.03	104.19	0.009	0.000	0.000	0.000	0.000	0.009	3.70	2.00	200	0.040	1.470	0.042	10.04
Site	MH5	CBMH6	0.07	0.09	0.04	0.66	93 73	0.012	0.000	0.000	0.000	0.000	0.172	45.80	0.50	525	0.304	1.405	0.543	12.77
One	11110			0.00	0.00	0.00	00.70	0.172	0.000	0.000	0.000	0.000	0.172	40.00	0.00	520	0.004		0.040	
Site	CBMH6	MH7	0.1	0.59	0.06	0.72	91.52	0.183	0.000	0.000	0.000	0.000	0.183	6.80	0.44	525	0.285	1.318	0.086	12.85
External	MH14	MH7	1.53	0.80	1.22	1.22	104.19	0.354	0.000	0.000	0.0000	0.0000	0.3543	64.10	0.41	600	0.393	1.391	0.768	10.76
Site	MH7	MH8	0	0.00	0.00	1.94	91.18	0.492	0.000	0.000	0.000	0.000	0.492	28.30	0.60	675	0.651	1.820	0.259	13.11
Site	CB11	CBMH9	0.08	0.64	0.05	0.05	104.19	0.015	0.000	0.000	0.000	0.000	0.015	30.60	0.49	200	0.023	0.731	0.698	10.69
Site	CBMH9	MH10	0.08	0.52	0.04	0.09	100.65	0.026	0.000	0.000	0.000	0.000	0.026	20.90	1.00	200	0.033	1.044	0.334	11.03
Site	MH10	CBMH11	0	0.00	0.00	0.09	99.04	0.026	0.000	0.000	0.000	0.000	0.026	43.80	0.50	250	0.042	0.857	0.852	11.884
Site		CBMH12	0.26	0.66	0.17	0.26	95.20	0.070	0.000	0.000	0.000	0.000	0.070	62.50	0.50	3/5	0.124	1.123	0.928	12.81
Sito	CB12	CBMH12	0.04	0.46	0.02	0.02	10/ 10	0.005	0.000	0.000	0.000	0.000	0.005	17.00	2.00	200	0.046	1 476	0 192	10.19
Site	CBMH12	MH13	0.04	0.40	0.02	0.02	91.37	0.094	0.000	0.000	0.000	0.000	0.094	29.00	0.50	375	0.124	1,123	0.431	13.24
Site	MH13	MH8	0.12	0.00	0.00	0.37	89.70	0.093	0.000	0.000	0.000	0.000	0.093	4.90	0.50	375	0.124	1.123	0.073	13.31
Site	MH8	STUB	0	0.00	0.00	2.31	89.43	0.575	0.000	0.000	0.000	0.000	0.575	1.73	0.40	750	0.704	1.594	0.018	13.33

Commercial Plaza Stormwater Management Calculations

URBANDALE CORPORATION 5100 KANATA AVE. - COMMERCIAL BLOCK PLAZA CITY OF OTTAWA

RUNOFF COEFFICIENTS FOR SUBCATCHMENT AREAS

					2 Yı	r		r i i i i i i i i i i i i i i i i i i i		100 Yr			1		
Subcatchment Area	Total Area, A (ha)	Surface Description	Surface Area (ha)	Runoff Coefficient, C	AxC	Total A x C	Weighted Runoff coefficient	Runoff Coefficient, C	AxC	Total A x C	Weighted Runoff coefficient	Flow Allocations	Total Area (ha)	Weighte Coeff	d Runoff icient
Building A		hard	0.041	0.90	0.037			1.00	0.041					2 11	100 11
Ť		soft	0.000	0.20	0.000			0.25	0.000						
Ruilding E	0.041	subtotal	0.052	0.00	0.049	0.037	0.90	1.00	0.052	0.041	1.00				
Dulluling L		soft	0.000	0.20	0.000			0.25	0.000						
	0.053	subtotal				0.048	0.90			0.053	1.00				
CB 508		hard	0.008	0.90	0.007			1.00	0.008						
	0.015	subtotal	0.007	0.20	0.001	0.009	0.57	0.25	0.002	0.010	0.65				
CB 509		hard	0.006	0.90	0.005			1.00	0.006						
	0.045	soft	0.009	0.20	0.002	0.007		0.25	0.002	0.000	0.55				
CBMH 510	0.015	hard	0.070	0.90	0.063	0.007	0.48	1.00	0.070	0.008	0.55				
		soft	0.007	0.20	0.001			0.25	0.002						
00.540/00500	0.077	subtotal	0.000	0.00	0.004	0.064	0.84	1.00	0.000	0.072	0.93				
CB 519/CB520		soft	0.038	0.90	0.034			0.25	0.038						
	0.043	subtotal				0.035	0.82			0.039	0.91	Area # 1			
CB 521		hard	0.057	0.90	0.051			1.00	0.057			ICD 53			
	0.074	soft	0.017	0.20	0.003	0.055	0.74	0.25	0.004	0.061	0.92				
CBMH 522	0.074	hard	0.126	0.90	0.113	0.033	0.74	1.00	0.126	0.001	0.05				
		soft	0.005	0.20	0.001			0.25	0.001						
0.0	0.131	subtotal	0.075			0.114	0.87	1.00	0.075	0.127	0.97	-			
CB 530		hard	0.075	0.90	0.068			1.00	0.075						
	0.075	subtotal	0.000	0.20	0.000	0.068	0.90	0.20	0.000	0.075	1.00				
CB 531		hard	0.064	0.90	0.058			1.00	0.064						
	0.064	soft	0.000	0.20	0.000	0.059	0.00	0.25	0.000	0.064	1.00				
CB 540	0.004	hard	0.058	0.90	0.052	0.056	0.90	1.00	0.058	0.064	1.00				
		soft	0.000	0.20	0.000			0.25	0.000						
	0.058	subtotal				0.052	0.90			0.058	1.00				
CB 541		hard	0.043	0.90	0.039			1.00	0.043						
	0.043	subtotal	0.000	0.20	0.000	0.039	0.90	0.25	0.000	0.043	1.00		0.69	0.85	0.95
Building D		hard	0.106	0.90	0.095			1.00	0.106			Area # 2			
	0.400	soft	0.000	0.20	0.000	0.005		0.25	0.000	0.400		Rooftop Control	0.44	0.000	4.00
CB 552	0.106	subtotal	0.074	0.90	0.067	0.095	0.90	1.00	0.074	0.106	1.00		0.11	0.900	1.00
00 002		soft	0.011	0.20	0.002			0.25	0.003			Area # 3 ICD 52			
	0.085	subtotal				0.069	0.81			0.077	0.90		0.09	0.81	0.90
CBMH 570		hard	0.122	0.90	0.110			1.00	0.122						
	0 147	soft	0.025	0.20	0.005	0 115	0.78	0.25	0.006	0 128	0.87	Area # 4			1
CBMH 571	0.111	hard	0.176	0.90	0.158	0.110	0.10	1.00	0.176	0.120	0.01	ICD 71			
		soft	0.010	0.20	0.002			0.25	0.003						
CP 572	0.186	subtotal	0.016	0.00	0.014	0.160	0.86	1.00	0.016	0.179	0.96		0.33	0.83	0.92
00 372		soft	0.010	0.20	0.007			0.25	0.009			Area # 5			
	0.053	subtotal				0.022	0.41			0.025	0.48	ICD 72	0.05	0.41	0.48
CB 573		hard	0.003	0.90	0.003			1.00	0.003			Area # 9			
	0.008	son	0.005	0.20	0.001	0.004	0.46	0.25	0.001	0.004	0.53	Uncontrolled	0.01	0.46	0.53
Building B		hard	0.095	0.90	0.086			1.00	0.095			Area # C			
-		soft	0.000	0.20	0.000			0.25	0.000			Rooftop Control			
Duilder - O	0.095	subtotal	0.005	0.00	0.077	0.086	0.90	1.00	0.005	0.095	1.00		0.10	0.900	1.00
Building C		soft	0.085	0.90	0.077			0.25	0.085			Area # 7			1
	0.085	subtotal	0.000	0.20	0.000	0.077	0.90	0.20	5.500	0.085	1.00	Rooftop Control	0.09	0.900	1.00
CB 580		hard	0.028	0.90	0.025			1.00	0.028			Area # 8			
	0.050	soft	0.022	0.20	0.004	0.020	0.50	0.25	0.006	0.024	0.67	ICD 80	0.05	0.50	0.67
Waldon Village	0.050	hard	0.011	0.90	0.010	0.030	0.59	1.00	0.011	0.034	0.67		0.05	0.59	0.07
(uncontrolled)		soft	0.033	0.20	0.007			0.25	0.008			Walden Village			
Maldar Miller O	0.044	subtotal	0.000	0.00	0.000	0.016	0.37	1.00	0.000	0.019	0.43	Residential Rear			1
(uncontrolled)		soft	0.000	0.20	0.000			0.25	0.005			Yards			
()	0.018	subtotal				0.004	0.20			0.005	0.25		0.06	0.32	0.38
Detionent															
Retirement		hard	0.012	0.90	0.011			1.00	0.012			Retirement			
1 Condenide												Residence			
(uncontrolled)		soft	0.022	0.20	0.004			0.25	0.006						
GER 1	0.034	subtotal	0.003	0 00	0.003	0.015	0.45	1.00	0.003	0.018	0.51		0.03	U.45	U.51
(uncontrolled)		soft	0.025	0.20	0.005			0.25	0.005			Golbourn			
	0.028	subtotal				0.008	0.28			0.009	0.33	Forced Road	0.03	0.28	0.33
Kanata Ave.		hard	0.005	0.90	0.005			1.00	0.005			Kanata Avo			
(uncontrolled)	0.022	subtotal	0.017	0.20	0.003	0.008	0.36	0.20	0.004	0.009	0.42	Nanata Ave.	0.02	0.36	0.42

Total Notes:

1.6500 (1) Runoff coefficient for soft surfaces increased by 25% for 100-yr storm calculations



JLR No. 23405-003.1

STORMWATER MANAGEMENT CALCULATIONS

Summary of allocated areas outletting uncontrolled offsite:

				A	Ilocated Peak Flow	
Uncontrolled Outlet	Total Area	C factor	C factor	Q ₂ with T _c	Q5 with T _c	Q ₁₀₀ with T _c
	(ha.)	2-Yr/5-Yr	100-Yr	10 min (L/s)	10 min (L/s)	10 min (L/s)
Retirement Residence (1)	0.03	0.62	0.78	3.97	5.39	11.54
Kanata Avenue	0.07	0.20	0.25	2.99	4.06	8.69
Walden Village Residential Rear Yards (2)	0.12	0.55	0.69	14.09	19.12	40.95
Total	0.22			21.05	28.56	61.18

Notes: (1) As per August 2016 retirement residence design prepared by SCS Consulting Group. (2) As per 2001 Walden Village subdivision design prepared by IBI (Formerly CCL).

Summary of proposed areas outletting uncontrolled offsite:

				F	roposed Peak Flow	
Uncontrolled Outlet	Total Area	C factor	C factor	Q ₂ with T _c	Q5 with T _c	Q ₁₀₀ with T _c
	(ha.)	2-Yr/5-Yr	100-Yr	10 min (L/s)	10 min (L/s)	10 min (L/s)
Retirement Residence	0.034	0.45	0.51	3.25	4.40	8.69
Kanata Avenue	0.022	0.36	0.42	1.69	2.29	4.59
Goulbourn Forced Road	0.028	0.28	0.33	1.64	2.23	4.59
Walden Village Residential Rear Yards	0.062	0.32	0.38	4.25	5.76	11.68
Total	0.146			10.82	14.68	29.55

139.70 L/s 2.23 L/s 137.47 L/s

Minor system allocation for proposed Commercial Plaza = (As per September 2016 Servicing report prepared by JLR) Uncontrolled Peak Flow to Goulbourn Forced Road =

Revised Release Rate for Commercial Plaza =

Summary: Areas outletting to proposed minor system:

			Drainage Area		Desig	n Flow	1:100 Yr Rest.	
Area No.	Type or ID. No.	Total Area	C factor	C factor	Q ₂ with T _c	Q ₁₀₀ with T _c	Restricted	ICD Type
		I Otal Area	2-Yr	100-Yr	10 min (L/s)	10 min (L/s)	Flow (L/s)	
1	MH 530 - ICD 53	0.689	0.85	0.95	124.93	323.40	74.0	Custom ICD 131 mm Ø
2	Building D	0.106	0.90	1.00	20.37	52.62	7.7	Zurn Control-Flo Roof Drain
3	CB 552 - ICD 52	0.085	0.81	0.90	14.69	38.10	4.0	50 VHV-1
4	CBMH 571 - ICD 71	0.333	0.83	0.92	58.76	152.27	18.0	Custom ICD 66 mm Ø
5	CB 572 - ICD 72	0.053	0.41	0.48	4.65	12.53	4.0	50 VHV-1
6	Building B	0.095	0.90	1.00	18.26	47.16	7.7	Zurn Control-Flo Roof Drain
7	Building C	0.085	0.90	1.00	16.33	42.19	6.5	Zurn Control-Flo Roof Drain
8	CB 580 - ICD 80	0.050	0.59	0.67	6.32	16.63	13.0	100 VHV-1
9	CB 573	0.008	0.46	0.53	0.79	2.11	2.11	*Uncontrolled flow
	Total	1.504			265.10	687.01	137.04	

Area C-Factor 1:2Yr	0.689	Release Rate:	74.0 L/s
Minimum storage volume requirement	<u>nt =</u>	211.90 m3	(refer to Model M1 in Appendix 'D7' for SWMHYMO results)
Surface Storage:	CB 521	1.61 m3	
	CBMH 522	25.18 m3	
	CB 530	23.57 m3	
	CB 531	5.85 m3	
	CB 540	2.23 m3	
	CB 541	3.38 m3	
Underground Pipe Storage (including (MH520-530, CB531-1050øST, CB5 MH520, CB521-CBMH522, MH511-	g MHs): 541-540, CB540-1050øST, CBMH522- •520, CBMH510-MH511, MH510-511)	150.54 m3	(refer to Model M1 in Appendix 'D7' for stage - storage calculations)
Total Storage Volume:		212.36 m3	

1



JLR No. 23405-003.1

STORMWATER MANAGEMENT CALCULATIONS

2 Building D	Assumed Rooftop Properties:											
	Total Area Roof =	0.1060 h	1a									
	Unusable roof (20%) =	0.0212 h	na									
	Usable roof (80%) =	0.0848 h	1a									
	Depth of Storage =	0.127 r	n									
	Roofton Volume Assuming Sloped Roof ((m ³) = I isable roofton area	(m ²) x storage dept	th (m)/3								
	Roofton Volume (m ³) = 949 m ² x 0 127 m	/3	(iii) x ciorago dopa	ur (m)/0								
	Robitop Volume (m) = $646 \text{ m} \times 6.127 \text{ m}$	75 350.	3									
	Roonop volume (m) =	55.9 h	n									
	One-te-line data of an lance and a - 4 00 1/2 and	f desire of 7 and 0 and all Fig		>								
	Controlled root release rate = 1.29 l/s roo	f drain x 6 Zurn Control-Flo	units (102 mm Ris	se)								
	Total controlled roof release rate =	7.74 L	_/s									
	Rooftop Area =	0.106										
	C-Factor (1:2 year) =	0.90										
	C-Factor (1:100 year) =	1.00										
	Time	Intensity	On	Qn	Qp	Max Volume	Intensity	On	On	On	Max Volume	
	(4.0.1/-	ωp	roof drain	stored	Requirement	1:400 Xr	αp	roof drain	etored	Requirement	
	(11111)	(mm/hr)	(1.(a)	(1 /e)	(1/e)	(m3)	(mm/hr)	(1.(2))	(1/e)	(1/e)	(m3)	
	12	76.91	20.27	7.74	(13,62	(113)	(1111/11)	(L/S)	(03)	(1/3)	(113)	
	10	70.81	20.37	7.74	12.03	7.58	1/8.56	52.62	7.74	44.00	26.93	
	15	61.77	10.30	7.74	6.04	1.18	142.89	42.11	1.14	34.37	30.93	
	20	52.03	13.80	1.14	6.06	7.27	119.95	35.35	7.74	27.61	33.13	
	25	45.17	11.98	7.74	4.24	6.36	103.85	30.60	7.74	22.86	34.29	
	30	40.04	10.62	7.74	2.88	5.18	91.87	27.07	7.74	19.33	34.80	
	35	36.06	9.56	7.74	1.82	3.83	82.58	24.33	7.74	16.59	34.85	
	40	32.86	8.72	7.74	0.98	2.34	75.15	22.14	7.74	14.40	34.57	
	45	30.24	8.02	7.74	0.28	0.76	69.05	20.35	7 74	12.61	34.04	
	50	28.04	7 44	7 74	N/A	N/A	63.95	18.85	7 74	11.11	33.32	
						10/1	00.00	10.00	1.14		00.02	
	Minimum and standard solutions and income to		24.05									
	Deef starses we are ideal to desire a		25.00									
	Rooi storage volume provided by design =		35.90	J ma								
	*Minimum storage volume requirement met	by the design										
-												
3	CB 552 - ICD 52											
3	CB 552 - ICD 52 Area	0.085		Release Rate:	4.0) L/s						
3	CB 552 - ICD 52 Area C-Factor 1:2Yr	0.085		Release Rate:	4.0) L/s						
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr	0.085		Release Rate:	4.0) L/s						
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr	0.085		Release Rate:	4.0) L/s						
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time	0.085 0.81 0.90	Qp	Release Rate:	4.0 Qp) L/s Max Volume	Intensity	Qp	Qp	Qp	Max Volume	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min)	0.085 0.81 0.90	Qp 1.2 Yr	Release Rate: Qp ICD	4.0 Qp stored) L/s Max Volume Requirement	Intensity 1:100 Yr	Qр 1:100 Yr	Qp ICD	Qp stored	Max Volume Requirement	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min)	0.085 0.81 0.90 Intensity 1:2 Yr (mm/hr)	Qp 1:2 Yr (Lls)	Release Rate: Qp ICD (L/s)	4.0 Qp stored (L/s)) L/s Max Volume Requirement (m3)	Intensity 1:100 Yr (mm/hr)	Qp 1:100 Yr (L/s)	Qp ICD (L/s)	Qp stored (L/s)	Max Volume Requirement (m3)	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10	0.085 0.81 0.90 Intensity 1:2 Yr (mm/hr) 76.81	Qp 1.2 Yr (L/s) 14.69	Release Rate: Qp ICD (L/s) 4.00	4.0 Qp stored (L/s) 10.69) L/s Max Volume Requirement (m3) 6.41	Intensity 1:100 Yr (mm/hr) 178 56	Qp 1:100 Yr (L/s) 38.10	Qp ICD (L/s)	Qp stored (L/s) 34.10	Max Volume Requirement (m3) 20.46	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 16	0.085 0.81 0.90 1:2 Yr (mm/tr) 76.81 61 77	Qp 1.2 Yr (Us) 14.69 11.81	Qp ICD (L/s) 4.00	4.0 Qp stored (L/s) 10.69 7.81	Max Volume Requirement (m3) 6.41 7.03	Intensity 1:100 Yr (mm/hr) 178.56 142.89	Qp 1:100 Yr (Us) 38.10 30.49	Qp ICD (L/s) 4.00	Qp stored (L/s) 34.10 26.49	Max Volume Requirement (m3) 20.46 23.84	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20	0.085 0.81 0.90 Intensity 1:2 Yr (mm/br) 76.81 61.77 50 g	Qp 1.2 Yr (Us) 14.69 11.81 9.95	Qp ICD ICD	4.0 Qp stored (L/s) 10.69 7.81 5.05	Max Volume Requirement (m3) 6.41 7.03 7.14	Intensity 1:100 Yr (mm/hr) 178.56 142.89	Op 1:100 Yr (U/s) 38.10 30.49 25.59	Qp ICD (L/s) 4.00 4.00	Qp stored (L/s) 34.10 26.49 21.50	Max Volume Requirement (m3) 20.46 23.84 25.91	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 77	0.085 0.81 0.90 1:2 Yr (mm/hr) 76.81 61.77 52.03 45 17	Qp 1.2 Yr (L/s) 14.69 11.81 9.95 8 64	Qp ICD (L/s) 4.00 4.00 4.00	4.0 Qp stored (L/s) 10.69 7.81 5.95 4.64	Max Volume Requirement (m3) 6.4.1 7.03 7.14 6.0	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95	Op 1:100 Yr (Us) 38:10 30:49 25:59 73 fe	Qp ICD (L/s) 4.00 4.00 4.00	Op stored (L/s) 34.10 26.49 21.59	Max Volume Requirement (m3) 20.46 23.84 25.91 27.24	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr	0.085 0.81 0.90 1.2 Yr (mm/hr) 76.81 61.77 62.03 45.17 40.01	Qp 1:2 Yr (L/s) 14.69 11.81 9.95 8.64 7.65	Op ICD (L/s) ICD 4.00 4.00 4.00 4.00 4.00	4.0 Op stored (Us) 10.69 7.81 5.95 4.64 2.00	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95	Op 1:100 Yr (Us) 38.10 30.49 25.59 22.16 10 CC	Qp ICD (L/s) 4.00 4.00 4.00 4.00	Qp stored (L/s) 34.10 26.49 21.59 18.16 4.50	Max Volume Requirement (m3) 20.46 23.84 25.91 27.24 28.00	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min)	0.085 0.81 0.90 intensity 1.2 Yr (mm/hr) 76.81 61.77 62.03 45.17 40.04	Qp 1.2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66	Qp ICD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00	4.0 Qp stored (U/s) 10.69 7.81 5.95 4.64 3.66 9.99	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.59	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87	Op 1:100 Yr (L/s) 38.10 30.49 25.59 22.16 19.60 17 ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	Qp ICD (L/s) 4.00 4.00 4.00 4.00	Qp stored (L/s) 34.10 26.49 21.59 18.16 15.60 40.00	Max Volume Requirement (m3) 20.46 23.84 25.91 27.24 28.08 20.05	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35	0.085 0.81 0.90 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06	Qp 1.2 Yr (Us) 14.69 11.81 9.95 8.64 7.66 6.90	Qp ICD ICD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00	4.0 Stored (Us) 10.69 7.81 5.95 4.64 3.66 2.90	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.59 6.08	Intensity 1:100 Yr (mm/br) 178.56 142.89 119.95 103.85 91.87 82.58	Cp 1:100 Yr (L/s) 38:10 30.49 25:59 22:16 19:60 17:62	Qp ICD (L/s) 4.00 4.00 4.00 4.00 4.00	Qp stored (L/s) 34.10 26.49 21.59 18.16 15.60 13.62	Max Volume Requirement (m3) 20.46 23.34 25.91 27.24 28.08 28.60	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min)	0.085 0.81 0.90 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86	Qp 1:2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66 6.90 6.29	Qp ICD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00	4.0 Op stored (U/s) 10.69 7.81 5.95 4.64 3.66 2.90 2.29	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.08 5.49	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15	Op 1:100 Yr (Us) 38.10 30.49 25.59 22.16 19.60 17.62 16.03	Op ICD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00	Op stored (L/s) 34.10 26.49 21.59 18.16 15.60 13.62 12.03	Max Volume Requirement (m3) 20.46 23.84 25.91 27.24 28.08 28.60 28.68	
3	CB 552 - ICD 52 Area -C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35 40 45	0.085 0.81 0.90 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 38.06 32.86 30.24	Op 1.2 Yr (Us) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78	Qp ICD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00	4.0 Qp stored (U/s) 10.69 7.81 5.95 4.64 3.66 2.90 2.29 1.78	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.59 6.59 6.59 6.549 4.82	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05	Op 1:00 Yr (Us) 38:10 30:49 25:59 22:16 19:60 17:62 16:03 14:73	Qp (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Qp stored (L/s) 34.10 26.49 21.59 18.16 15.60 13.62 12.03 10.73	Max Volume Requirement (m3) 20.46 23.84 25.91 27.24 28.00 28.60 28.88 28.99	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr 10 10 15 20 25 30 35 40 45 50	0.085 0.81 0.90 111ensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 30.24 28.04	Qp 1.2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.78 5.36	Application Cp ICD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00	4.0 Op stored (<i>Us</i>) 10.69 7.81 5.95 4.64 3.66 2.90 2.29 1.78 1.36	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.08 5.49 4.82 4.09	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.95	Qp 1:100 Yr (Us) 38.10 30.49 25.59 22.16 19.60 17.62 16.03 14.73 13.65	Op ICD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Op stored (Us) 34.10 26.49 21.59 18.16 15.60 13.62 12.03 10.73 9.65	Max Volume Requirement (m3) 20.46 23.84 25.91 27.24 28.08 28.80 28.80 28.80 28.89 28.99 28.94	
3	CB 552 - ICD 52 Area C-Factor 1:2YY C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35 40 45 50 55	0.085 0.81 0.90 Intensity 1.2 Yr (mm/hy) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 30.24 28.04 28.17	Qp 1.2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66 6.80 6.29 5.78 5.36 5.01	Cp ICD (L/S) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00	4.0 Qp stored (Us) 10.69 7.81 5.95 4.64 3.66 2.90 2.29 1.78 1.36 1.01	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.08 5.49 4.82 4.09 3.32	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.95 59.62	Op 1:100 Yr (L/s) 38.10 30.49 25.59 22.16 19.60 17.62 16.03 14.73 13.65 12.72		Qp stored (L/s) 34.10 26.49 21.59 18.16 15.60 13.62 12.03 10.73 9.65	Max Volume Requirement (m3) 20.46 23.84 25.91 27.24 28.08 28.60 28.60 28.88 28.98 28.94 28.94 28.76	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr	0.085 0.81 0.90 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 30.24 28.04 28.04 28.17 24.56	Qp 1.2 Yr (Us) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.01 4.70	Op ICD ICD 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00	4.0 Qp stored (Us) 10.69 7.81 5.95 4.64 3.66 2.90 2.29 1.78 1.36 1.36 1.01 0.70	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.08 5.49 5.49 5.49 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.95 55.89	Cp 1:100 Yr (L/s) 38:10 30:49 25:59 22:16 19:60 17:62 16:03 14:73 13:65 12:72 11:93	Qp ICD (Us) 4.00 4.0	Op stored (L/s) 34.10 26.49 21.59 18.16 15.60 13.62 12.03 9.65 8.77 7.93	Max Volume Requirement (m3) 20.45 23.34 25.91 27.24 28.60 28.80 28.60 28.89 28.99 28.94 28.73	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35 40 45 50 55 60 60	0.085 0.81 0.90 Intensity 1.2 Yr (mm/hr) 76.81 61.77 62.03 45.17 40.04 36.06 32.86 30.24 28.04 28.04 26.17 24.56	Qp 1.2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.01 4.70	Cp Cp ICD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00	4.0 Op stored (Us) 10.69 7.81 5.95 4.64 3.66 2.90 2.29 1.78 1.36 1.01 0.70	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.08 5.49 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 1142.89 119.95 91.87 82.58 75.15 69.05 63.96 59.62 55.89	Op 1:00 Yr (L/s) 38.10 30.49 22.559 22.16 19.60 17.62 16.03 14.73 13.65 12.72 11.93	Qp ICD (Us) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Qp stored (L/s) 34.10 26.59 18.16 15.60 13.62 12.03 10.73 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.24 28.08 28.60 28.88 28.98 28.94 28.78 28.78 28.53	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35 40 45 50 55 60 Minimum strange volume requirement =	0.085 0.81 0.90 intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 38.06 32.86 30.24 28.04 26.17 24.56	Qp 1.2 Yr (Us) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.01 4.70 28.98	Qp ICD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00	4.0 Qp stored (Us) 10.69 7.81 5.95 4.64 3.66 2.90 2.29 1.78 1.36 1.01 0.70	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.08 5.49 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.95 59.62 55.89	Op 1:100 Yr (Us) 38:10 30:49 25:59 22:16 19:60 17:62 16:03 14:73 13:65 12:72 11:93	Op (L/5) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Qp stored (L/s) 34.10 26.49 21.59 18.16 15.60 13.62 12.03 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.24 28.00 28.80 28.80 28.98 28.99 28.94 28.78 28.53	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 10 15 20 25 30 36 40 45 50 56 60 Minimum storage volume requirement =	0.085 0.81 0.90 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 32.86 30.24 28.04 28.04 28.17 24.56	Qp 1:2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.78 5.36 5.01 4.70 28.98	App ICD (L/s) 4.00 3 m3	4.0 Qp stored (U/s) 10.69 7.81 5.95 4.64 3.66 2.90 1.78 1.78 1.36 1.01 0.70	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.08 5.49 4.09 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.95 59.62 55.89	Qp 1:100 Yr (Us) 38.10 30.49 25.59 22.16 19.60 17.62 16.03 14.73 13.65 12.72 11.93	Qp ICD (L's) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Qp stored (L/s) 26.49 21.59 18.16 15.60 13.62 12.03 10.73 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.74 28.08 28.60 28.88 28.98 28.98 28.94 28.75 28.53	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 10 15 20 25 30 36 40 45 50 60 Minimum storage volume requirement =	0.085 0.81 0.90 Intensity 1:2 Yr (mm/hy) 76.81 61.77 52.03 45.17 40.04 38.06 32.86 30.24 28.04 28.17 24.56	Qp 1.2 Yr (Us) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.36 5.01 4.70 28.98	Qp ICD (L/s) 4.00	4.0 Qp stored (Us) 10.69 7.81 5.95 4.64 3.66 2.90 1.78 1.36 1.01 0.70	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.08 5.49 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 82.58 91.87 69.05 63.95 59.62 55.89	Op 1:100 Yr (Us) 38:10 30:49 25:59 22:16 19:60 17:62 16:03 14:73 13:65 12:72 11:93	Qp (LCD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Op stored (Us) 26.49 21.59 15.60 13.62 12.03 10.73 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.72 28.06 28.60 28.88 28.98 28.98 28.94 28.94 28.78 28.53	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 10 15 20 26 30 35 40 45 50 56 60 Mnimum storage volume requirement = Surface Storage: Surface Storage:	0.085 0.81 0.90 Intensity 1:2 Yr (mm/tr) 76.81 61.77 52.03 45.17 40.04 38.06 32.86 30.24 28.04 28.04 28.04 28.04 28.17 24.56 C8 552	Qp 1:2 Yr (Ls) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.78 5.36 5.01 4.70 28.98 35.70	Qp ICD (L/s) 4.00 3 m3	4.0 Qp stored (Us) 10.69 7.81 5.95 4.64 4.64 3.66 2.90 2.29 1.78 1.36 1.01 0.70	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.59 6.08 5.49 5.49 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.95 63.95 59.62 55.89	Cp 1:100 Yr (L/s) 38:10 30.49 25:59 22:16 19:60 17:62 16:03 14:73 13:65 12:72 11:93	Qp ICD (Us) 4.00 4.0	Op stored (U/s) 34.10 26.49 21.59 18.16 15.60 13.62 12.03 10.73 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.34 25.91 27.24 28.60 28.80 28.60 28.89 28.94 28.94 28.94 28.73 28.53	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35 40 45 50 55 60 Mnimum storage volume requirement = Surface Storage: Surface Storage:	0.085 0.81 0.90 1.2 Yr (mm/hr) 76.81 61.77 62.03 45.17 40.04 36.06 32.86 30.24 28.04 28.04 28.17 24.56	Qp 1.2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.36 5.01 4.70 28.98 35.70	Cp ICD (L/s) 4.00 3 m3	4.0 Op stored (Us) 10.69 7.81 5.95 4.64 3.86 2.90 2.29 1.78 1.36 1.01 0.70	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.08 6.08 6.08 6.08 6.08 6.08 4.82 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 91.87 82.58 75.15 69.05 63.95 55.89	Op 1:00 Yr (Us) 38:10 30:49 22:59 22:16 19:60 17:62 16:03 14:73 13:65 12:72 11:93	Qp (LS) (LS) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Qp stored (L/s) 24.10 26.49 21.59 13.62 12.03 10.73 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.74 28.08 28.60 28.88 28.99 28.94 28.94 28.76 28.53	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Imme (min) 10 15 20 35 40 45 50 60 Mnimum storage volume requirement = Surface Storage:	0.085 0.81 0.90 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 38.06 32.86 30.24 28.04 28.17 24.56 CB 552 by the design	Qp 1.2 Yr (Us) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.01 4.70 28.98 35.70	Qp ICD (L/s) 4.00 3 m3	4.0 Qp stored (Us) 10.69 7.81 5.95 4.64 3.66 2.90 2.29 1.78 1.36 1.01 0.70	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.59 6.08 5.49 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.95 59.62 55.89	Op 1:100 Yr (Us) 38:10 30:49 25:59 22:16 19:60 17:62 16:03 14:73 13:65 12:72 11:93	Qp (LCD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Qp stored (U/s) 34.10 26.49 21.59 15.60 13.62 15.60 13.62 10.73 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.24 28.00 28.80 28.99 28.99 28.94 28.78 28.53	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Image: Comparison of the second	0.085 0.81 0.30 1.2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.26 30.24 28.04 28.04 28.04 28.04 28.55 24.56	Qp 1.2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.01 4.70 28.98 35.70	Cp Cp ICD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 9 m3 9 m3	4.0 Qp stored (L/s) 10.69 7.81 5.95 4.64 3.66 2.90 2.29 1.78 1.36 1.01 0.70	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.08 5.49 4.82 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 1142.89 119.95 91.87 91.87 91.87 91.87 55.15 69.05 63.95 55.69 55.89	Op 1:100 Yr (L/s) 38.10 30.49 22.59 22.16 19.60 17.62 16.03 14.73 13.85 12.72 11.93	Qp ICD (L's) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Qp stored (L/s) 24.10 26.49 21.59 13.62 12.03 10.73 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.24 28.00 28.80 28.90 28.88 28.98 28.98 28.94 28.78 28.53	
3	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35 40 45 55 60 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement met in the	0.085 0.81 0.81 0.90 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 38.06 32.86 30.24 28.04 28.04 28.17 24.56 CB 552 by the design	Qp 1.2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.01 4.70 28.98 35.70	Qp ICD (L/s) 4.00 3.03	4.0 Qp stored (Us) 10.69 7.81 5.95 4.64 3.66 2.90 2.29 1.78 1.36 1.01 0.70	Max Volume Requirement (m3) 6.41 7.03 7.14 6.59 6.59 6.59 6.59 6.08 5.49 4.82 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.95 59.62 55.89	Op 1:00 Yr (Us) 38:10 30:49 25:59 22:16 19:60 17:62 16:03 14:73 13:65 12:72 11:93	Qp (CD (Us) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Op stored (U/s) 26.49 26.49 21.59 15.60 13.62 12.03 10.73 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.34 25.91 27.72 28.00 28.60 28.60 28.88 28.98 28.94 28.94 28.78 28.53	
4	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 10 15 20 26 30 35 40 45 50 56 60 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement met 1 CBMH 571 - ICD 71	0.085 0.81 0.90 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 32.86 30.24 28.04 28.04 28.04 28.17 24.56 CB 552 by the design	Qp 1:2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.01 4.70 28.98 35.70	App ICD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 3 m3	4.0 Qp stored (U/s) 10.09 7.81 5.95 4.64 3.66 2.90 2.29 1.78 1.36 1.01 0.70	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.08 5.49 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.96 59.62 55.89	Op 1:100 Yr (Us) 38.10 30.49 25.59 22.16 19.60 17.62 16.03 14.73 13.65 12.72 11.93	Qp ICD (L's) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Qp stored (L/s) 24.10 26.49 21.59 18.16 15.60 13.62 12.03 10.73 9.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.74 28.08 28.60 28.88 28.98 28.98 28.94 28.75 28.53	
4	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 36 40 45 50 60 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement met CBMH 571 - ICD 71	0.085 0.81 0.90 Intensity 1.2 Yr (mm/hy) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 30.24 28.04 28.04 28.04 28.17 24.56 CB 552 by the design	Qp 1.2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66 6.50 6.50 5.78 5.36 5.01 4.70 28.98 35.70	Cp ICD (L/S) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 3 m3 D m3	4.0 Qp stored (U-s) 10.69 7.81 5.95 4.64 3.66 2.29 1.78 1.36 1.01 0.70	Max Volume Requirement (m3) 6.41 7.03 7.14 6.59 6.59 6.08 5.49 4.82 4.09 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.95 59.62 55.89	Op 1:100 Yr (L/s) 38.10 30.49 25.59 22.16 19.60 17.62 16.03 14.73 13.66 12.72 11.93	Qp (LCD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Qp stored (U/s) 26.49 21.59 13.62 12.03 10.73 9.65 8.72 7.93	Max Volume Requirement (m3) 20,46 23,84 25,91 27,74 28,08 28,60 28,60 28,88 28,98 28,94 28,94 28,76 28,53	
4	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35 40 45 50 60 Mnimum storage volume requirement = Surface Storage: *Minimum storage volume requirement met to CEBMH 571 - ICD 71	0.085 0.81 0.81 0.90 Intensity 1:2 Yr (mm/tr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 30.24 28.04 28.04 28.04 28.04 28.17 24.56 C8 552 by the design	Qp 1:2 Yr (Ls) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.01 4.70 28.98 35.70	Qp ICD ICD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 3.00 3.00 3.00	4.0 Qp stored (Us) 10.69 7.81 5.95 4.64 3.66 2.90 2.29 1.78 1.36 1.01 0.70	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.08 5.49 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 172.56 142.29 119.95 103.85 91.87 82.58 75.15 69.05 63.95 59.62 55.89	Cp 1:100 Yr (Us) 38:10 30.49 25:59 22:16 19:60 17:62 16:03 14:73 13:65 12:72 11:93	Op ICD (L/S) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Op stored (U/s) 34.10 26.49 21.59 18.16 15.60 13.62 12.03 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.24 28.08 28.98 28.98 28.98 28.98 28.94 28.78 28.53	
4	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 10 15 20 26 30 35 40 45 50 55 60 Mnimum storage volume requirement = Surface Storage: *Minimum storage volume requirement met I CBMH 571 - ICD 71 Area C-Factor 1:2Yr	0.085 0.81 0.90 intensity 1.2 Yr (mm/hr) 76.81 61.77 62.03 45.17 40.04 36.06 32.86 30.24 28.04 28.04 28.04 28.04 28.04 28.04 28.04 28.05 CB 552 by the design 0.333 0.83	Qp 1.2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.01 4.70 28.98 35.70	Cp ICD (L/S) 4.00 3 m3 0 m3	4.0 0p stored (Us) 10.69 7.81 5.95 4.64 3.66 2.90 2.90 1.78 1.36 1.01 0.70	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.08 6.59 6.08 6.59 6.08 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 1142.89 119.95 91.67 82.58 75.15 69.05 63.95 63.95 55.89	Op 1:100 Yr (L/s) 38:10 30:49 22:59 22:16 19:60 17:62 16:03 14:73 13:65 12:72 11:93	Qp ICD (Us) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Qp stored (L/s) 24.10 26.49 21.59 13.62 12.03 10.73 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.24 28.08 28.60 28.88 28.98 28.94 28.94 28.78 28.53	
4	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Imme (min) 10 15 20 35 40 45 55 60 Mnimum storage volume requirement = Surface Storage: 'Minimum storage volume requirement met CBMH 571 - ICD 71 Area C-Factor 1:2Yr Uning storage volume requirement =	0.085 0.81 0.90 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.26 30.24 28.04 28.17 24.56	Qp 1.2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.01 4.70 28.98 35.70	Qp ICD (L/s) 4.00 3 m3 D m3	4.0 Qp stored (Us) 10.69 7.81 5.95 4.64 3.66 2.90 2.29 1.78 1.36 1.01 0.70 	Max Volume Requirement (m3) 6.41 7.03 7.14 6.59 6.59 6.59 6.59 6.59 6.59 6.59 2.51 2.51	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.95 59.62 55.89	Op 1:100 Yr (Us) 38:10 30:49 25:59 22:16 19:60 17:62 16:03 14:73 13:65 12:72 11:93	Qp (CD (Us) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Op stored (L/s) 26.49 26.49 21.59 15.60 15.60 15.60 15.60 13.62 12.03 10.73 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.34 25.91 27.24 28.00 28.60 28.80 28.94 28.94 28.94 28.53	
4	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 10 15 20 20 25 30 36 40 45 55 60 Mnimum storage volume requirement = Surface Storage: 'Minimum storage volume requirement met 1 CBMH 571 - ICD 71 Area C-Factor 1:2Yr Minimum storage volume requirement = Surface Storage:	0.085 0.81 0.30 Intensity 1.2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.26 30.24 28.04 26.17 24.56	Qp 1:2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.01 4.70 28.98 35.70 138.40	Op ICD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 3 m3 D m3	4.0 Qp stored (L/s) 10.69 7.81 5.96 4.64 3.66 2.90 2.29 1.78 1.36 1.01 0.70 1.01 0.70 18.0 (refer to Model M3	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.08 5.49 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 1142.89 119.95 91.87 82.58 75.15 69.05 63.95 55.62 55.89	Op 1:100 Yr (<i>Us</i>) 38.10 30.49 25.59 22.16 19.60 17.62 16.03 14.73 13.66 12.72 11.93	Qp ICD (1/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Qp stored (L(s) 28.49 21.59 18.16 15.60 13.62 12.03 10.73 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.24 28.00 28.60 28.88 28.96 28.98 28.94 28.78 28.53	
4	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 36 40 45 50 55 60 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement met to CBMH 571 - ICD 71 Area C-Factor 1:2Yr Minimum storage volume requirement =	0.085 0.81 0.90 Intensity 1.2 Yr (mm/hy) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 30.24 28.04 28.04 28.17 24.56 CB 552 by the design 0.333 0.83	Qp 1.2 Yr (Us) 14.69 11.81 9.95 8.64 7.66 6.29 5.78 5.36 5.01 4.70 28.98 35.70 138.40	Cp ICD (L/S) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 3.00 3.00 3.00	4.0 Qp stored (U-s) 10.69 7.81 5.95 4.64 3.66 2.29 1.78 1.36 1.36 1.36 1.01 0.70 	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.08 5.49 4.82 4.09 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 91.87 82.58 91.87 69.05 63.95 55.69 55.89	Op 1:00 Yr (Us) 38:10 30:49 25:59 22:16 19:60 17:62 16:03 14:73 13:65 12:72 11:93	Qp (LCD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Op stored (Us) 26.49 21.59 13.60 13.62 12.03 10.73 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.724 28.08 28.60 28.60 28.98 28.98 28.94 28.94 28.76 28.53	
4	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 10 15 20 20 25 30 35 40 45 50 56 60 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement = CBMH 571 - ICD 71 Area C-Factor 1:2Yr Minimum storage volume requirement =	0.085 0.31 0.30 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 32.86 30.24 28.04 28.04 28.04 28.17 24.56 CB 552 by the design 0.333 0.83 CBMH571	Qp 1:2 Yr (L8) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.01 4.70 28.98 35.70 138.40 71.97	App ICD ICD 4.00 3 m3 0 m3 7 m3	4.0 Qp stored (L/s) 10.09 7.81 5.95 4.64 3.66 2.90 1.78 1.36 1.01 0.70 1.01 0.70 18.0 (refer to Model M3	Max Volume Requirement (m3) 6.41 7.03 7.14 6.99 6.08 5.49 6.08 5.49 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.66 142.89 119.95 91.87 82.58 75.15 69.05 63.95 59.62 55.89	Op 1:100 Yr (Us) 38.10 30.49 25.59 22.16 19.60 17.62 16.03 14.73 13.65 12.72 11.93	Qp ICD (L's) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Qp stored (U/s) 24.10 26.49 21.59 18.16 15.60 13.62 12.03 10.73 9.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.74 28.08 28.60 28.88 28.98 28.98 28.94 28.78 28.53	
4	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 10 15 20 26 30 35 40 46 50 56 60 Mnimum storage volume requirement = Surface Storage: *Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement = Surface Storage: Minimum storage volume requirement = Surface Storage: Minimum storage volume requirement = Surface Storage:	0.085 0.81 0.90 Intensity 1.2 Yr (mm/hr) 76.81 61.77 62.03 45.17 40.04 36.06 32.86 30.24 28.04 2	Qp 1.2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.01 4.70 28.98 35.70 138.40 71.97 26.44	Cp ICD Cp (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 3 m3 0 m3	4.0 Qp stored (U-s) 10.69 7.81 5.95 4.64 3.86 2.90 1.78 1.36 1.36 1.01 0.70 18.0 (refer to Model M3	Max Volume Requirement (m3) 6.41 7.03 7.14 6.59 6.59 6.69 6.59 6.08 5.49 4.82 4.09 4.82 4.09 4.09 2.51	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.95 55.69 55.89	Op 1:00 Yr (L/s) 38.10 30.49 25.59 22.16 19.60 17.62 16.03 14.73 13.65 12.72 11.93	Qp (LCD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Qp stored (U/s) 24.10 26.49 21.59 13.62 12.03 10.73 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.74 28.06 28.60 28.60 28.88 28.98 28.94 28.94 28.73 28.53	
4	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 10 15 20 20 25 30 35 40 45 50 60 Mnimum storage volume requirement = Surface Storage: *Minimum storage volume requirement met in CEBMH 571 - ICD 71 Area C-Factor 1:2Yr Mnimum storage volume requirement = Surface Storage: Underground Pipe Storage (including MHs): Storage (including MHs):	0.085 0.81 0.90 Intensity 1:2 Yr (mm/tr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 30.24 28.04 28.04 28.04 28.04 28.17 24.56 CB 552 by the design 0.333 0.83 CBMH571 CBMH570 - CBMH571	Qp 1:2 Yr (L8) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.01 4.70 28.98 35.70 138.40 71.67 26.44 48.48	Qp ICD ICD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 3.00 8.00 4.00 9.00 3.00 9.03 3.03	4.0 Qp stored (L/s) 10.69 7.81 5.95 4.64 3.66 2.90 2.29 1.78 1.36 1.01 0.70 18.0 (refer to Model M3 (refer to Model M3)	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.59 6.69 6.69 6.69 6.69 6.69	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.95 59.62 55.89 r SWMHYMO res	Op 1:100 Yr (U/s) 38:10 30:49 25:59 22:16 19:60 17:62 16:03 14:73 13:65 12:72 11:93 ults)	Op ICD (L/S) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Op stored (L/s) 34.10 26.49 21.59 15.60 13.62 15.60 13.62 12.03 8.75 8.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.24 28.08 28.98 28.98 28.98 28.98 28.94 28.78 28.53	
4	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 10 15 20 20 25 30 36 40 45 50 55 60 Strate Storage: *Minimum storage volume requirement = Surface Storage: CBMH 571 - ICD 71 Area C-Factor 1:2Yr Minimum storage volume requirement = Surface Storage: Underground Pipe Storage (including MHs): Total Storage Volume: Surface Storage (including MHs):	0.085 0.81 0.90 Intensity 1.2 Yr (mm/hr) 76.81 61.77 62.03 45.17 40.04 36.06 32.86 30.24 28.04 2	Qp 1.2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66 6.90 6.29 5.78 5.36 5.01 4.70 28.98 35.70 138.40 71.97 26.44 48.84 146.89	Cp ICD (L/S) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.00 3.33 3.33 3.33	4.0 0p stored (Us) 10.69 7.81 5.95 4.64 3.66 2.90 2.90 1.78 1.36 1.36 1.01 0.70 18.0 (refer to Model MS	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.08 5.49 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.95 59.62 55.89 55.89	Op 1:100 Yr (L/s) 38.10 30.49 25.59 22.16 19.60 17.62 16.03 14.73 13.65 12.72 11.93	Qp ICD (Us) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Qp stored (L/s) 24.10 26.49 21.59 13.62 12.03 10.73 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.74 28.08 28.98 28.98 28.94 28.94 28.76 28.53	
4	CB 552 - ICD 52 Area C-Factor 1:2Yr C-Factor 1:2Yr C-Factor 1:100 Yr Image: Comparison of the second se	0.85 0.81 0.90 1:2 Yr (mm/hy) 76.81 61.77 52.03 45.17 40.04 32.06 32.86 30.24 28.04 28.17 24.56 CB 552 by the design 0.333 0.83 CBMH571 CBMH570 CBMH570 - CBMH571	Qp 1.2 Yr (L/s) 14.69 11.81 9.95 8.64 7.66 6.50 6.29 5.78 5.36 5.01 4.70 28.98 35.70 138.40 71.97 72.64 4.848 146.89	Qp ICD (L/s) 4.00 3.03 3.33 3.33 3.33	4.0 Qp stored (U/s) 10.69 7.81 5.95 4.64 2.90 1.78 1.36 2.99 1.78 1.36 1.01 0.70 1.8.0 (refer to Model M3)	Max Volume Requirement (m3) 6.41 7.03 7.14 6.96 6.59 6.08 5.49 4.82 4.82 4.09 3.32 2.51	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.95 59.62 55.89 r SWMHYMO res	Op 1:100 Yr (Us) 38:10 30:49 25:59 22:16 19:60 17:62 16:03 14:73 13:65 12:72 11:33 vits)	Qp (LCD (L/s) 4.00 4.00 4.00 4.00 4.00 4.00 4.00 4.0	Op stored (Us) 34.10 26.49 21.59 15.60 13.62 12.03 10.73 9.65 8.72 7.93	Max Volume Requirement (m3) 20.46 23.84 25.91 27.72 28.06 28.60 28.88 28.98 28.94 28.94 28.94 28.53	



JLR No. 23405-003.1

STORMWATER MANAGEMENT CALCULATIONS

	Area	0.053		Release Rate:	4 0	11/s							
	C-Factor 1:2Yr	0.41		Relieuse Rute.	-1.0	20							
	C-Factor 1:100 Yr	0.41											
		0.40											
	Time	Intensity	On	Qp	Qp	Max Volume	Intensity	On	Qp	Qp	Max Volume		
	(min)	1.2 Vr	400 1-2 Vr	ICD	stored	Requirement	1:100 Vr	4p		stored	Requirement		
	()	(mm/hr)	(1/e)	(1/s)	(1/s)	(m3)	(mm/br)	(1/e)	(1/s)	(1/s)	(m3)		
	10	76.81	4.65	4.00	0.65	0.39	179.56	10.52	(1.0)	8.53	5.12		
	10	61.77	3.74	4.00	0.00	0.00 N/A	140.00	12.00	4.00	6.03	5.43		
	15	50.00	3.14	4.00	N/A	IN/A	142.89	10.03	4.00	0.03	5.43		
	20	52.03	3.15	4.00	N/A	N/A	119.95	8.42	4.00	4.42	5.30		
	25	45.17	2.14	4.00	IN/A	IN/A	103.85	7.29	4.00	3.29	4.93		
	30	40.04	2.43	4.00	N/A	N/A	91.87	6.45	4.00	2.45	4.41		
	35	36.06	2.19	4.00	N/A	N/A	82.58	5.80	4.00	1.80	3.77		
	40	32.86	1.99	4.00	N/A	N/A	75.15	5.27	4.00	1.27	3.06		
	45	30.24	1.83	4.00	N/A	N/A	69.05	4.85	4.00	0.85	2.29		
	50	28.04	1.70	4.00	N/A	N/A	63.95	4.49	4.00	0.49	1.47		
	55	26.17	1.59	4.00	N/A	N/A	59.62	4.19	4.00	0.19	0.61		
	Minimum storage volume requirement =		5.4	3 m3									
	Surface Storage: CB572		9.2	9.28 m3									
	*Minimum storage volume requirement met b	by the design											
ing B	Assumed Rooftop Properties:												
	Total Area Roof =	0.0950 H	ia										
	Unusable roof (20%) =	0.0190 H	ia										
	Usable roof (80%) =	0.0760 1	ia										
	Depth of Storage =	0.127 r	n										
	Controlled roof release rate = 1.29 l/s roof Total controlled roof release rate =	f drain x 6 Zurn Control-Flc 7.74 I	units (102 mm Ri ./s	se)									
	Roofton Area =	0.095											
	C-Factor (1:2 year) =												
		0.90											
	C-Factor (1:100 year) =	0.90											
	C-Factor (1:100 year) =	0.90											
	C-Factor (1:100 year) = Time	0.90 1.00	Qp	Qp	Qp	Max Volume	Intensity	Qp	Qp	Qp	Max Volume		
	C-Factor (1:100 year) = Time (min)	0.90 1.00	Qp	Qp roof drain	Qp stored	Max Volume Requirement	Intensity 1:100 Yr	Qp	Qp roof drain	Qp stored	Max Volume Requirement		
	C-Factor (1:100 year) = Time (min)	0.90 1.00	Qp (L/s)	Qp roof drain (L/s)	Qp stored (L/s)	Max Volume Requirement (m3)	Intensity 1:100 Yr (mm/hr)	Qp (L/s)	Qp roof drain (L/s)	Qp stored (L/s)	Max Volume Requirement (m3)		
	C-Factor (1:100 year) = Time (min) 10	0.90 1.00 Intensity 1:2 Yr (mm/hr) 76.81	Qp (L/s) 18.26	Qp roof drain (L/s) 7.74	Qp stored (L/s) 10.52	Max Volume Requirement (m3) 6.31	Intensity 1:100 Yr (mm/hr) 178.56	Qp (L/s) 47.16	Qp roof drain (L/s) 7.74	Qp stored (L/s) 39.42	Max Volume Requirement (m3) 23.65		
	C-Pactor (1:100 year) =	0.90 1.00 Intensity 1:2 Yr (mm/hr) 76.81 61.77	Qp (L/s) 18.26 14.68	Qp roof drain (L/s) 7.74 7.74	Qp stored (L/s) 10.52 6.94	Max Volume Requirement (m3) 6.31 6.25	Intensity 1:100 Yr (mm/hr) 178.56 142.89	Qp (L/s) 47.16 37.74	Qp roof drain (L/s) 7.74 7.74	Qp stored (L/s) 39.42 30.00	Max Volume Requirement (m3) 23.65 27.00		
	C-Factor (1:100 year) = Time (min) 10 15 20	0.90 1.00 1:2 Yr (mm/hr) 76.81 61.77 52.03	Qp (L/s) 18.26 14.68 12.37	Op roof drain (L/s) 7.74 7.74 7.74	Qp stored (L/s) 10.52 6.94 4.63	Max Volume Requirement (m3) 6.31 6.25 5.55	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95	Qp (L/s) 47.16 37.74 31.68	Qp roof drain (Us) 7.74 7.74 7.74	Qp stored (L/s) 39.42 30.00 23.94	Max Volume Requirement (m3) 23.65 27.00 28.73		
	C-Factor (1:100 year) = Time (min) 10 15 20 25	0.90 1.00 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17	Qp (L/s) 18.26 14.68 12.37 10.74	Qp roof drain (L/s) 7.74 7.74 7.74 7.74	Qp stored (U/s) 10.52 6.94 4.63 3.00	Max Volume Requirement (m3) 6.31 6.25 5.55 4.49	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85	Op (L/s) 47.16 37.74 31.68 27.43	Qp roof drain (L/s) 7.74 7.74 7.74 7.74	Qp stored (L/s) 39.42 30.00 23.94 19.69	Max Volume Requirement (m3) 23.65 27.00 28.73 29.53		
	C-Factor (1:100 year) = Time (min) 10 15 20 25 30	0.90 1.00 1.2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04	Qp (L/s) 18.26 14.68 12.37 10.74 9.52	Op roof drain (L/s) 7.74 7.74 7.74 7.74 7.74	Qp stored (L/s) 10.52 6.94 4.63 3.00 1.78	Max Volume Requirement (m3) 6.31 6.25 5.55 4.49 3.20	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87	Qp (L/s) 47.16 37.74 31.68 27.43 24.26	Op roof drain (L/s) 7.74 7.74 7.74 7.74 7.74	Qp stored (L/s) 39.42 30.00 23.94 19.69 16.52	Max Volume Requirement (m3) 23.65 27.00 28.73 29.53 29.53		
	C-Factor (1:100 year) = Time (min) 10 15 20 25 30 35	0.90 1.00 1:2 Yr (mm/kr) 76.81 61.77 52.03 45.17 40.04 38.06	Qp (L/s) 18.26 14.68 12.37 10.74 9.52 8.57	Qp roof drain (L/s) 7.74 7.74 7.74 7.74 7.74 7.74	Qp stored (U/s) 10.52 6.94 4.63 3.00 1.78 0.83	Max Volume Requirement (m3) 6.31 6.25 5.55 4.49 3.20 1.74	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58	Qp (L/s) 47.16 37.74 31.68 27.43 24.26 21.81	Qp roof drain (Us) 7.74 7.74 7.74 7.74 7.74 7.74 7.74	Qp stored (L/s) 39.42 30.00 23.94 19.69 16.52 14.07	Max Volume Requirement (m3) 23.65 27.00 28.73 29.53 29.74 29.54		
	C-Factor (1:100 year) = Time (min) 10 15 20 25 30 30 40	0.90 1.00 	Op (L/s) 18.26 14.68 12.37 10.74 9.52 8.57 7.81	Op roof drain (L/s) 7.74 7.74 7.74 7.74 7.74 7.74 7.74 7.7	Op stored (L/s) 10.52 6.94 4.63 3.00 1.78 0.83 0.07	Max Volume Requirement (m3) 6.31 6.25 5.55 4.49 3.20 1.74 0.17	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15	Qp (Us) 47.16 37.74 31.68 27.43 24.26 21.81 19.85	Op roof drain (L/s) 7.74 7.74 7.74 7.74 7.74 7.74 7.74 7.7	Qp stored (L/s) 39.42 30.00 23.94 19.69 16.52 14.07 12.11	Max Volume Requirement (m3) 23.65 27.00 28.73 29.54 29.74 29.54 29.05		
	C-Factor (1:100 year) = Time (min) 10 15 20 25 30 35 40 45	0.90 1.00 Intensity 1.2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 30.24	Qp (L/s) 18.26 14.68 12.37 10.74 9.52 8.57 7.81 7.19	Op roof drain (<i>U/s</i>) 7.74 7.74 7.74 7.74 7.74 7.74 7.74 7.7	Qp stored (L/s) 10.52 6.94 4.63 3.00 1.78 0.83 0.07 NA	Max Volume Requirement (m3) 6.31 6.25 5.55 4.49 3.20 1.74 0.17 NA	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05	Op (L/s) 47.16 37.74 31.68 27.43 24.26 21.81 19.85 18.24	Op roof drain (U/s) 7.74 7.74 7.74 7.74 7.74 7.74 7.74 7.7	Qp stored (L/s) 39.42 30.00 23.94 19.69 16.52 14.07 12.11 10.50	Max Volume Requirement (m3) 23.65 27.00 28.73 29.53 29.54 29.54 29.54 29.05 28.34		
	C-Factor (1:100 year) = Time (min) 10 15 20 25 30 35 40 45 50	0.90 1.00 1.2 Yr (mm/kr) 76.81 61.77 52.03 45.17 40.04 38.06 32.86 30.24 28.04	Qp (L/s) 18.26 14.68 12.37 10.74 9.52 8.57 7.81 7.19 6.67	Qp roof drain (L/s) 7.74 7.74 7.74 7.74 7.74 7.74 7.74 7.7	Op stored ((L/s) 10.52 6.94 4.63 3.00 1.78 0.83 0.07 N/A	Max Volume Requirement (m3) 6.31 6.25 5.55 4.49 3.20 1.74 0.17 N/A N/A	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.95	Op (L/s) 47.16 37.74 31.68 27.43 24.26 21.81 19.85 18.24 16.89	Qp roof drain (U/s) 7.74 7.74 7.74 7.74 7.74 7.74 7.74 7.7	Qp stored (L/s) 39.42 30.00 23.94 19.69 16.52 14.07 12.11 10.50 9.15	Max Volume Requirement (m3) 23.65 27.00 28.73 29.54 29.54 29.54 29.06 28.34 27.45		
	C-Factor (1:100 year) = Time (min) 10 15 20 25 30 35 40 45 50	0.90 1.00 Intensity 1:2 Yr (mm/hr) 76.81 61.77 62.03 45.17 40.04 38.06 32.86 30.24 28.04 28.04 28.07	Op (L/s) 18.26 14.68 12.37 10.74 9.52 8.57 7.81 7.19 6.67 6.22	Op roof drain (L/s) 7.74 7.74 7.74 7.74 7.74 7.74 7.74 7.7	Op stored (L/s) 10.52 6.94 4.63 3.00 1.78 0.83 0.07 N/A N/A N/A	Max Volume Requirement (m3) 6.31 6.25 5.55 4.49 3.20 1.74 0.17 N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 69.05 63.95 59.62	Qp (L/s) 47.16 37.74 31.68 27.43 24.26 21.81 19.85 18.24 16.89 15.75	Op roof drain (L/s) 7.74 7.74 7.74 7.74 7.74 7.74 7.74 7.7	Op stored (Us) 39.42 30.40 23.94 19.69 16.52 14.07 12.11 10.50 9.15 8.01	Max Volume Requirement (m3) 23.85 27.00 28.73 29.53 29.74 29.54 29.54 29.54 28.34 27.45 28.34 27.45 26.42		
	C-Factor (1:100 year) = Time (min) 10 15 20 25 30 355 40 45 50 55 Minimum roof storage volume requirement =	0.90 1.00 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 38.06 32.86 30.24 28.04 28.04 28.17	Qp (L/s) 18.26 14.68 12.37 10.74 9.52 8.57 7.81 7.19 6.67 6.22	Qp roof drain (U/s) 7.74 7.74 7.74 7.74 7.74 7.74 7.74 7.7	Op stored (L/s) 10.52 6.94 4.63 3.00 1.78 0.83 0.07 N/A N/A	Max Volume Requirement (m3) 6.31 6.25 5.55 4.49 3.20 1.74 0.17 N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 91.87 75.15 69.05 63.95 59.62	Op (L/s) 47.16 37.74 31.68 27.43 24.26 21.81 19.85 18.24 16.89 15.75	Op roof drain 7.74 7.74 7.74 7.74 7.74 7.74 7.74 7.7	Op stored (L/s) 39.42 30.00 23.94 19.69 16.52 14.07 12.11 10.50 9.15 8.01	Max Volume Requirement (m3) 23.65 27.00 28.73 29.54 29.54 29.54 29.54 29.05 28.34 27.45 26.42		
	C-Factor (1:100 year) = Time (min) 10 15 20 25 30 35 40 45 50 55	0.90 1.00 1.2 Vfr (mm/hr) 76.81 61.77 52.03 45.17 40.04 38.06 32.86 30.24 28.04 28.04 28.04	Op (U/s) 18.26 14.68 12.37 10.74 9.52 8.57 7.81 7.19 6.67 6.22 23.7	Op roof drain (L/s) 7.74 7.74 7.74 7.74 7.74 7.74 7.74 7.7	Qp stored ((L/s) 10.52 6.94 4.63 3.00 1.78 0.83 0.07 N/A N/A N/A	Max Volume Requirement (m3) 6.31 6.25 5.55 4.49 3.20 1.74 0.17 N/A N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 91.87 82.58 75.15 69.05 63.95 59.62	Op (L/s) 47.16 37.74 31.68 27.43 24.26 21.81 19.85 18.24 16.69 15.75	Op roof drain (L/s) 7.74 7.74 7.74 7.74 7.74 7.74 7.74 7.7	Op stored (L/s) 39.42 30.00 23.94 19.69 16.52 14.07 12.11 10.50 9.15 8.01	Max Volume Requirement (m3) 23.65 27.00 28.73 29.54 29.05 28.34 29.05 28.34 27.45 26.42		
	C-Factor (1:100 year) = Time (min) 10 15 20 25 30 35 40 45 50 55	0.90 1.00 1.2 Vf (mm/hr) 76.81 61.77 52.03 45.17 40.04 38.06 32.86 30.24 28.04 28.04 28.04	Op (L/s) 18.26 14.68 14.68 14.68 14.68 15.2 8.57 7.81 7.19 6.67 6.22 29.7 32.1	Qp roof drain (L/s) 7.74 7.74 7.74 7.74 7.74 7.74 7.74 7.7	Qp stored (L/s) 10.52 6.94 4.63 3.00 1.78 0.83 0.07 N/A N/A N/A	Max Volume Requirement (m3) 6.31 6.25 5.55 4.49 3.20 1.74 0.17 N/A N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 91.87 75.15 63.95 59.62	Qp (L/s) 47.16 37.74 31.68 27.43 24.26 21.81 19.85 18.24 16.89 15.75	Op roof drain (L/s) 7.74 7.74 7.74 7.74 7.74 7.74 7.74 7.7	Op stored (Us) 39.42 30.00 23.94 19.69 16.52 14.07 12.11 10.50 9.15 8.01	Max Volume Requirement (m3) 23.65 27.00 28.73 29.54 29.54 29.54 29.54 29.06 28.34 27.45 26.42		



JLR No. 23405-003.1

STORMWATER MANAGEMENT CALCULATIONS

7	Building C	Assumed Rooftop Properties:	

Assumed Roomop Properties:										
Tatal Area Daví -	0.0050 1	h -								
Iotal Area Root =	0.0850 h	na								
Unusable root (20%) =	0.0170 ł	na								
Usable roof (80%) =	0.0680 h	ha								
Depth of Storage =	0.127 r	m								
Rooftop Volume Assuming Sloped Roo	of (m ³) = Usable rooftop area	a (m ²) x storage dept	th (m)/3							
D - ft - 1/- l (3) 0003 - 0 407	7 (0	· (··· / ··								
Roonop volume (m) = 680 m* x 0.127	/ m / 3									
Rooftop Volume (m ³) =	28.8 r	m ³								
Controlled roof release rate = 1.29 l/s r Total controlled roof release rate	roof drain x 5 Zurn Control-Flo 6.45 L	ა units (102 mm Ris L/s	se)							
Rooftop Area =	0.085	l								
C-Factor (1:2 year) =	0.90									
C-Factor (1:100 year) =	1.00	1								
Time	Intensity	Qp	Qp	Qp	Max Volume	Intensity	Qp	Qp	Qp	Max Volume
(min)	1:2 Yr	- -	roof drain	stored	Requirement	1:100 Yr	~~	roof drain	stored	Requirement
()	(mm/hr)	(1/s)	(L/s)	(L/s)	(m3)	(mm/br)	(/s)	(1/s)	(L/s)	(m3)
10	76.81	16.33	645	9.88	E 02	179.56	(23)	6.45	35.74	21.45
10	61.77	12.14	6.45	6.60	0.90	110.00	42.19	0.45	07.22	21.40
15	01.77	13.14	0.45	0.09	6.02	142.89	33.77	6.45	21.32	24.58
20	52.03	11.07	6.45	4.62	5.54	119.95	28.34	6.45	21.89	26.27
25	45.17	9.61	6.45	3.16	4.73	103.85	24.54	6.45	18.09	27.13
30	40.04	8.52	6.45	2.07	3.72	91.87	21.71	6.45	15.26	27.47
35	36.06	7.67	6.45	1.22	2.56	82.58	19.51	6.45	13.06	27.43
40	32.86	6.99	6.45	0.54	1.29	75 15	17 76	6 45	11.31	27.14
45	30.24	643	6.45	N/A	N/A	60.05	16.20	6.45	9.87	26.64
45	30.24	5.43	6.45	N/A	IN/A	09.05	10.32	0.45	0.01	20.04
50	28.04	5.90	0.40	IN/A	N/A	63.95	15.11	6.45	0.00	25.99
Minimum roor storage volume requirement =	<u>.</u>	27.47	7 m3							
Roof storage volume provided by design =		28.79	h							
			e ma							
			9 m3							
*Minimum storage volume requirement m	net by the design		9 m3							
*Minimum storage volume requirement m	net by the design		9 m3							
*Minimum storage volume requirement m	net by the design		9 m3							
*Minimum storage volume requirement m	net by the design		9 m3							
*Minimum storage volume requirement m	net by the design		9 m3							
*Minimum storage volume requirement m CB 580 - ICD 80	net by the design		9 m3							
*Minimum storage volume requirement m CB 580 - ICD 80 Area	net by the design		Release Rate:	13.0) L/s					
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr	0.05		Release Rate:	13.0) L/s					
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:2Yr	0.05 0.59 0.67		Release Rate:	13.0) L/s					
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr	0.05 0.59		Release Rate:	13.0) Us					
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time	et by the design 0.05 0.59 0.67 Intensity	 Qp	Release Rate:	13.(Qp) L/s Max Volume	Intensity	Ορ	Qp	Qp	Max Volume
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min)	0.05 0.59 0.67	 Qp	Release Rate:	13.0 Qp stored) L/s Max Volume Requirement	Intensity 1:100 Yr	Qp	Qp ICD	Qp stored	Max Volume Requirement
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min)	0.05 0.59 0.67 Intensity 1:2 Yr (mm/br)	Qp	Release Rate:	13.0 Qp stored ([//s])) L/s Max Volume Requirement (m3)	Intensity 1:100 Yr (mm/br)	Ор ((/%)	Qp ICD ((/s)	Op stored ([/s)	Max Volume Requirement (m3)
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min)	0.05 0.59 0.67 Intensity 1:2 Yr (mm/hr)	Op (L/s)	Release Rate: Qp ICD (L/s) 12 00	Qp stored (Us)	Max Volume Requirement (m3)	Intensity 1:100 Yr (mm/hr)	Ор (Us)	Qp ICD (U/s)	Qp stored (U/s)	Max Volume Requirement (m3)
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10	0.05 0.05 0.59 0.67 Intensity 1:2 Yr (mm/hr) 76.81	Qp (L/s) 6.32	Release Rate: Qp ICD (L/s) 13.00	Op stored (L/s) N/A	Max Volume Requirement (m3) N/A	Intensity 1:100 Yr (mm/br) 178.56	Ор (Us) 16.63	Qp ICD (L/s) 13.00	Qp stored (L/s) 3.63	Max Volume Requirement (m3) 2.18
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15	0.05 0.59 0.67 Intensity 1:2 Yr (mm/hy) 76.81 61.77	Qp (L/s) 6.32 5.08	Release Rate: (CD (L/s) 13.00 13.00	Qp stored (L/s) N/A N/A	Max Volume Requirement (m3) N/A N/A	Intensity 1:100 Yr (mm/br) 178.56 142.89	Qp (Us) 16.63 13.31	Qp ICD (L/s) 13.00	Qp stored (L/s) 3.63 0.31	Max Volume Requirement (m3) 2.18 0.28
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20	0.05 0.59 0.67 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03	Op (L/s) 6.32 5.08 4.28	Release Rate:	Op stored (L/s) N/A N/A N/A	Max Volume Requirement (m3) N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95	Qp (Us) 16.63 13.31 11.17	Qp ICD (L/s) 13.00 13.00	Qp stored (L/s) 3.63 0.31 N/A	Max Volume Requirement (m3) 2.18 0.28 N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:20 Yr Time (min) 10 15 20 25	0.05 0.59 0.67 Intensity 1.2 Yr (mm/hr) 76.81 61.77 52.03 45.17	Qp (L/s) 5.08 4.28 3.72	Release Rate: (CD ((L/s) 13.00 13.00 13.00 13.00	Qp stored (Us) N/A N/A N/A N/A	Max Volume Requirement (m3) N/A N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 178.66 142.89 119.95 103.85	Qp (Us) 16.63 13.31 11.17 9.67	Qp ICD (L/s) 13.00 13.00 13.00	Qp stored (L/s) 3.63 0.31 N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30	0.05 0.59 0.67 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04	Qp (L/s) 6.32 5.08 4.28 3.72 3.30	Release Rate:	13.0 stored (L/s) N/A N/A N/A N/A	D L/s Max Volume Requirement (m3) N/A N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 01.87	Op (Us) 16.63 13.31 11.17 9.67 8.56	Qp ICD (L/s) 13.00 13.00 13.00 13.00	Qp stored (L/s) 0.31 N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 27	0.05 0.59 0.67 1.2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 26.02	Qp (L/s) 5.08 4.28 3.72 3.30 2.67	Qp UD (LD) 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Qp stored (L/s) N/A N/A N/A N/A N/A N/A N/A	U/s Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 9.87	Qp (Us) 16.63 13.31 11.17 9.67 8.56 7 CC	Qp (CD (L/s) 13.00 13.00 13.00 13.00	Qp stored (L/s) 3.63 0.31 N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35 0	0.05 0.59 0.67 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 20.97	Op (Us) 6.32 5.08 4.28 3.72 3.30 2.97 2.37	Release Rate: (DP (CD (U/s) 13.00	Op stored (L/s) N/A N/A N/A N/A N/A N/A N/A	D Us Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/br) 172556 142.29 119.95 103.85 91.87 82.58	Qp (Us) 16.63 13.31 11.17 9.67 8.56 7.69	Qp ICD (Us) 13.00 13.00 13.00 13.00 13.00 13.00	Qp stored (U/s) 0.31 N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:00 Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35 40	0.05 0.05 0.59 0.67 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86	Op (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70	Release Rate: Qp (CD (L/s) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Qp stored (L/s) N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/br) 178,56 142,29 119,95 103,85 91,87 82,558 91,87 75,15	Qp (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp ICD (L/s) 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Qp stored (L/s) 3.63 0.31 N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 NIA NIA NIA NIA NIA NIA
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35 40	0.05 0.59 0.67 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86	Qp (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70	Release Rate: (DP (CD (Us) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Op stored (L/s) N/A N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/kr) 142.89 119.95 103.85 91.87 82.58 75.15	Qp (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp (L/s) (1/s) 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Ор (L/s) 3.63 0.31 N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:100 Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35 40 Minimum storage volume requirement =	0.05 0.05 0.05 0.67 Intensity 1.2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86	Op (Us) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.18	Release Rate:	Op stored (L/s) N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 178,56 142,89 119,95 103,85 91,87 103,85 91,87 75,15	Op (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp ICD (L/s) 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Op (U/s) 3.63 0.31 N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35 40 Minimum storage volume requirement =	0.05 0.59 0.67 Intensity 1.2 Yr (mm/hr) 76.81 61.77 52 03 45.17 40 04 36.06 32.86	Qp (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.18	Release Rate: (DP (CD (L/s) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 8 m3	Op stored (L/s) N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/kr) 1142.89 119.95 103.85 91.87 82.58 75.15	Qp (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp ICD (Us) 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Qp stored (L/s) 3.63 0.31 N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 10 15 20 25 30 25 30 40 Minimum storage volume requirement = Surface Storage:	0.05 0.05 0.05 0.07 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 32.86 08.580	Qp (U/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.70 2.18 4.35	Release Rate:	Qp stored (L/s) N/A N/A N/A N/A N/A N/A N/A	D L/s Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 85.82 75.15	Ор (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp ICD (Us) 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Qp stored (U/s) 3.63 0.31 N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 15 20 30 35 40 Minimum storage volume requirement = Surface Storage;	net by the design 0.06 0.59 0.67 1.2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 CB 580	Qp (L/s) 5.08 4.28 3.72 3.30 2.97 2.70 2.18 4.35	Release Rate: (CD (LS) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 5 m3	Op stored (U/s) N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A N/A	Intensity 1:00 Yr (mm/kr) 178.86 142.89 119.95 103.85 91.87 82.58 75.15	Qp (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp ICD (L/s) 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Qp stored (L/s) 3.63 0.31 N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35 40 Minimum storage volume requirement = Surface Storage; *Ninimum storage volume requirement m	0.05 0.59 0.67 Intensity 1.2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 CB 580 vt by the design	Op (Us) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.18 4.35	Release Rate: (CD (L/s) 13.00 13.	Op stored (L/s) N/A N/A N/A N/A N/A N/A N/A N/A	D Us Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/br) 178.56 142.29 119.95 103.85 91.87 82.58 75.15	Qp (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp ICD (U/s) 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Op stored (L/s) 0.31 N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:100 Yr C-Factor 1:100 Yr Time (min) 10 10 15 20 25 30 35 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m	0.05 0.59 0.67 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 CB 580 vet by the design	Qp (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.18 4.35	Op ICD ICD ICD ICS Op ICD ICD ICS 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 5 m3 5 m3	Qp stored (Us) N/A N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/br) 178.56 142.89 119.95 191.87 82.58 75.15	Op (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp ICD (L/s) 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Op stored (L/s) 3.83 0.31 N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m	CB 580	Qp (L/s) 5.08 4.28 3.72 3.30 2.97 2.70 2.18 4.35	Release Rate: (LS) (LS) (13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 5 m3	Op stored (L/s) N/A N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 142.89 1103.85 91.87 82.58 75.15	Qp (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp ICD (<i>U</i> s) 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Qp stored (L/s) 0.31 N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 10 15 20 25 30 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m	CB 580	Op (Us) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.70 2.18 4.35	Release Rate: (DD (L/s) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 3 m3 5 m3	Qp stored (L/s) N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 91.87 85.85 75.15	Op (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp ICD (Us) 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Qp stored (U/s) 0.3163 0.31 N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 30 35 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m	0.05 0.59 0.67 Intensity 1.2 Yr (mm/hr) 76.81 61.77 52.03 445.17 40.04 36.06 32.86 CB 580 vet by the design	Qp (L/s) 5.08 4.28 3.72 3.30 2.97 2.70 2.18 4.35	Release Rate: (CD (LS) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 5 m3	Op stored (L/s) N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 178.86 142.89 119.95 103.85 91.87 82.58 75.15	Qp (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp ICD (L/s) 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Qp stored (L/s) 3.63 0.31 N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 10 15 20 25 30 25 30 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m CB 573	0.05 0.05 0.59 0.67 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 32.86 CB 580 vet by the design	Op (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.70 2.18 4.35	Release Rate: (CD (L/s) 13.00 13.	Op stored (L/s) N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/br) 178:56 142:289 119:95 103:85 91:87 82:58 75:15	Op (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp ICD (Us) 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Op stored (U/s) 0.31 N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m	0.05 0.59 0.67 1.2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 CB 580 net by the design	Qp (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.18 4.35	Release Rate: (CD (LS) (13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 3 m3 5 m3	200 stored (L/s) N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	D L/s Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/kr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 Vs	Op (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp ICD (L/s) 13.00 13.00 13.00 13.00 13.00 13.00	Qp stored (L/s) 3.63 0.31 N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.16 0.28 N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Imme (min) 10 10 15 20 25 30 35 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m CB 573 Area C-Factor 1:2Yr	0.05 0.05 0.59 0.67 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 CB 580 net by the design 0.008 0.008	Qp (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.18 4.35	Release Rate: (DD (Us) 13.00 13.0	200 stored (U/s) N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/br) 142.89 119.95 103.85 91.87 82.58 75.15	Qp (Us) 18.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp ICD (Us) 13.00 13.00 13.00 13.00 13.00 13.00 13.00	0p stored (L/s) 0.31 N/A N/A N/A N/A	Max Volume Requirement (mi3) 2.18 0.28 N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 10 15 20 25 30 35 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m CB 573 Area C-Factor 1:2Yr C-Factor 1:2YP C-Factor 1:2Y	0.05 0.05 0.59 0.67 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 CB 580 net by the design 0.008 0.46	Qp (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.18 4.35	Op (CD) (CD) (LS) (LS) (LS) (LS) (13.00) (13.00)	200 stored (L/s) N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A N/A 2.1	Intensity 1:100 Yr (mm/br) 178.56 142.89 119.95 191.87 82.58 75.15 L/s	Qp (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp ICD (L/s) 13.00 13.00 13.00 13.00 13.00 13.00	Op stored (L/S) 3.83 0.31 N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 30 35 40 Minimum storage volume requirement m Surface Storage: *Minimum storage volume requirement m CB 573 Area C-Factor 1:2Yr C-Factor 1:2Yr C-Factor 1:2Yr	CB 580 CB 580 CB 580 CB 580 CB 550 CB	Qp (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.18 4.35	Release Rate: (US) (US) (13.00 10	Op stored (L/s) N/A N/A N/A N/A N/A N/A N/A N/A Rolease Rate:	D L/s Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 178:56 142:89 119:95 103:85 91:87 82:58 75:15 L/s	Qp (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp ICD (<i>U</i> s) 13.00 13.00 13.00 13.00 13.00 13.00	Qp stored (Us) 0.31 N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:2Yr C-Factor 1:2Yr C-Factor 1:2Yr 20 10 15 20 25 30 35 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m CB 573 Area C-Factor 1:2Yr C-Factor 1:2Yr C-Factor 1:100 Yr	CB 580	Op (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.18 4.35	Ap Ap CD CD (LD) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 5 m3 5 m3	Qp stored (L/s) N/A N/A N/A N/A N/A N/A N/A N/A Release Rate:	L/S Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A 2.1	Intensity 1:100 Yr (mm/br) 178.56 142.89 119.95 103.85 91.87 82.56 75.15 L/s	Qp (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Qp ICD (U's) 13.00 13.00 13.00 13.00 13.00 13.00	Ор stored (L/s) 3.63 0.31 N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 10 15 20 30 35 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m CB 573 Area C-Factor 1:2Yr C-Factor 1:2Yr C-Factor 1:2Yr C-Factor 1:2Yr C-Factor 1:100 Yr	0.05 0.59 0.67 Intensity 1.2 Yr (mm/hr) 76.81 61.77 52.03 445.17 40.04 36.06 32.86 CB 580 net by the design 0.008 0.44 0.53	Qp (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.18 4.35	Release Rate: (Dp (CD (Us) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 5 m3 Uncontrolled	Op stored (L/s) N/A N/A N/A N/A N/A N/A N/A Release Rate:	D L/s Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A 2.1 Max Volume	Intensity 1:100 Yr (mm/hr) 178:56 113:95 103:85 91:87 82:58 75:15 L/s	Qp (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Ор ICD (Us) 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Qp stored (L(s) 0.31 N/A N/A N/A N/A N/A Qp	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 15 20 25 30 35 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m CB 573 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min)	0.05 0.05 0.59 0.67 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 CB 580 net by the design 0.008 0.46 1.2 Yr	Qp (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.70 2.18 4.35	Ap CP CD CD (CD) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 5 m3 5 Uncontrolled Op	Qp stored (U/s) N/A N/A N/A N/A N/A N/A N/A Release Rate:	2 L/s Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A 2.1 Max Volume Requirement	Intensity 1:100 Yr (mm/br) 178.56 142.89 119.95 19.87 82.58 75.15 L/s	Ор (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00	Ср ICD (Us) 13.00 10.00	Op stored (L/S) 3.83 0.31 N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2:18 0.28 N/A N/A N/A N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr IIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIII	CB 580 CB	Qp (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.18 4.35	Release Rate: (LS) (LS) (13.00 10	Op stored (L/s) N/A N/A N/A N/A N/A N/A N/A N/A Release Rate:	D Us Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A 2.1 Max Volume Requirement (m3)	Intensity 1:100 Yr (mm/hr) 178:56 113:95 103:85 91:87 82:58 75:15 L/s L/s	Qp (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00 7.00	Qp ICD (Us) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Qp stored (L(s) 0.31 N/A N/A N/A N/A N/A N/A (L(s)	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr 10 10 15 20 25 30 30 35 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m CB 573 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 10 10 10 10 10 10 10 10 10 10 10 10	0.05 0.05 0.59 0.67 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 CB 580 net by the design 0.008 0.453 1:2 Yr (mm/hr) 72.81	Op (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.70 2.18 4.35	Ap Ap CD CD (LD) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 5 m3 5 Uncontrolled (U/s) (L/s) (L/s)	Qp stored (L/s) N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	2.1 Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A 2.1 Max Volume Requirement (m3) N/A	Intensity 1:100 Yr (mm/br) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 // .15 // .15 // .15	Ор (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00 7.00 7.00	Ср ICD (Us) 13.00 10.00	Ор stored (L/s) 3.63 0.31 N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr IIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIII	0.05 0.59 0.67 Intensity 1.2 Yr (mm/hr) 76.81 61.77 52.03 445.17 40.04 36.06 32.86 CB 580 net by the design 0.008 0.446 0.53 Intensity 1.2 Yr (mm/hr) 76.81	Qp (L/s) 6.32 5.08 4.28 3.72 2.70 2.47 2.70 2.48 4.35 0 Qp (L/s) 0.79	Release Rate: (LS) (LS) (13.00 13	Op stored (L/s) N/A N/A N/A N/A N/A N/A N/A Release Rate:	D Us Max Volume Requirement (m3) N/A N/A N/A N/A N/A 2.1 Max Volume Requirement (m3) N/A	Intensity 1:100 Yr (mm/hr) 178:56 119:95 103:85 91:87 82:58 75:15 119:95 103:85 119:95 119	Ор (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00 7.00 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	Qp ICD (Us) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00	Qp stored (L(s) 0.31 N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr 10 10 15 20 10 15 20 25 30 30 35 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m CB 573 Area C-Factor 1:2Yr C-Factor 1:100 Yr 10 10 10 10 10 10 10 10 10 10 10 10 10	0.05 0.05 0.59 0.67 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 CB 580 net by the design 0.008 0.46 0.53 Intensity 1:2 Yr (mm/hr) 76.81 61.77	Op (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.70 2.18 4.35 4.35 0.00 (L/s) 0.79 0.64	Ap Ap CD CD (CD) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 5 m3 5 m3 Uncontrolled i Op (CS) (L/s) N/A	Qp stored (L/s) N/A N/A N/A N/A N/A N/A Release Rate: Cp stored (L/s) N/A N/A	2 L/s Max Volume Requirement (m3) N/A N/A N/A N/A N/A 2.1 Max Volume Requirement (m3) N/A N/A N/A	Intensity 1:100 Yr (mm/br) 178.56 142.89 119.95 103.85 91.87 82.56 75.15 L/s L/s	Ор (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00 7.00 0 0 0 (Us) 2.11 1.69	Ср ICD (L/s) 13.00 10.00	Ор stored (L/s) 3.63 0.31 N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A M/A M/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr IIIme (min) 10 15 20 15 20 30 35 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m CB 573 Area C-Factor 1:2Yr C-Factor 1:100 Yr IIIme (min) 10 10 15 20	0.05 0.59 0.67 Intensity 1.2 Yr (mm/hr) 76.81 61.77 52.03 445.17 40.04 36.06 32.86 CB 580 net by the design 0.008 0.446 0.53 Intensity 1.2 Yr (mm/hr) 76.81 61.77	Qp (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.18 4.35 Qp (L/s) 0.79 0.64 0.54	Release Rate: (LS) (LS) (13.00 13	Op stored (L/s) N/A N/A N/A N/A N/A N/A N/A Release Rate:	D Us Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A 2.1 Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 178.66 142.89 119.95 103.85 91.87 82.58 75.15 L/s L/s L/s	Ор (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00 7.00 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	Qp ICD (L/s) 13.00	Qp stored (L(s) 3.63 0.31 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr 10 10 15 20 25 30 32 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m CB 573 Area C-Factor 1:2Yr C-Factor 1:100 Yr 10 10 10 10 15 20 20 25 20 25 20 20 25 20 20 25 20 20 25 20 20 20 20 20 20 20 20 20 20 20 20 20	0.05 0.05 0.59 0.67 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86 CB 580 et by the design 0.008 0.45 1:2 Yr (mm/hr) 76.81 0.75 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17	Op (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.18 4.35 (L/s) 0.79 0.64 0.54 0.54 0.46	Ap Ap CD CD (LD) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 5 m3 5 m3 Uncontrolled i Op (LS) (LS) N/A N/A N/A	Qp stored (L's) N/A	2.1/S Max Volume Requirement (m3) N/A N/A N/A N/A N/A 2.1 Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 82.58 75.15 L/s L/s	Ор (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00 7.00 (Us) 2.11 1.69 1.42 1.23	Ср ICD (L/s) 13.00	Ор stored (L/s) 3.63 0.31 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 30 35 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m CB 573 Area C-Factor 1:2Yr C-Factor 1:	0.05 0.59 0.67 Intensity 1.2 Yr (mm/hr) 76.81 61.77 32.86 CB 580 cB 580 net by the design 0.05 1.2 Yr (mm/hr) 76.81 61.77 52.03 1.2 Yr (mm/hr) 76.81 61.77 52.03 45.17 61.77 52.03 45.17 61.77 52.03 45.17 61.77 52.03 45.17 61.77	Qp (L/s) 5.08 4.28 3.72 2.70 2.70 2.18 4.35 Qp (L/s) 0.79 0.64 0.64 0.64 0.64 0.64	Ap CP ICD (L/s) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 3 m3 5 m3 Uncontrolled Qp (LD) (L/s) N/A N/A N/A N/A N/A	Op stored (L/s) N/A N/A	D L/s Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A 2.1 Max Volume Requirement (m3) N/A	Intensity 1:00 Yr (mm/hr) 142.89 119.95 103.85 91.87 62.58 75.15 L/s L/s L/s L/s L/s L/s L/s L/s	Op (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00 0 (Us) 2.11 1.69 1.42 1.23 1.00	Qp ICD (L/s) 13.00	Qp stored (L(s) 3.63 0.31 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr 10 10 15 20 25 30 30 35 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m CB 573 Area C-Factor 1:2Yr C-Factor 1:100 Yr 10 10 10 10 10 10 10 10 10 10 10 15 20 30	0.05 0.05 0.59 0.67 Intensity 1:2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 38.06 32.86 CB 580 net by the design Intensity 1:2 Yr (mm/hr) 76.81 0.008 0.45 76.81 61.77 52.03 45.17 40.04 52.03 45.17 40.04 9.00	Op (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.18 4.35 (L/s) 0.79 0.64 0.54 0.54 0.64 0.46 0.41 0.47	Ap Ap CD CD (LD) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 5 m3 5 m3 Uncontrolled I (LS) (LS) N/A N/A N/A N/A	Qp stored (L's) N/A	2.1/S Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A 2.1 Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A N/A	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 75.15 L/s L/s L/s L/s Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87	Ор (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00 7.00 (Us) 2.11 1.69 1.42 1.23 1.09	Ср ICD (L/s) 13.00	Ор stored (L/s) 3.63 0.31 N/A N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Time (min) 10 15 20 25 30 35 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m CB 573 Area C-Factor 1:2Yr C-Factor	0.05 0.59 0.67 0.159 0.67 0.6177 0.008 0.017 0.028 0.028 0.03286 0.046 0.53 0.051 0.068 0.07 0.08 0.08 0.046 0.52 0.12 Yr (mm/hv) 76.81 61.77 52.03 45.17 40.04 36.06	Qp (L/s) 5.08 4.28 3.72 3.30 2.97 2.70 2.18 4.35 0.079 0.64 0.64 0.64 0.64 0.41 0.37	Ap CP ICD (L/S) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 3 m3 5 m3 Uncontrolled Qp (LD) (L/S) N/A N/A N/A N/A N/A	Op stored (L's) N/A	Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A 2.1 Max Volume Requirement (m3) N/A N/A N/A N/A N/A N/A N/A N/A	Intensity 1:00 Yr (mm/hr) 142.89 119.95 103.85 91.87 62.58 75.15 L/s L/s L/s L/s L/s L/s L/s L/s	Op (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00 0 0 0 0 0 0 0 0 0 0 0 0 0 9 1.42 1.23 1.09 0.98	Qp ICD (L/s) 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 13.00 IO IO	Qp stored (L(s) 3.63 0.31 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A
*Minimum storage volume requirement m CB 580 - ICD 80 Area C-Factor 1:2Yr C-Factor 1:100 Yr Imme (min) 10 10 15 20 25 30 30 35 40 Minimum storage volume requirement = Surface Storage: *Minimum storage volume requirement m CB 573 Area C-Factor 1:2Yr C-Factor 1:100 Yr Imme (min) 10 10 15 20 25 30 35 40	0.05 0.05 0.59 0.67 Intensity 1.2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 386.06 32.86 CB 580 net by the design 0.008 0.46 0.63 1.2 Yr (mm/hr) 76.81 61.77 52.03 45.17 40.04 36.06 32.86	Op (L/s) 6.32 5.08 4.28 3.72 3.30 2.97 2.70 2.70 2.18 4.35 0.79 0.64 0.54 0.54 0.37 0.34	Op ICD (L/S) ISO 13.00 ISO 8 m3 ISO 5 m3 IOCD (L/S) N/A N/A N/A N/A N/A N/A N/A N/A	Qp stored (L/s) N/A	L/s Max Volume Requirement (m3) N/A N/A N/A N/A N/A 2.1 Max Volume Requirement (m3) N/A	Intensity 1:100 Yr (mm/hr) 178.56 142.89 119.95 103.85 91.87 25.55 75.15 L/s L/s L/s L/s L/s L/s 2.58 91.87 142.89 110.95 103.85 91.87 142.89 119.95 103.85 91.87 142.89 119.95 103.85 142.89 143.85 143.87 143.85 143.87 143.85 143.87 143.85 143.87 143.85 143.87 143.87 143.85 143.87 143.87 143.85 143.87 143.85 143.87 143.85 143.87 143.85 143.87 143.85 143.87 143.87 143.85 143.87 143.87 143.85 143.87 14	Ор (Us) 16.63 13.31 11.17 9.67 8.56 7.69 7.00 7.00 (Us) 2.11 1.69 1.42 1.23 1.09 0.96 0.89		Ор stored (L/s) 3.63 0.31 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	Max Volume Requirement (m3) 2.18 0.28 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A



Urbandale Commercial Plaza

5100 Kanata Ave.

JLR No. 23405-003.1

INLET CONTROL DEVICE (ICD) TABLE



	ICD TABLE											
ICD #	Qr (L/s)	Outlet Diameter (mm)	Outlet Invert Elv. (m)	Top of Grate Elv. (m)	Max Ponding Elv. (m)	Design Head (m)	Hydrovex					
MH 530 - ICD 53	74.0	525	103.03	107.45	107.20	4.10	Custom ICD 131 mm Ø					
CB 552 - ICD 52	4.0	200	104.75	107.05	107.35	2.60	50 VHV-1					
CBMH 571 - ICD 71	18.0	250	103.48	107.00	107.30	3.79	Custom ICD 66 mm Ø					
CB 572 - ICD 72	4.0	200	103.76	107.30	107.25	3.49	50 VHV-1					
CB 580 - ICD 80	13.0	200	104.40	106.70	107.00	2.60	100 VHV-1					

ORIFICE SIZING FOR TEMPORARY STORM SEWER ICD

JLR No.:	23405-003					Notes:	Values in blu	e are user variables	
Project:	Commercial P	laza - 5100	Kanata Ave				Values in rec	are calculated	
Date:	November 8, 2	2017					Cells highligh	hted in Yellow reveal	a condition not met.
Revised:	March 5, 2019	1							
Designed by:	AW								
Checked by:	GF					User Notes:	Temporary IG are installed.	CD used to control flo	w in storm sewer until all facilities
		MH 530 -	ICD 53						
	Outlet Pipe			Orifice					
Q_{all} (L/s)	Dia. (mm)	Invert (m)	1:100 (m)	Radius (m)	Head (m)				
74.00	525	103.030	107.200	0.066	4.104	-			
	:	Solving	for 'Q'				S	olving for 'r' (r	adius of pipe)
h= C= D=	Q =	CA v Head (m) (i Coefficient Diameter (n	$\sqrt{2gh}$	alculated abo	ve)			$r = \sqrt{\frac{1}{C_{r}}}$	$\frac{Q}{\tau\sqrt{2gh}}$
g=	9.81	Gravity (9.8	31 m/s²)				<u>Circular O</u>	rifice	Square Orifice
A=	0.01352	Area of Flo	w (m²)				Radius = Diameter =	<mark>0.066</mark> m 0.131 m	One side = 0.116 m = 116 mm
Q=	0.074	Discharge ((m³/s)				=	131 mm	
	74.00	Discharge ((L/s)				=	5.17 in	

ORIFICE SIZING FOR TEMPORARY STORM SEWER ICD

JLR No.:	23405-003					Notes:	Values in blu	e are user variables	
Project:	Commercial P	laza - 5100	Kanata Ave				Values in red	are calculated	
Date:	November 8, 2	2017					Cells highligh	hted in Yellow reveal	a condition not met.
Revised:	March 5, 2019	1							
Designed by:	AW								
Checked by:	GF					<u>User Notes:</u>	Temporary IC are installed.	CD used to control flo	w in storm sewer until all facilities
	С	BMH 571	- ICD 71						
	Outlet Pipe			Orifice					
Q_{all} (L/s)	Dia. (mm)	Invert (m)	1:100 (m)	Radius (m)	Head (m)				
18.00	250	103.480	107.300	0.033	3.787				
		Solving	for 'Q'				S	olving for 'r' (ı	radius of pipe)
h= C= D=	Q =	CA v Head (m) (i Coefficient Diameter (r	$\sqrt{2gh}$	alculated abo	ve)			$r = \sqrt{\frac{1}{C_{r}}}$	$\frac{Q}{\pi\sqrt{2gh}}$
g=	9.81	Gravity (9.8	31 m/s²)				<u>Circular O</u>	rifice	Square Orifice
A=	0.00342	Area of Flo	w (m ²)				Radius = Diameter =	0.033 m 0.066 m	One side = 0.059 m = 59 mm
Q=	0.018	Discharge ((m³/s)				=	66 mm	
	18.00	Discharge ((L/s)				=	2.60 in	

Commercial Plaza Storm Sewer Design Sheet



Urbandale Commercial Plaza

5100 Kanata Ave.

JLR No. 23405-003.1

Manning's Coefficient n =	0.013	
IDF CURVE =	2	year

Per SCS consulting group retirement residence design dated August 2016 Building Service Laterals

			AR	REA		1:2 YR PEAK	(FLOW CO	MPUTATION				SEWER	R DATA				UPST	REAM			D	OWNSTREA	М	
M.	.н.	C factor	Total Area	CUM. Area	2.78AR	2.78AR	TIME	INTENS.	PEAK FL.	DIA.	SLOPE	CAPAC.	VEL.	LENGTH	FL.TIME	Center	Obvert	Invert	Cover	Center	Obvert	Obvert	Invert	Cover
FROM	то	C-lactor	(ha)	(ha)		(CUM.)	(min.)	(mm/hr)	(L/s)	(mm)	(%)	(L/s)	(m/s)	(m)	(min.)	Line				Line	Drop			
Building A	MH 510	0.90	0.04	0.04	0.10	0.10	10.00	76.81	7.88	150	3.00	27.5	1.51	4.60	0.05	108.15	105.85	105.70	2.30	107.92	0.86	105.72	105.56	2.20
MH510	MH 511	0.00	0.00	0.04		0.10	10.05	76.61	7.86	1050	0.70	2383.5	2.67	23.50	0.15	107.92	104.86	103.79	3.06	107.50	0.00	104.69	103.62	2.81
							10.20																	
CBMH 510	MH 511	0.75	0.11	0.11	0.22	0.22	10.00	76.81	17 17	750	0.05	1132.0	2 / 8	20.60	0.20	107.40	105.26	104 50	2.14	107 50	0.20	104.08	104.22	2.52
CDIVITI 510	IVITI	0.75	0.11	0.11	0.22	0.22	10.00	70.01	17.17	730	0.95	1132.0	2.40	29.00	0.20	107.40	103.20	104.50	2.14	107.50	0.29	104.90	104.22	2.52
							10.20														-			
MH 511	MH 520	0.00	0.00	0.15		0.33	10.20	76.05	24.81	1050	0.70	2383.5	2.67	24.40	0.15	107.50	104.69	103.62	2.81	107.33	0.16	104.52	103.45	2.81
							10.35																	
CBMH 522	MH 520	0.82	0.25	0.25	0.57	0.57	10.00	76.81	43.56	250	1.00	62.0	1.22	20.30	0.28	106.97	104.56	104.31	2.41	107.33	0.00	104.36	104.11	2.97
							10.28																	
	NALL 500	0.00	0.05	0.05	0.10	0.40	40.00	70.01	10.10	450	4.50	007	4.05	7.00	0.00	407.00	405 50	405.07	0.00	407.00	0.05	405.04	405.00	0.40
Building E	MH 520	0.90	0.05	0.05	0.13	0.13	10.00	76.81	10.18	150	4.50	33.7	1.85	7.00	0.06	107.82	105.52	105.37	2.30	107.33	0.85	105.21	105.06	2.12
							10.06																	
MH 520	MH 530	0.90	0.24	0.69	0.60	1.63	10 35	75.48	122.76	1050	0.15	1103 3	1 23	28.20	0.38	107 33	104 36	103.20	2 07	107.45	0.75	104 32	103 25	3 13
MH 530	MH 540	0.00	0.00	0.69	0.00	1.03	10.33	73.40	122.70	525	0.30	245.7	1.20	20.20	0.30	107.55	103.57	103.03	3.88	107.40	0.03	104.52	102.23	3.78
11110000	1011010	0.00	0.00	0.00		1.00	11.04	74.10	120.02	020	0.00	210.1	1.10	20.10	0.00	101.10	100.01	100.00	0.00	101.20	0.00	100.01	102.07	0.10
Building D	MH 550	0.90	0.11	0.11	0.27	0.27	10.00	76.81	20.37	150	3.00	27.5	1.51	10.50	0.12	107.72	105.42	105.27	2.30	107.30	0.45	105.11	104.96	2.19
MH 550	MH 540	0.81	0.09	0.19	0.19	0.46	10.12	76.36	34.87	250	1.10	65.1	1.28	21.80	0.28	107.30	104.66	104.40	2.64	107.29	0.94	104.42	104.16	2.87
							10.40																	
MH 540	MH 570	0.82	0.33	1.21	0.76	2.85	11.04	73.04	207.91	525	0.30	245.7	1.10	66.50	1.01	107.29	103.48	102.94	3.81	107.27	0.06	103.28	102.74	3.99
							12.04																	
Building B	MH 570	0.00	0.10	0.10	0.24	0.24	10.00	76.91	18.26	150	3.00	27.5	1 5 1	10.00	0.11	107.67	105.27	105.22	2 30	107.27	1.95	105.07	104.02	2 20
Building B		0.90	0.10	0.10	0.24	0.24	10.00	70.01	10.20	150	3.00	21.5	1.01	10.00	0.11	107.07	105.57	105.22	2.30	107.27	1.00	105.07	104.92	2.20
							10.11																	
MH 570	EX. MH 14	0.49	0.11	1.4	0.15	3.24	12.04	69.76	225.78	525	0.30	245.7	0.82	34.70	0.70	107.27	103.22	102.68	4.05	107.06	0.16	103.11	102.58	3.95
							12.75																	
Building C	EX. MH 14	0.90	0.09	0.09	0.21	0.21	10.00	76.81	16.33	150	4.50	33.7	0.82	14.00	0.28	107.72	105.48	105.33	2.24	107.06	1.90	104.85	104.70	2.21
-							10.28																	
EX. MH 14	EX. MH 7			1.50		3.45	12.75	67.65	233.35							107.06	102.95	102.34						

STORM SEWER DESIGN SHEET

Designed by:	R.M.	
Checked by:	A.W.	
Date:	Feb 2019	

ZURN Control-Flo Roof Drainage System Technical Manual



RN a step ahead of tomorrow

ZURN Control-Flo... Today's Successful Answer to More

THE ZURN "CONTROL-FLO CONCEPT"

Originally, Zurn introduced the scientifically-advanced "Control-Flo" drainage principle for dead-level roofs. Today, after thousands of successful applications in modern, large dead-level roof areas, Zurn engineers have adapted the comprehensive "Control-Flo" data to **sloped roof** areas.

WHAT IS "CONTROL-FLO"?

It is an advanced method of removing rain water off deadlevel or sloped roofs. As contrasted with conventional drainage practices, which attempt to drain off storm water as quickly as it falls on the roof's surface, "Control-Flo" drains the roof at a controlled rate. Excess water accumulates on the roof under controlled conditions ... then drains off at a lower rate after a storm abates.

CUTS DRAINAGE COSTS

Fewer roof drains, smaller diameter piping, smaller sewer sizes, and lower installation costs are possible with a "Control-Flo" drainage system because roof areas are utilized as temporary storage reservoirs.

REDUCES PROBABILITY OF STORM DAMAGE

Lightens load on combination sewers by reducing rate of water drained from roof tops during severe storms thereby reducing probability of flooded sewers, and consequent backflow into basements and other low areas.

THANKS TO EXCLUSIVE ZURN "AQUA-WEIR" ACTION

Key to successful "Control-Flo" drainage is a unique, scientifically-designed weir containing accurately calibrated notches with sides formed by parabolic curves which provide flow rates directly proportional to the head. Shape and size of notches are based on predetermined flow rates, and all factors involved in roof drainage to assure permanent regulation of drainage flow rates for specific geographic locations and rainfall intensities.



DEFINITION

DEAD LEVEL ROOFS

DIAGRAM "A"

A dead-level roof for purposes of applying the Zurn "Control-Flo" drainage principle is one which has been designed for zero slope across its entire surface. Measurements shown are for maximum distances.



(Plan View)



SLOPED ROOFS

DIAGRAM "B"

A sloped roof is one designed commonly with a shallow slope. The Zurn "Control-Flo" drainage system can be applied to any slope which results in a total rise up to 152mm(6").

The total rise of a roof as calculated for "Control-Flo" application is defined as the vertical increase in height in inches, from the low point or valley of a sloping roof (A) to the top of the sloping section (B). (Example: a roof that slopes 3mm(1/8") per foot having a 7.25m(24') span would have a rise of 7.25m x 3mm or 76mm (24' x 1/8" or 3")).

Measurements shown are for maximum distances.



Dimensions and other measurements given in metric and imperial forms.

12522/010

Economical Roof Drainage Installations

SPECIFICATION DATA



- POLY-DOME
- CONTROL FLO WEIR WITH INTEGRAL CLAMP COLLAR AND GRAVEL GUARD 3
- E-EXTENSION WITH GASKET (WHEN SPECIFIED) 4
- ROOFING MEMBRANE(BY OTHERS)
- 5 R-ROOF SUMP RECEIVER (WHEN SPECIFIED)
- 6 - C-UNDERDECK CLAMP (WHEN SPECIFIED)
- 7 BODY

Z-105-5-ERC "Control-Flo" Dura-Coated Cast Iron Body, Aluminum Parabolic Weir With Integral Clamping Collar And Gravel Guard, Poly Dome. Extension, Roof Sump Receiver, Under Deck Clamp, Aluminum Dome Available When Specified.

ROOF DESIGN RECOMMENDATIONS

Basic roofing design should incorporate protection that will prevent roof overloading by installing adequate overflow scuppers in parapet walls.

GENERAL INFORMATION

The "Control-Flo" roof drainage data is tabulated for four areas (232.25m2(2500 sq. ft.), 464.50m2(5000 sq. ft.), 696.75m2(7500 sq. ft.), 929m2(10,000 sq. ft.) notch areas ratings) for each locality. For each notch area rating the maximum discharge in L.P.M. (G.P.M.) - draindown in hours. and maximum water depth at the drain in inches for a dead level roof - 51mm(2 inch) rise - 102mm(4 inch) rise and 152mm(6 inch) rise - are tabulated. The rise is the total change in elevation from the valley to the peak. Values for areas, rise or combination thereof other than those listed, can be arrived at by extrapolation. All data listed is based on the fifty-year return frequency storm. In other words the maximum conditions as listed will occur on the average of once every fifty years.

NOTE: The tabulated "Control-Flo" data enables the individual engineer to select his own design limiting condition. The limiting condition can be draindown time, roof load factor, or maximum water depth at the drain. If draindown time is the limiting factor because of possible freezing conditions, it must be recognized that the maximum time listed will occur on the average of once every 50 years and would most likely be during a heavy summer thunder storm. Average winter drain down times would be much shorter in duration than those listed

GENERAL RECOMMENDATIONS

On sloping roofs, we recommend a design depth referred to as an equivalent depth. An equivalent depth is the depth of water attained at the drains that results in the same roof stresses as those realized on a dead-level roof. In all cases this equivalent depth is almost equal to that attained by using the same notch area rating for the different rises to 152mm(6"). With the same depth of water at the drain the roof stresses will decrease with increasing total rise. Therefore, it would be possible to have a depth in excess of 152mm(6") at the drain on a sloping roof without exceeding stresses normally encountered in a 152mm(6") depth on a dead-level roof. However, it is recommended that scuppers be placed to limit the maximum water depth on any roof to 152mm(6") to prevent the overflow of the weirs on the drains and consequent overloading of drain piping. In the few cases where the data shows a flow rate in excess of 136 L.P.M.(30 G.P.M.) if all drains and drain lines are sized according to recommendations, and the one storm in fifty years occurs, the only consequence will be a brief flow through the scuppers or over-flow drains.

NOTE: An equivalent depth is that depth of water attained at the drains at the lowest line or valley of the roof with all other conditions such as notch area and rainfall intensity being equal. For Toronto, Ontario a notch area rating of 464.50m²(5,000 square feet) results in a 74mm(2.9 inch) depth on a dead level roof for a 50year storm. For the same notch area and conditions, equivalent depths for a 51mm(2"), 102mm(4") and 152mm(6") rise respectively on a sloped roof would be 86mm(3.4"), 104mm(4.1") and 124mm(4.9"). Roof stresses will be approximately equal in all cases.

ZURN Control-Flo Drain Selection is Quick and Easy.

The exclusive Zurn "Selecta-Drain" Chart (pages 8, 9, 10, 11) tabulates selection data for 34 localities in Canada. Proper use of this chart consitutes your best assurance of sure, safe, economical application of Zurn "Control-Flo" systems for your specific geographical area. If the "Selecta-Drain" Chart does not cover your

specific design criteria, contact Zurn Drainage and Control Systems Ltd., Weston, Ontario, for additional data for your locality. Listed below is additional information pertinent to proper engineering of the "Control-Flo" system.

ROOF USED AS TEMPORARY RETENTION

The key to economical "Control-Flo" is the utilization of large roof areas to temporarily store the maximum amount of water without overloading average roofs or creating excessive draindown time during periods of heavy rainfall. The data shown in the "Selecta-Drain" Chart enables the engineer to select notch area ratings from 232.25m²(2,500 ft.²) to 929m²(10,000 ft.²) and to

accurately predict all other design factors such as maximum roof load, L.P.M. (G.P.M.) discharge, draindown time and water depth at the drain. Obviously, as design factors permit the notch area rating to increase the resulting money saved in being able to use small leaders and drain lines will also increase.

ROOF LOADING AND RUN-OFF RATES

The four values listed in the "Selecta-Drain" Chart for notch area ratings for different localities will normally span the range of good design. If areas per notch below 232.25m²(2,500 ft.²) are used considerable economy of the "Control-Flo" concept is being lost. The area per notch is limited to 929m²(10,000 square feet) to keep the draindown time within reasonable limits. Extensive studies show that stresses due to water load on a sloping roof for any fixed set of conditions are very nearly the same as those on a dead-level roof. A sloping roof tends to concentrate more water in the valleys and increase the water depth at this point. The greater depth around the drain leads to a faster run-off rate, particularly a faster early run-off rate. As a result, the total volume of water stored on the roof is less, and the total load on the sloping roof is less. By using the same area on the sloping roof as on the dead-level roof the increase in roof stresses due to increased water depth in the valleys is offset by the decrease in the total load due to less water stored. The net result is the maximum roof stress is approximately the same for any single span rise and fixed set of conditions. A fixed set of conditions, would be the same notch area, the same frequency storm, and the same locality.

SPECIAL CONSIDERATIONS FOR STRUCTURAL SAFETY: Normal practice of roof design is based on 18kg(40 lbs.) per 929cm²(square ft.) (subject to local codes and by-laws.) Thus it is extremely important that design is in accordance with normal load factors so deflection will be slight enough in any bay to prevent progressive deflection which could cause water depths to load the roof beyond its design limits.

ADDITIONAL NOTCH RATINGS

The "Selecta-Drain" Chart along with Tables I and II enables the engineer to select "Control-Flo" Drains and drain pipe sizes for most Canadian applications. These calculations are computed for a proportional flow weir that is sized to give a flow of 23 L.P.M. (5 G.P.M.) per inch of head. The 23 L.P.M. (5 G.P.M.) per inch of head. notch opening, is selected as the basis of design as it offers the most economical installation as applied to actual rainfall experienced in Canada.

Should you require design criteria for locations outside of Canada, or for special project applications please contact Zurn Drainage and Control Systems Ltd., Weston, Ontario.

LEADER AND DRAIN PIPE SIZING

Since all data in the "Selecta-Drain" Chart is based on the 50-year storm it is possible to exceed the water depth listed in these charts if a 100-year or 1000-year storm would occur. Therefore, for good design it is recommended that scuppers or other methods be used to limit water depth to the design depth and tables I and II be used to size the leaders and drain pipes. If the roof is capable of supporting more water than the design depth it is permissible to locate the scuppers or other overflow means at a height that will allow a greater water depth on the roof. However, in this case the leader and drain pipes should be sized to handle the higher flow rates possible based on a flow rate of 23 L.P.M. (5 G.P.M.) per inch of depth at the drain.

PROPER DRAIN LOCATION

The following good design practice is recommended for selecting the proper number of "Control-Flo" drains for a given area. **On dead-level roots**, drains should be located no further than 15.25m(50 feet) from edge of roof and no further than 30.50m(100 feet) between drains. See diagram "A" page 2. **On sloping roots**, drains should be located in the valleys at a distance no greater than 15.25m(50 feet) from each end of the valleys and no further than 30.50m(100 feet) between drains. See diagram "B" page 2. Compliance with these recommendations will assure good run off regardless of wind direction.

Saves Specification Time, Assures Proper Application

QUICK, EASY SELECTION

Using the "Selecta-Drain" Chart (pages 8, 9, 10, 11) in combination with the steps and examples appearing below, should save you countless hours in engineering specification time. This vast compilation of data is related to the proper selection of drains for 34 cities. All cities in alphabetical order by Provinces. If a specific city does not appear in this tabulation, choose the city nearest your area and select the proper drain using these factors.

3 EASY STEPS ... AND 3 TYPICAL EXAMPLES FOR APPLICATION OF SURE, SCIENTIFIC CONTROL OF DRAINAGE FROM DEAD-LEVEL AND SLOPING ROOFS WITH THE ZURN CONCEPT

	TORONTO, ONTARIO	DEAD-LEVEL ROOF	102mm(4 INCH) SLOPE	152mm(6 INCH) SLOPE
1	Determine total roof area or individual areas when roof is divided by expansion joints or peaks in the case of sloping roof.	Roof Area: 58.52m x 152.40m = 8918.40m² (192ft x 500ft = 96.000 sq.ft.) (See Z-105-5 layout bottom this page.)	3 Individual Roof Areas: 19.50m x 152.40m = 2972.80m ² (64ft x 500ft = 32,000 sq.ft.) Valleys 152.40m(500 ft.) long 3 x 2972.80 = 8918.40m ² (3 x 32,000 = 96,000 sq.ft.)	2 Individual Roof Areas: 29.87m x 152.40m = 4552m ² (98 ft. x 500 ft. = 49,000 sq. ft.) Valleys 152.40m (500 ft.) long 2 x 4552 = 9104m ² (2 x 49,000 = 98,000 sq.ft.)
2	Divide roof area or individual areas by Zurn Notch Area Rat- ing selected to obtain the total number of notches required.	Zurn Notch Area Rating selected for Toronto=464.50m ² (5,000 sq.ft.) from "Selecta- Drain" Chart, page 11. Total Roof Area= 8918.40m ² (96,000 sq.ft.) Entire roof. 464.50m ² (5,000 sq.ft.) notch area = 19.2 notches - USE 20	Zurn Notch Area Rating selected for Toronto=464.50m ² (5,000 sq.ft.) from "Selecta- Drain" Chart, page 11. Total Root Area=2972.80m ² (32,000 sq.ft.) Each area. 464.50m ² (5,000 sq.ft.) notch area = 6.4 notches - USE 7 PER AREA	Zurn Notch Area Rating selected for Toronto=464,50m ² (5,000 sq.ft.) from "Selecta- Drain" Chart, page 11. Total Roof Area=4552m ² (49,000 sq.ft.) Each area 464,50m ² (5,000 sq.ft.) notch area = 9.8 notches - USE 10 PER AREA
3	Determine total number of drains required by not exceeding maximum spacing dimensions in the preceding instructions. See Diagrams "A" or "B", page 2. Divide total number of notches required to determine the number of notches per drain. Note maximum water depth at drain and use this dimension to determine scupper height to be used is 152mm(6"). Use this flow rate to size leaders and drain lines.	*10 drains required. All drains must have two notches each for a total of 20 notches. Flow rate is 66 L.P.M.(14.5 G.P.M.) per notch. Size leaders for 2 notch weirs for a flow rate of 66 L.P.M. (14.5 G.P.M.) 50mm (Two inch) pipe size leaders required. Maximum water depth and scupper height is 74 mm (2.9 inches). Requires 19 hrs. draindown time max. For drain, vertical, and horizontal pipe sizing data see Tables I and II on pages 6 and 7.	**5 drains per area required located in the valleys 15.25m(50 ft) from each end with 3 in the middle at 30.50m(100ft) spacings. Two drains on ends with two notches—3 drains in middle one notch each for a total of 7 notches. Maximum flow rate 93 L.P.M. (20.5 G.P.M.) per notch. Leader size 50mm(2") for single notch weirs—75mm(3") notch weirs. Maximum water depth and scupper height is 104mm(4.1 inches). Requires 11 hrs. draindown time max. For drain, vertical, and horizontal pipe sizing data see Tables L and II on pages 6 and	**5 drains per area required located in the valleys 15.25m(50 ft) from each end with 3 at 30.50m(100 ft) spacing in the middle. 10 notches are required therefore all drains must have two notches. Flow rate is 111 L.P.M. (24.5 G.P.M.) per notch. Size all leaders for 2 notch weirs. 75mm(3 inch) pipe size required. Maximum water depth and scupper height is 124mm (4.9 inches). Requires 9 hrs. draindown time max. For drain. vertical, and horizontal pipe sizing data see Tables I and II on pages 6 and 7

DEAD LEVEL ROOF 6mm(1/4") PER FT. SLOPE STORM DRAIN



ZURN Select The Proper Vertical Drain Leaders

ROOF DRAINAGE DATA

The flow rate for any design condition can be easily read from the data contained on the following pages; the tabulations shown below (and on the opposite page) can be used to simplify selection of drain line sizes.

TABLE 1 -SUGGESTED RELATION OF DRAIN OUTLET AND VERTICAL LEADER SIZE TO ZURN CONTROL-FLO ROOF DRAINS (BASED ON NATIONAL PLUMBING CODE ASA-A40.8 DATA ON VERTICAL LEADERS).

	Max. Flow p	er Notch in L.	P.M. (G.P.M.)						
No. of Notches	Pipe Size								
in Drain	50mm (2″)	75mm (3″)	100mm (4'')						
1	136° (30°)	-	-						
2	68 (15)	136* (30*)	-						
3	45 (10)	136* (30*)	-						
/ 4	-	105 (23)	136* (30*)						
5	-	82 (18)	136° (30*)						
6	-	68 (15)	136° (30°)						

"Maximum flow obtainable from 1 notch with 152mm(six inch) water depth at drain. Table 1 should be used to select vertical drain leaders which at the same time establishes the drain outlet size. This table illustrates the maximum flow per notch in L.P.M. (G.P.M.) Since the Z-105-5 drain is available with a minimum of one and a maximum of six notches, calculations have already been made and are listed in this table for any quantity of weir notch openings established in your design. It was determined ten drains with two notches each weir would be required in Dead-Level Roof example on page 5. A 66 L.P.M. (14.5 G.P.M.) discharge per notch flow rate was also established.

Once this design criteria has been determined it will be the key to the proper selection of all drain outlet sizes, vertical and horizontal storm drain sizes in Table I and II. Enter the column "Number of Notches in Drain", Table I, read down the column to the figure 2 which indicates two notches in weir, then read across until you reach a figure equal to or closest figure in excess of 66 L.P.M. (14.5 G.P.M.) You will find fifteen in the column under 50mm(2") which represents the pipe size. Therefore all drain outlets and vertical leaders are 50mm(2") size.

Let us digress for a moment assuming a specific structure requires a total of six drains each containing a weir with a different number of notches. One with 1, one with 2, etc. Table 1 discloses the pipe size for one notch is 50mm(2"), two notch is 50mm(2"), three notch is 75mm(3"), four notch is 75mm(3"), five notch is 75mm(3") and six notch is 75mm(3") as they all equal or closely exceed the 66 L.P.M. (14.5 G.P.M.) design

NOTE: Although pipe size calculations should be based on accumulated flow rate, local by-laws should be referred to for minimum pipe size requirements and roof drain spacing.

Table II should be used to select horizontal storm drain piping. Use the same flow rate 66 L.P.M. (14.5 G.P.M.) used to establish the vertical leaders to size the storm drainage system and main storm drain. Let us assume the ten drains each with two notch weirs were actually on the roof in two separate lines of five drains each and joined at a common point before leaving the building. Since Table II includes 3mm(1/8"), 6mm(1/4") and 13mm(1/2") per foot slope, let us use 6mm(1/4") as our basis for selection which will take us to the centre section. Starting with the first of five drains we enter the extreme left column in Table II and read down to the figure 2 since this drain has two notches in weir, read across horizontally and the size of first section of horizontal storm drain is 75mm(3") between 1st and 2nd drain, return to left hand column proceed reading down until you reach figure 4 then read across horizontally and the pipe size will be 100mm(4") between 2nd and 3rd drain, 100mm(4") between 3rd and 4th and 125mm(5") (if available) between 4th and 5th. If not available use 150mm(6") (You may be tempted to use 100m(4") since the capacity is close. We recommend you go to the larger size.) Pipe size leaving 5th drain would be 150mm(6"). The same sizing would hold true for the second line of five drains. Since both columns of five drains each are being joined together before leaving the building there will be a total of twenty notches discharging into the main building storm sewer. Enter left hand column Table II, read down until you reach the figure twenty, then read across horizontally to the 6mm(%") per 305mm(foot) slope column and you will see a 150mm(6") storm drain will handle the job adequately. The same procedure should be followed for sloped roof installations. The above method of sizing was done to better acquaint you with Table II and its use. The more economical and practical way of laying out and installing this same job is illustrated in the control-flo layout shown on bottom of page 5.

NOTE: Although pipe size calculations should be based on accumulated flow rates, local by-laws should be referred to for minimum pipe size requirements and roof drain spacing.

Select Proper Horizontal Storm Drain Piping

Total No.		MA	X. FLOW	PER NOT	TCH IN L	P.M. (6.	P.M.1		MAX, FLOW PER NOTCH IN L.P.M. (G.P.M.) MAX, FLOW PER NOTCH IN									L.P.M. (G.P.M.)				
Discharging		Storm	Drain Siz	e 3mm(1	/8") per	305mm(It.) slope		St	torm Drai	n Size 6	nm(\4*) ;	per 305m	im(tt.) sli	ope	Storm Drain Size 13mm(1;+*) per 305mm(ft.) slope						
Drain	75 3"	100 (4°)	125 (5')	150 (61)	200	250 [10"]	300	375 (15°)	75 [3']	100	125	150 (61)	200 (8*)	250	300 (12")	75 (3*)	100 [4"]	125	150 (6°)	200	250 (10°)	300
1	136+(30+)	-	-		-	-		-	136-00-	1	-	-	-	-		136+00+		-	-	-	-	-
2	77(17)	136-30-	P	100	-	2	-		10924	135-(30-	-	-	-		100	136+00+	-	2	12	100	12	
3	50(11)	118(25)	136-00-	-	-	-	-	-	73(16)	136+(30+	-	-	1.000	-	14	100(22)	136-00-1	-	12	-	-	
4	368	85(19)	136+00+						55(12)	127(28)	106-00-	-	-	1.000	-	77(17)	136+00*	5	121		100	
5		68(15)	127-028-1	136*(30*)	2	1.00	1.00	-	-	100(22)	136-100-1	-	-	-	-	59(13)	136+(30+)	2	1	120	2	
6	-	59(13)	105/271	136-00-1	-		_	_	-	87(18)	135+00+	_				40111	118/26	1361001				
Ť	-	50(11)	91(20)	136-(30-)	-	12	120	-	1.2	73/16	177/28	136+(30+)	-	-	- 2		100/22	136-120-1			5	
8	724		77/17	127(28)	136-00-	22	12	-	-	54/14	114/29	136-(30-)	195	-	- 22	2	86/10	136+(36+)				
9	-	-	68(15)	114(25)	136-00-		-	-	_	5517	100/22	136-00-1	-	-	-		7707	106+(00+)		2.71	E	
10	-	-	54(14)	100(22)	106-00-	62	-	2	-		91/20	106-00-	-		12	2	58:15	123/270	18-00-	1025	181	
11	-	-	55(12)	41/201	106+00+	-	-	-	_	-	82(1B)	12029	136+00+1	_	_		64/14	114/251	136+(30+			
12	-	-		82(1B)	136+(30+)	2		29	-	-	73(16)	118/26	136-00-	122	- 21	2	69110	105/23	135+(30+)		12	
13	1	-	124	7/1175	136+00+	12		-	2	-	6815	109(24)	136+(30+)	-	-	-	55(12)	95/211	136-(30+)		12	
14				73/16	136-00-1		-	-		-	6414	100221	136+(30+)	-	-	-	and rel	8610	136-00-1			
15	-	-	33	68(15)	136-130-	22	122	22	1	2	5913	95/211	136+00+	100	2	1		2018	11009	136+00+1	1.1	
16	-	-	22	64(14)	106-00-		-	-	-	-		91/20	136-(3)-)	-	_		-	75175	123/275	18+(8)+		
17	-	-	-	59(13)	127(28)	136-00-	-	20	-	-	-	R3(18)	136+30+	22	- 22	12	1000	73/16	118/90	136+(10+)	E	
18	-	-	1	\$5(12)	118(26)	136+(0)+	1	-	2		-	77170	136-(3)-)	1	-	1.2		6819	109/341	136+(30+)		
19			-	all al	114(25)	136+(30+			-	-	-	7316	136+(30+)				-	6414	105/231	136+(30+)		
20	-		12	-	109(24)	136+00+	1	-		20	12	6815	136-00-		5	1.2	1	5913	100/22	135+(20+)		
23	100	-	-	-	91/70	136+00+	-	-	-	1	22	54/14	112/29	136+00+		-		55/12	8610	156+(10+)		
25	-	-	-	-	8619	136+00+	-			-	-	5912	123/22	136+(30+)		1.2.		- Sector	1212	110+10+1		
30	1	-	12		7316	127/28	136-00-)	2		100	- 22		100/22	136+00+		12		- 31	GATE	136+(30+)	100	100
35		-		_	5913	109/24	136*(30*)		_				86/19	136-(30+)		_			55(12)	179/25	136+(20+)	
40	100	-	22	-	55(12)	95(21)	136*(30*)	3	1.00	-	222	-	77/17	136+(30+	-	12	-	- 56	and set	106/78	136+(30+)	
45	1	2	22	122		86(19)	136+(30+)	-		124	123	22	68/15	123/271	136+00+1	12	100	61	E	46/211	136+(30+)	
50	-	-		-	-	77/17	121/270	136-130-1	-	-	-		59(11)	109(24)	136+(30+)	1.2.1		- 20	12	85/10	136+00+1	
55	100	2	1	-	2	68(15)	114/25	136+00+	- 2		123	- 21	20100	100(22)	136+(30+)	100	100	34	-	721173	130*(30*)	-
60	_	_	_	-	_	54114	105/23	136+00+1			-	-	-	91/20	136+(30+)					68:15	177/08	15+130+1
65	2.55	-	-		199	59(13)	95/211	136+(30+)		-	20	-	-	87118	136+(30+)	12		SI	100	6414	118/30	06+(20+)
70	-		12	2	691	55/12	91/20	136+(30+)	1.0	100	100	12.2	120	73175	122/28	02		3	1	50117	100/241	06+(30-)
10	-	_		-	-	-141	autral	120-120-1		_	_	-	_	entrell.	12 HERE	-	-	2	-	20175	100(74)	20-120-1

TABLE II —SUGGESTED RELATION OF HORIZONTAL STORM DRAIN SIZE TO ZURN CONTROL-FLO ROOF DRAINAGE

'Maximum flow obtainable from 1 notch with 152mm(six inch) water depth at drain.

TABLE III -- TO BE USED WHEN ROOF STORM WATER RUN OFF AND OTHER SURFACE WATER RUN OFF IS BEING CONSOLIDATED INTO ONE COMMON MAIN HORIZONTAL STORM SEWER.

Flow capacity of vertical leaders litres per minute (gallons per minute)

Pipe Size	Maximum Capacity L.P.M.(G.P.M.)
50mm(2")	136(30)
75mm(3")	409(90)
100mm(4")	864(190)
†125mm(5")	1582(348)
150mm(6")	2550(561)

fin some areas 125mm(5") drainage pipe may not be available

Flow capacity of horizontal storm sewers litres per minute (gallons per minute).

Pipe	Slope per 305mm(Per Foot)										
Size	3mm(1/8")	6mm(\\\")	13mm(%")								
75mm(3")	163(36)	232(51)	327(72)								
100mm(4°)	355(78)	505(111)	714(157)								
†125mm(5")	646(142)	914(201)	1291(284)								
150mm(6")	1050(231)	1487(327)	2100(462)								
200mm(8")	2264(498)	3205(705)	4528(996)								
250mm(10")	4100(902)	5796(1275)	8201(1804)								
300mm(12")	6669(1467)	9437(2076)	13338(2934)								
375mm(15")	12120(2666)	17157(3774)	24239(5332)								
		and the second s									

Note: Although pipe size calculations should be based on accumulated flow rate, local by-laws should be referred to for minimum pipe size requirements and roof drain spacing.

SCUPPERS AND OVERFLOW DRAINS

Roofing members and understructures, weakened by seepage and rot resulting from improper drainage and roof construction can give away under the weight of rapidly accumulated water during flash storms. Thus, it is recommended, and often required by building codes, to install scuppers and overflow drains in parapet-type roofs. Properly selected and sized scuppers and overflow drains are vital to a well-engineered drainage system to prevent excessive loading, erosion, seepage and rotting.

ZURN Selecta-Drain Chart

	SQUARE					-	тоти	AL RO	OF SL	ΟΡΕ				
	(SOUARE)		DE	AD-LEVEL		51m	m (2") RIS	E	102	2mm (4") RI	SE	152	mm (6") RI	SE
LOCATION	NOTCH AREA RATING	ROOF LOAD FACTOR KGS (LBS.)	L.P.M. (G.P.M.) Discharge	Praindown Fime Hrs.	mm (In.) Water Depth	L.P.M. (G.P.M.) Discharge	raindown Time Hrs.	mm (ln.) Water Depth	L.P.M. (G.P.M.) Discharge	Draindown Time Hrs.	mm (In.) Water Depth	L.P.M. (G.P.M.) Discharge	Draindown Time Hrs.	(in,) Water Depth
	232	4.7 (10.4)	45.5 (10)	7	51 (2)	57 (12.5)	6	63.5 (2.5)	72.5	4	81.5 (3.2)	86.5 (19)	3.2	96.5 (3.8)
Calgary,	465 (5,000)	5.9 (13)	57 (12.5)	17	63.5 (2.5)	66 (14.5)	14	73.5 (2.9)	82 (18)	9	91.5 (3.6)	97.5 (21.5)	7.5	109 (4.3)
Alberta	697 (7,500)	6.4 (14)	61,5 (13,5)	28	68,5 (2,7)	72,5 (16)	22	81.5 (3.2)	88.5 (19.5)	15	(3.9)	104.5 (23)	12	117 (4.6)
	929 (10,000)	6.8 (15.1)	66 (14.5)	38	73.5 (2.9)	77.5	31	86.5 (3.4)	93 (20.5)	22	104 (4.1)	109 (24)	17	122 (4.8)
	(2,500)	4.5 (9.9)	43 (9.5)	7	48,5 (1,9)	57 (12.5)	6	63.5 (2.5)	72.5 (16)	4	81.5 (3.2)	82 (18)	3	91.5 (3.6)
Edmonton,	465 (5,000)	5.9 (13)	57 (12.5)	17	63.5 (2.5)	68 (15)	14.5	76 (3)	84 (18.5)	9.5	94 (3.7)	97.5 (21.5)	7.5	109 (4.3)
Alberta	697 (7,500)	6.6 (14.5)	63.5 (14)	28	71 (2.8)	75 (16.5)	24	(3.3) (84	97.5 (21.5)	16	104 (4,1)	107 (23.5)	12	119.5 (4,7)
	929 (10,000)	7,1 (15.6)	68 (15)	38	76 (3.0)	79.5 (17.5)	32	(3.5)	100 (22)	22	112 (4.4)	113.5 (25)	18	127 (5.0)
	232	3.8 (8.3)	36.5 (8)	6	40.5	38.5 (8.5)	4	43 (1.7)	52.5 (11,5)	3	58.5 (2.3)	61.5 (13.5)	2.3	68.5 (2.7)
Penticton,	465 (5,000)	4.0 (8.8)	38.5 (8.5)	13	43 (1.7)	41 (9)	9	45.5 (1.8)	57 (12.5)	6	63.5 (2.5)	68 (15)	5	76 (3.0)
British Columbia	697 (7,500)	4.2 (9.3)	41 (9)	21	45.5 (1.8)	43 (9.5)	14.5	48,5 (1.9)	61.5 (13.5)	10.5	68.5 (2.7)	72.5	8	81.5 (3.2)
	929 (10,000)	4.2 (9.3)	41 (9)	27	45.5 (1.8)	45.5 (10)	20	51 (2.0)	63.5 (14)	14	(2.8)	75 (16.5)	11	84 (3.3)
	232	(3.3 (7.3)	32 (7)	5.5	35.5 (1.4)	38.5 (8.5)	4	43 (1.7)	47.5 (10.5)	2.8	53.5 (2.1)	57 (12.5)	2	63.5 (2.5)
Vancouver,	465	4.0 (8.8)	38.5 (8.5)	13	(1.7)	45.5 (10)	10	51 (2)	57 (12.5)	6	63.5 (2.5)	68 (15)	5	76 (3)
British Columbia	697 (7,500)	4.5 (9.9)	43 (9.5)	22	48.5 (1.9)	50 (11)	17	(2.2)	63,5 (14)	11	71 (2.8)	75 (16.5)	8,5	84 (3.3)
	929 (10,000)	4.9 (10.9)	47.5 (10.5)	30	53.5 (2.1)	54.5 (12)	24	(2.4) (2.4)	68 (15)	15	76 (3)	79.5 (17.5)	12	(3.5)
	232	3.3 (7.3)	32 (7)	5.5	35.5 (1.4)	38.5 (8.5)	4	(1.7)	43 (9.5)	2.5	48.5 (1.9)	54.5 (12)	2	61 (2,4)
Victoria,	465	4.0 (8.8)	38.5 (8.5)	13	(1.7)	45.5 (10)	10	51 (2)	54.5 (12)	6	61 (2.4)	68 (15)	5	76 (3)
British Columbia	697 (7,500)	4.5 (9.9)	43 (9.5)	22	48.5 (1.9)	50 (11)	16	56 (2.2)	59 (13)	10	66 (2,6)	75 (16.5)	8	84 (3.3)
	929 (10,000)	4.7 (10.4)	45,5 (10)	30	51 (2)	54.5 (12)	23	61 (2.4)	63.5 (14)	14	(2.8)	79,5 (17,5)	12	89 (3.5)
	232	5.9 (13)	57 (12.5)	8	63.5 (2.5)	68 (15)	7	76 (3)	82 (18)	4.5	91.5 (3.6)	95.5 (21)	3.5	106.5 (4.2)
Brandon.	465 (5,000)	7.3 (16.1)	73 (16)	20	81,5 (3.2)	84 (18.5)	17	94 (3.7)	97.5 (21.5)	11	109 (4,3)	113.5 (25)	8,5	127 (5)
Manitoba	697 (7,500)	8.3 (18.2)	79.5 (17.5)	32	(3.5)	93 (20.5)	27	104 (4.1)	107 (23.5)	19	119.5 (4,7)	125 (27.5)	15	139.5 (5.5)
	929 (10,000)	9.0 (19.8)	86.5 (19)	43	96.5 (3.8)	100	38	(4.4)	113.5	26	127 (5.0)	132 (29)	21	147,5 (5.8)
	232	4.7 (10.4)	45.5	7	51 (2)	57 (12.5)	6	63.5 (2.5)	75 (16.5)	4	(3.3)	86.5 (19)	3.2	96,5 (3.8)
Winnipeg,	465	5.9 (13)	57 (12.5)	17	63.5 (2.5)	68 (15)	15	76 (3)	84 (18.5)	10	94 (3.7)	100	7.5	112 (4,4)
Manitoba	697 (7,500)	6,6 (14,5)	63,5 (14)	28	71 (2.8)	75 (16.5)	24	84 (3.3)	93 (20.5)	16	104 (4,1)	107 (23.5)	12	119,5 (4,7)
	929 (10,000)	7.1 (15.6)	68 (15)	39	76 (3)	82 (18)	32	91.5 (3.6)	97.5 (21.5)	22	109 (4.3)	113.5 (25)	17	127 (5.0)
	232	6.4 (14)	62 (13.5)	9	68.5 (2.7)	70.5 (15.5)	7	78.5	79.5	4.5	89 (3.5)	91 (20)	3.5	101.5 (4.0)
Campbellton,	465	9.0 (19.8)	86.5 (19)	22	96.5 (3.8)	91 (20)	18	101.5	102.5	12	115 (4.5)	113.5 (25)	9	127 (5.0)
New Brunswick	697 (7,500)	10.4 (22.9)	100 (22)	35	(4.4)	102.5 (22.5)	28	114.5 (4.5)	118 (26)	20	132 (5.2)	132 (29)	15	147.5 (5.8)
	929 (10,000)	11.3 (25)	109 (24)	47	122 (4.8)	111.5 (24.5)	40	124.5 (4.9)	127.5	29	142 (5.6)	141 (31)	22	157.5 (6.2)

	SQUARE			-	_		тот	AL R	DOF SL	OPE		-		-
-	(SOUARE)		DE	AD LEVE	L	510	nm (2'') RI	SE	102	mm (4'') RI	SE	152	mm (6**) R	ISE
LOCATION	NOTCH AREA RATING	ROOF LOAD FACTOR KGS (LBS.)	L.P.M. (G.P.M.) Discharge	Draindown Time Hrs.	mm (In.) Water Depth									
1	232 (2,500)	4.5 (9.9)	43 (9.5)	7	48.5 (1.9)	52,5 (11,5)	5.5	58.5 (2.3)	63.5 (14)	3.5	71 (2.8)	77.5	2.9	86.5 (3.4)
Chatham,	465 (5,000)	5.7 (12.5)	54.5 (12)	16	(2.4)	63.5 (14)	13	(2.8)	77.5 (17)	9	86.5 (3.4)	91 (20)	7	101.5 (4.0)
Brunswick	697 (7,500)	6.4 (14)	61.5 (13.5)	27	68.5 (2.7)	68 (15)	22	76 (3)	84 (18,5)	14	94 (3.7)	102.5	12	114,5 (4,5)
	929 (10,000)	(14,6)	63,5 (14)	3/	(2.8)	75 (16.5)	30	84 (3.3)	91 (20)	20	101.5 (4.0)	107 (23.5)	16	1 19.5 (4.7)
Moncton, New	(2,500)	4.3 (9.4)	41 (9)	-	45.5 (1.8)	54.5 (12)	6	61 (2.4)	63.5 (14)	3,5	(2.8)	72.5 (16)	2.7	81.5 (3.2)
	465 (5,000)	5.9 (13)	57 (12.5)	1/	63.5 (2,5)	68 (15)	14	76 (3)	82 (18)	9	91.5 (3.6)	93 (20.5)	7	104
Brunswick	697 (7,500)	6.6 (14.6)	63.5 (14)	28	(2.8)	79.5 (17.5)	24	89 (3.5)	93 (20.5)	16	104 (4,1)	104.5 (23)	12	(4.6)
-	929 (10,000)	7.5 (16.6)	72.5 (16)	39	81,5 (3.2)	84 (18.5)	34	94 (3.7)	100 (22)	23	112 (4,4)	113.5 (25)	17	127 (5.0)
	(2,500)	5.7 (12.5)	54.5 (12)	8	61 (2.4)	57 (12,5)	6	63.5 (2.5)	75 (16.5)	4	84 (3.3)	86.5 (19)	3	96.5 (3.8)
Saint John,	465 (5,000)	7.5 (16.6)	72,5 (16)	20	81.5 (3.2)	79.5 (17.5)	16	89 (3.5)	95.5 (21)	11	106.5 (4.2)	104.5 (23)	8	117 (4,6)
Brunswick	697 (7,500)	8.7 (19.2)	84 (18.5)	32	94 (3.7)	93 (20.5)	27	(4.1)	107 (23.5)	19	119,5 (4,7)	118 (26)	13.5	132 (5.2)
	929 (10,000)	9.7 (21.3)	93 (20.5)	44	104 (4,1)	104.5 (23)	38	(4.6)	1.13.5 (25)	27	127 (5.0)	127.5 (28)	20	142 (5.6)
	(2,500)	3.5 (7.8)	34 (7.5)	0.0	(1,5)	45.5 (10)	5	(2.0)	57 (12.5)	3.5	63.5 (2.5)	68 (15)	2.5	76 (3.0)
Gander, Newfoundland	465 (5,000)	(10.4)	45.5 (10)	10	(2.0) (2.0)	57 (12.5)	12	63.5 (2.5)	72.5 (16)	8	81.5 (3.2)	82 (18)	6.5	91.5 (3.6)
New Brunswick () () Gander, () Newfoundland () () St. Andrews, () Newfoundland ()	697 (7,500)	5.7 (12.5)	54,5 (12)	20	(2.4)	63.5 (14)	21	(2.8)	79.5 (17.5)	13.5	(3.5)	93 (20.5)	11	104 (4,1)
	929 (10,000)	6,1 (13.5)	59 (13)	35	(2.6)	70.5 (15.5)	29	78.5 (3.1)	84 (18.5)	19	.94 (3.7)	100 (22)	15	112 (4.4)
	(2,500)	3.5 (7.8)	34 (7.5)	5.5	38 (1.5)	45.5 (10)	5	51 (2.0)	59 (13)	3,5	66 (2.6)	63,5 (14)	2.5	71 (2.8)
Newfoundland St. Andrews, Newfoundland	465 (5,000)	5.2 (11,4)	47,5 (10.5)	15	53.5 (2.1)	59 (13)	13	(2.6) (2.6)	72.5 (16)	8	81.5 (3.2)	79.5 (17.5)	6	89 (3.5)
	697 (7,500)	5.9 (13)	57 (12.5)	20	63.5 (2.5)	66 (14,5)	21	73.5 (2.9)	82 (18)	14	91,5 (3.6)	88.5 (19.5)	10	.99 (3.9)
	929 (10,000)	6.6 (14.6)	63,5 (14)	30	(2.8)	72.5 (16)	30	81,5 (3.2)	86.5 (19)	20	96,5 (3.8)	95.5 (21)	14.5	106.5
	(2,500)	5.9 (13)	57 (12.5)	8	63.5 (2.5)	68 (15)	3	76 (3.0)	77.5 (17)	4.5	86.5 (3.4)	86.5 (19)	3.2	96.5 (3.8)
St. John's,	465 (5,000)	8.5 (18.7)	82 (18)	21	91.5 (3.6)	91 (20)	18	101 (4.0)	100 (22)	11	112 (4.4)	113.5 (25)	9	127 (5.0)
The second second second	697 (7,500)	10.6 (23.4)	102.5 (22.5)	34	114.5 (4.5)	109 (24)	29	122 (4.8)	122.5 (27)	21	137 (5.4)	132 (29)	15	147.5 (5.8)
	929 (10,000)	11.8 (26)	113.5 (25)	48	127 (5.0)	129.5 (28.5)	43	145 (5.7)	143 (31.5)	33	160 (6.3)	150 (33)	24	167.5 (6.6)
	(2,500)	4.9 (10.9)	47.5 (10.5)	7.5	53.5 (2.1)	61.5 (13.5)	6.5	68.5 (2.7)	75 (16.5)	4	84 (3.3)	84 (18.5)	3	94 (3.7)
Torbay,	465 (5,000)	6.4 (14)	61.5 (13.5)	18	68.5 (2.7)	75 (16.5)	15.5	84 (3.3)	88.5 (19.5)	10	99 (3.9)	102.5	8	114.5 (4.5)
Newroundand	697 (7,500)	(16.1)	70.5 (15.5)	29	78,5 (3.1)	84 (18.5)	25	94 (3.7)	100 (22)	17.5	112 (4,4)	113.5 (25)	13	127 (5)
	929 (10,000)	8.0 (17,7)	77,5	40	86,5 (3,4)	88.5 (19.5)	34	99 (3.9)	107 (23.5)	24	119.5 (4,7)	122.5 (27)	19	137 (5.4)
-	232 (2,500)	5.9 (13)	57 (12.5)	8	63:5 (2.5)	68 (15)	7	(3.0)	77.5	4.5	86.5 (3.4)	86.5 (19)	3.2	96.5 (3.8)
Halifax,	465 (5,000)	8.5 (18.7)	82 (18)	21	91.5 (3.6)	91 (20)	18	101.5 (4.0)	100 (22)	11	112	113.5	9	127 (5.0)
IVOVA SCOTIA	697 (7,500)	10.6 (23.4)	102.5 (22.5)	34	114.5 (4.5)	109	29	122 (4.8)	122.5 (27)	21	137 (5.4)	132 (29)	15	147.5
	929 (10,000)	11,8 (26)	113.5 (25)	48	127 (5.0)	129.5	43	145	143 (31.5)	33	160 (6.3)	150 (33)	24	167.5 (6.6)

	SQUARE						тот	AL RO	OFSL	DPE				
	(SOUARE) FOOT		DE	AD LEVEL		51	nm (2'') RIS	έE	102	mm (4") RI	SE	152	SE	
LOCATION	NOTCH AREA RATING	ROOF LOAD FACTOR KGS (LBS.)	L.P.M. (G.P.M.) Discharge	raindown ime Hrs.	(in.) Water Depth	L.P.M. (G.P.M.) Discharge	Draindown Time Hrs.	mm (In.) Water Depth	L.P.M. (G.P.M.) Discharge	Draindown Time Hrs,	mm (In.) Water Depth	L.P.M. (G.P.M.) Discharge	Draindown Time Hrs.	mm (In.) Water Depth
	232	4.3 (9.4)	41 (9)	6.5	45.5	45.5	5	51 (2.0)	57 (12.5)	3.5	63.5 (2.5)	68 (15)	2.5	76 (3.0)
Sydney	465	5.7	54.5	16	(2.4)	59 (13)	13	66 (2.6)	75 (16.5)	8	84 (3.3)	84 (18.5)	6.5	94 (3.7)
Nova Scotia	697	6.4 (14)	61.5	28	68.5	68 (15)	22	76 (3.0)	84 (18.5)	14	94 (3.7)	97.5 (21.5)	11	109 (4.3)
	929	7.1	68 (15)	38	76	75 (16.5)	30	84 (3.3)	91 (20)	20	101.5	104.5 (23)	16	117 (4.6)
	232	6.4	61.5	9	68.5	70.5	7.5	78.5	82 (18)	4.5	91.5 (3.6)	91 (20)	3.5	101.5
Yarmouth	465	8.3	79.5	21	(3.5)	88.5	18	99 (3.9)	104.5	12	117 (4.6)	116 (25.5)	9	129.5
Nova Scotia	697	9,4 (20.8)	91 (20)	34	101.5	102.5	29	114,5	118 (26)	21	132	132 (29)	15	147,5
	929	10.4	100	45	112	109	41	122	129.5	29	145	141 (31)	22	157.5 (6.2)
	232	4.9	47.5	7.5	53.5	61.5	6.5	68.5	75	4	84 (3.3)	88.5	3.5	91,5 (3,6)
Thursday Bau	465	6.1	59	18	66	72.5	15	81.5	86.5	9.5	96.5	102.5	7.5	114,5
Ontario	697	6.6	63.5	28	71	77.5	24	86.5	93	16	104	109	13	122
	929	7.1	68	38	76	84	33	94	97.5	22	109	116	18	129.5
	232	5.7	54.5	8	61	63.5	7	71	86.5	5	96.5	100	3.7	112
	465	6.6	63.5	19	71	75	15.5	84	97.5	11	109	116	9	129.5
Guelph, Ontario	697	7.3	70.5	29	78.5	82	25	91.5	104.5	18	117	125	14	139.5
	929	8.0	77.5	40	86.5	84	34	94	109	26	122	132	20	147.5
	232	5.9	57	8.5	63.5	72,5	7.5	81.5	93	5	104	109	4	122
	(2,500)	(13)	63.5	19	(2.5)	79.5	16	(3.2)	104.5	12	117	122.5	9	137
Hamilton, Ontario	(5,000)	(14.6)	(14)	28	73.5	84	26	94	111.5	20	124.5	127.5	15	142
	929	(15.1)	(14.5)	39	(2.9)	86.5	34	96.5	116	27	129.5	134	21	150
	(10,000) 232	(15.6) 6.4	61.5	9	(3.0)	(19)	8	(3.8)	(25.5)	5	(5.1)	109	4	122
	(2,500)	(14)	(13.5)	20	(2.7) 81.5	(17) 86.5	18	(3.4) 96.5	(20)	12	117	(24)	9.5	137
Kingston, Ontario	(5,000)	(16.6)	(16)	31	(3.2)	93	28	(3.8)	111.5	20	124.5	132	15	147.5
	(7,500) 929	(18.7) 8.7	(18) 86.5	42	(3.6) 96.5	(20.5)	38	(4.1)	(24.5)	27	129.5	68	21	152.5
-	(10,000) 232	(19.2) 6.1	(19)	8.5	(3.8)	(21.5)	7.5	(4.3)	(25.5) 68.5	5	(5.1)	107	4	119,5
	(2,500)	(13.5)	(13)	20	(2.6)	(16)	17	(3.2) 94	(19.5)	12	(3.9)	(23.5)	9.5	13;
London, Ontario	(5,000)	(15.6) 8.0	(15)	30	(3.0) 86.5	(18.5)	27	(3.7)	(22.5)	19	(4.5)	(27)	15	141
	(7,500)	(17.7) 8.5	(17) 82	41	(3.4) 91.5	(19.5)	36	(3.9)	(24)	27	(4.8)	134	21	15(
-	(10,000)	(18.7)	(18)	8	(3.6)	(20)	7	(4.0)	(25) 86.5	5	(5.0) 96.5	(29.5)	3.8	(5.9
	(2,500)	(12,5)	(12)	19	(2.4)	(15)	16	(3.0)	97.5	11	(3.8)	113.5	9	(4.4
North Bay, Ontario	(5,000)	(14.6)	(14)	30	(2.8)	(17.5) 86.5	26	(3.5) 96.5	(21.5)	19	(4:3)	(25)	14	(5.0
	(7,500)	(16.6)	(16)	40	(3.2) 86.5	(19)	36	(3.8)	(23.5)	26	(4.7)	127.5	20	(5.4
	(10.000)	(18.2)	(17)	7	(3.4)	(20.5)	6.5	(4.1)	(24.5)	4.5	(4.9) 86.5	(28) 86.5	3.2	(5.6
	(2,500)	(10.4)	(10)	17	(2.0)	(13)	14	(2.6)	(17) 86.5	10	(3.4) 96.5	(19)	7.5	(3,8
Ottawa, Ontario	(5,000)	(13)	(12.5)	27	(2.5)	(15)	23	(3.0)	(19)	16	(3.8)	(22)	12	(4,4
	(7,500)	(14)	(13.5)	36	(2.7)	(16.5)	32	(3.3)	(20.5)	22	(4.1)	(23.5)	18	12
	(10,000)	(14.6)	(14)		(2.8)	(17.5)		(3.5)	(21.5)	and a	(4.3)	(25)		(5.0

	SQUARE		TOTAL ROOF SLOPE												
	(SQUARE) FOOT		DE	AD-LEVEL		51m	nm (2") RIS	E	102	nm (4") RI	SE	152m	SE		
LOCATION	NOTCH AREA RATING	ROOF LOAD FACTOR KGS (LBS.)	L.P.M. (G.P.M.) Discharge	raindown fime Hrs.	mm (In.) Water Depth	L.P.M. (G.P.M.) Discharge	Draindown Time Hrs.	mm (In.) Water Depth	L.P.M. (G.P.M.) Discharge	Draindown Time Hrs.	mm (In.) Water Depth	L.P.M. (G.P.M.) Discharge	raindown lime Hrs.	mm (In.) Water Depth	
	232	5,7 (12.5)	54.5 (12)	8	61 (2.4)	68 (15)	7	76 (3.0)	86.5 (19)	5	96.5 (3.8)	104.5 (23)	4	117 (4.6)	
St. Thomas,	465	6.6 (14.6)	63.5 (14)	19	(2.8)	77.5 (17)	16	86.5 (3.4)	97.5 (21.5)	11	109 (4.3)	118 (26)	9	132 (5.2)	
Ontario	697 (7,500)	7.1 (15.6)	68 (15)	29	76 (3.0)	82 (18)	26	91.5 (3.6)	102.5 (22.5)	18	114.5 (4.5)	125 (27.5)	15	139.5 (5.5	
	929 (10,000)	7,5 (16.6)	72.5 (16)	40	81.5 (3.2)	86.5 (19)	34	96.5 (3.8)	107 (23.5)	24	119.5 (4.7)	132 (29)	20	147.5 (5.8	
	232	4.3 (9.4)	41 (9)	7	45.5 (1.8)	57 (12.5)	6	63.5 (2.5)	72.5 (16)	4	81,5 (3.2)	86.5 (19)	3.3	96.5 (3.8	
Timmins,	465	5,7 (12.5)	54.5 (12)	16	(2.4)	63.5 (14)	14	(2.8)	82 (18)	9	91.5 (3.6)	97.5 (21.5)	7.5	109 (4.3	
Ontario	697 (7,500)	6.4 (14)	61,5 (13.5)	27	68.5 (2.7)	70.5 (15.5)	22	78.5 (3.1)	86.5 (19)	15	96.5 (3.8)	104.5 (23)	12	117 (4.6	
	929 (10,000)	6.6 (14.6)	63.5 (14)	36	71 (2.8)	72.5 (16)	30	81,5 (3.2)	91 (20)	21	101.5 (4.0)	109 (24)	17	122 (4.8	
	232	5.7 (12.5)	54.5 (12)	8	61 (2.4)	66 (14.5)	1	73.5 (2.9)	82 (18)	4.5	91,5 (3.6)	97.5 (21.5)	3.5	109 (4.3	
Toronto,	465 (5,000)	6.8 (15.1)	66 (14.5)	19	73.5 (2.9)	77.5 (17)	16	86.5 (3.4)	93 (20.5)		104 (4.1)	111.5 (24.5)	a	124. (4.9	
Ontario	697 (7,500)	8.0 (17.7)	77.5	30	86.5 (3.4)	84 (18.5)	26	94 (3.7)	100 (22)	18	112 (4.4)	120.5 (26.5)	14	134.0 (5.3	
	929 (10,000)	8.7 (19.2)	82 (18)	42	91.5 (3.6)	86.5 (19)	34	96.5 (3.8)	104.5 (23)	24	117 (4,6)	127.5 (28)	20	14) (5.6	
Windsor	232	6,1 (13.5)	59 (13)	8.5	66 (2.6)	70,5 (15.5)	7.5	78.5 (3.1)	84 (18.5)	4.5	94 (3.7)	107 (23.5)	4	119. (4.7	
	465	7.1 (15.6)	68 (15)	20	76 (3.0)	79.5 (17.5)	16	89 (3.5)	97.5 (21.5)	"	109 (4,3)	118 (26)	9	13 (5.2	
Ontario	697 (7,500)	8.0 (17.7)	77.5	30	86.5 (3.4)	86,5 (19)	26	96.5 (3.8)	107 (23.5)	18	119.5 (4.7)	125 (27.5)	15	139, (5.5	
	929 (10,000)	8.7 (19.2)	82 (18)	42	91,5 (3.6)	91 (20)	36	101.5 (4.0)	113.5 (25)	26	127 (5.0)	129.5 (28.5)	20	14 (5.7	
	(232	4.9 (10.9)	47.5 (10.5)	7.5	53.5 (2.1)	57 (12.5)	6	63.5 (2.5)	68 (15)	3.8	(3.0)	79.5 (17.5)	3	(3.5	
Charlottetown.	465	6.6 (14.6)	63.5 (14)	19	(2.8)	75 (16.5)	15.5	(3.3) (84	88,5 (19.5)	10	99 (3.9)	100 (22)	7.5	11 (4.4	
P.E.I.	697 (7,500)	7.8	75 (16.5)	31	(3.3)	86.5 (19)	26	96.5 (3.8)	102.5 (22.5)	18	114.5 (4.5)	113.5 (25)	13	12 (5.0	
	929 (10,000)	8.7 (19.2)	84 (18,5)	42	(3.7)	97.5 (21.5)	37	106.5 (4.2)	111.5 (24.5)	26	124.5 (4.9)	125 (27.5)	20	139. (5.5	
	(232	5.2 (11,4)	50 (11)	7.5	(2.2)	61.5 (13.5)	7	68.5 (2.7)	79.5 (17.5)	4.5	(3.5)	97.5 (21.5)	3.5	10	
Montreal.	465	5.9 (13)	57 (12.5)	17	63.5 (2.5)	70.5 (15.5)	15	78.5 (3.1)	88.5 (19.5)	10	99 (3.9)	109 (24)	8	12 (4,8	
Quebec	697 (7,500)	6.1 (13.5)	59 (13)	27	66 (2.6)	72.5 (16)	23	81.5 (3.2)	93 (20.5)	16	104 (4.1)	113.5 (25)	13	12	
	929 (10,000)	6.4 (14)	61.5 (13.5)	36	68.5 (2.7)	77.5	31	86.5 (3.4)	95.5 (21)	22	106.5 (4.2)	120.5 (26.5)	19	134,	
	(232	5.4 (12)	52,5 (11,5)	8	58,5 (2.3)	63.5 (14)	7	(2.8)	79.5 (17.5)	4.5	89 (3.5)	97.5 (21.5)	3.5	10 (4.)	
Quebec City.	465	6.4 (14)	61.5 (13.5)	18	68,5 (2.7)	70.5 (15.5)	15	78.5 (3.1)	84 (18.5)	10	94 (3.7)	104.5 (23)	8	(4.0	
Quebec	697	6,6 (14,6)	63.5 (14)	28	(2.8)	72.5 (16)	23	81,5 (3,2)	86.5 (19)	15	96.5 (3.8)	107 (23.5)	12	119 (4.	
	929 (10,000)	7.1 (15.6)	68 (15)	37	(3.0)	77.5	31	86.5 (3.4)	88,5 (19,5)	20	99 (3.9)	109 (24)	17	12 (4.1	
	(232)	4.5	43 (9.5)	7	48.5	54,5 (12)	6	61 (2.4)	72,5 (16)	4	81.5 (3.2)	79.5 (17.5)	3	(3.	
Regina	(5 000)	6.4 (14)	61.5	18	68,5	68 (15)	14	(3.0)	86.5 (19)	10	96.5 (3.8)	97.5 (21.5)	7.5	10 (4.3	
Saskatchewan	697	7.3 (16.1)	70.5	29	78,5 (3,1	77.5	24	86.5 (3.4)	100 (22)	17	(4.4)	109 (24)	12	(4.)	
	929	8.3	79.5	40	(3.5	82 (18)	32	91,5 (3.6)	104.5 (23)	24	117 (4.6)	118 (26)	18	13 (5.	
	232	4.0	38.5	6	43	57	6	63.5 (2.5)	66 (14.5)	3.8	73.5	77.5	2.8	86 (3,	
Sarkatooo	465	5,7	54.5 (12)	16	(2.4	68 (15)	14.5	(3.0)	82 (18)	9	91.5 (3.6)	95.5 (21)	7	106	
Saskatchewan	697	6.6	63.5	28	12.8	75 (16.5)	24	(3.3)	91 (20)	16	101.5 (4.0)	104.5 (23)	12	(4,4	
	929	7.1	68	38	(3.0	82	32	91.5	97.5	22	(4.3)	113.5 (25)	18	12	

ZURN Control-Flo Roof Drains

the most advanced drainage control available, lets you design roof drainage systems with confidence

Check These ZURN Engineered Features

Large 955cm²(148 Square-Inch) Open Area Dome permits unobstructed flow. Dome is made of lightweight, shock-resistant aluminum and is bayonet-locked to gravel guard on weir. Aluminum Dome supplied when specified. Poly-Dome supplied standard.

Multi-weir Barrier provides flow rates directly proportional to the head. Available with 1 to 6 inverted parabolic notches to meet varying requirements.

Gravel

Insulation

Integral Clamping-Collar at bottom of weir provides positive clamping action without puncturing roof or flashing. Also provides integral gravel guard.

Bayonet-type Locking Device on dome holds dome firmly in place with weir yet allows dome to be easily removed.

Broad Plane Surface combines with clamping collar to hold flashing and roofing felts in tight vise-like grip.

Roof Sump Receiver Distributes Weight of drain over 3716cm²(4 square feet). Supports the drain body and assures flush, roof-level placement.

Waterproofing Membrane

Metal Roof Deck

Extension Sleeve Accommodates the Addition of Insulation to a roof deck. Height as required by thickness of insulation.

Threaded, caulk, M. J. connections available. (Z-105-5-ERC w/Aluminum dome illustrated.) Underdeck Clamp For Rigid Mounting stabilizes the entire assembly and renders it an integral part of the roof structure.



ZURN DRAINAGE AND CONTROL SYSTEMS LTD. Telephone: (416) 741-8260 Fax: (416) 741-7477

SWMHYMO Results
COMMERCIAL PLAZA - 5100 KANATA AVENUE MODEL 1 - OUTFLOW-STORAGE RELATIONSHIP

Pipe Storage	FROM	то	Inner Diameter (m)	Length (m)	Volume (m3)	U/S OBV	U/S INV	D/S OBV	D/S INV	н
1050 mm dia. ST	MH 520	MH 530	1.067	28.2	25.22	104.36	103.29	104.32	103.25	1.11
1050 mm dia. ST	MH 511	MH 520	1.067	24.4	21.82	104.69	103.62	104.52	103.45	1.24
1050 mm dia. ST	MH 510	MH 511	1.067	23.5	21.01	104.86	103.79	104.69	103.62	1.24
750 mm dia. ST	CBMH 510	MH 511	0.762	29.6	13.50	105.26	104.50	104.98	104.22	1.04
200 mm dia. ST	CB 509	CBMH 510	0.250	29.4	1.44	105.60	105.35	105.30	105.05	0.55
200 mm dia. ST	CB 508	CBMH 510	0.200	14.5	0.46	105.29	105.09	105.14	104.94	0.35
200 mm dia. ST	CB 519	CB 520	0.200	8.5	0.27	104.88	104.68	104.79	104.59	0.29
200 mm dia. ST	CB 520	CBMH 522	0.200	21.7	0.68	104.76	104.56	104.54	104.34	0.42
200 mm dia. ST	CB 521	CBMH 522	0.200	12.3	0.39	105.05	104.85	104.93	104.73	0.32
250 mm dia. ST	CBMH 522	MH 520	0.250	20.3	1.00	104.56	104.31	104.36	104.11	0.45
150 mm dia. ST	BLDG A	MH 510	0.150	4.6	0.08	105.85	105.70	105.71	105.56	0.29
150 mm dia. ST	BLDG E	MH 520	0.150	7.0	0.12	105.52	105.37	105.21	105.06	0.46
200 mm dia. ST	CB 530	CB 531	0.200	10.5	0.33	104.22	104.02	104.12	103.92	0.30
250 mm dia. ST	CB 531	1200 ST	0.250	21.8	1.07	104.12	103.87	103.90	103.65	0.47
200 mm dia. ST	CB 541	CB 540	0.200	10.5	0.33	104.27	104.07	104.16	103.96	0.31
250 mm dia. ST	CB 540	1200 ST	0.250	11.7	0.57	104.16	103.91	104.04	103.79	0.37

MH / CB Storage	Inner Diameter / Width (m)	Area (m2)	1:100 yr WL or T/G	LOWER INV	н	Volume (m3)
MH 530	1.829	2.6273	107.20	103.03	4.17	10.96
MH 520	1.829	2.6273	107.20	103.29	3.91	10.27
MH 511	2.438	4.6683	107.20	103.62	3.58	16.71
MH 510	1.829	2.6273	107.20	103.79	3.41	8.96
CBMH 510	1.524	1.8241	107.20	104.50	2.70	4.93
CBMH 522	1.219	1.1671	106.97	104.31	2.66	3.10
CB 519	0.610	0.3721	107.20	104.68	2.52	0.94
CB 520	0.610	0.3721	107.20	104.56	2.64	0.98
CB 521	0.610	0.3721	107.05	104.85	2.20	0.82
CB 530	0.610	0.3721	107.00	104.02	2.98	1.11
CB 531	0.610	0.3721	107.05	103.87	3.18	1.18
CB 541	0.610	0.3721	107.05	104.07	2.98	1.11
CB 540	0.610	0.3721	107.10	103.91	3.19	1.19

Elevation						Underground St	orage Volume (m3)						570	Oout
(m)	Head (m)	MH 530	1050 mm dia. ST (MH 520 - MH 530)	MH 520	1050 mm dia. ST (MH 511 - MH 520)	MH 511	1050 mm dia. ST (MH 510 - MH 511)	MH 510	750 mm dia. ST (CBMH 510 - MH 511)	СВ / СВМН	CB Lead	Total U/G Volume	(ha-m)	(cms)
103.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00000	0.0000
103.30	0.20	0.71	1.14	0.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.87	0.00019	0.0165
103.70	0.60	1.76	10.25	1.08	4.41	0.37	1.36	0.00	0.00	0.00	0.00	19.23	0.00192	0.0283
104.00	0.90	2.55	17.08	1.87	9.70	1.77	6.46	0.55	0.00	0.00	0.00	39.98	0.00400	0.0346
104.34	1.24	3.44	24.83	2.76	15.70	3.36	12.23	1.45	1.55	0.04	2.30	67.66	0.00677	0.0406
104.69	1.59	4.36	25.22	3.68	21.82	5.00	18.18	2.36	6.09	0.79	3.30	90.79	0.00908	0.0460
104.99	1.89	5.15	25.22	4.47	21.82	6.40	21.01	3.15	9.98	1.69	4.25	103.12	0.01031	0.0501
105.27	2.17	5.89	25.22	5.20	21.82	7.70	21.01	3.89	13.50	2.52	4.64	111.38	0.01114	0.0537
105.97	2.87	7.72	25.22	7.04	21.82	10.97	21.01	5.73	13.50	4.62	6.74	124.37	0.01244	0.0617
106.66	3.56	9.54	25.22	8.85	21.82	14.19	21.01	7.54	13.50	6.68	6.74	135.09	0.01351	0.0688
106.97	3.87	10.35	25.22	9.67	21.82	15.64	21.01	8.35	13.50	7.61	6.74	139.91	0.01399	0.0717
107.10	4.00	10.69	25.22	10.01	21.82	16.25	21.01	8.70	13.50	13.25	6.74	147.18		
107.20	4.10	10.96	25.22	10.27	21.82	16.71	21.01	8.96	13.50	15.36	6.74	150.54		

Surface Storage	Ponding Volume (m3)	1:100 yr WL	T/G	н
CBMH 522	25.18	107.20	106.97	0.23
CB 521	1.61	107.20	107.05	0.15
CB 530	23.57	107.20	107.00	0.20
CB 531	5.85	107.20	107.05	0.15
CB 541	3.38	107.20	107.05	0.15
CB 540	2.23	107.20	107.10	0.10

Elevation		Above-ground Storage Volume (m3)									
(m)	CBMH 522	CB 521	CB 530	CB 531	CB 541	CB 540	Surface	Underground	Total Volume	(ha-m)	(cms)
107.10	14.23	0.54	11.78	1.95	1.13	0.00	29.63	147.18	176.81	0.01768	0.0729
107.20	25.18	1.61	23.57	5.85	3.38	2.23	61.82	150.54	212.36	0.02124	0.0738

M1-100.dat

Metric units 2 *# Project Name: [COMMERCIAL PLAZA 5100 KANATA] Project Number: [23405-003] *# Date : 03-05-2019 *# Modeller : [AW] : J. L. Richards & Associates Limited *# Company *# License # : 4418403 TZERO=[0.0], METOUT=[2], NSTORM=[1], NRUN=[100] START ["100yr3h.stm"] * READ STORM STORM_FILENAME=["STORM.001"] *%-----|----|-----| *Drainage Area Contributing to MH 530 - ICD 53 DESIGN STANDHYD ID=[1], NHYD=["AREA1"], DT=[1]min, AREA=[0.689](ha), XIMP=[0.85], TIMP=[0.85], DWF=[0](cms), LOSS=[2], CN=[98], SLOPE=[1.5](%), RAINFALL=[, , , ,](mm/hr), END=-1 IDout=[2], NHYD=["STO-1"], IDin=[1], ROUTE RESERVOIR RDT=[1](min),TABLE of (OUTFLOW-STORAGE) values (cms) - (ha-m) 0.0, 0.0] Γ [0.0000, 0.00000] [0.0165, 0.00019] [0.0283, 0.00192] [0.0346, 0.00400] [0.0406, 0.00677] [0.0460, 0.00908] [0.0501, 0.01031] [0.0537, 0.01114] [0.0617, 0.01244] [0.0688, 0.01351] [0.0717, 0.01399][0.0729, 0.01768] [0.0738, 0.02124][-1 , -1] (max twenty pts) IDovf=[3], NHYDovf=["OVF-1"] *%-----FINISH

SSSSS W ΥM 000 999 999 м Μ Н Н Y М W _____ MM MM 9 S WWW MM MM Н Н ΥY 0 0 9 9 9 SSSSS WWW ммм HHHHH Υ ммм 0 0 ## 9 9 9 9 Ver 4.05 0 0 9999 Sept 2011 S WW Μ Μ Н н М Μ 9999 γ SSSSS WW М Μ Н Н Υ М М 000 9 9 ========= 9 9 9 # 4418403 q StormWater Management HYdrologic Model 999 999 _____ ****************************** SWMHYMO Ver/4.05 ********************************* ******* ******* A single event and continuous hydrologic simulation model ******* ******* based on the principles of HYMO and its successors ******* OTTHYMO-83 and OTTHYMO-89. ******* ******** Distributed by: J.F. Sabourin and Associates Inc. ******* ******* Ottawa, Ontario: (613) 836-3884 ******* ******* Gatineau, Quebec: (819) 243-6858 ******* ******* ******* E-Mail: swmhymo@jfsa.Com ++++++++ Licensed user: J. L. Richards & Associates Limited +++++++++ SERIAL#:4418403 Ottawa +++++++++ +++++++++ ******* ++++++ PROGRAM ARRAY DIMENSIONS ++++++ ******* ******* Maximum value for ID numbers : 10 ******* Max. number of rainfall points: 105408 ******* ******* Max. number of flow points : 105408 ******* ***** ****** DETAILED OUTPUT ****** DATE: 2019-03-05 TIME: 14:14:35 RUN COUNTER: 000002 * Input filename: C:\SWMHYMO\23405\M1-100.dat * * * Output filename: C:\SWMHYMO\23405\M1-100.out * * Summary filename: C:\SWMHYMO\23405\M1-100.sum * User comments: * * * 1: * 2: * * 3:

M1-100.out

M1-100.out

001:0001------- -*# Project Name: [COMMERCIAL PLAZA 5100 KANATA] Project Number: [23405-003] : 03-05-2019 *# Date *# Modeller : [AW] : J. L. Richards & Associates Limited *# Company *# License # : 4418403 ** END OF RUN : 99 | START Project dir.: C:\SWMHYMO\23405\ Rainfall dir.: C:\SWMHYMO\23405\ -----TZERO = .00 hrs on 0 METOUT= 2 (output = METRIC) NRUN = 100NSTORM= 1 # 1=100yr3h.stm - -100:0002------ -*# Project Name: [COMMERCIAL PLAZA 5100 KANATA] Project Number: [23405-003] : 03-05-2019 *# Date *# Modeller : [AW] : J. L. Richards & Associates Limited *# Company *# License # : 4418403 - -100:0002------ -Filename: 100yr_3hr CHICAGO STORM - OTTAWA INT. AI READ STORM | Ptotal= 71.66 mm| Comments: 100yr_3hr CHICAGO STORM - OTTAWA INT. AI Page 2

M1-100.out

RAIN | RAIN | TIME RAIN TIME TIME TIME RAIN hrs mm/hr | hrs mm/hr | hrs mm/hr hrs mm/hr 6.046 1.00 178.559 1.83 11.059 5.760 .17 2.67 .33 7.542 | 1.17 54.049 2.00 9.285 2.83 5.280 .50 10.159 | 1.33 27.319 | 2.17 8.024 3.00 4.879 1.50 18.240 2.33 7.080 .67 15.969 .83 40.655 1.67 13.737 2.50 6.347 _____ 100:0003------ -* *Drainage Area Contributing to MH 530 - ICD 53 -----(ha)= .69 DESIGN STANDHYD Area | 01:AREA1 DT= 1.00 | Total Imp(%)= 85.00 Dir. Conn.(%)= 85.00 IMPERVIOUS PERVIOUS (i) Surface Area (ha)= .59 .10 Dep. Storage (mm)= 1.50 .80 (%)= 1.50 Average Slope 1.50 Length (m) =67.77 40.00 Mannings n .013 .250 = Max.eff.Inten.(mm/hr)= 178.56 174.11 over (min) 1.00 8.00 Storage Coeff. (min)= 1.42 (ii) 7.58 (ii) Unit Hyd. Tpeak (min)= 1.00 8.00 Unit Hyd. peak (cms)= .15 .86 *TOTALS* .29 PEAK FLOW (cms)= .03 .320 (iii) TIME TO PEAK (hrs)= 1.00 1.07 1.000 RUNOFF VOLUME 65.34 (mm) =70.86 70.036 71.66 TOTAL RAINFALL (mm)= 71.66 71.665 RUNOFF COEFFICIENT = .99 .91 .977 (i) CN PROCEDURE SELECTED FOR PERVIOUS LOSSES: Ia = Dep. Storage (Above) $CN^* = 98.0$ (ii) TIME STEP (DT) SHOULD BE SMALLER OR EQUAL THAN THE STORAGE COEFFICIENT. (iii) PEAK FLOW DOES NOT INCLUDE BASEFLOW IF ANY. _____ - -100:0004----- M1-100.out

- -

ROUTE RESERVOIR	Requested	l routing ti	me step = 1.	.0 min.	
$ 0 _{2} = 0.02 \cdot (STO_{-1}) $			TOPACE TABLE		
		STORAGE		STORAGE	
		(ham)		(ham)	
	(CIIIS)	00005100		1031E_01	
	.000	.0000L+00	054	1111/E_01	
	.000	1000E 02	.054 062	12445-01	
	.010	10205 02		12515 01	
	.020	.1920E-02	.009	12005 01	
	.035	.4000E-02	.072	.1399E-01	
	.041	.6//0E-02	.073	.1/68E-01	
	.040	.9080E-02	.074	.2124E-01	
ROUTING RESULTS	AR	REA QPEA	к треак	R.V.	
	- (h	ia) (cms) (hrs)	(mm)	
INFLOW >01: (AREA1) .	69 .32	0 1.000	70.036	
OUTFLOW<02: (STO-1) .	69 .07	4 1.217	70.036	
OVERFLOW<03: (OVF-1) .	00.00	000.00	.000	
TOTAL CUMUL PERCE PEAK TIME MAXIM	NUMBER OF ATIVE TIME NTAGE OF T FLOW R SHIFT OF P NUM STORAG	SIMULATED OF OVERFLO IME OVERFLO REDUCTION [Q PEAK FLOW GE USED	<pre>OVERFLOWS = WS (hours)= WING (%)= out/Qin](%)= (min)= (ha.m.)=.</pre>	0 .00 .00 23.047 13.00 .2119E-01	
					
PRINT HYD A	REA	(ha)= .	000		
ID=03 (OVF-1) Q	PEAK ((cms)= .	000 (i)		
DT= 1.00 PCYC= 1 T	РЕАК (hrs)= .	000		
V	/OLUME	(mm)= .	000		
<pre>(i) PEAK FLOW DOES *** WARNING: This</pre>	NOT INCLU	DE BASEFLOW is dry.	IF ANY.		
100:0006					
FINISH					

MI-100.000

**
WARNINGS / ERRORS / NOTES
100:0005 PRINT HYD
*** WARNING: This hydrograph is dry.
Simulation ended on 2019-03-05 at 14:14:36
==

M1-100 out

COMMERCIAL PLAZA - 5100 KANATA AVENUE MODEL 3 - OUTFLOW-STORAGE RELATIONSHIP

Pipe Storage	FROM	то	Inner Diameter (m)	Length (m)	Volume (m3)	U/S OBV	U/S INV	D/S OBV	D/S INV	н
975 mm dia. ST	CBMH 570	CBMH 571	0.991	40.0	30.85	104.90	103.91	104.50	103.51	1.39

CB Storage	Inner Diameter (m)	Area (m2)	T/G	LOWER INV	Н	Volume (m3)
CBMH 571	1.829	2.6273	107.00	103.48	3.52	9.25
CBMH 570	1.829	2.6273	107.10	103.91	3.19	8.38

Elevation			Underground Sto	rage Volume (m3	3)	STO	Oout
(m)	Head (m)	СВМН 571	975 mm dia. ST (CBMH 570 - 571)	CBMH 570	Total U/G Volume	(ha-m)	(cms)
103.51	0.00	0.00	0.00	0.00	0.00	0.00000	0.0000
103.70	0.19	0.58	4.21	0.00	4.79	0.00048	0.0040
104.05	0.54	1.50	11.98	0.37	13.84	0.00138	0.0068
104.50	0.99	2.68	21.96	1.55	26.19	0.00262	0.0092
105.00	1.49	3.99	30.85	2.86	37.71	0.00377	0.0113
105.50	1.99	5.31	30.85	4.18	40.34	0.00403	0.0130
106.00	2.49	6.62	30.85	5.49	42.97	0.00430	0.0146
106.50	2.99	7.93	30.85	6.80	45.59	0.00456	0.0160
107.00	3.49	9.25	30.85	8.12	48.22	0.00482	0.0173
107.15	3.64	9.25	30.85	8.38	48.48		
107.30	3.79	9.25	30.85	8.38	48.48		

Surface Storage	Ponding Volume (m3)	1:100 yr WL	T/G	н
CBMH 571	71.97	107.30	107.00	0.30
CBMH 570	26.44	107.30	107.10	0.20

Elevation		STO	Qout				
(m)	CBMH 571	CBMH 570	Surface	Underground	Total Volume	(ha-m)	(cms)
107.15	35.985	6.61	42.595	48.48	91.08	0.00911	0.0176
107.30	71.97	26.44	98.41	48.48	146.89	0.01469	0.0180

M3-100.dat

Metric units 2 *# Project Name: [COMMERCIAL PLAZA 5100 KANATA] Project Number: [23405-003] *# Date : 03-05-2019 *# Modeller : [AW] : J. L. Richards & Associates Limited *# Company *# License # : 4418403 TZERO=[0.0], METOUT=[2], NSTORM=[1], NRUN=[100] START ["100yr3h.stm"] * READ STORM STORM_FILENAME=["STORM.001"] *%-----|----|-----| *Drainage Area Contributing to CBMH 571 - ICD 71 DESIGN STANDHYD ID=[1], NHYD=["AREA1"], DT=[1]min, AREA=[0.333](ha), XIMP=[0.83], TIMP=[0.83], DWF=[0](cms), LOSS=[2], CN=[98], SLOPE=[1.5](%), RAINFALL=[, , , ,](mm/hr), END=-1 IDout=[2], NHYD=["STO-1"], IDin=[1], ROUTE RESERVOIR RDT=[1](min),TABLE of (OUTFLOW-STORAGE) values (cms) - (ha-m) 0.0, 0.0] Γ [0.0000, 0.00000] [0.0040, 0.00048] [0.0068, 0.00138] [0.0092, 0.00262] [0.0113, 0.00377] [0.0130, 0.00403] [0.0146, 0.00430] [0.0160, 0.00456] [0.0173, 0.00482] [0.0176, 0.00911] [0.0180, 0.01469][-1 , -1] (max twenty pts) IDovf=[3], NHYDovf=["OVF-1"] *%-----|-----|------| ID=[3], # OF PCYCLES=[1] PRINT HYD FINISH

_______ SSSSS W 000 999 999 м Μ Н Н Y ΥM М W _____ MM MM 9 S WWW MM MM Н Н ΥY 0 0 9 9 9 SSSSS WWW ммм HHHHH Υ ммм 0 0 ## 9 9 9 9 Ver 4.05 0 0 9999 Sept 2011 S WW Μ Μ Н н М Μ 9999 γ SSSSS WW М Μ Н Н Υ М М 000 9 9 ========= 9 9 9 # 4418403 q StormWater Management HYdrologic Model 999 999 _____ ****************************** SWMHYMO Ver/4.05 ********************************* ******* ******* A single event and continuous hydrologic simulation model ******* ******* based on the principles of HYMO and its successors ******* OTTHYMO-83 and OTTHYMO-89. ******* ******** Distributed by: J.F. Sabourin and Associates Inc. ******* ******* Ottawa, Ontario: (613) 836-3884 ******* ******* Gatineau, Quebec: (819) 243-6858 ******* ******* ******* E-Mail: swmhymo@jfsa.Com ++++++++ Licensed user: J. L. Richards & Associates Limited +++++++++ SERIAL#:4418403 Ottawa +++++++++ +++++++++ ******* ++++++ PROGRAM ARRAY DIMENSIONS ++++++ ******* ******* Maximum value for ID numbers : 10 ******* Max. number of rainfall points: 105408 ******* ******* Max. number of flow points : 105408 ******* ***** DETAILED ****** OUTPUT DATE: 2019-03-05 TIME: 14:16:44 RUN COUNTER: 000003 * Input filename: C:\SWMHYMO\23405\M3-100.dat * * * Output filename: C:\SWMHYMO\23405\M3-100.out * * Summary filename: C:\SWMHYMO\23405\M3-100.sum * User comments: * * * 1: * 2: * * 3:

M3-100.out

M3-100.out

001:0001------- -*# Project Name: [COMMERCIAL PLAZA 5100 KANATA] Project Number: [23405-003] : 03-05-2019 *# Date *# Modeller : [AW] : J. L. Richards & Associates Limited *# Company *# License # : 4418403 ** END OF RUN : 99 | START Project dir.: C:\SWMHYMO\23405\ Rainfall dir.: C:\SWMHYMO\23405\ -----TZERO = .00 hrs on 0 METOUT= 2 (output = METRIC) NRUN = 100NSTORM= 1 # 1=100yr3h.stm - -100:0002------ -*# Project Name: [COMMERCIAL PLAZA 5100 KANATA] Project Number: [23405-003] : 03-05-2019 *# Date *# Modeller : [AW] : J. L. Richards & Associates Limited *# Company *# License # : 4418403 - -100:0002------ -Filename: 100yr_3hr CHICAGO STORM - OTTAWA INT. AI READ STORM | Ptotal= 71.66 mm| Comments: 100yr_3hr CHICAGO STORM - OTTAWA INT. AI Page 2

```
M3-100.out
```

TIME	RAIN	TIME RAIN	TIME	RAIN	TIME F	RAIN
hrs	mm/hr	hrs mm/hr	, hrs	mm/hr	hrs m	n/hr
17	6 946	1 00 178 559	1 1 83	11 059	2 67 5	760
.1/		1 17 5/ 0/0		0 205	2.07 5.	200
	7.542	1.17 54.049	2.00	9.205	2.05 5.	, 200
.50	10.159	1.33 27.319	2.1/	8.024	3.00 4.	.879
.67	15.969	1.50 18.240	2.33	7.080		
.83	40.655	1.67 13.737	2.50	6.347		
100:0003						
*						
*Durationana Auron Conto						
*Drainage Area Contr	Touring it) CBMH 5/1 - 1				
*						
DESIGN STANDHYD	Area	(ha)=	.33			
01:AREA1 DT= 1.00) Total	Imp(%)= 83	.00 Dir.	Conn.(%)=	83.00	
·						
		IMPERVIOUS	PERVIOUS (i)		
Surface Area	(ha)=	28	96	-)		
	(na)-	.20	1 50			
Dep. Storage	(mm) =	.00	1.50			
Average Slope	(%)=	1.50	1.50			
Length	(m)=	47.12	40.00			
Mannings n	=	.013	.250			
Max.eff.Inten.(mm/hr)=	178.56	174.62			
over	(min)	1.00	7.00			
Storage Coeff.	(min)=	1.14 (ii)	7.30 (i	i)		
Unit Hyd Tneak	(\min)	1 00	7 00	-)		
	(m±n)=	1.00	1.00			
ОПІС НУС. реак	(CmS) =	.99	.10	****		
	<i>,</i> ,			*101A	LS* 	
PEAK FLOW	(cms)=	.14	.02	.1	55 (iii)	
ΤΙΜΕ ΤΟ ΡΕΑΚ	(hrs)=	1.00	1.05	1.0	00	
RUNOFF VOLUME	(mm)=	70.86	65.34	69.9	25	
TOTAL RAINFALL	(mm)=	71.66	71.66	71.6	65	
RUNOFF COEFFICI	ENT =	.99	.91	.9	76	
					-	
(i) CN PROCED						
	$\beta \alpha = \tau_{2}$	- Don $+$ $ -$	$(\Lambda have)$			
$CN^{*} = 98$		- Dep. Storage	(ADOVE)			
(11) IIME SIEP	(DI) SHOU	JLD RE SMALLER	UK EQUAL			
THAN THE	STORAGE CO	DEFFICIENT.				
(iii) PEAK FLOW	DOES NOT	INCLUDE BASEF	LOW IF ANY.			
100:0004						

M3-100.out

- -

ROUTE RESERVOIR IN>01:(AREA1)	Requeste	d routing	g time	step = 1.	0 min.	
OUT<02:(STO-1)	=======	= OUTLFO	OW STOR	RAGE TABLE	========	
	OUTFLOW	STORAG	GE	OUTFLOW	STORAGE	
	(cms)	(ha.m.	.)	(cms)	(ha.m.)	
	.000	.0000E+0	90	.013	.4030E-02	
	.000	.0000E+0	90 İ	.015	.4300E-02	
	.004	.4800E-0	93 İ	.016	.4560E-02	
	.007	.1380E-0	92 İ	.017	.4820E-02	
	.009	.2620E-0	92 İ	.018	.9110E-02	
	.011	.3770E-0	92	.018	.1469E-01	
ROUTING RESULTS	А	REA (QPEAK	TPEAK	R.V.	
	(ha) ((cms)	(hrs)	(mm)	
INFLOW >01: (AREA1	.)	.33	.155	1.000	69.925	
OUTFLOW<02: (STO-1	.)	.33	.018	1.500	69.925	
OVERFLOW<03: (OVF-1	.)	.00	.000	.000	.000	
ΤΟΤΑ	L NUMBER O	F SIMULA	red ove	RFLOWS =	0	
CUMU	ILATIVE TIM	IE OF OVER	RFLOWS	(hours)=	.00	
PERC	ENTAGE OF	TIME OVER	RFLOWIN	IG (%)=	.00	
PEAK	FLOW	REDUCTION	N [Qout	:/Qin](%)=	11.598	
TIME	SHIFT OF	PEAK FLOW	N	(min)=	30.00	
MAXI	MUM STORA	GE USEI)	(ha.m.)=.	1384E-01	
100:0005						
	ΛΟΕΛ	(ba)-	000			
$ TD_{02} / OVE 1 \rangle$		(na) =	000.	, , (;)		
1D=03 (0VF-1)	UPEAK TDEAK	(CmS) =	.000) (1)		
DI= 1.00 PCYC= 1		$(\Pi S) =$.000)		
	VULUME	(mm)=	.000)		
<pre>(i) PEAK FLOW DOE *** WARNING: This</pre>	S NOT INCL hydrograp	UDE BASEN h is dry	FLOW IF	ANY.		
100:0006						
 FINISH						

M3-100.out
**
WARNINGS / ERRORS / NOTES
100:0005 PRINT HYD
*** WARNING: This hydrograph is dry.
Simulation ended on 2019-03-05 at 14:16:44
==

Appendix D8

Water Quality Memorandum



IBI GROUP 400–333 Preston Street Ottawa ON K1S 5N4 Canada tel 613 225 1311 fax 613 225 9868 ibigroup.com

Memorandum

To/Attention	Damien Whittaker	Date	October 27, 2015
From	Peter Spal	Project No	28661
cc	Bob Wingate		
Subject	Kanata Lakes Existing Conditions -	Water Quality	

Dear Mr. Whittaker,

A Certificate of Approval was obtained from the Ministry of the Environment on November 26, 2008 to provide Enhanced (Level 1) water quality protection and attenuation of post development peak flows in two stormwater management wet ponds in series: Kizell Cell (upstream) and Beaver Cell (downstream).

This memo provides an evaluation of the existing conditions water quality control based on the most up to date information available. The drainage area requiring water quality protection is 416 ha.

The MOE Manual notes four (4) stormwater management pond (SWMP) types. Listed in order of increasing efficiency of providing water quality control these are: (i) wet pond, (ii) wet pond/wetland, (iii) wetland, and (iv) infiltration.

Based on the MOE Manual calculations for a wet pond to provide water quality treatment with 80% TSS removal this requires:

- permanent storage volume of 36,958 m³
- extended storage volume of 16,636 m³

The stage-storage curve from the existing conditions XPSWMM model provided with AECOM's "Shirley's Brook and Watts Creek Phase 2" April 27, 2015 report was used to obtain the most up to date existing permanent storage and extended storage available in the Beaver Cell. Based on this stage-storage curve the Beaver Cell provides:

- permanent storage volume of 35,210 m³
- extended storage volume of 154,647 m³

The Beaver Cell alone is able to provide for 95% of the permanent storage volume required for water quality control when considered as a wet pond. Classification of the Beaver Pond as a wet pond is conservative considering that a significant proportion of the facility consists of wetland area. This would enhance the water quality treatment beyond that of a wet pond.

Based on the MOE Manual calculations for a wet pond/wetland to provide water quality treatment with 80% TSS removal would require:

- permanent storage volume of 25,253m³
- extended storage volume of 16,636 m³

The permanent storage volume in the Beaver Cell exceeds the storage requirement by 39% when considered as a wet pond/wetland pond.

The below figure shows the existing permanent storage volume in comparison to the MOE requirements for the wet pond and the wet pond/wetland.



In our opinion, the existing permanent storage volume in Beaver Cell using the wet pond calculations closely corresponds to the MOE requirements. In reality, water quality attenuation (control) is enhanced in the wetland areas of both Beaver and Kizell Cells. The enclosed aerial photos from GeoOttawa (<u>http://maps.ottawa.ca/geoottawa/</u>) for the years 2009, 2011, and 2014 demonstrate substantial wetland areas and permanent standing water in both the Kizell and Beaver Cells. Aerial photography of the Beaver Cell from 2011 shows additional existing ponding areas which was excluded from the volume used to determine the existing permanent storage volume. In light of the above it is our opinion that under existing conditions the permanent storage volume requirement is adequately provided.

The extended storage volume required for a wet pond can be fully accommodated in the Beaver Cell.

Enclosed:

Water quality calculations GeoOttawa aerial photos Certificate of Approval - November 26, 2008

Water Quality Calculations - Existing Conditions - Wet Pond

Total Drainage Area to the Beaver Pond for Water Quality Treatment: 416 ha

(*)Total weighted TIMP for Drainage Areas to Beaver Pond for Water Quality Treatment: 30.4 %

Enhanced Level of Treatment (80% TSS removal)

Permanent Storage required for Wet Pond (from MOE Manual p3-10 Table 3.2):

		Storage Volume	
	IMP (%)	(m³/ha)	
	30	128	(extrapolated)
	35	140	
For Beaver Pond:		129	•

Calculated storage volume minus 40 m ³ /ha extended storage:	89 m³/ha
Total Permanent Storage Required in Beaver Pond:	36958 m ³

0.17 ha-m	35210 m ³ 1749 m ³	Existing permanent storage in Beaver Pond as per AECOM stage-area curve at permanent water elevation of 90.42 m: Deficit of Permanent Storage in Beaver Pond:
	16636 m ³	Extended Storage Required in Beaver Pond:

Notes: (*) The weighted TIMP assumes rural areas (AECOM existing condition areas modeled with NASHYD) have a TIMP equal to 0.

Water Quality Calculations - Existing Conditions - Hybrid (Wet Pond/Wetland)

Total Drainage Area to the Beaver Pond for Water Quality Treatment: 416 ha

(*)Total weighted TIMP for Drainage Areas to Beaver Pond for Water Quality Treatment: 30.4 %

Enhanced Level of Treatment (80% TSS removal)

Permanent Storage required for Hybrid (from MOE Manual p3-10 Table 3.2):

		Storage Volume	
	IMP (%)	(m³/ha)	
	30	100	(extrapolated)
	35	110	
For Beaver Pond:		101	

Calculated storage volume minus 40 m³/ha extended storage: 61 m³/ha 25253 m³ Half PP Storage: 12626.6 m³ Total Permanent Storage Required in Beaver Pond: 42088.67 m² Wetland at 0.3 m depth: 4.208867 ha Existing permanent storage in Beaver Pond as per AECOM stage-area curve at MOE - PW Volume should be 50% within wet cell and 50% in 35210 m³ permanent water elevation of 90.42 m: wetland at average 0.15 to 0.3 m depth -9956 m³ Deficit of Permanent Storage in Beaver Pond: 16636 m³ Extended Storage Required in Beaver Pond:

Notes: (*) The weighted TIMP assumes rural areas (AECOM existing condition areas modeled with NASHYD) have a TIMP equal to 0.

Aerial Photos of Kizell Cell



Aerial Photos of Kizell Cell



Aerial Photos of Kizell Cell



Detailed Aerial Photo of Ponding Areas Extending Beyond Beaver Pond



Aerial Photos obtained on 28/10/2015 from GeoOttawa (http://maps.ottawa.ca/geoottawa/)

Detailed Aerial Photo of Ponding Areas In Kizell Pond



Aerial Photos obtained on 28/10/2015 from GeoOttawa (http://maps.ottawa.ca/geoottawa/)







Ministry of the Environment Ministère de l'Environnement



CERTIFICATE OF APPROVAL MUNICIPAL AND PRIVATE SEWAGE WORKS NUMBER 5190-7L6RRY Issue Date: November 26, 2008

City of Ottawa 110 Laurier Avenue West Ottawa, Ontario K1P 1J1

Site Location: Kanata Lakes Stormwater Management Facility Lot 6 and 7, Concession 2 and 3, March City of Ottawa, Ontario

You have applied in accordance with Section 53 of the Ontario Water Resources Act for approval of:

stormwater management *Works* for the treatment and disposal of stormwater runoff from a catchment area of 397 hectares, servicing Kanata Lakes Subdivision, to provide Enhanced (Level 1) water quality protection and to attenuate post-development peak flows in two cells in series, upstream Kizell Cell and downstream Beaver Cell, to a maximum flow rate of 0.96 cubic metres per second for the 100 year storm event, discharging to Kizell Drain, consisting of the following:

Stormwater Management System

Kizell Cell

a stormwater management wet pond, located west of Goulbourn Forced Road, having a minimum liquid retention volume of approximately 10,271 cubic metres at an elevation of 93.30 metres, and a maximum active retention volume of approximately 89,825 cubic metres at an elevation of 94.28 metres for the 100 year storm event, complete with two (2) energy dissipaters at the storm inlets to the cell, and one (1) outlet berm, discharging at a controlled flow rate of 1.16 cubic metres per second for the 100 year storm event to the downstream Beaver Cell;

Beaver Cell

a stormwater management wet pond, located east of Goulbourn Forced Road, having a minimum liquid retention volume of approximately 41,042 cubic metres at an elevation of 90.47 metres, and a maximum active volume of approximately 236,696 cubic metres at an elevation of 92.60 metres for the 100 year storm event, complete with three (3) storm inlets to the cell, two (2) with energy dissipaters, and one (1) outlet structure consists of a 600 millimetre diameter orifice at an invert elevation of 90.47 metres and an overflow weir set at an invert elevation of 92.60 metres, discharging at a controlled flow rate of 0.96 cubic metre per second for the 100 year storm event via an 80 metre long 1200 millimetre diameter

culvert to Kizell Drain;

including erosion/sedimentation control measures during construction and all other controls and appurtenances essential for the proper operation of the aforementioned Works;

all in accordance with the following submitted supporting documents:

- 1. <u>Application for Approval of Municipal and Private Sewage Works</u> submitted by Guy Bourgon, Program manager, Infrastructure Approvals West of City of Ottawa dated October 21, 2008;
- a letter dated October 9, 2008 and a letter date November 24, 2008 from Peter Spal, P.Eng., Manager - Water Resources of IBI Group, to the Ministry of the Environment;
- 3. *Kanata Lakes North Serviceability Study* dated June 2006 and prepared by IBI Group, including enclosed drawings dated June 15, 2006 by IBI Group and Cumming Cockburn Ltd.;
- 4. *Kanata Lakes, Beaver Pond, Urban Stormwater quality Control,* dated November 1994, prepared by Cumming Cockburn Ltd;
- 5. *Kanata Lakes Dam & Outlet Structure Operation & Maintenance Manual* dated April 1990, prepared by Oliver, Mangione, McCalla & Associates Limited, Consulting Engineers; and
- 6. *Kanata Lakes Storm Drainage Report Campeau Corporation* dated March 1985, prepared by Oliver, Mangione, McCalla & Associates Limited, Consulting Engineers.

For the purpose of this Certificate of Approval and the terms and conditions specified below, the following definitions apply:

- 1. "*Certificate* " means this entire certificate of approval document, issued in accordance with Section 53 of the <u>Ontario Water Resources Act</u>, and includes any schedules;
- 2. "*Director* " means any *Ministry* employee appointed by the Minister pursuant to section 5 of the <u>Ontario</u> Water Resources Act;
- 3. "District Manager " means the District Manager of the Ottawa District Office of the Ministry ;
- 4. "*Ministry*" means the Ontario Ministry of the Environment;
- 5. "Owner " means City of Ottawa and includes its successors and assignees;
- 6. "*Works* " means the sewage works described in the *Owner* 's application, this *Certificate* and in the supporting documentation referred to herein, to the extent approved by this *Certificate*.

You are hereby notified that this approval is issued to you subject to the terms and conditions outlined below:

TERMS AND CONDITIONS

I. <u>GENERAL PROVISIONS</u>

- (1) Except as otherwise provided by these Conditions, the *Owner* shall design, build, install, operate and maintain the *Works* in accordance with the description given in this *Certificate*, the application for approval of the works and the submitted supporting documents and plans and specifications as listed in this *Certificate*.
- (2) Where there is a conflict between a provision of any submitted document referred to in this *Certificate* and the Conditions of this *Certificate*, the Conditions in this *Certificate* shall take precedence, and where there is a conflict between the listed submitted documents, the document bearing the most recent date shall prevail.
- (3) Where there is a conflict between the listed submitted documents, and the application, the application shall take precedence unless it is clear that the purpose of the document was to amend the application.

2. <u>EXPIRY OF APPROVAL</u>

The approval issued by this *Certificate* will cease to apply to those parts of the *Works* which have not been constructed within five (5) years of the date of this *Certificate*.

3. <u>CHANGE OF OWNER</u>

The Owner shall notify the District Manager and the Director, in writing, of any of the following changes within thirty (30) days of the change occurring:

- (a) change of *Owner*;
- (b) change of address of the *Owner*;
- (c) change of partners where the *Owner* is or at any time becomes a partnership, and a copy of the most recent declaration filed under the <u>Business Names Act</u>, R.S.O. 1990, c.B17 shall be included in the notification to the *District Manager*; and
- (d) change of name of the corporation where the Owner is or at any time becomes a corporation, and a copy of the most current information filed under the <u>Corporations</u> <u>Information Act</u>, R.S.O. 1990, c. C39 shall be included in the notification to the *District* Manager.

4. <u>OPERATION AND MAINTENANCE</u>.

(1) The *Owner* shall ensure that the design minimum liquid retention volume(s) is maintained at all times.

- (2) The Owner shall inspect the Works at least once a year and, if necessary, clean and maintain the Works to prevent the excessive buildup of sediments and/or vegetation.
- (3) The *Owner* shall maintain a logbook to record the results of these inspections and any cleaning and maintenance operations undertaken, and shall keep the logbook available for inspection by the *Ministry*. The logbook shall include the following:
 - (a) the name of the Works ; and
 - (b) the date and results of each inspection, maintenance and cleaning, including an estimate of the quantity of any materials removed.

5. <u>RECORD KEEPING</u>

The *Owner* shall retain for a minimum of five (5) years from the date of their creation, all records and information related to or resulting from the operation and maintenance activities required by this *Certificate*.

The reasons for the imposition of these terms and conditions are as follows:

- 1. Condition 1 is imposed to ensure that the *Works* are built and operated in the manner in which they were described for review and upon which approval was granted. This condition is also included to emphasize the precedence of Conditions in the *Certificate* and the practice that the Approval is based on the most current document, if several conflicting documents are submitted for review.
- 2. Condition 2 is included to ensure that, when the *Works* are constructed, the *Works* will meet the standards that apply at the time of construction to ensure the ongoing protection of the environment.
- 3. Condition 3 is included to ensure that the Ministry records are kept accurate and current with respect to approved works and to ensure that subsequent owners of the works are made aware of the certificate and continue to operate the works in compliance with it.
- 4. Condition 4 is included to require that the *Works* be properly operated and maintained such that the environment is protected.
- 5. Condition 5 is included to require that all records are retained for a sufficient time period to adequately evaluate the long-term operation and maintenance of the *Works*.

In accordance with Section 100 of the <u>Ontario Water Resources Act</u>, R.S.O. 1990, Chapter 0.40, as amended, you may by written notice served upon me and the Environmental Review Tribunal within 15 days after receipt of this Notice, require a hearing by the Tribunal. Section 101 of the <u>Ontario Water Resources Act</u> , R.S.O. 1990, Chapter 0.40, provides that the Notice requiring the hearing shall state:

- 1. The portions of the approval or each term or condition in the approval in respect of which the hearing is required, and;
- 2. The grounds on which you intend to rely at the hearing in relation to eachportion appealed.

The Notice should also include:

- 3. The name of the appellant;
- 4. The address of the appellant;
- 5. The Certificate of Approval number;
- 6. The date of the Certificate of Approval;
- 7. The name of the Director;
- 8. The municipality within which the works are located;

And the Notice should be signed and dated by the appellant.

AND

This Notice must be served upon:

The Secretary* Environmental Review Tribunal 655 Bay Street, 15th Floor Toronto, Ontario M5G 1E5

The Director Section 53, *Ontario Water Resources Act* Ministry of the Environment 2 St. Clair Avenue West, Floor 12A Toronto, Ontario M4V 1L5

* Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 314-4600, Fax: (416) 314-4506 or www.ert.gov.on.ca

The above noted sewage works are approved under Section 53 of the Ontario Water Resources Act.

DATED AT TORONTO this 26th day of November, 2008



NH/

c: District Manager, MOE Ottawa District Office Lance Erion, P.Eng., IBI Group

Wurner &

Mansoor Mahmood, P.Eng. Director Section 53, Ontario Water Resources Act

Appendix D9

E-mail Correspondance – Maintenance

Riley McGee

Christa Jones <cjones@urbandale.com></cjones@urbandale.com>
Monday, February 25, 2019 10:12 AM
Annie Williams
Riley McGee; Roger Tuttle; Marcel Denomme
RE: 5100 Kanata Ave - City Comments

Hi Annie,

Roger will be getting information from JRP for points C8 and C14.

As for C11, Urbandale, as the owner will be taking responsibility for the roof drain and ICD maintenance.

For point C17, Urbandale will arrange to have the snow removed from site.

Thank you,

Christa Jones Land Development Coordinator T: 613-731-6331 ext. 1240

F: 613-731-9226



2193 Arch Street Ottawa, Ontario K1G2H5 <u>www.urbandale.com</u>

From: Annie Williams <awilliams@jlrichards.ca> Sent: Wednesday, February 20, 2019 10:57 AM To: Christa Jones <cjones@urbandale.com> Cc: Riley McGee <rmcgee@jlrichards.ca> Subject: 5100 Kanata Ave - City Comments

Hi Christa,

As discussed, here are the City comments for which we require confirmation (see below and attached):

- C8. Letter to confirm that the sprinkler systems will satisfy all of the requirements of Item 3 from Part II of the FUS Guidelines.
- C11. Confirmation that the site owner will be responsible for roof drain and ICD maintenance (to be clear from any obstructions). An email confirmation may be enough for this one.
- C14. Memo signed and sealed by a Professional Engineer to confirm that the roof system (flow control drains, scuppers, etc) will be designed in accordance with the OBC.
- > C17. Confirm if there will be snow storage on site? Or is snow to be removed off site?

Let me know if you have any questions regarding the above.

Thank you,

Annie Williams, EIT Civil Engineering Intern

J.L. Richards & Associates Limited 700 - 1565 Carling Avenue, Ottawa, ON K1Z 8R1 Tel: 613-728-3571 Fax: 613-728-6012





Drawings



23000\23405-003.1 - KNL Commercial Block 111 (South Portion)\JLR I

		WATERMAIN 1	FABLE-Sta. 1+000.00 T PVC DR-18 CL. 150	O 1+144.	51	
PER CITY OF	SIZE	STATION ALONG WM	DETAIL	FINISHED GRADE	TOP OF WM	Beverpool Park / Graham Beasley Trail
DETAIL SC20.		1+000	200 x 400 TEE CONNECTION TO EXISTING	107.22	104.82	
THE SITE TITS RELATIVE	2	1+009.47 1+014.50	WM CROSSING OVER STORM	107.15	104.75	
EPICTED ON	00mm(1+020.32 1+020.62	VALVE BOX PROPERTY LINE	107.42 107.42	105.02 105.02	
ROXIMITY OF ICH BOX		1+030.00 1+040.39	5° HORIZONTAL BEND	107.16 107.04	104.76 104.64	BUBJECT PROPERTY
NGS. SELECT EXISTING ISED FOR		1+043.19 1+050.00	WM CROSSING OVER STORM	107.02 107.10	104.62 104.70	
ACENT TO A	┢	1+060.92 1+065.00	200x150 REDUCER WM CROSSING OVER STORM	107.28 107.32	104.88 104.92	
W19.		1+065.36 1+065.90	45° VERTICAL BEND 45° VERTICAL BEND	107.33 107.33	104.93 105.52	
TIVE NOT.		1+067.00 1+068.10	WM CROSSING OVER SAN 45° VERTICAL BEND	107.35 107.34	105.52 105.52	
IE IALT NOTES		1+068.44 1+070.00	45° VERTICAL BEND 150 x 150 TEE	107.34 107.28	104.88 104.88	EXISTING CATCH BASIN
	150mn	1+076.69 1+080.63	WM CROSSING OVER STORM 150 x 150 TEE	107.07 107.16	104.67 104.76	CATCH BASIN c/w ICD
	Ø	1+081.63 1+086.35	22.5° HORIZONTAL BEND 5° HORIZONTAL BEND	107.17 107.29	104.77 104.89	CATCH BASIN MAINTENANCE HOLE
A PERMIT TO		1+090.00 1+100.00		107.45 107.31	105.05 104.91	PROPOSED CATCH BASIN LEAD
		1+109.16 1+124.61	HYDRANT, VALVE & VB WM CROSSING OVER STORM	107.44 107.30	105.04 104.90	CURB STOP AND SERVICE POST, VALVE & VALVE BOX AND REDUCER
		1+130.00 1+144.51	150 x 150 TEE	107.30 107.29	104.90 104.89	EXISTING WATERMAIN, VALVE & HYDRANT
		WATERMAIN 1	ABLE-Sta. 2+000.00 T	O 2+082.	51	
	IS		PVC DR-18 CL. 150	FINISHED		
	ZE	2+000.00	150 x 150 TEE	GRADE 107.28	104.88	150mm/0 SAN PROPOSED SANITARY SEWER & MANHOLE 22mm/d SAN EXISTING SANITARY SEWER & MANHOLE
		2+009.00 2+021.08	WM CROSSING OVER STORM 150 x 150 TEE	107.22 107.30	104.82 104.90	PROPOSED TERRACING (MAX 3:1)
~	150r	2+026.73 2+040.00	WM CROSSING OVER CB LEAD	107.22 107.30	104.82 104.90	FF = 107.72FINISHED FLOOR ELEVATIONUSF = 105.92UNDERSIDE OF FOOTING ELEVATION
	nmØ	2+051.68 2+055.00	150 x 150 TEE CURB STOP AND SERVICE POST	107.49 107.61	105.09 105.21	CONCRETE SURFACE
>		2+060.00 2+073.64	45° HORIZONTAL BEND	107.73 107.92	105.33	SIAMESE CONNECTION
		2+079.35 2+082.51	45° HORIZONTAL BEND	107.92	105.52	DC DEPRESSED CURB
		WATERMAIN 1	ABLE-Sta. 3+000.00 T	O 3+072.	40	BUILDING ENTRANCE
	s		PVC DR-18 CL. 150			TEST PIT (PATERSON, JULY 2, 2019)
	IZE	STATION ALONG WM 3+000.00	DETAIL 150 x 150 TEE	GRADE	TOP OF WM 105.09	ROCK TEST PIT (AOV. JAN. 7. 2010)
	203n	3+014.16 3+020.00	WM CROSSING OVER CB LEAD	107.37 107.42	105.11 105.02	
	nmØ &	3+030.00 3+035.04	22.5° HORIZONTAL BEND	107.38	104.98	
	150mm	3+046.06 3+060.00	WM CROSSING OVER CB LEAD	107.59	105.19	
	ø	3+069.89	150 x 150 TEE	107.38	104.98	3 ISSUED FOR TENDER / SITE PLAN SUBMISSION 31/10/1
		WATERMAIN 1	ABLE-Sta. 4+000.00 T	O 4+042.	97	2 ISSUED FOR SITE PLAN SUBMISSION 08/03/1
	SIZE	STATION ALONG WM	DETAIL	FINISHED GRADE	TOP OF WM	1 ISSUED FOR SITE PLAN SUBMISSION 02/05/1
		4+000.00 4+002.18	CONNECTION @ BUILDING B VALVE & VALVE BOX	107.65 107.43	105.25 105.03	No. ISSUE / REVISION DD/MM/
		4+004.18 4+006.05	150 x 150 TEE 45° HORIZONTAL BEND	107.38 107.34	104.98	This drawing is copyright protected and may not be reproduced
		4+008.23 4+009.72	11.25° HORIZONTAL BEND 150 x 150 TEE	107.33	104.93	the express written consent of J.L. Richards & Associates Limited.
	15	4+010.72 4+011.32	VALVE & VALVE BOX 45° VERTICAL BEND	107.27 107.25	104.87 104.85	VERIFY SHEET SIZE AND SCALES. BAR TO THE RIGHT IS 25mm IF THIS IS A FULL SIZE DRAWING. 0 25
	DmmØ	4+011.62 4+012.72	45° VERTICAL BEND	107.24	105.14	SCALE: 1:300
		4+013.82 4+014.12	45° VERTICAL BEND	107.25	105.14	
		4+014.26 4+020.00	WM CROSSING OVER STORM	107.26	104.86	CLIENT: Urbandale Corporatio
/		4+030.00 4+037.65	45° HORIZONTAL BEND	107.68	105.28	2193 Arch Street Ottawa, ON Canada
DN		4+039.69 4+042.97	45° HORIZONTAL BEND	107.60	105.20	K1G 2H5 URBANDALE Tel: 613 737 6331 Fay: 613 731 9226
		WATERMAIN 1	ABLE-Sta. 5+000.00 T	O 5+032.	38	
	s		PVC DR-18 CL. 150		1	
	IZE	STATION ALONG WM 5+000.00	DETAIL 150 x 150 TEE	GRADE 107.16	TOP OF WM 104.76	- II Richards
		5+001.00 5+001.60	VALVE & VALVE BOX	107.14	104.74	
	1:	5+001.90 5+003.00	45° VERTICAL BEND	107.13	105.40	CONSULTANT:
	50mm@	5+004.10 5+004 44	45° VERTICAL BEND	107.20	105.40	\exists
	「	5+004.50 5+026.80	WM CROSSING OVER ST	107.21	104.81	
0		5+029.38 5+030.38		107.55	105.15	
ODO PVC DIC		WATERMAIN 1	ABLE-Sta. 6+000.00 T	O 6+012.	00	PROFESSIONAL STAMP PROJECT NORTH
200	<u>s</u>		PVC DR-18 CL. 150	FINISHED	TOP CT	OROFESSIONE
	ZE	STATION ALONG WM 6+000.00	DETAIL CONNECTION @ BUILDING E	GRADE 107.52	TOP OF WM 105.12	- Selling St
		6+007.00 6+008.50	WM CROSSING OVER STORM 45° VERTICAL BEND	107.34 107.34	104.94 104.94	M. N. L. DALRYMPLE
	5	6+008.00 6+009.00	45° VERTICAL BEND	107.34 107.33	105.59	
	JmmØ	6+010.00 6+010.53	45° VERTICAL BEND	107.32	105.59	UNCE OF ONT
		6+011.00 6+012.00	CURB STOP AND SERVICE POST	107.31	104.91	PROJECT:
		01012.00		107.50	104.30	
						COMMERCIAL PLAZA
× × × × × × × × × × × × × × × × × × ×						5100 KANATA AVE.
× × × × × × × × × × × × × × × × × × ×						
× * * * * * * * * * * * * * * * * * * *						
3572 G 106.95	* * * * * *					SITE SERVICING PLAN
v 104.53						
× × × × × × × × × × × × × × × × × × ×						DESIGN: JW
× × × × × × × × × × × × × × × × × × ×	/					DRAWN: CJM DRAWING #:
						JLR #: 22405 000 4
						23405-003.1










www.jlrichards.ca

Ottawa

864 Lady Ellen Place Ottawa ON Canada K1Z 5M2 Tel: 613 728-3571

ottawa@jlrichards.ca

North Bay

200-175 Progress Road North Bay ON Canada P1A 0B8 Tel: 705 495-7597

northbay@jlrichards.ca

Kingston

203-863 Princess Street Kingston ON Canada K7L 5N4 Tel: 613 544-1424

kingston@jlrichards.ca

Hawkesbury

326 Bertha Street Hawkesbury ON Canada K6A 2A8 Tel: 613 632-0287

hawkesbury@jlrichards.ca

Sudbury

314 Countryside Drive Sudbury ON Canada P3E 6G2 Tel: 705 522-8174

sudbury@jlrichards.ca

Guelph

107-450 Speedvale Ave. West Guelph ON Canada N1H 7Y6 Tel: 519 763-0713



guelph@jlrichards.ca

Timmins

201-150 Algonquin Blvd. East Timmins ON Canada P4N 1A7 Tel: 705 360-1899 timmins@jlrichards.ca