



January 20, 2020

City of Ottawa
Development Review West
Planning Infrastructure + Economic Development Department

Attention: Colette Gorni

**Re: 1140 Terry Fox Drive
Kanata, Ottawa
File #D07-12-19-0193
Plan #18066
Our Reference #19-000-198**

Dear Ms. Gorni;

In regards to the Site Plan Control Approval Application, we advise that the site lighting has been installed at the above mentioned Site Development and meets the following criteria:

- Lighting has been designed using Full Cut-Off (Sharp cut-off) Classification as recognized by IESNA or IES.
- Lighting has been designed to minimize lighting spillage onto adjacent properties as much as possible, within max. at 0.5FC allowable as per City guideline.

Yours very truly,

HAMMERSCHLAG & JOFFE INC.

Mark Hammerschlag, P.Eng.
/sa

