

Engineers, Planners & Landscape Architects

#### Engineering

Land / Site Development

Municipal Infrastructure

Environmental / Water Resources

Traffic / Transportation

Structural

Recreational

#### Planning

Land / Site Development

Planning Application Management

Municipal Planning Documents & Studies

Expert Witness (OMB)

Wireless Industry

# Landscape

Architecture

Urban Design & Streetscapes

Open Space, Parks & Recreation Planning

Community & Residential Developments

Commercial & Institutional Sites

Environmental Restoration



# PROJECT PYTHON 222 CITIGATE DRIVE

# Servicing and Stormwater Management Report

# **PROJECT PYTHON**

222 CITIGATE DRIVE OTTAWA, ONTARIO

# SERVICING AND STORMWATER MANAGEMENT REPORT

Prepared By:

NOVATECH Suite 200, 240 Michael Cowpland Drive Ottawa, Ontario K2M 1P6

Issued: April 9, 2020

Revised: June 1, 2020

Novatech File: 120025 Report Ref: R-2020-044



June 1, 2020

City of Ottawa Planning Infrastructure and Economic Development Department 110 Laurier Avenue West, 4th Floor Ottawa, ON K1P 1J1

#### Attention: Jeffrey Shillington

#### Reference: 222 CitiGate Drive, Ottawa Servicing and Stormwater Management Report Novatech File No.: 120025

Please find enclosed the 'Servicing and Stormwater Management Report' for the above noted project. This report has been revised per City comments in support of the Site Plan Application and is hereby resubmitted for review and approval.

Should you have any questions or comments, please do not hesitate to contact us.

Sincerely,

NOVATECH

Lee Sheets, C.E.T. Director | Land Development & Public Sector Engineering

CC:

M:\2020\120025\DATA\REPORTS\SERV & SWM\REVISED PER CITY COMMENTS NO. 1\120025\SERVICING AND SWM REPORT.DOCX

# TABLE OF CONTENTS

1.0	INTRODUCTION	3
1.1 1.2 1.3 1.4	Existing Conditions Proposed Development Site Design and Constraints Background Reports	3 3 3 4
2.0	WATER SERVICING	4
2.1 2.2 2 2.3	Existing Water Services Proposed Water Servicing 2.1 Proposed Development Domestic Water Demands 2.2 Proposed Development Fire Protection System Boundary Conditions and Hydraulic Analysis	4 4 5 5 6
3.0	SANITARY SERVICING	7
3.1 3.2 3.3	Existing Sanitary Services Proposed Sanitary Services 2.2.1 Proposed Peak Sanitary Flows CitiGate Sanitary Flow Allotment	7 8 <i>8</i> 8
4.0	STORM SERVICING AND STORMWATER MANAGEMENT	9
4.0 4.1 4.2 4 4.3 4 4.4 4.4 4.4 4 4 4 4	STORM SERVICING AND STORMWATER MANAGEMENT         Existing Off-Site Storm Infrastructure – CitiGate (Phase 1)         Stormwater Management Criteria         2.1 Stormwater Quality Control         2.2 Stormwater Quantity Control – Allowable Release Rate         Proposed On-Site Storm Infrastructure         3.1 Storm Sewer Sizing Criteria         3.2 Overland Flow Sizing Criteria         3.3 Temperature Mitigation         Stormwater Management Modeling         4.1 Design Storms         4.2 Model Development         4.3 Model Results         4.4 Future Development Area	<b>9</b> 10 10 11 12 12 12 13 15 18
4.0 4.1 4.2 4 4.3 4 4.4 4.4 4.4 5.0	STORM SERVICING AND STORMWATER MANAGEMENT         Existing Off-Site Storm Infrastructure – CitiGate (Phase 1)         Stormwater Management Criteria         2.1 Stormwater Quality Control         2.2 Stormwater Quantity Control – Allowable Release Rate         Proposed On-Site Storm Infrastructure         3.1 Storm Sewer Sizing Criteria         3.2 Overland Flow Sizing Criteria         3.3 Temperature Mitigation         Stormwater Management Modeling         4.1 Design Storms         4.2 Model Development         4.3 Model Results         4.4 Future Development Area         EROSION AND SEDIMENT CONTROL	<b>9</b> 10 10 11 12 12 12 13 15 18
4.0 4.1 4.2 4 4.3 4 4.4 4.4 4.4 5.0 6.0	STORM SERVICING AND STORMWATER MANAGEMENT         Existing Off-Site Storm Infrastructure – CitiGate (Phase 1).         Stormwater Management Criteria         2.1 Stormwater Quality Control.         2.2 Stormwater Quantity Control – Allowable Release Rate         Proposed On-Site Storm Infrastructure         3.1 Storm Sewer Sizing Criteria         3.2 Overland Flow Sizing Criteria         3.3 Temperature Mitigation         Stormwater Management Modeling         4.1 Design Storms         4.2 Model Development         4.3 Model Results         4.4 Future Development Area         EROSION AND SEDIMENT CONTROL         1         CONCLUSIONS AND RECOMMENDATIONS	<b>9</b> 10 10 11 12 12 13 15 18 19

## LIST OF TABLES

- Table 2.1: Domestic Water Demand Summary
- Table 2.2: Boundary Condition Water Demand Summary
- Table 2.3: Boundary Condition Summary
- Table 3.1: Peak Sanitary Flow Summary
- Table 3.2: Sanitary Flow Allotment Summary
- Table 4.1: Storm Sewer Design Parameters
- Table 4.2: Subcatchment Parameters
- Table 4.3: Required (100-year) and Provided Storage Volumes
- Table 4.4: Summary of Peak Flows
- Table 4.5: Estimated Hydraulic Grade Line (HGL) Elevations

#### **LIST OF FIGURES**

- Figure 1 Key Plan
- Figure 2 Existing Conditions Site
- Figure 3 Existing Conditions Overall
- Figure 4 Proposed Site Plan
- Figure 5 Existing Water Servicing
- Figure 6 Existing Sanitary Servicing
- Figure 7 Existing Storm Servicing

#### LIST OF APPENDICIES

- Appendix A Water Servicing Information
- Appendix B Sanitary Servicing Information
- Appendix C Storm Servicing Information
- Appendix D Stormwater Management Modeling
- Appendix E Development Servicing Study Checklist
- Appendix F Drawings

## LIST OF DRAWINGS (enclosed)

Sanitary Drainage Area Plan	(120025-SAN)
Storm Sewer Drainage Area Plan	(120025-STM)
Stormwater Management Drainage Area Plan	(120025-SWM)

#### LIST OF DRAWINGS (separate)

Cover Page	
Notes and Details	(120025-ND)
General Plan of Services	(120025-GP, GP1, GP2, GP3, GP4)
Grading Plan	(120025-GR, GR1, GR2, GR3, GR4)
Erosion Sediment Control Plan	(120025-ESC)

#### ENCLOSED CD

- Report (pdf)
- Drawings (pdf)
- PCSWMM Packaged Model Files
  - 100-year 3-hour Chicago Storm

#### 1.0 INTRODUCTION

Novatech has been retained to prepare a Servicing and Stormwater Management Report for the proposed development located at 222 CitiGate Drive within Ottawa, Ontario. This report will support a Site Plan Application for the proposed development. **Figure 1** is a Key Plan showing the site location.

This report outlines the site sanitary and water servicing, along with the proposed storm drainage and stormwater management strategy for the proposed development.

#### **1.1 Existing Conditions**

The total site area is approximately 26.0 hectares in size and is located within the CitiGate Development southeast of the Highway 416 and Fallowfield Road interchange. The site is registered as Block 13 on the registered Plan 4M-1538 of the CitiGate Development and has a municipal address of 222 CitiGate Drive. The site is bounded by Fallowfield Drive to the north, the O'Keefe Municipal Drain and the future CitiGate Drive extension to the East, vacant land to the South, and Highway 416 to the west. The topography of the site slopes easterly towards the O'Keefe Municipal Drain and the future CitiGate Drive extension. **Figure 2** shows the existing site conditions and **Figure 3** shows the subject site with respect to the surrounding areas.

It should be noted that the CitiGate Drive extension has received City of Ottawa approval and the works will be constructed prior to the occupancy of this proposed development. The scope of work is for the construction of Systemhouse Street and CitiGate Drive extensions including the underground watermain and storm sewer infrastructure. For the purposes of this report the watermain and storm sewer extensions in CiteGate Drive and Systemhouse Street will be considered as existing.

#### 1.2 Proposed Development

The proposed development consists of a single prestige office/light industrial building, truck and trailer parking and staff parking lots which will cover approximately 23.5 hectares of the 26.0 hectare site. The remaining 2.5 hectares will remain vacant for the time being with the potential of a future development. Access to the site would be provided by 4 separate entrances, two from CitiGate Drive and two from the proposed private roadway extension. **Figure 4** shows the proposed development.

It should be noted that this report should be read in conjunction with the engineering drawing set:

120025-ND	Notes and Details
120025-GP	General Plan of Services
120025-GR	Grading Plan
120025-ESC	Erosion Sediment Control Plan

#### 1.3 Site Design and Constraints

As indicated previously the subject site is part of the CitiGate Development. Design criteria and information for the CitiGate Development is provided in a report entitled '*CitiGate 416 Corporate Campus, Detailed Servicing and Stormwater Management Report (Phase 1)*' prepared by Novatech, dated October 1, 2014 (CitiGate Phase 1 Report). The CitiGate Phase 1 Report provides design criteria for the interior sites and designed the overall servicing systems including sanitary sewers, watermain and stormwater management systems. Each system is discussed in more detail in the appropriate sections of this report.







CHT11Y17 DIMC \_ 970mmYA29mm



CUT11V17 NIM2 - 970mm YA29mm

TECH	PROJECT PYTHON CITIGATE DRIVE
Landscape Architects ael Cowpland Drive Canada K2M 1P6	PROPOSED SITE PLAN
(613) 254-9643 (613) 254-5867	SCALE 1:2500° 25 50 75 100
w.novatech-eng.com	JUNE 2020 JOB 120025 FIGURE FIG-4

A geotechnical investigation was completed for the subject development and a report provided entitled '*Geotechnical Investigation, Proposed Python Building Complex, CitiGate Drive,* Ottawa, Ontario' prepared by Paterson Group dated March 30, 2020. The following criteria is to be included in the servicing and grading design:

- Groundwater level is estimated to be between 3 to 4 meters below existing grade.
- Bedrock elevation fluctuates over the site and is estimated between 0 to 15 meters below existing grade.
- The report also provides detailed asphalt and concrete compositions along with pipe bedding and foundation cover requirements for the site.
- There is a recommended permissible grade raise restriction for this site of 2 to 3 meters for the access roadways and parking areas on the east side of the proposed building.
- A preloading program for 8 to 12 months should be implemented to eliminate all post construction settlement.
- It should also be noted that an MECP permit to take water category 3 may be required if more than 400,000 L/day of ground and/or surface water is to be pumped during construction.

#### 1.4 Background Reports

This report provides information on the considerations and approach by which Novatech has designed and evaluated the proposed servicing and stormwater management strategies. This report should be read in conjunction with the following:

- CitiGate 416 Corporate Campus Detailed Servicing and Stormwater Management Report (Phase1), prepared by Novatech revised dated October 1, 2014.
- Geotechnical Investigation, Proposed Python Building Complex, CitiGate Drive, Ottawa, ON, prepared by Paterson Group dated March 30,2020.

## 2.0 WATER SERVICING

#### 2.1 Existing Water Services

There is an existing 200mm diameter watermain in CitiGate Drive and a 250mm diameter watermain in Crosskey Place that were constructed as part of the Phase 1 CitiGate development. This watermain infrastructure currently terminates at the extents of the CitiGate Drive and Crosskey Place round-a-bout right-of-way limits. There is also an existing 250mm diameter watermain in Systemhouse Street which is capped on the west side of the realigned O'Keefe drain. Each watermain described is connected to the existing 400mm diameter watermain in Strandherd Drive.

As previously mentioned, the existing 250mm diameter watermain in CitiGate Drive is to extend from its termination point at the round-a-bout to the capped 250mm watermain in Systemhouse Street. For the purposes of this report the 250mm diameter watermain extension in CitiGate Drive will be referred to as existing. Refer to **Figure 5** Existing Water Servicing for more details.

#### 2.2 Proposed Water Servicing

It is proposed to service the development by constructing approximately 320 meters of 250mm diameter private watermain on site. The private watermain on site will provide service to both the



100mm diameter domestic building service connection and the fire suppression system water storage tank. The proposed 250mm diameter watermain on site will connect to the existing 250mm watermain in CitiGate Drive near the south east corner of the site. As per the City of Ottawa Technical Bulletin ISDTB-2014-02, the proposed development will require two service connections as the average day demand is greater than 50 cubic meters of water. The two services will be separated by an isolation valve on the existing watermain system in the event maintenance on the system is required. A water meter chamber will be required on the private watermain near the property line due to the large quantity of pipe and the potential for leakage. Refer to the General Plan of Services (120025-GP) for water servicing details.

# 2.2.1 Proposed Development Domestic Water Demands

Design Criteria from the City of Ottawa Water Distribution Guidelines and Section 8 of the Ontario Building Code were used to calculate the theoretical water demands for proposed development. The demand calculations are based on flow requirements for the proposed different uses on site.

The water demand calculations for the proposed development are calculated based on the following criteria:

- Industrial Water Demand
  - per each water closet = 950L/day
  - per each loading bay = 150L/day (each)
- Commercial Office Water Demand
  - per each  $9.3m^2$  floor space = 75L/day
- Peaking Factor
  - Max Day = 1.5
  - Peak Hour = 1.8

The domestic water demands for the proposed development are summarized in Table 2.1 below.

ary
1

Use	Ave. Daily Demand (L/s)	Max. Daily Demand (L/s)	Peak Hour Demand (L/s)
Industrial Flows	1.197	1.795	3.231
Commercial Flows	0.146	0.218	0.393
Total Domestic Demands	1.34	2.01	3.62

# 2.2.2 Proposed Development Fire Protection System

The fire flow calculations and fire protection system for this type of development are complex so Civelec Consulting Inc. a specialized fire consulting engineer was retained. They have calculated the required fire flow for the development to be 1750 USGPM. Civelec has also designed the fire protection infrastructure on site which includes the following:

• The proposed 250mm diameter watermain on site provides water to drive fire pump and provides water as required to fill the 950,000-liter fire suppression water storage tank which provides water to the standby fire pump.

- Two internal fire pump rooms in the southwest corner of the building contains 2 pumps which draw water from the city watermain and from fire suppression storage tank to pressurize the system and to control the fire as required.
- There are approximately 1140 meters of 250mm diameter high pressure fire protection watermain that loops around the building.
- There are eight proposed fire hydrants evenly spaced around the proposed building that are directly connected to the high pressure watermain loop.
- There are multiple connections to the building from the fire loop which supply the internal sprinkler system.
- There are 2 fire hydrants located next to the pump rooms and are connected to the city incoming feed main to allow the firefighter to properly use the siamese connections.

## 2.3 Boundary Conditions and Hydraulic Analysis

The latest boundary conditions are specific to the block 13 connection points on the 250mm diameter watermain in CitiGate Drive. These boundary conditions were based on the updated total domestic demands for the northern portion of the Citi Gate development (including block 13) and fire flows for block 13. The boundary condition domestic demands are calculated from more conservative general land use demands and fire underwriter survey. The boundary condition water demands were calculated using the following criteria provided in Section 4 of City of Ottawa Design Guidelines – Water Distribution:

- Light Industrial Water Demand = 35,000L/ha/day
- Peaking Factor
  - Max Day = 1.5; Peak Hour = 1.8
- Fire Flows = Fire Underwriters Survey

The boundary condition water demands for the Citi Gate development are summarized below in **Table 2.3.** The demand from node 36 is the total allotment for block 13.

Model Node ID	Block No.	Fire Flow (L/s)	Avg Day (L/s)	Max Day (L/s)	Peak Hour (L/s)
14	16	N/A	1.01	1.52	2.73
15	1	N/A	1.42	2.13	3.83
16	2	N/A	4.86	7.29	13.13
17	3	N/A	2.15	3.22	5.80
36	13	267	10.17	15.25	27.45
			19.61	29.41	52.94

Table 2.2. Boundary	Condition	Water	Demand	Summary
Table Z.Z. Doullual		vvaler	Demanu	Summary

The latest boundary conditions provide system pressures and head based on the ground elevation at the site connection locations for three theoretical conditions:

- 1. High Pressure check under Average Day conditions
- 2. Peak Hour demand
- 3. Maximum Day + Fire Flow demand.

A summary of the boundary condition results are provided below in **Table 2.3**.

Condition	Service Connection	Min/Max Allowable Operating	Operating (p	Pressures si)
	Location Pressures (psi)		Connection 1	Connection 2
High Pressure	CitiGate Dr	80psi (Max)	77.1	78.1
Max Day + Fire Flow	CitiGate Dr	20psi (Min)	59.3	52.7
Peak Hour	CitiGate Dr	40psi (Min)	71.1	72.0

Table 2.3: Boundary Condition Summary

The theoretical domestic water demand and fire flows calculated based on the specific building use are much lower than the flows accounted for in the latest boundary conditions and the Citi Gate watermain design. The flows accounted for in CitiGate design are conservative and would allow for future development on site. Based on the latest boundary conditions the watermain infrastructure in CitiGate Drive can provide adequate pressures for domestic use and flows for fire protection. Refer to **Appendix A** for water demand, fire flow calculations, watermain schematics, boundary conditions and the fire protection study information.

## 3.0 SANITARY SERVICING

## 3.1 Existing Sanitary Services

There is an existing 300mm diameter sanitary sewer fronting the site in CitiGate Drive that was constructed as part of the Phase 1 CitiGate development. The conveyance of the existing sanitary sewer is as follows:

- Sanitary flows for this portion of the CitiGate development are conveyed south on CitiGate Drive and east on Systemhouse Street via a 300mm diameter sewer.
- The 300mm diameter sewer then connects to a 525mm diameter sewer in Strandherd Drive where flows are conveyed south to an interim pump station at the corner of Strandherd Drive and Dealership Drive.
- The pump station conveys flows in the interim condition to a gravity sewer which outlets to the Tartan Pump Station.
- In the ultimate condition sanitary flows from the development will be conveyed by the 300mm sewer in CitiGate Drive and Systemhouse Street to the South Nepean Collector Trunk sewer in Strandherd Drive.

Refer to **Figure 6** Existing Sanitary Servicing for more details.



## 3.2 Proposed Sanitary Services

It is proposed to service the development by constructing approximately 775m of 250mm diameter private sanitary sewer on site. The proposed 250mm diameter sewer will outlet to the existing 300mm diameter sanitary sewer in CitiGate Drive at the far south east corner of the site as recommended in the CitiGate Phase 1 Report. Refer to the General Plan of Services (120025-GP) for details.

# 3.2.1 Proposed Peak Sanitary Flows

The total theoretical peak sanitary flow for the proposed development was calculated based on the following criteria from Section 4 of the City of Ottawa Sewer Design Guidelines and Section 8 of the Ontario Building Code:

- Site Area Block 13 = 25.9ha
- Industrial Sanitary Flow
  - per each water closet = 950L/day
  - per each loading bay = 150L/day (each)
- Commercia Office Sanitary Flow
  - $\circ$  per each 9.3m<sup>2</sup> floor space = 75L/day
- Commercial Peaking Factor = 1.5
- Light Industrial Peaking Factor = 3.5 (Appendix 4-B)
- Infiltration Rate = 0.33L/s/ha

The proposed sanitary flows are summarized below in Table 3.1.

#### Table 3.1: Peak Sanitary Flow Summary

Proposed Use	Peak Flow (L/s)
Industrial Flows	4.19
Commercial Flows	0.29
Sewer Infiltration Flow	7.56
Total Peak Flows	12.04
Future Commercial Development Flows	1.47
Sewer Infiltration Flows	1.00
Total Additional Future Peak Flows	2.47
Total Development Peak Flows	14.51

## 3.3 CitiGate Sanitary Flow Allotment

The proposed development block 13 was originally designed as block 14 and 15 in the original CitiGate Phase 1 report. The sanitary flow allotment for each block was calculated in CitiGate Phase 1 report using the following criteria provided in Section 4 of City of Ottawa Sewer Design Guidelines:

- Site Area Block 14 = 18.03ha
- Site Area Block 15 = 7.98ha

- Design Sanitary Flow = 50,000L/ha/d (Commercial/Institutional Flow Rate)
- Commercial Peaking Factor =1.5
- Infiltration Rate = 0.28L/s/ha

The sanitary flow allotments are summarized below in **Table 3.2**.

## Table 3.2: Sanitary Flow Allotment Summary

Block No.	Peak Flow (L/s)	Infiltration Flow (L/s)	Total Peak Design Flow (L/s)
Block 14	15.65	5.05	20.70
Block 15	6.93	2.23	9.16
Total Allocation for Block 13	22.58	7.28	29.86

The Sanitary Sewer Design Sheet provided in the CitiGate Phase 1 Report shows the total sanitary flow allotment for the Block 13 development area to be 29.86 L/s. A copy of the sanitary drainage area plans and sanitary sewer design sheet from the CitiGate Phase 1 Report are included in **Appendix B** for reference.

The proposed 250mm diameter sanitary sewer on site has a theoretical capacity of 34.1 L/s at the proposed slope of 0.3%. Therefore, there is adequate capacity in the proposed infrastructure to convey the required peak flow of 14.51 L/s from the site. Also, based on the total flow allotment of 29.86L/s from CitiGate Phase 1 Report there is capacity in the existing infrastructure for the proposed development. Refer to **Appendix B**, for the proposed detailed sanitary flow calculations, sanitary drainage area pans and sanitary sewer design sheets.

# 4.0 STORM SERVICING AND STORMWATER MANAGEMENT

The storm servicing and stormwater management strategy for the site is based on the established criteria in the 2014 CitiGate SWM Report.

## 4.1 Existing Off-Site Storm Infrastructure – CitiGate (Phase 1)

The storm infrastructure servicing the CitiGate (Phase 1) lands includes a stormwater management facility (SWM Facility 'A') and storm sewers with sizes ranging from 1800mm to 1950mm in diameter. The storm sewer system extends from the north outlet to the SWM facility, to the roundabout, along an extension of CitiGate Drive. Currently only the storm infrastructure at the north outlet to the SWM Facility is constructed. The storm sewer will be extended to the roundabout in advance of the development of the site. Refer to **Figure 7** – Existing Storm Servicing.

The CitiGate Drive storm sewer receives drainage from the proposed development, CitiGate Drive storm infrastructure, and existing flows from the Parks lands. The Parks lands are located between the proposed development and the SWM Facility. Flows are currently collected via a ditch-inlet catchbasin (DICB). The future development of the Parks lands will also outlet to the SWM Facility.



The SWM Facility was designed to provide stormwater quality and quantity control before outlettting to the O'Keefe Drain. The facility was sized to accommodate all future development within the tributary drainage area, including Phases 1 & 2, and adjacent lands.

## 4.2 Stormwater Management Criteria

## 4.2.1 Stormwater Quality Control

The existing SWM Facility was sized to provide an Enhanced level of stormwater quality control. The permanent pool and extended detention have been sized to provide 80% long-term removal of total suspended solids (TSS).

The future development blocks identified in the 2014 CitiGate SWM Report were estimated to be 85% impervious. The proposed development, including the future development lands to the north, has a total imperviousness of 79%. The overall drainage area to the pond will remain unchanged due to the proposed development.

## 4.2.2 Stormwater Quantity Control – Allowable Release Rate

The 2014 CitiGate SWM Report included the following stormwater management criteria for the future development blocks that drain to SWM Facility 'A' (lands west of the O'Keefe Drain):

- Allowable release rates and storage requirements for individual sites are to be calculated as follows, based on a runoff coefficient of C=0.80:
  - The 5-year peak flow can be released uncontrolled.
- The maximum release rate is not to exceed 120% of the 5-year peak flow for all storms up to and including the 100-year event.
- Ensure no overland flow for all storms up-to and including the 100-year event.

Based on these release rates, it was anticipated that 100 m<sup>3</sup>/ha of on-site storage would be enough to prevent major system (overland) flows during the 100-year event.

The proposed development will alter the storm servicing layout that was previously approved as part of the CitiGate (Phase 1). For example, the previous storm servicing layout included a storm sewer for a 'ring-road' that encompassed the entire CitiGate lands. The proposed development includes both the future development blocks and future ring-road; therefore, the allowable release rate specified above would not apply in this case.

The allowable release rate for the proposed development was established using the results from the approved Autodesk Storm and Sanitary Analysis (SSA) SWMM model that was built for the CitiGate Phase 1 lands. Report excerpts (model results) are provided in **Appendix C**.

The proposed development will outlet to storm maintenance holes 208 & 214. The 100-year allowable release rate to these nodes is based on the following model results for a 100-year, 3-hour Chicago Storm (critical design storm):

<u>Structure</u>	100-year Allowable Release Rate
Storm MH208	3,413 L/s
Storm MH214	4,586 L/s

Note that the off-site storm sewer was designed to convey the 5-year peak flow and surcharge during larger storm events. The storm sewer can surcharge as there are no basement connections.

#### 4.3 **Proposed On-Site Storm Infrastructure**

The on-site storm sewer and stormwater management system will include storm sewers ranging in size from 450mm to 1350mm in diameter. On-site storage will be provided underground using Stormtech MC-3500 & MC-4500 arch-type storage chambers covered in 50mm ( $D_{50}$ ) clearstone (**Appendix C**). Peak flows will be attenuated to the allowable release rates specified using orifices and flow control structures. The inlet controls at each flow control structures are as follows:

MH01: 600mm (x3) openings within a 2.40m wide weir (top of weir elev. = 97.55m) MH11: 600mm (x3) openings within a 2.40m wide weir (top of weir elev. = 98.45m) MH103: 340mm orifice MH108: 300mm orifice MH118: 108mm orifice

The south storm sewer will include two (2) flow control structures connected in series. This is to utilize all of the pipe storage at the higher elevation; instead of providing all of the storage within the chambers at the lower elevation, near the outlet.

No above ground (i.e. surface storage) is accounted for in the storm servicing design. The 100year peak flow will be attenuated to the allowable release rate via underground storage (at the request of the client). Check valves will be installed within the pipe downstream the flow controls.

Refer to the General Plan of Services (Drawing 120025-GP).

#### 4.3.1 Storm Sewer Sizing Criteria

The storm drainage design is based on the principals of dual drainage (i.e. minor and major system). The on-site storm sewers (i.e. minor system) have been designed based on the criteria outlined in the City of Ottawa Sewer Design Guidelines (October 2012) and associated technical bulletins. The design criteria used in sizing the storm sewers are summarized in **Table 4.1**.

Parameter	Design Criteria
Private Roads	5 Year Return Period
Storm Sewer Design	Rational Method
IDF Rainfall Data	Ottawa Sewer Design Guidelines
Initial Time of Concentration (Tc)	10 min
Minimum Velocity	0.8 m/s
Maximum Velocity	3.0 m/s
Minimum Diameter	250 mm

#### Table 4.1: Storm Sewer Design Parameters

Refer to the storm sewer design sheets provided in **Appendix C** and Storm Drainage Area Plan (Drawing 120025-STM).

## 4.3.2 Overland Flow Sizing Criteria

As previously indicated all flows will be contained underground for all storm events up-to and including the 100-year storm event. Storm events that exceed the 100-year storm will pond on the surface and be conveyed through major system flow pathways. The grading design includes maximum 0.35m of surface ponding before 'spilling' over a high-point. This would happen only in very rare events that exceed the 100-year storm.

Refer to the Grading Plan (Drawing 120025-GR).

#### 4.3.3 Temperature Mitigation

The O'Keefe Drain is considered a cool-cold watercourse, as such on-site lot level thermal mitigation best management practices have been provided for temperature mitigation. The proposed storm drainage and stormwater management design incorporates the use of underground storage. As such there will be no surface ponding. In addition, the use of permeable storage chambers for the stormwater management system provides direct contact between the stormwater and the surrounding soil. This increases the amount of heat transfer to the surrounding soil. This approach is consistent with the recommendations in the 2014 CitiGate SWM Report.

#### 4.4 Stormwater Management Modeling

The *City of Ottawa Sewer Design Guidelines* (October 2012) requires hydrologic / hydraulic modeling for all dual drainage systems. The performance of the proposed storm drainage system for the site was evaluated using the PCSWMM hydrologic / hydraulic model.

The PCSWMM model schematics and 100-year model output data are provided in **Appendix D**. Digital copies of the modeling files and model output for all storm events are provided on the enclosed CD.

## 4.4.1 Design Storms

The hydrologic analysis was completed using the following synthetic design storms that are consistent with the 2014 CitiGate SWM analysis:

- 3-hour Chicago storm distribution
- 12-hour SCS Type II storm distribution

The return periods analyzed include the 5-year & 100-year storm events. The IDF parameters used to generate the design storms were taken from the *City of Ottawa Sewer Design Guidelines* (October 2012).

The 3-hour Chicago distribution generated the highest peak flows for both the minor and major systems and was determined to be the critical storm distribution for the design of the storm drainage system.

The proposed drainage system was also 'stress tested' using a 100-year (+20%) 3-hour Chicago design storm. This design storm has a 20% higher intensity and total volume compared to the 100-year event.

#### 4.4.2 Model Development

The PCSWMM model includes the subcatchment areas to the trunk storm sewer system, the future development area to the north, and the future CitiGate Drive Extension. Individual drainage areas to each inlet have been lumped together to determine the total area to each pipe run. The purpose of the model is to ensure that the proposed storm drainage and stormwater management system adheres to the allowable release rates specified and that there is no surface ponding during the 100-year storm event.

## Infiltration

Infiltration losses for all catchment areas were modeled using Horton's infiltration equation, which defines the infiltration capacity of soil over the duration of a precipitation event using a decay function that ranges from an initial maximum infiltration rate to a minimum rate as the storm progresses. The default values as specified in the City of Ottawa Sewer Design Guidelines were used for all catchments.

Horton's Equation:	Initial infiltration rate:	$f_{o} = 76.2 \text{ mm/hr}$
$f(t) = f_c + (f_o - f_c)e^{-k(t)}$	Final infiltration rate:	f <sub>c</sub> = 13.2 mm/hr
	Decay Coefficient:	k = 4.14/hr

#### Depression Storage

The default values for depression storage in the City of Ottawa were used for all subcatchments.

•	Depression	Storage	(pervious areas)	): 4.67 mr	m
		0	· · · · · · · · · · · · · · · · · · ·		

• Depression Storage (impervious areas): 1.57 mm

The rooftops assumed to provide no depression storage (zero-impervious parameter).

#### Equivalent Width

'Equivalent Width' refers to the width of the sub-catchment flow path. This parameter (Table 5.1) is calculated as described in Section 5.4.5.6 of the City of Ottawa Sewer Design Guidelines. The flow path lengths are shown on the PCSWMM model schematics provided in **Appendix D**.

#### Impervious Values

Runoff coefficients for each subcatchment area were determined based on the proposed site plan. Refer to the Storm Drainage Area Plan (120025-SWM) for details. Percent impervious values were calculated using:

%imp = (C – 0.20) / 0.70

#### Storm Drainage Areas

For modeling purposes, the site has been divided into subcatchments based on the drainage areas tributary to each inlet of the proposed storm sewer system. The subcatchment areas are shown on the Storm Drainage Area Plan (120025-SWM).

The hydrologic modeling parameters for each subcatchment were developed based on the Site Plan (**Figure 3**) and Storm Drainage Area Plan specified above. Subcatchment parameters are provided in **Table 4.2**.

	Catchment	Runoff	Percent	Zero-	Equiv. Width	Average
Area ID	Area	Coefficient	Impervious	Imperv.	(Flow Length)	Slope
	(ha)	(C)	(%)	(%)	(m)	(%)
		Con	trolled Areas			
A-01	0.25	0.65	64.3	0	83 (30)	1.5
A-04	0.10	0.66	65.7	0	100 (10)	1.5
A-06	0.66	0.73	75.7	0	264 (25)	1.5
A-07	1.04	0.81	87.1	0	173 (60)	1.5
A-08	1.05	0.84	91.4	0	162 (65)	1.5
A-09	0.64	0.79	84.3	0	128 (50)	1.5
A-10	0.88	0.86	94.3	0	220 (40)	1.5
A-11	0.04	0.83	90.0	0	40 (10)	1.5
A-12	0.45	0.47	38.6	0	180 (25)	1.5
A-13	0.30	0.63	61.4	0	120 (25)	1.5
A-14a	0.35	0.73	75.7	0	140 (25)	1.5
A-14b	0.07	0.90	100.0	100	35 (20)	1.5
A-15a	0.25	0.87	95.7	0	125 (20)	1.5
A-15b	0.36	0.90	100.0	100	72 (50)	1.5
A-16a	0.82	0.90	100.0	100	103 (80)	1.5
A-16b	0.67	0.90	100.0	100	112 (60)	1.5
A-17a	0.17	0.89	98.6	0	68 (25)	1.5
A-17b	0.25	0.90	100.0	100	63 (40)	1.5
A-18	0.23	0.89	98.6	0	115 (20)	1.5
A-19	0.47	0.67	67.1	0	188 (25)	1.5
A-20	0.23	0.50	42.9	0	77 (30)	1.5
A-21a	0.25	0.66	65.7	0	125 (20)	1.5
A-21b	0.05	0.90	100.0	100	33 (15)	1.5
A-22a	1.16	0.79	84.3	0	193 (60)	1.5
A-22b	0.76	0.90	100.0	100	117 (65)	1.5
A-23a	2.08	0.53	47.1	0	297 (70)	1.5
A-23b	0.65	0.90	100.0	100	81 (80)	1.5
A-24a	1.16	0.69	70.0	0	211 (55)	1.5
A-24b	1.06	0.90	100.0	100	133 (80)	1.5
A-25a	1.11	0.66	65.7	0	222 (50)	1.5
A-25b	0.48	0.90	100.0	100	80 (60)	1.5
A-26a	1.27	0.86	94.3	0	212 (60)	1.5
A-26b	0.66	0.90	100.0	100	94 (70)	1.5
A-27a	1.84	0.67	67.1	0	307 (60)	1.5
A-27b	0.08	0.90	100.0	100	40 (20)	1.5
A-28	0.11	0.63	61.4	0	55 (20)	1.5
TOTAL	22.00	0.76	90.7			
(Controlled)	22.00	0.70	00.7	-	-	-

#### **Table 4.2: Subcatchment Parameters**

Servicing & Stormwater Management Report

Area ID	Catchment Area (ha)	Runoff Coefficient (C)	Percent Impervious (%)	Zero- Imperv. (%)	Equiv. Width (Flow Length) (m)	Average Slope (%)
Uncontrolled / Direct Runoff Areas						
A-02	0.25	0.60	57.1	0	125 (20)	1.5
A-03	0.10	0.55	50.0	0	50 (20)	1.5
A-05	0.18	0.59	55.7	0	90 (20)	1.5
D-01	0.25	0.22	2.9	0	250 (10)	1.5
D-02	0.53	0.39	27.1	0	353 (15)	1.5
D-03	0.04	0.20	0.0	0	80 (5)	1.5
TOTAL (Uncontrolled)	1.35	0.43	32.9	-	-	-
External Drainage Areas						
FUT	2.66	0.80	85.0	50	231 (115)	1.5
CG-DR-EXT	0.52	0.80	85.0	0	14 (375)	1.5
OVERALL	26.53	0.75	78.8	-	-	-

#### 4.4.3 Model Results

The on-site storage and conveyance system requirements were refined using the PCSWMM model. The model was used to ensure that peak flows are controlled to the allowable release rates and ensure that the 100-year hydraulic grade line is contained on-site within the storm sewer system.

#### Storage Requirements

The 2014 CitiGate SWM analysis estimated that 100 m<sup>3</sup>/ha of storage would be sufficient to control the 100-year storm event. The 100-year storm event was to be controlled to a 5-year peak flow that is increased by 20%. Storage was assumed to be provided on the surface.

Per the client request, the 100-year storm is to be confined underground in the proposed storm sewer and stormwater management system. Due to the site configurations / building area the PCSWMM model indicates that the storage required is more than the previously estimated 100 m<sup>3</sup>/ha. The storage required and storage provided in the storm sewers and stormwater management system is shown in **Table 4.3** below.

Storage Node	Drainage	Inlet	Required 100-yr	Provided	Storage Volu	ume (m³)
(MH) ID	Area (ha)	Control Device	Storage Volume* (m <sup>3</sup> )	Storm Sewers	SWM System	TOTAL
		-	South Outlet		-	-
Storage-S01 (MH11)	10.81	600mm (x3) 2.40m Weir	1,298	605	822	1,427
Storage-S02 (MH01)	+4.22	600mm (x3) 2.40m Weir	1,614	342	1,298	1,640
TOTAL (South Outlet)	15.03	-	2,912	947	2,120	3,067
			North Outlet			
Storage-N01 (MH118)	0.72	108mm Orifice	236	17	218	235
Storage-N02 (MH108)	3.76	300mm Orifice	1,120	144	1,054	1,198
Storage-N03 (MH103)	2.30	340mm Orifice	431	84	348	432
Storage-NFUT	2.66	450mm Pipe**	306	-	306**	306**
TOTAL (North Outlet)	9.44	-	2,093	245	1,926	2,171
OVERALL	24.47	-	5,005	1,192	4,046	5,238

#### Table 4.3: Required (100-year) and Provided Storage Volumes

\*Based on PCSWMM Model Results for a 100-year, 3-hour Chicago Storm.

\*\*Theoretical outlet control pipe and provided storage for the future development area (Storage-NFUT).

#### Peak Flows

As shown in **Table 4.4**, the overall release rates from the site (both uncontrolled / controlled) will adhere to the allowable release rates specified in **Section 4.2.2**. Peak flows are controlled at storm MH's 208 & 214. The uncontrolled drainage, including the future CitiGate Drive extension, is accounted for in the overall release rates.

Table 4.4:	Summary	of Peak	Flows
------------	---------	---------	-------

	Allowable	Peak Flow (L/s)			
Outfall	Release Rate (L/s)	External Areas	Uncontrolled Areas	Controlled Areas	Overall (Outfall)
Storm MH208	-	654	124	539	1,289
Storm MH214 (overall)	-	+101 (755)	+73 (197)	+1,742 (2,281)	+1,874 (3,163)
Storm MH208	3,413	842	309	705	1,775
Storm MH214 (overall)	4,586	+198 (1,040)	+209 (518)	+2,674 (3,379)	+2,801 (4,576)

\*Based on PCSWMM Model Results for a 3-hour Chicago Storm; outfall results account for hydrograph timing.

#### Hydraulic Grade Line (HGL)

The PCSWMM model was used to estimate the hydraulic grade line (HGL) elevation of the of the storm sewer system during the 100-year storm event. **Table 4.5** provides a summary of the 100-year HGL elevation at each storm manhole within the proposed development. The model results indicate that the 100-year HGL elevations will be confined within the storm sewer system.

MH ID	Obvert Elevation	T/G Elevation	100-yr HGL Elevation	Surcharge	Clearance from T/G	HGL in Stress Test
	(m)	(m)	(m)	(m)	(m)	(m)
CBMH109	98.42	102.00	100.60	2.18	1.40	101.28
CBMH201	98.87	100.55	99.53	0.66	1.02	100.55
CBMH211	98.25	100.81	99.04	0.80	1.77	100.67
MH01	95.92	99.07	97.53	1.61	1.54	97.90
MH02	96.04	98.37	97.63	1.59	0.74	98.07
MH04	97.93	100.90	98.72	0.79	2.18	99.75
MH05	98.57	101.42	98.96	0.00	2.46	100.10
MH06	96.62	100.60	97.99	1.37	2.61	98.58
MH07	97.70	102.11	98.77	1.07	3.34	99.47
MH08	98.80	102.70	100.30	1.50	2.40	101.12
MH09	99.06	102.38	100.74	1.68	1.64	101.55
MH10A	99.82	102.63	101.61	1.79	1.02	102.45
MH10B	100.55	102.51	101.80	1.25	0.71	102.51
MH101	96.81	98.62	96.52	0.00	2.10	96.86
MH102	97.06	99.85	96.77	0.00	3.08	97.12
MH103	97.27	100.69	99.04	1.77	1.65	100.65
MH104	98.18	101.88	99.41	1.23	2.47	100.74
MH105	98.65	100.60	99.54	0.89	1.06	100.60
MH106	97.22	100.69	96.89	0.00	3.80	97.25
MH107	97.32	100.84	97.00	0.00	3.84	97.34
MH108	97.98	100.94	100.29	2.32	0.65	100.90
MH11	98.29	101.25	99.33	1.04	1.92	100.08
MH110	98.52	102.29	100.66	2.15	1.63	101.36
MH111	100.33	102.73	101.01	0.68	1.72	101.96
MH113	98.78	102.29	100.83	2.05	1.46	101.55
MH114	100.00	102.58	101.43	1.44	1.15	102.29
MH115	100.32	102.24	101.49	1.17	0.75	102.24
MH116	101.68	103.55	101.81	0.13	1.74	102.88
MH117	97.60	99.87	97.40	0.00	2.47	97.80
MH118	97.93	100.03	99.53	1.60	0.50	100.03
MH119	99.30	101.65	99.54	0.24	2.11	100.24
MH12	98.62	101.54	99.97	1.35	1.57	100.62
MH120	102.08	104.32	102.85	0.77	1.47	104.32
MH13	98.87	101.56	100.35	1.48	1.21	100.97
MH14	99.29	101.58	100.96	1.67	0.62	101.50
MH15	99.66	101.57	101.17	1.51	0.40	101.57
MH16	99.98	102.03	101.20	1.22	0.83	101.74

Table 4.5: Estimated H	vdraulic Grade Line (	(HGL) Elevations

\*Based on PCSWMM Model Results for a 3-hour Chicago Storm.

#### Stress Test

**Table 4.5** also provides the estimated HGL elevations for the 'stress test' event. The stress test event represents a 20% increase (rainfall intensity and total precipitation) in the 100-year design event. The 'stress test' event will not be confined within the storm sewer system. Ponding will occur within the parking lot sags and may cascade off-site. The major system overland flow will be diverted through overland pathways and spill off-site to the future CitiGate Drive; ultimately discharging to the O'Keefe Drain.

#### Foundation Drains

The proposed building will be slab-on-grade, consistent with the 2014 CitiGate Report. As such, there are no concerns with the surcharged HGL elevations. The general grade of the site will allow water to pond in the parking lot and overflow downstream before impacting the building, which is at a higher grade. Refer to the Grading Plan (drawing 120025-GR).

#### 4.4.4 Future Development Area

The PCSWMM model includes the 2.66 ha future development area to the north (adjacent Fallowfield Road). This area is represented in the model based on the following:

Drainage Area:2.66 haImperviousness:85% (C=0.80)100-year Allowable Release Rate:842 L/s (approx. 20% increase of 5-year – 654 L/s)Est. On-Site Storage Requirements:306 m³ (115 m³/ha)

The future development of these lands is to adhere to the above release rates. The storage requirements have been estimated as above-ground surface storage in the PCSWMM model.

The 2014 CitiGate SWM Report originally estimated the impervious percentage (85%). This value was used for the future development blocks for the design of the stormwater management facility.

#### 5.0 EROSION AND SEDIMENT CONTROL

Temporary erosion and sediment control measures will be implemented on-site during construction in accordance with the Best Management Practices for Erosion and Sediment Control. This includes the following temporary measures:

- Filter socks (catchbasin inserts) will be placed in existing and proposed catchbasins and catchbasin manholes, and will remain in place until vegetation has been established and construction is completed;
- Silt fencing will be placed along the surrounding construction limits;
- Mud mats will be installed at the site entrances;
- Strawbale or rock check dams will be installed in swales and ditches;
- The contractor will be required to perform regular street sweeping and cleaning as required, to suppress dust and to provide safe and clean roadways adjacent to the construction site;

Erosion and sediment control measures should be inspected daily and after every rain event to determine maintenance, repair or replacement requirements. Sediments or granulars that enter site sewers shall be removed immediately by the contractor. These measures will be implemented prior to the commencement of construction and maintained in good order until

vegetation has been established. Refer to the Erosion and Sediment Control Plan (120025-ESC) for additional information.

#### 6.0 CONCLUSIONS AND RECOMMENDATIONS

#### <u>Watermain</u>

The analysis of the proposed watermain network confirms the following:

- The proposed 250mm diameter watermain that connects to the existing watermain along CitiGate Drive can service the proposed development.
- It is anticipated that there are adequate pressures in the existing watermain infrastructure to meet the required domestic demands for the development.
- It is anticipated that there is adequate flow to service the proposed fire protections system.
- Flows and pressures will be confirmed with an updated hydraulic analysis once the City provides new boundary conditions.

#### Sanitary Servicing

The analysis of the proposed sanitary servicing confirms the following:

- There is adequate capacity within the existing sanitary infrastructure to service the proposed development.
- The existing sanitary allotment would allow for future expansion or development on site.

#### Stormwater Management

The following provides a summary of the storm sewer and stormwater management system:

- Proposed storm sewer system is to connect with the existing storm sewer system on the extension of CitiGate Drive.
  - Storm sewers (minor system) have been designed to convey the uncontrolled 5year peak flow using the Rational Method.
  - Underground storage is be provided within the storm sewers and stormwater management systems, which are to consist of Stormtech MC-3500 / MC-4500 Arch-type Chambers (or approved equivalent).
  - There will be no surface ponding during the 100-year storm event as the 100-year hydraulic grade line (HGL) is contained within the storm sewer system.
- Parking lot graded to ensure that static ponding depths do not exceed 0.35m.
  - Surface ponding would only office for storm events greater than the 100-year event.
  - A major overland flow route is provided to the CitiGate Drive extension and ultimately the O'Keefe Drain.

#### Erosion and Sediment control

• Erosion and sediment control measures (i.e. filter fabric, catchbasin inserts, silt fences, etc.) will be implemented prior to construction and are to remain in place until vegetation is established.

## 7.0 CLOSURE

The preceding report is respectfully submitted for review and approval. Please contact the undersigned should you have questions or require additional information.

#### NOVATECH

Prepared by:



Matt Hrehoriak, P.Eng. Project Coordinator Land Development Engineering

Reviewed by:



Conrad Stang, M.A.Sc., P.Eng. Project Manager Water Resources



J. Lee Sheets, C.E.T. Director Land Development Engineering

# Appendix A

Water Servicing Information



#### **Detailed Building Use Domestic Water Demands**

#### Daily Demands from OBC Table 8.2.1.3

Establishment	Daily Demand Volume		
Industrial Building:	150	L/day/loading bay	
	950	L/day/bathroom	
Commercial Office:	75	L/day/9.3m <sup>2</sup> Floor area	

Commercial / Industrial Peaking Factors City of Ottawa Water Distrubution Guidelines

Conditions	Peaking Factor		
Maximum Day	1.5	x avg day	
Peak Hour	1.8	x max day	

#### Proposed Development Conditions

	Commercial Office	Industrial Building	Totals
Floor Area	1559	N/A	
No. Bathrooms	N/A	100	
No. Loading Bays	N/A	56	
Total Daily Volume (Liters)	12572.6	103400.0	115972.6
Avg Day Demand (L/s)	0.146	1.197	1.34
Max Day Demand (L/s)	0.218	1.795	2.01
Peak Hour Demand (L/s)	0.393	3.231	3.62



SHT11X17.DWG - 279mmX432mm



Table B1 Block 13 Water Demand					
			Demand (L/s)		
Node	Block #	Area (ha)	High Pressure (Average Day)	Max. Daily	Peak Hour
14	16	2.5	1.01	1.52	2.73
15	1	3.5	1.42	2.13	3.83
16	2	12.0	4.86	7.29	13.13
17	3	5.3	2.15	3.22	5.80
36	13	25.1	10.17	15.25	27.45
			19.61	29.41	52.94

#### Notes:

1. All water demand calculations based on the City of Ottawa Design Guidelines for Water Distribution Table 4.2.

2. Water Demand is based assuming all lands to be Industrial - Light with a demand of 35,000L/gross ha/d.

3. Peaking Factors: Maximum Daily Demand = 1.5 Average Daily Demand (High Pressure); Peak Hour = 1.8 Max Daily Demand.

#### Fireflows

Industrial Light Fireflow - Block 13	267	L/s
Industrial Light Fireflow (as per Approved Phase 1 Design Brief	165	L/s
dated Sept. 5, 2014)		

# **FUS - Fire Flow Calculations**

As per 1999 Fire Underwriter's Survey Guidelines

Novatech Project #: 120025 Project Name: Citigate Block 13 Date: 3/18/2020 Input By: Steve Zorgel Reviewed By: MSP



Engineers, Planners & Landscape Architects

Legend Inpu

Input by User No Information or Input Required

Building Description: Building to have 5 floors, sprinklered, exposure is >45m all sides. Fire Resistive Construction

						Total Fire
Step			Choose		Value Used	Flow
						(L/min)
		Base Fire Flow	N			
	Construction Ma	iterial		Mult	iplier	
Coofficient	Coefficient	Wood frame		1.5		
1	related to type	Ordinary construction		1		
-	of construction	Non-combustible construction		0.8	0.6	
	С	Modified Fire resistive construction (2 hrs)	Yes	0.6		
	<b>`</b>	Fire resistive construction (> 3 hrs)		0.6		
	Floor Area		-			
		Building Footprint (m <sup>2</sup> )	37200			
	•	Number of Floors/Storeys	5			
2	~	Protected Openings (1 hr)	Yes			
		Area of structure considered (m <sup>2</sup> )			55,800	
	F	Base fire flow without reductions				31,000
	•	$F = 220 C (A)^{0.5}$				01,000
		Reductions or Surc	harges			
	Occupancy haza	rd reduction or surcharge		Reduction	Surcharge	
		Non-combustible		-25%		
3		Limited combustible		-15%		31,000
, in the second s	(1)	Combustible	Yes	0%	0%	
		Free burning		15%		
		Rapid burning		25%		
	Sprinkler Reduc	tion		Redu	ction	
		Adequately Designed System (NFPA 13)	Yes	-30%	-30%	-15,500
4	(2)	Standard Water Supply	Yes	-10%	-10%	
	(2)	Fully Supervised System	Yes	-10%	-10%	
			Cur	nulative Total	-50%	
	Exposure Surch	arge (cumulative %)			Surcharge	
		North Side	> 45.1m		0%	
E		East Side	> 45.1m		0%	0
5	(3)	South Side	> 45.1m		0%	
		West Side	> 45.1m		0%	
			Cur	nulative Total	0%	
Results						
	Total Required Fire Flow, rounded to nearest 1000L/min				L/min	16,000
6	(1) + (2) + (3)	(2.000 L/min . Fins Flow		or	L/s	267
		(2,000 L/Min < Fire Flow < 45,000 L/Min)		or	USGPM	4,227
	Required Duration of Fire Flow (bours)				35	
7	Storage Volume	Poquired Volume of Fire Flow (notic)			m <sup>3</sup>	3360
		Required volume of File Flow (m)			II) -	3300

# Boundary Conditions 416 Citigate Dr.

## **Provided Information**

<b>O</b> sum and s	Demand		
Scenario	L/min	L/s	
Average Daily Demand	1,177	19.61	
Maximum Daily Demand	1,765	29.41	
Peak Hour	3,176	52.94	
Fire Flow Demand #1	16,020	267.00	

# Location



#### <u>Results</u>

#### Connection 1 – Citigate Dr.

Demand Scenario	Head (m)	Pressure <sup>1</sup> (psi)
Maximum HGL	151.5	77.1
Peak Hour	147.3	71.1
Max Day plus Fire 1	139.0	59.3

<sup>1</sup> Ground Elevation = 97.3 m
#### Connection 2 – Citigate Dr.

Demand Scenario	Head (m)	Pressure <sup>1</sup> (psi)
Maximum HGL	151.5	78.1
Peak Hour	147.3	72.0
Max Day plus Fire 1	133.6	52.7

<sup>1</sup> Ground Elevation = 96.6 m

#### Disclaimer

The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of watermains deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation. Fire Flow analysis is a reflection of available flow in the watermain; there may be additional restrictions that occur between the watermain and the hydrant that the model cannot take into account.

# FIRE PROTECTION STUDY FOR

# **PROJECT PYTHON**

OTTAWA, ONTARIO

ALTERNATIVE SOLUTION FOR EXITING



FIRE PROTECTION STUDY FOR

# **PROJEC PYTHON**

# OTTAWA, ONTARIO

ALTERNATIVE SOLUTION FOR EXITING

Prepared by

Civelec Consultants Inc. 3900 Cote Vertu, suite 200 St. Laurent, Québec H4R 1V4

Paul Lhotsky, PhD, P. Eng.



May 15 2020



1.	Executive Summary	.1
2.	Building Description	.2
3.	Proposed description for Exit Location for typical floors	.3
4.	Code Requirements	.3
5	Code Compliance	.6
6.	Requirements for Alternative Solution	.6
7.	Travel Distance to Exits	.7
7.1	Code requirements and objectives	.7
7.2	Exiting proposal	.9
7.3	Fire modeling and test results	.9
7.4	Exiting study	0
8.	Smoke layer analyses	13
9.	Design and Construction Requirements	13
10.	Conclusion	13
11.	Copyright	4

CODE STUDY	APPENDIX '	"A"	
TIME EXIT CALCUI	LATIONS	APPENDIX "B"	
EXITING PLANS			APPENDIX "C"



#### 1. Executive Summary

- 1.1 The developer is planning to build a semi-automated light industrial sort center. The building will be approximately 58,222 m2 on the ground floor including 3280 m2 of offices. The ground floor will have approximately 25,427 m2 of mezzanines. The building will also have additional 4 levels of robotic sorting platforms each having an area of 45,075 m2. The building is considered 6 storeys high (5 stories and mezzanine that is calculated as a floor in building height). The ground floor will be approximately 8.53 m (28 ft) high with mezzanine levels located at approximately 4.27 m (14 ft) height. The robotic platforms will be 4.27 m (14 ft) high and the top platform roof will be 4.57 m (15 ft) above the platform.
- 1.2 The ground floor and mezzanines will be used for packaging shipping and receiving. This area will have numerous conveyers and automated handling systems. 2nd, 3rd 4th and 5th floors (robotic platforms) will be used for a sorting area and manual picking sector on the perimeter of the building. The merchandise is placed in special pods that are 2.616 m (8 ft 7 in) high. The individual items are located in the pods. The pods are delivered to the picking stations by robots. The individual items are loaded into the pods or removed from the pods. The items are transported to the ground floor by conveyer systems typically in open plastic totes. The pods stationary and delivery area has restricted access and is not occupied during normal operation.
- 1.3 Due to the configuration of the automated system and the equipment, the travel distance to reach an exit exceeds the requirements of the Ontario Building Code article 3.4.2.5 (1).
- 1.4 As the main aisles cannot lead directly to an exit the use of exception (3.4.2.5 (2)) by providing exits at the perimeter of the building cannot be used.
- 1.5 Our alternative solution is to meet the Objectives and Functional Statements that are: to facilitate the timely movement of persons to a safe place in an emergency. An objective is to limit the probability that as a result of design and construction of the building, the person in the building will be exposed to an unacceptable risk of injury due to hazards caused persons being delayed in or impeded from moving to a safe place during an emergency.
- 1.6 We have calculated the time to exit as well as the time it will take for smoke descend to a level of 3m for ground floor, 2<sup>nd</sup>, 3<sup>rd</sup>, 4<sup>th</sup> and 5<sup>th</sup> floor as well as from the platform located on the ground floor. The worst case scenario is exiting from the platform.

Fire starts Sprinkler system is activated Alarm system is activated Evacuation starts time = 0 sec. time = 237 sec (approximately 4 min) time = 267 sec (4 min and 30 sec) time = 567 sec (9 min and 30 sec)



Person reaches exit (221 sec) Smoke reaches 3 m level above platform time = 788 sec (13 min and 08 sec) time = 8,760 sec (2 hr and 26 min)

- 1.7 From the above mentioned calculations we can see that the occupant can exit the building from the platform before the smoke reaches 3 m above the floor level of the platform. Based on travel speed given on Ontario Building Code the time for a person time to exit was calculated at 3 minutes and 25 seconds. The time for the smoke level to descend to 3 m from the floor of the platform was calculated to be 2 hours 12 minutes after the evacuation.
- 1.8 Based on the time travel exit study evacuation, the exiting is considered safe.
- 1.9 For detailed code study see Appendix A.
- 1.10 See detailed calculation sheets Appendix B

# 2. Building Description

- 2.1 The building will be approximately 58,222 m<sup>2</sup> on the ground floor including 3280 m<sup>2</sup> of offices. The ground floor will have approximately 25,427 m<sup>2</sup> of mezzanines. The building will also have additional 4 levels of robotic sorting platforms each having an area of 45,075 m<sup>2</sup>. The building is considered 6 storeys high. The ground floor will be approximately 8.53 m (28 ft) high with mezzanine levels located at approximately 4.27 m (14 ft) height. The robotic platforms will be 4.27 m (14 ft) high and the top platform roof will be 4.57 m (15 ft) above the platform.
- 2.2 The ground floor will be used for packaging shipping and receiving. This area will have numerous conveyers and automated handling systems. 2<sup>nd</sup>, 3<sup>rd</sup>, 4<sup>th</sup> and 5<sup>th</sup> floors will be used for a sorting area and manual picking sector on the perimeter of the building. The merchandize is placed in special pods that are 2.616 m (8 ft 7 in) high. The individual items are stored in the pods. The pods are delivered to the picking stations by robots. The individual items are loaded into the pods or removed from the pods. The items are transported to the ground floor by conveyer systems typically in open plastic totes. The pods sorting and delivery area has restricted access and is not occupied during normal operation.
- 2.3 Typical merchandize consist of combination of class 2, 3, 4 and class A non-expanded cartooned plastics as defined by NFPA 13. Due to the plastic totes and pods, the commodity is classified as exposed non-expanded class A plastics.
- 2.5 The building will be approximately 28.65 m (94 ft) high.



- 2.6 The semi-automated conveyer system will be used for transport of goods. As the actual sorting and conveyer plans are not yet available, we have used plans for a similar use building that are provided in appendix D
- 2.7 See appendix C for plans.
- 2.5 The building will be approximately 28.65 m (94 ft) high.
- 2.6 The semi-automated conveyer system will be used for transport of goods. As the actual layout and conveyer plans are not yet available, we have used two conveyer crossings ant two conveyer gates in the calculations.
- 2.5 See appendix C for plans.

# **3. Proposed description for Exit Location for typical floors**

- 3.1 Exits will be provided so that a travel to an exit will not exceed 45 m from: office area and mechanical rooms.
- 3.2 In the typical floor areas (2, 3, 4 and 5<sup>th</sup> levels) the exact equipment and conveyer layout is not completed, we have used maximum travel distance and 2 stair crossing of the conveyers and 2 gate in the conveyer system. The distance to an exit used is 140 m. When the travel distance is converted travel time to an exit, the maximum exit time is calculated to be 207 seconds (3 min and 27 seconds).
- 3.3 As the alarm system is normally activated by the sprinkler system with a typical delay of 30 sec. and the sprinkler system is calculated to activate 3 minutes after the start of the fire.

# 4. Code Requirements

- 4.1 The OBC 3.4.2.5. states: *Location of Exits* 
  - (1) Except as permitted by Sentences (2), 3.2.8.4.(4) and 3.3.2.4.(13) to (16), if more than one exit is required from a floor area, the exits shall be located so that the travel distance to at least one exit shall be not more than,
    - (a) 25 m in a high hazard industrial occupancy,
    - (b) 40 m in a business and personal services occupancy,
    - (c) 45 m in a floor area that contains an occupancy other than a high hazard industrial occupancy, provided it is sprinklered,



- (d) 105 m in any floor area, served by a public corridor, in which rooms and suites are not separated from the remainder of the floor area by a fire separation, provided,
  - (i) the public corridor is not less than 9 m wide,
  - (ii) the ceiling height in the public corridor is not less than 4 m above all floor surfaces,
  - (iii) the building is sprinklered, and
  - (iv) not more than one-half of the required egress doorways from a room or suite open into the public corridor if the room or suite is required to have more than one egress doorway,
- (e) 60 m in any storage garage that conforms to the
- (f) 30 m in any floor area other than those referred to in requirements of Article 3.2.2.83., and Clauses (a) to (e).
- (2) Except for a high hazard industrial occupancy, Sentence (1) need not apply if exits are placed along the perimeter of the floor area and are not more than 60 m apart, measured along the perimeter, provided each main aisle in the floor area leads directly to an exit.
- (3) Exits shall be located and arranged so that they are clearly visible or their locations are clearly indicated and they are accessible at all times.
- 4.2 Ontario Building Code has a special section that deals with "Shelf and Rack Storage Systems". Even though we do not consider the automated sorting system configuration to be a "Shelf and Rack Storage" the exiting and use is similar.
- 4.3 Ontario Building Code article 3.16.1.7 provides requirements and calculation methods for exiting times from Shelf and Rack Storage System. The article states:
  - 3.16.1.7. Exits and Means of Egress
  - (1) Except as permitted in Sentences (2) and (3), every walkway or platform level shall be provided with no fewer than two exits conforming to Section 3.4.
  - (2) An access to exit from an elevated platform level may be provided by means of open unenclosed stairs serving,
    - (a) not more than four platform levels, the highest of which shall be not more than 12 m above the main floor, where the shelf and rack storage system is intended for the storage of Class I, II, III and IV commodities, as defined in NFPA 13, "Installation of Sprinkler Systems", and



- (b) not more than two platform levels, where the shelf and rack storage system is intended for the storage of Group A, B and C plastics and rubber tires, as defined in NFPA 13, "Installation of Sprinkler Systems".
- (3) Any single platform or walkway in a shelf and rack storage system may be served by a single unenclosed stair leading to the platform or walkway level immediately below provided,
  - (a) the platform or walkway does not exceed 200 m2 in area,
  - (b) the travel distance on the platform or walkway to the level below, including the travel distance along the single unenclosed egress stair, does not exceed 25 m, and
  - (c) the platform or walkway below is provided with two separate egress stairs or exits.
- (4) The maximum travel distance on an elevated platform to the ground floor level, including the travel distance along unenclosed stairs, shall not exceed 45 m.
- (5) The maximum travel distance on an elevated platform to an exit serving that platform shall not exceed 45 m.
- (6) Except as permitted in Sentence (7), the maximum travel distance from the bottom of an unenclosed stair to an exit along a main aisle on the ground floor level shall not exceed 45 m.
- (7) Where the travel distance in Sentence (6) exceeds 45 m,
  - (a) an egress system serving the shelf and rack storage system shall be designed on the basis of a time-based egress analysis using the following criteria:
    - (i) occupant egress speed of 1 m/sec shall be used for horizontal egress routes within the shelf and rack storage system,
    - (ii) occupant egress speed of 0.6 m/sec shall be used for vertical egress routes within the shelf and rack storage system, measured on the diagonal along the nosing of the stairs,
    - (iii) occupant egress speed of 1.3 m/sec shall be used for horizontal egress routes along a main aisle on the ground floor level,
    - (iv) each lift-gate shall be accorded an egress time of 10 seconds,
    - (v) each at-level conveyor cross-over shall be accorded a time of 5 seconds,
    - (vi) a safety factor of 1.5 shall be used in calculating the total egress time,



(b) the total egress time shall be calculated using the following formula: Total Egress Time = (Hp + Vp/0.6 + Hm/1.3 + 10Nlg + 5Nlc) 1.5 (in seconds)

where:

Hp = horizontal travel distance on the shelf and rack storage system, in metres,

- Vp = vertical travel distance on the shelf and rack storage system, in metres,
- Hm = horizontal travel distance on the main floor, in metres,

Nlg = number of lift gates in the means of egress,

Nlc = number of at-level cross overs in the means of egress,

- (c) the total egress time from any point in the shelf and rack storage system shall be a maximum of 4 minutes,
- (d) a fire alarm and detection system conforming to Subsection 3.2.4. shall be installed in the building,
- (e) smoke detectors shall be provided under all solid decking and walkways,

# 5 Code Compliance

- 5.1 The OBC provides two alternatives to comply to the code.
- 5.2 One option is to use the descriptive design of Part B of the OBC and if this part B is used for the design it is assumed that the objectives of Part A of OBC are met.
- 5.3 The second option is to use the objectives and functional statements of the code. The design requires to present an alternative solution with a proof of meeting the objectives of Part A of OBC.

#### 6. **Requirements for Alternative Solution**

- 6.1 The OBC article 1.2.1.1 states: Complience with Division B
  - (1) Complience with Division B shall be achieved,
    - (a) by complying with the applicable acceptance solution in Division B, or
    - (b) by using alternative solutions that will achieve the level of performance required by the applicable acceptable solutions in respect of objectives and functional statements attributed to the acceptable solutions in Supplementary Standard SA-1.
  - (2) For the purposes of Clause (1)(b), the level of performance in respect of functional statement refers to the performance of the functional statements as it relates to the objective with which it is associated in Supplementary Standard SA-1.



Clause A-1.2.1.1.(1)(b) states: "Where a design differs from the acceptable solutions in Division B, then it should be treated as an "alternative solution." A proponent of an alternative solution must demonstrate that the alternative solution addresses the same issues as the applicable acceptable solutions in Division B and their attributed objectives and functional statements. However, because the objectives and functional statements are entirely qualitative, demonstrating compliance with them in isolation is not possible. Therefore, Clause 1.2.1.1.(1)(b) identifies the principle that Division B establishes the quantitative performance targets that alternative solutions must meet. In many cases, these targets are not defined very precisely by the acceptable solutions — certainly far less precisely than would be the case with a true performance code, which would have quantitative performance targets and prescribed methods of performance measurement for all aspects of building performance. Nevertheless, Clause 1.2.1.1.(1)(b) makes it clear that an effort must be made to demonstrate that an alternative solution will perform as well as a design that would satisfy the applicable acceptable solutions in Division B – not "well enough" but "as well as."...

# Applicable Acceptable Solutions

In demonstrating that an alternative solution will perform as well as a design that would satisfy the applicable acceptable solutions in Division B, its evaluation should not be limited to comparison with the acceptable solutions to which an alternative is proposed. It is possible that acceptable solutions elsewhere in the Code also apply. The proposed alternative solution may be shown to perform as well as the most apparent acceptable solutions. For example, an innovative sheathing material may perform adequately as sheathing in a wall system that is braced by other means but may not perform adequately as sheathing in a wall system where the sheathing must provide the structural bracing. All applicable acceptable solutions. "

# 7. Travel Distance to Exits

# 7.1 Code requirements and objectives

- 7.1.1 This alternative solution is to comply with the objectives of Travel Distance Location of Exits 3.4.2.5 of OBC.
- 7.1.2 3.4.2.5. Location of Exits
  - 1) Except as permitted by Sentences (2) and 3.3.2.5.(6), if more than one exit is required from a floor area, the exits shall be located so that the travel distance to at least one exit shall be not more than
    - a) 25 m in a high-hazard industrial occupancy,



- b) 40 m in a business and personal services occupancy,
- c) 45 m in a floor area that contains an occupancy other than a high hazard industrial occupancy, provided it is sprinklered,
- 2) Except for a high-hazard industrial occupancy, Sentence (1) need not apply if exits are placed along the perimeter of the floor area and are not more than 60 m apart, measured along the perimeter, provided each main aisle in the floor area leads directly to an exit.
- 7.1.3 The applicable objectives and functional statements as summarized by the OBC SA-1 table 3 are the following:

3.4.2.:	5. Lo	ocation of Exits
(1)		[F10–OS3.7]

7.1.4 The objectives of the Code are achieved by measures, such as those described in the acceptable solutions in Division B, that are intended to allow the *building* or its elements to perform the following functions:

F10 – To facilitate the timely movement of persons to a safe place in an emergency

7.1.5 [OS3]

An objective of this Code is to limit the probability that, as a result of the design or construction of the building, a person in or adjacent to the building will be exposed to an unacceptable risk of injury due to hazards. The risks of injury due to hazards addressed in this Code are those caused by persons being delayed in or impeded from moving to a safe place during an emergency

- 7.1.6 To summarize the code objectives, the code takes into consideration that a typical fire spread and generated smoke will not adversely affect occupants if they can reach an exit within 45 m for a fire condition when the fire is controlled by sprinklers.
- 7.1.7 As the prescriptive part of the code must cover most of the buildings, and individual evaluation of fire spread and smoke spread is not easily done, the prescriptive code (part B) determines the safe travel distance (this can be converted to a travel time as demonstrated in article 3.16.1.1 of OBC).



7.1.8 To meet the objectives and functional statements associated with article 3.4.2.5 we plan to demonstrate by using fire modeling that the occupants have ample time to exit the building using the proposed exits and not be affected by the smoke or the fire.

# 7.2 Exiting proposal

- 7.2.1 The sprinkler systems in the automated sorting areas are designed using K 25.2 EC sprinklers rated at 165 deg F. This sprinkler system is designed not only to control the fire but to extinguish the fire.
- 7.2.2 To assure minimal fire spread as well as an audibility of the fire alarm system, upon activation of any fire alarm, the automated sorting system, conveyer system and the ventilation fans will shut down.
- 7.2.3 To assure proper operation of the sprinkler system smoke extraction is not recommended.

# 7.3 Fire modeling and test results

- 7.3.1 We have used a fire that follows exponential growth for a fast fire following  $\alpha t^2$ . The maximum temperature and velocity was calculated using Alpert's Correlations for celling jets. The activation of sprinklers was simulated by convective heating and using the sprinkler RTI. We have used buoyant plume model for calculation of total upward mass flow.
- 7.3.2 In our calculations we have calculated total upward mass (smoke) generated by the fire with the fire growing exponentially until the opening of the sprinkler heads. Once the sprinkler heads open we have assumed that fire will no longer grow but remain constant and generate upward mass flow at a constant rate.
- 7.3.3 These assumptions are very conservative as the sprinkler system is expected to extinguish the fire rather than to only control the fire. In addition we have not accounted for heating of air with flames prior to the heat generated with adequate energy to activate the sprinklers. This provides additional safety margins.
- 7.3.4 For the toxicity of the smoke level we have used polyurethane as the fuel. This calculation is very conservative as most of the combustibles will generate smaller percentages of by products (soot, CO2, CO and HCl.) Therefore the calculated toxicity values are considered conservative.
- 7.3.5 Our model is based on equations from graduate courses of Fire Dynamic at Carleton University for fire that is not oxygen controlled.
- 7.3.6 Civelec Consultants and Harrington Group (fire protection consultants) have made a full scale test using the K25 EC QR pendent sprinkler and the proposed structural assembly at



UL test center in Chicago. In the tests using a full-scale test with the same structural configurations and elevations two (2) K25.2 EC QR sprinklers opened and extinguished the fire and the maximum air temperature and sprinkler activation times were very similar to our calculated results. During the test, we were located approximately 3 m from the fire and remained at this distance until the sprinklers operated. At that point we have slowly exited the test center building without being affected by the smoke.

# 7.4 Exiting study

7.4.1 Based on travel time determined by National Research Council and used in Ontario Building Code, the exit time can be estimated by using the following equation:

Total Egress Time =  $(H_p + V_p/0.6 + H_m/1.3 + 10N_{lg} + 5N_{lc}) \times 1.5$  (in seconds)

where

=	horizontal travel distance on the platform
=	vertical travel distance
=	horizontal travel distance on a main floor
=	number of gates to open
=	number of stairs crossings
	= = = =

- 7.4.2 We have calculated time to exit and obtained the following results: (for calculation details see appendix B, and for visual egress route see plans in appendix C).
- 7.4.3 In our fire and smoke model we have used  $\alpha t^2$  growth of fire. We have calculated the accumulation of smoke as the fire increases until the activation of sprinklers. Once the sprinklers are activated we have assumed that the generation of smoke will remain constant. This assumption is very conservative as the sprinklers used in our design are designed to extinguish the fire rather than to only control the fire.
- 7.4.4 The worst case scenario is on the mezzanine floor due to the relatively low ceiling. If the fire starts at the ground level below the high section of the ceiling.



Item	<b>Event Time</b>	Running Time
Fire starts		0
Sprinkler system is activated	3 min 57 sec	3 min 57 sec
Alarm system is activated	30 sec	4 min 27 sec
Evacuation starts	0	9 min 27 sec
Person reaches ground level	3 min 8 sec	12 min 35 sec
Person reaches exit	33 sec	13 min 08 sec
Smoke reaches 3 m above platform		146 min
Smoke reaches 3 m above ground		631 min

The calculations demonstrate that it will take 3 minutes 41 seconds to move from the most remote area to the exit and 2 conveyer crossings and 2 conveyer gate crossing. Considering that the evacuation starts 9 minutes and 27 seconds after the fire starts (this includes 5 minutes to take the decision to evacuate). Based on the above, 13 minutes and 8 seconds after the start of fire the person reaches an exit. The calculations also show that the smoke will descend to 3 m above the ground floor will take over 10 hours (631 minutes) after the start of the fire. The safety margin to escape from the smoke is calculated to be the time between the evacuation and the time that the smoke will reach 3 m above the platform. This is calculated at 2 hours and 12 minutes.

- 7.4.5 We have also calculated time that it would take if the occupant will decide to reach an exit in the opposite direction, longer route to an exit. In this case the exiting time is calculated to 6 minutes and 4 seconds (364 seconds). Even if the occupant will take the long way out it is demonstrated that the person has adequate time to safely exit the building.
- 7.4.6 The following table provides times for exiting from typical floors (2<sup>nd</sup>, 3<sup>rd</sup> and 4<sup>th</sup>):

Item	Event Time	Running Time
Fire starts		0
Sprinkler system is activated	2 min 58 sec	2 min 58 sec
Alarm system is activated	30 sec	3 min 28 sec
Evacuation starts	0	8 min 28 sec
Person reaches exit	3 min 27 sec	11 min 55 sec
Smoke reaches 3 m above floor	417 min	6 hours 57 min



7.4.7 The typical scenario is on the 2<sup>nd</sup>, 3<sup>rd</sup> or 4<sup>th</sup> floor due to the relatively low ceiling. If the fire starts at the ground level below the high section of the roof. The calculations demonstrate that it will take 3 minutes 27 seconds to move from the most remote area to the exit and 2 conveyer crossings and 2 conveyer gate crossing. Considering that the evacuation starts 8 minutes and 28 seconds after the fire starts (this includes 5 minutes to take the decision to evacuate), 11 minutes and 55 seconds after the start of fire the person reaches an exit. The calculations also show that the smoke will descend to 3 m above the slab 6 hrs and 57 minutes after the start of the fire. The safety margin to escape from the smoke is calculated at approximately 6 hrs 45 minutes.

Item	Event Time	Running Time
Fire starts		0
Sprinkler system is activated	3 min 57 sec	3 min 57 sec
Alarm system is activated	30 sec	4 min 27 sec
Evacuation starts	0	9 min 27 sec
Person reaches exit	3 min 27 sec	12 min 54 sec
Smoke reaches 3 m above floor	631 min	10 hours 31 min

7.4.8 The following table provides times for exiting from ground floor:

- 7.4.9 In this scenario there is a very large volume available to collect the smoke. The calculations demonstrate that it will take 3 minutes 27 seconds to move from the most remote area to the exit including 2 conveyer crossings and 2 conveyer gate crossing. Considering that the evacuation starts 9 minutes and 27 seconds after the fire starts (this includes 5 minutes to take the decision to evacuate), 12 minutes and 54 seconds after the start of fire the person reaches an exit. The calculations also show that the smoke will descend to 3 m above the ground level 10 hrs and 31 minutes after the start of the fire.
- 7.4.10 As the estimated time to exit from the most remote area is less than 4 minutes, the occupants will have an adequate time to exit the building.
- 7.4.11 We have used time based egress analyses using the same equations as Ontario Building Code. The design objective for the travel routes was to attain 4 min egress time. We have calculated the time that the smoke will descend to 3 m above the travel pass and verified that adequate time is available to safely exit before being affected by the smoke layer.
- 7.4.12 The Ontario Building Code allows travel distance to exceed 45 m from "shelf and Rack Storage System," subject to time based egress analyses and the time for egress should not exceed 4 minutes. The time based egress analyses does not take into consideration fire



modeling and in a relatively small buildings where the occupants could be affected by the smoke. In our case we have met the 4 minute exit time and calculated the time for the smoke to reach 3 m above the slab without affecting the exiting.

#### 8. Smoke layer analyses

- 8.1 We have used polyurethane (expected to provide to worst case scenario) as the burning material to determine the toxicity levels expected in the smoke layer.
- 8.2 The worst case scenario results of our calculations are as follows:

Item	amounts generated (g/g)	amounts	survibility
Soot	0.133		
CO2	1.55	0.9 %	critical 2%
CO	0.01	92 ppm	382 minutes
HCl	0.0015	10.68 ppm	critical = 100 ppm
HCN	0.0006	5.70 ppm	critical = 180 ppm

Visibility of reflective signs was calculated at 0.36 m.

Due to the large area, the fire is not expected to be oxygen controlled that explains low toxicity of the smoke layer.

8.3 We understand that after the smoke layer cools down, the smoke will slowly mix with the cool air and affect all sections of the building. The time for this smoke despersement is not expected to affect the exiting. The sprinkler operation time required by NFPA is 60 minutes. Therefore the smoke generation is expected to stop before 60 minutes. Due to the size of the building, the smoke concentration after the cooling would be greatly reduced and is not expected to cause major problem for safety of trained firefighters.

## 9. Design and Construction Requirements

- 9.1 The design of the sprinkler system must meet the conditions of this report.
- 9.2 The system must be designed by a professional engineer licensed in Ontario.
- 9.3 The system must be inspected and certified by a P. Eng. representing our office.

#### 10. Conclusion

10.1 This code equivalency report is based on OBC, NRC tests FM Global data sheets, NFPA. The analyses are based on graduate courses – fire dynamics at Carleton University in fire protection. The calculations demonstrate that adequate time is available to exit the building before the occupants are affected by the smoke layer.



# 11. Copyright

11.1 This document and its technical contents is a property of Civelec Consultants Inc. This document is confidential and is distributed under condition that the document not be reproduced, copied, circulated in part or in its entirety. It shall not be used in any matters that can cause prejudice directly or indirectly to Civelec Consultants Inc. and or be released to its competitors without the prior consent and written permission of Civelec Consultants Inc.





APPENDIX A

CODE STUDY

1. C	eneral	. 3
1.1	Building description	. 3
1.2	Used codes	.4
1.3	Occupant load	.4
2. B	uilding Fire Safety	.4
2.1	Major occupancies	.4
2.2	Building area	. 5
2.3	Number of storevs	. 5
2.4	Number of streets	. 5
2.5	Building construction requirements	. 5
2.6	Spatial separation and exposure protection	. 5
2.7	Fire alarm system	. 6
2.8	Fire fighter access routes	.7
2.9	Water supplies	. 8
2.1	) Standpipe system and hose system (OBC 3.2.9)	. 8
2.1	Sprinkler system (OBC 3.2.5.13)	. 8
2.1	2 Fire department connection (OBC 3.2.5.16)	. 8
2.1	Fire numps (OBC 3.2.5.19)	8
2.1	Protection from freezing (OBC 3.2.5.18)	9
2.1	5 Lighting (OBC 3.2.7.1)	. )
2.1	6 Emergency lighting (OBC 3.2.7.3)	9
3 F	ioh huildings	9
31	Classification of high building (OBC 3.2.6)	9
4 F	ire senarations	9
41	Interconnected floors and mezzanines	. )
42	Fire resistance	10
5 F	xiting	11
5.1	Access to exits	11
5.1	Frits	11
53	Guards	12
6 A	coessibility	12
61	Flevators	12
6.2	Handicanned	12
63	Entrance	13
6.5 6.4	Accessibility	13
65	Barrier free washrooms	13
7 5	anitary – Health requirements	13
7.5	Washrooms	13
7.1	Potable water	1 <i>3</i> 1 <i>1</i>
8 5	afety during Construction	14 1/
0. 3 Q1	OBC and OEC requirements	14 1/
0.1 Q 7	Fire Safety Dlan	14 1/
0.2 Q 2	Access for Firefighting	14 15
0.J 0.J	Dortable Extinguishers	1J 15
ð.4	Foliable Extiliguishers	13 15
ð.3	stanupipe systems	13



8.6	Hot Surface Applications	16
8.7	Ignition Sources	16
8.8	Provision for Egress	16
8.9	Fire Warning	16



#### 1. General

## **1.1 Building description**

- 1.1.1 The building will be approximately  $58,222 \text{ m}^2$  on the ground floor including  $3280 \text{ m}^2$  of offices. The ground floor will have approximately  $25,427 \text{ m}^2$  of mezzanines. The building will also have additional 4 levels of robotic sorting platforms each having an area of  $45,075 \text{ m}^2$ . The building is considered 6 storeys high. The ground floor will be approximately 8.53 m (28 ft) high with mezzanine levels located at approximately 4.27 m (14 ft) height. The robotic platforms will be 4.27 m (14 ft) high and the top platform roof will be 4.57 m (15 ft) above the platform. The top floor is located approximately 21.34 m above the ground floor.
- 1.1.2 The ground floor and mezzanines will be used for packaging shipping and receiving. This area will have numerous conveyers and automated handling systems. 2<sup>nd</sup>, 3<sup>rd</sup> 4<sup>th</sup> and 5<sup>th</sup> floors (robotic platforms) will be used for a sorting area and manual picking sector on the perimeter of the building. The articles are placed in special pods that are 2.616 m (8 ft 7 in) high. The individual items are loaded in the pods. The pods are delivered to the picking stations by robots. The individual items are loaded into the pods or removed from the pods. The items are transported to the ground floor by conveyer systems typically in open plastic totes. The pods stationary and delivery area has restricted access and is not occupied during normal operation.
- 1.1.3 The mezzanines located above the ground level are considered as a floor in calculating the building height. We may consider this area as shelf and racking system (to be decided) and in this case, these mezzanines will not form an interconnected floor space and will not be calculated as a floor in building height. This will not change any code requirements but will be part of the alternative solution.
- 1.1.4 The floors fire resistance will be provided using sprinkler system with increased reliability. See alternative solution.
- 1.1.6 Due to the ASRS, the maximum travel distance of 45 m cannot be respected and a time travel study will be used to assure safe exiting. See alternative solution.
- 1.1.7 The mechanical equipment:
  - Fire pumps room will be located within the building. Each pump room will be separated by 2 hr separation. The building will have two diesel driven fire pumps (one in each section.)
  - Some of the ventilation equipment will be located on the roof.
  - Battery charging will be in an open areas in the in the robotic sections of the building.



1.1.8 The building will be approximately 28.65 m (94 ft) high.

#### 1.2 Used codes

- 1.2.1 The building is designed to the Ontario Building Code 2012 Division B with the O. Reg. 88/19 amendments, and to Division A for exiting from the warehouse areas, fire resistance of the floors.
- 1.2.2 A separate alternative solution reports will be prepared for compliance with Division A of OBC.
- 1.2.2 The building size requires to use Part 3 of the OBC.

#### **1.3** Occupant load

- 1.3.1 The occupant load is to be based on the OBC table 3.1.17.1. See table 1.2.6 of this report.
- 1.3.2 Where the occupant load based on OBC is not realistic, a real occupant load can be used but a sign indicating the maximum number of occupants must be provided.
- 1.3.3 The real occupant load is used for the following areas:

Ground level	550 occupants
Mezzanine level	50 occupants
Level 2	176 occupants
Level 3	176 occupants
Level 4	176 occupants
Level 5	176 occupants
Total	1304 occupants

The maximum foreseen occupant load for the building due to washroom limitations is 2810 occupants.

#### 2. Building Fire Safety

#### 2.1 Major occupancies

2.1.1 The building is classified as medium hazard industrial occupancy F2. The office area is classified as Business and Personal services – D. This occupancy is not classified as a major occupancy as the use is subsidiary and normal for F2 operations.



## 2.2 Building area

2.2.1 For determining the building construction requirements the building area is approximately  $60,000 \text{ m}^2 (640,000 \text{ ft}^2)$ .

## 2.3 Number of storeys

2.3.1 The building is considered as 5 storeys high. The platforms on the ground floor are not calculated as a storey in building height as this will be considered under "shelf and rack storage system" section of the OBC. The remaining mezzanines aggregate area is expected to be less than 10 % of the floor area and will be used only to service equipment. (Ref OBC 3.2.1.1 (4))

## 2.4 Number of streets

- 2.4.1 See definition of street in OBC section 1.
- 2.4.2 The fire fighting equipment will have access from all sides of the building. The access is over 75 % of the perimeter. The building is considered to be accessed from 3 streets. (Reference OBC 3.2.2.10).

## 2.5 Building construction requirements

- 2.5.1 The building is to be constructed in compliance with article 3.2.2.67 Group F, Division 2, Any Height, Any Area, Sprinklered Except for the use of heavy timber construction as permitted by Article 3.2.2.16., the *building* shall be of *noncombustible construction*, and
  - a) the *building* shall be *sprinklered* throughout,
  - b) floor assemblies shall be *fire separations* with a *fire-resistance rating* not less than 2 h,
  - c) mezzanines shall have a fire-resistance rating not less than 1 h, and
  - d) *loadbearing* walls, columns and arches shall have a *fire-resistance rating* not less than that required for the supported assembly.

# 2.6 Spatial separation and exposure protection

2.6.1 The building has the following limiting distances:



Wall	Limiting distance	Permitted unprotected opening	Wall construction
North	Over 15m	100%	No restrictions
East	Over 15 m	100%	No restrictions
South	Over 15 m	100%	No restrictions
West	Over 15 m	100%	No restrictions

2.6.2 Based on Table 3.2.3.2.1 E if the limiting distance is 15 m or more the exposing wall is permitted to have 100% unprotected openings.

## 2.7 Fire alarm system

- 2.7.1 The building is required to have a fire alarm system. (Reference OBC 3.2.4.1)
- 2.7.2 The Fire alarm system is permitted to be single or two stage system. (Reference OBC 3.2.4.3)
- 2.7.3 A fire alarm annunciator is to be installed near the main entrance. (Reference OBC 3.2.4.9)
- 2.7.4 Audible signal devices forming part of a fire alarm system shall be installed in a *building* so that *alert signals* and *alarm signals* are clearly audible throughout the *floor area* in which they are installed.

The sound pattern of an *alarm signal* shall conform to the temporal pattern defined in Clause 4.2 of International Standard ISO 8201, "Acoustics – Audible emergency evacuation signal."

The sound patterns of *alert signals* shall be significantly different from the temporal patterns of *alarm signals*.

The fire *alarm signal* sound pressure level shall be not more than 100 dBA in the office areas.

The sound pressure level from a fire alarm system's audible signal device within a *floor area* shall be not less than 10 dBA above the ambient noise level without being less than 65 dBA.

Fire alarm audible signal devices shall be supplemented by visual signal devices in any *floor area* in which

- a) the ambient noise level is more than 87 dBA, or
- b) the occupants of the *floor area* 
  - i) use ear protective devices,
  - ii) are located within an audiometric booth, or



iii) are located within sound insulating enclosures.

Audible signal devices shall be installed in a *service space* and shall be connected to the fire alarm system. (OBC 3.2.4.20)

- 2.7.5 The fire alarm system is to be connected to a Central station Supervision for each of the following (OBC 3.2.4.8 and10):
  - Any fire detection
  - Any sprinkler water flow
  - Any Fire Alarm system trouble
  - Any Sprinkler system trouble
  - Any closed sprinkler valves
  - Any fire pump off / trouble
  - Any fire pump running
- 2.7.6 The voice communication system is not required for this building.
- 2.7.7 The fire alarm system is to shut down the following upon any fire detection:

All robots All conveyers and VRCs All "Big Ass Fans" or similar fans Any HVAC system that provides supply to more than one fire rated area. Close fire shutters Open all maglocks for doors

#### 2.8 Fire fighter access routes

- 2.8.1 Access route for fire trucks is required only for the building face that has the principal entrance. (OBC 3.2.5.4)
- 2.8.2 The fire route is to be 3 to 15 m from the main entrance (OBC 3.2.5.6). The acceptance of the layout will have to be discussed with the chief building official.
- 2.8.3 The route is to be located so that a fire truck can be connected to the hydrant and reach the Siamese connection within 45 m. (OBC 3.2.5.16)

#### 2.8.4 The access route is to have:

- Width at least 6 m.
- Turning radius centerline not less than 12 m.
- Overhead clearance not less than 5 m.
- Change in elevation less than 1 in 12.5 over 15 m.
- If longer dead end than 90 m, requires turnaround facility.
- Connection to public thoroughfare.



## 2.9 Water supplies

2.9.1 Adequate water supplies will be provided from municipal water distribution system. An additional water supply will be provided by a water tank. The municipal water supply and tank (each) is to be adequate for sprinkler flow and reserve for hydrants based on NFPA 13 and FM Global standards and an alternative solution for fire resistance rating of the floors.

#### 2.10 Standpipe system and hose system (OBC 3.2.9)

- 2.10.1 The standpipe and hose system (as per NFPA 14) is required by OBC for building over 14 m high. Building height is measured from the lowest average ground level taken from each side of the building. It is expected that standpipe system will be required. An alternative solution may be proposed to eliminate the need for hoses and hose connections within certain sections of the floor area or be modified depending on fire department firefighting procedures.
- 2.10.2 65 mm hose connections are required.
- 2.10.3 Hose stations with 30 m of 38 mm diameter hose are required.
- 2.10.4 Hose stations in the office areas will be in hose cabinets with an extinguisher and a hose.
- 2.10.5 Depending on the meeting with the city and fire department, an alternative solution may be required. This would modify the standpipe requirements mentioned above.

#### 2.11 Sprinkler system (OBC 3.2.5.13)

- 2.11.1 The building will be fully sprinklered as per FM Global standards and NFPA 13 2013.
- 2.11.2 Use of combustible sprinkler piping is not permitted for areas that are not considered light hazard. (OBC 3.2.5.14)

#### 2.12 Fire department connection (OBC 3.2.5.16)

2.12.1 The fire department connection is to be located within 45 m from the fire hydrant. The connection is to be 300 to 900 mm from ground.

#### 2.13 Fire pumps (OBC 3.2.5.19)

2.13.1 The additional pressure for water supplies will be provided by two fire pumps, one taking suction from the municipal water supplies and one taking suction from



the tank. The fire pumps will be diesel driven. The fire pumps installation will follow requirements of NFPA 20.

#### 2.14 **Protection from freezing. (OBC 3.2.5.18)**

2.14.1 Any equipment susceptible to must be adequately protected.

#### 2.15 Lighting (OBC 3.2.7.1)

- 2.15.1 Exits and access to exits for public, electrical room and transformer vault shall have average light level at floor of 50 lx.
- 2.15.2 Elevator machine room shall have average light level at floor of 100 lx.

#### 2.16 Emergency lighting (OBC 3.2.7.3)

- 2.16.1 Exits and access to exits for public, service rooms, main corridors in open area shall have average light level at floor of 10 lx and minimum level of 1 lx.
- 2.16.2 The power supply for emergency lights is 30 minutes. (OBC 3.2.7.4)
- 2.16.3 Illuminated signs for direction of exit are also required in mechanical rooms. (OBC 3.3.1.23)

#### 3. High buildings

#### **3.1** Classification of high building (OBC 3.2.6)

3.1.1 This building is not classified as high building and the OBC requirement for high building do not apply as long as the following condition are met (the floor of the top storey is 21.34 m above ground floor):

Total number of occupants above ground floor = TO The cumulative width of exit stairs measured in meters = EW

TO / (EW x 1.8) must be less than 300

#### 4. Fire separations

#### 4.1 Interconnected floors and mezzanines

4.1.1 The building will have an interconnected floor space between 1<sup>st</sup> and mezzanine (platforms) floor. The interconnected floors space will be sprinklered, and will contain only group D or F2 occupancy. The interconnected floor space does not need any additional protection. (Reference OBC 3.2.8.2 (6)).



## 4.2 Fire resistance

4.2.1 The following is a summary of required fire resistance.

Location	<b>Required rating</b>	Reference
Floors and supporting columns**	2 hr**	3.2.2.67
Mezzanine floors and supporting	1 hr *	3.2.2.67
columns		
Roof and supporting columns	None	
Walls mechanical rooms	None	
Robotic area office mezz/electrical	See 4.2.2	
Fire Pump room (separation inside the	2 hr	NFPA 20
building		
Open robotic area to offices	Not required	
Exits (staircase)	2 hr	3.4.4.1
Elevators shaft	1.5 hr	3.5.3.1
Elevator machine room	1.5 hr	3.5.3.3
Between Elevator shaft and elevator	Not required	3.5.3.3
mechanical room ***		
Janitor rooms	None required	3.3.1.20 (3)
Room with liquids having flash point	1 hr	3.6.2.1
less than 93.3 F		
Electrical room	1 hr	3.6.2.1
Electrical vault	3 hr	3.6.2.7
	2 hrs if	
	sprinklered	
Garbage room	1 hr	3.6.2.5
Generator room	1 hr	3.6.2.8
Vertical service space	1 hr	3.6.3.1
Duct shafts	1 hr	3.6.3.1

\* if the mezzanine supporting column supports also other mezzanine or floor that requires higher rating, than this column shall have the higher rating. An alternative solution will be provided for the mezzanines in the process area.

\*\* An alternative solution will be provided for 2 hr fire resistance rating.

\*\*\* Fire resistance is required only if the electrical room contains electrical equipment that is required to be in an electrical room by the electrical code.

4.2.2 The MHE Shafts will be treated as openings in the floors as permitted in section 3.6 of OBC for conveyer systems or similar. The shafts will have 2hr fire resistance rating.



- 4.2.3 As the robotic area and all associated area are under the same management, the building does not have any suites.
- 4.2.4 As per the tenant specification, any fire shutter will be provided with a fusible link and an electric release activated by the fire alarm panel. The shutter will close if the fusible link is melted or by electric release activated by the fire alarm panel upon any alarm signal.

#### 5. Exiting

#### 5.1 Access to exits

- 5.1.1 Roof exit is permitted to be stairway or a fixed ladder. (If a stairway or a ladder is connected to a roof hatch and the roof hatch must be open to provide access to the mechanical equipment the roof, this seems to meet the intent of OBC.) (OBC 3.3.1.3)
- 5.1.2 If the mechanical rooms (service rooms) are larger than 200 m<sup>2</sup> least 2 means of egress is to be provided. (OBC 3.3.1.3)
- 5.1.3 Maximum travel distance to a door for a mechanical room with only one means of egress is 25 m (inside the mechanical room). (OBC 3.3.1.3)
- 5.1.4 The headroom clearance for access to exit is 2,100 mm with doors 2,030 mm stairwell landings 2,050 mm and door closures can not reduce height to less than 1,980 mm.
- 5.1.5 The minimum corridor width for access to exit is 1,100 mm.
- 5.1.6 Dead end corridor should be avoided. Maximum length is 9 m if serving lees than 30 people, doors to the corridor are self closing and other means of egress is provided for the rooms leading into the corridor.
- 5.1.7 Egress doors shall swing in the direction of an egress if the door is to serve more than 60 people. (OBC 3.3.1.10)
- 5.1.8 The width of access to exits (corridor) shall be wider of 1.100 mm or 6.1 mm/person. (OBC 3.3.1.16)
- 5.1.9 From any area a means of egress (passage) can not be reduced to less than 750 mm.
- 5.2 Exits



- 5.2.1 To avoid requirements for high buildings the cumulative width of exit stairs must meet the requirements of section 3.1.1 of this report. Upon review and using the actual occupancy load, this condition is met.
- 5.2.1 At least two exits are required from each storey.
- 5.2.2 Mezzanines require at least two exits with the exceptions of the following articles.
- 5.2.3 Mezzanine does not require exits (but requires means of egress) if:
  - A mezzanine does not require to terminate at a vertical fire separation and does not have to have special protection required by articles 3.2.8.3 to 3.2.8.11 and is less than 500 m<sup>2</sup>. (OBC 3.4.2.2(2))
  - Occupant load is less than 60, the area of the mezzanine is 300 m<sup>2</sup> for offices and 200 m<sup>2</sup> for industrial occupancy or less and the travel distance to a stair does not exceed 25 m. (OBC 3.4.2.2(4))
- 5.2.4 Maximum travel distance to exit is 45. (OBC 3.4.2.5(1)(c)). A perimeter exiting is permitted for a building having exits located at 60 m at the perimeter. (OBC 3.4.2.5 (2)) Aisles must lead directly to an exit. See alternative solution for exiting.
- 5.2.5 Maximum travel distance from a mechanical room is 50 m. (OBC 3.4.2.4 (3)).
- 5.2.6 The headroom clearance for access to exit is 2,100 mm with doors 2,030 mm stairwell landings 2,050 mm and door closures can not reduce height to less than 1,980 mm. (OBC  $3.3.1.8 \rightarrow 3.4.3.5$ )

# 5.3 Guards

5.3.1 Normally the guards are required to limit openings to 200 mm diameter. In our case the building will have limited access only to maintenance staff or escorted visitors. As such, the larger opening do not represent hazard.

#### 6. Accessibility

#### 6.1 Elevators

- 6.1.1 Elevator serving the office areas is to have electrical supply protected by 1 hr. fire rating (OBC 3.3.1.7  $\rightarrow$  3.2.6.5 (6)) is waived by OBC 3.3.1.7 (3)). Therefore fire resistance for elevators electrical supply is not required.
- 6.1.2 Elevator shall conform to Appendix E of CSA B44 Safety code for Elevators. (OBC 3.5.2.2)



#### 6.2 Handicapped

6.2.1 The elevator must have a vestibule with 45 minute fire rating or lead into a corridor with no occupancy that has a fire separation of 1 hr from other areas is waived as the building is sprinklered. (OBC 3.3.1.7 (3))

#### 6.3 Entrance

- 6.3.1 The number of barrier free entrances from outdoor side walk depends on total number of these entrances as follows (OBC 3.8.1.2):
  - 1 to 3 requires 1 barrier free
  - 4 to 5 requires 2 barrier free
  - More than 5 requires not less than 50%

#### 6.4 Accessibility

- 6.4.1 Any floors accessible by elevators will have barrier free path of travel. (OBC 3.8.2.1)
- 6.4.2 Illumination in the barrier free path of travel will be at least an average of 50 lx at the floor level. (OBC 3.8.1.6)
- 6.4.3 Barrier free access is not required for mechanical rooms, janitor rooms, service rooms etc.

#### 6.5 Barrier free washrooms

- 6.5.1 The robotic operation requires mobility and the barrier free access will be provided only for the main office area.
- 6.5.2 Washrooms will be barrier free unless another barrier free washroom is provided within 45 m. (OBC 3.8.2.3)

#### 7. Sanitary – Health requirements

#### 7.1 Washrooms

- 7.1.1 The number of male vs female washrooms is to be equal unless a ratio can be as per the real ratio if the ratio can be determined with reasonable accuracy. (OBC 3.7.4.2)
- 7.1.2 2/3 of the male WC can be urinals. (OBC 3.7.4.2)
- 7.1.3 At least 1 lavatory is to be provided for 2 WC (or urinals). (OBC 3.7.4.2)



- 7.1.4 If wash fountains are provided, 500 mm / WC.
- 7.1.5 The following table should be used to determine the number of washrooms for F2 or D occupancy.

Number of persons of each sex	Minimum number of WC and Lavatories for each sex
Up to 9	1
10 to 24	2
25 to 49	3
50 to 74	4
75 to 100	5
Over 100	6 plus 1 / each additional 30 over 100

- 7.1.6 In our case the total occupant load is 1304. If equally divided we have 652 of each sex. Therefore we need 5 for first 100 and 19 additional for total of 24 WC for each sex.
- 7.1.7 We have 97 WC and this is adequate for an occupancy of 2810 and the actual estimated occupancy is 1304.

## 7.2 Potable water

7.2.1 Potable water is to be provided within 100 m of any working area.

# 8. Safety during Construction

#### 8.1 OBC and OFC requirements

8.1.1 OBC and OFC do not include conditions for construction of a new building. The following sections are requirements of the NBC and NFC that we consider should be applied to the construction site as a good construction practice.

# 8.2 Fire Safety Plan

- 8.2.1 Prior to the commencement of construction, a fire safety plan shall be prepared for the site and shall include
  - a) the designation and organization of site personnel to carry out fire safety duties, including a fire watch service if applicable,
  - b) the emergency procedures to be followed in the event of a fire, including
    - i) initiating a fire warning,
    - ii) notifying the fire department,
    - iii) instructing site personnel on the procedures to be followed once the warning has been initiated, and



- iv) confining, controlling and extinguishing the fire,
- c) measures for controlling fire hazards in and around the building
- d) a maintenance procedure for firefighting measures required in Section 5.6.

## 8.3 Access for Firefighting

- 8.3.1 Unobstructed access to fire hydrants, portable extinguishers and to fire department connections for standpipe and sprinkler systems shall be maintained.
- 8.3.2 A means shall be provided to allow firefighters to perform their duties on all levels of the building.
- 8.3.3 Provision shall be made for the use of existing elevators, hoists or lifts to assist firefighting personnel in reaching all levels of the building.
- 8.3.4 Access routes for fire department vehicles shall be provided and maintained to construction and be made for access by fire department equipment and personnel.

#### 8.4 **Portable Extinguishers**

- 8.4.1 In addition to the other requirements of the Code, portable extinguishers shall be provided in unobstructed and easily accessible locations in any areas
  - a) where hot work operations are carried out,
  - b) where combustibles are stored,
  - c) near or on any internal combustion engines,
  - d) where flammable liquids and combustible liquids or gases are stored or handled,
  - e) where temporary fuel-fired equipment is used, or
  - f) that are designated for smoking.
- 8.4.2 The extinguishers shall have a minimum rating of 3-A:20-B:C on moveable equipment and 4-A:40-B:C in all other locations.

#### 8.5 Standpipe Systems

- 8.5.1 The standpipe system is to be installed progressively as the construction is advancing and a permanent or temporary standpipe system shall be provided with conspicuously marked and readily accessible fire department connections on the outside of the building at street level and shall have at least one hose outlet at each floor.
- 8.5.2 The standpipe system shall, as a minimum, be securely supported and restrained on alternate floors, at least one hose valve for attaching fire department hose shall be provided at each intermediate landing or floor level in the exit stairway.



- 8.5.3 Valves shall be kept closed at all times and guarded against mechanical damage, the standpipe shall be not more than one floor below the highest forms, staging, and similar combustible elements at all times.
- 8.5.4 If the standpipe system is temporary, it shall remain in service until the permanent standpipe installation is complete.

#### 8.6 Hot Surface Applications

- 8.6.1 Roofing operations and other surface applications that involve heat sources and hot processes shall be considered hot works and shall conform to the requirements of the OBC.
- 8.6.2 Bitumen kettles shall not be located on roofs, be provided with adequate metal covers that are close-fitting and constructed of steel having a thickness of not less than No. 14 sheet metal gauge thickness, be under constant supervision when in operation, and be maintained free of excessive residue.
- 8.6.3 Mops that have been used for spreading bitumen shall be kept outside the building in a safe location when not in use.

#### 8.7 Ignition Sources

- 8.7.1 Devices capable of producing ignition, internal combustion engines, temporary heating equipment and associated devices shall be kept at a safe distance from combustible material so as not to cause ignition.
- 8.7.2 The clearance between combustible materials and temporary heating equipment, including flues, shall be in conformance with the minimum clearances shown on certified heating equipment.

#### 8.8 **Provision for Egress**

8.8.1 In areas of a building where construction are taking place, at least one exit shall be accessible and usable at all times.

#### 8.9 Fire Warning

8.9.1 A means shall be provided to alert site personnel of a fire and such means shall be capable of being heard throughout the building or facility.



APPENDIX B

# CALCULATION


EXITING CALCULATIONS	Platform Exiting normal wa	<b>SMOK</b> у	E LEVEL 3 m		
BUILDING Building boight	Ph	9 52 m			
Building length	BI	284 m			
Building width	Bw	150 m			
Height of the base of fire	Zo	0.5 m			
HEAT RELEASE CALCULATIONS					
Fire groth $Q = \alpha t^2$					
Slow fire $a = 0.0066$ Medium fire $a = 0.02675$ Fast fire $a = 0.0469$ Ultra fast fire $a = 0.1876$ Time calculations to reach tempearture to activate Time 1 (s) a	sprinklers 210 0.02675				
Q (kW) =	1179.68	AS activ	ation 237		
Heat release rate	30	kw/m2 Heat rele	ease verification for smoke to r	each ceiling	
Smoke height calculations	Te		$z_{max} = \left[Q_{C}^{2/3}\right]$	$\left(\frac{14.1}{\Delta T_{min}} - 0.0026\right)^{3/5}$	
Smoke height	Sh		dTmin (deg C)= Qc (kW) =	2 1179.68	
Ceiling jet temperature calculations			Zmax (m) =	55.14 au dessus du	u niveau du sol
Temperature ambient	T (deg C)	20			
Ceiling (sprinkler) height from floor Ceiling height from base of fire Horizontal distance from center of fire	Hr H r	8.2 7.7 1.5	Sprinkler height		
For r < 0.18 H $T_{max} = 16.9 \frac{q^{2/3}}{H^{5/3}} + T_{co}$					
For r > 0.18 H $T_{max} = 5.38 \frac{Q^{2/3}/H^{5/3}}{\left(r_{/H}\right)^{2/3}} + T_{\infty}$					
Maximum Temperature (deg C)	79.53	at ceiling	(sprinkler) height		
Ceiling jet velocity calcualtions					
for r<0.15 H $u_{max} = 0.96 \left(\frac{Q}{H}\right)^{1/3}$					
for r > 0.15 H $u_{max} = 0.195 \frac{\left( {^0/_H} \right)^5}{\left( {^{7}/_H} \right)^5}$	/3 /6				
Maximum jet velocity Umax =	4.08	at celing	(sprinkler ) height		
Sprinkler activation calculations					
$t_r = \frac{RTI}{u^{1/2}} ln \left( \frac{T_g - T_a}{T_g - T_r} \right)$	)		STANDARD	80 TO	100
Sprinkler response factor RTI (98) Sprinkler activation temperature (deg C)	25 73		QR STANDARD ESFR	40 TO 25 TO	50 30
Time for sprinklers to open T 2 (s) Time for sprinklers to open from start of fire (s)	27 237	time ca time ca	Iculated from time 1 Iculated T1 +T2		
Mass flows calculations					
$\dot{m} = 0.071 Q_c^{1/3} (z - z_0)^{5/3} \left[ 1 + 0.026 Q_c^{1/3} (z - z_0)^{5/3} \right]$	$\left[ D_{c}^{2/3}(z-z_{0})^{-5/3} \right]$				
Qc (kW) = 0.7Q = calculation of effective fire height z = Base of the fire height Zo Mass flow m (kg/s) =	825.77 3.73 0.50 <b>6.24</b>				

#### Volumetric flows calculations

Volume of smke at sprinkler activation T1+T2

Volumetric flows - steady state

$$\dot{V} = \frac{\dot{m}}{\rho_p}$$
 
$$\rho_p = \rho \frac{T_\infty}{T_p}$$

T (deg K) Tp (deg K)	293 353					
ρ (gas) (kg/m3) =	1.203					
V (m3/s)	6.24					
Smoke level calculations						
Elapse time from sprinkler activation (s) Tas (s)	8550	Time from	n start of fire (s)	8760		
$H_s = H_b - (V_s T_s + V_{totalAS}) / (B_L B_W)$						
Bottom elevation of smoke layer Hs (m) =	7.27		smoke height	4.27 m	+ 3 m =	7.27 m
Smoke layer contents calculations USED POLYURETHANE AS DATA Soot concentration (g/g) CO2 concentration (g/g) CO concentration (g/g) HCI concentration (g/g) HCN concentration (g/g)	wei 0.133 1.55 0.01 0.0015 0.0006	ght moles 889868.18 20224 5741.09 205 861.16 23 344.47 12	survibility 28 04 92 76	ppm 9029.59 91.54 10.68 crit 5.70 crit	0.90 382.33 t tical = 100 tical = 180	% crtical at 2% time(min)
Heat release Hch (kj/g) Volume (m3) Moles of air Mass consumption (g/s) Total mass	18 53777 2239777 66 574109					
soot concentration g/m3 Cs Visibility Km K=Km soot	1.397 6.0 8.383	is mass co	onsumed / volume			
Visibility of reflective signs	0.36	3 / (Km x	Cs)			

437.4715

#### PLATEFORM EXITING

#### Exiting times based on Ontario Building Code

$$T_{egress} = \left(H_p + \frac{V_p}{1.6} + \frac{H_m}{1.3} + 10N_{lg} + 5N_k\right) 1.5$$

Horizontal Travel Distance Rack Hp (m) vertical travel distance rack Vp (m) Horizontal Travel Distance floor Hm (m) Number of gates - Rack Nig	75 12 29.0 2	
number of crossing - stairs rack Nk	2 unit	total
time to get to the stairs (s)	113	113
time to cross obstuctions	45	158
time to get to ground level (s)	30	188
time to exit ground level (s)	33	221

EXITING CALCULATIONS	Platform Exiting lor	ng way		SMOKE L	EVEL 3 m		
BUILDING Building height Building length Building width	Bh Bl Bw		8.53 284 150	m m m			
Height of the base of fire	Zo		0.5	m			
HEAT RELEASE CALCULATIONS							
Fire groth $Q = \alpha t^2$							
Slow fire $a = 0.0066$ Medium fire $a = 0.02675$ Fast fire $a = 0.0469$ Ultra fast fire $a = 0.1876$ Time calculations to reach tempearture to activate Time 1 (s) a	sprinklers	<b>210</b> 0.02675					
Q (kW) =		1179.68		AS activation	l	237	
Heat release rate		30 kw/m2		Heat release	verification for sm	noke to reach ceiling	
Smoke height calculations					$z_{max} =$	$= \left[ Q_C^{2/3} \left( \frac{14.1}{\Delta T_{min}} - 0.0026 \right) \right]$	) 3/5
Time Smoke height	Ts Sh				dTmin (deg C)=	2	/ ]
					Qc (kW) =	1179.68	
Ceiling jet temperature calculations					Zmax (m) =	55.14 au de	essus du niveau du sol
Temperature ambient	T (deg C)		20				
Ceiling (sprinkler) height from floor Ceiling height from base of fire Horizontal distance from center of fire	Hr H r		8.2 7.7 1.5		Sprinkler height		
For r < 0.18 H $T_{max} = 16.9 \frac{Q^{2/3}}{\mu^{8/3}} T_{\infty}$							
For r > 0.18 H $T_{max} = 5.38 \frac{Q^{2/3}/H^{5/3}}{\left(r/_{H}\right)^{2/3}} + T_{\infty}$							
Maximum Temperature (deg C)		79.53		at ceiling (sp	rinkler) height		
Ceiling jet velocity calcualtions $(0)^{1/3}$							
for r<0.15 H $u_{max} = 0.96 \left(\frac{Q}{H}\right)$							
for r > 0.15 H $u_{max} = 0.195 \frac{\left(\frac{Q}{H}\right)^{1}}{\left(\frac{r}{H}\right)^{5}}$	/ <sub>3</sub>						
Maximum jet velocity Umax =		4.08		at celing (spr	inkler ) height		
Sprinkler activation calculations							
$t_r = \frac{RTI}{u^{1/2}} ln \left( \frac{T_g - T_a}{T_g - T_r} \right)$	)				STANDARD	80 TO	100
Sprinkler response factor RTI (98) Sprinkler activation temperature (deg C)		25 73			QR STANDARD ESFR	40 TO 25 TO	50 30
Time for sprinklers to open T 2 (s) Time for sprinklers to open from start of fire (s)		27 237		time calcul time calcul	ated from time 1 ated T1 +T2	1	
Mass flows calculations							
$\dot{m} = 0.071 Q_c^{1/3} (z - z_0)^{5/3} \left[ 1 + 0.026 Q_c^{1/3} (z - z_0)^{5/3} \right]$	$Q_c^{2/3}(z-z_0)^{-1}$	-5/3]					
Qc (kW) = 0.7Q = calculation of effective fire height z = Base of the fire height Zo Mass flow m (kg/s) =		825.77 3.73 0.50 <b>6.24</b>					

Volumetric flows calculations

Volume of smke at sprinkler activation T1+T2

Volumetric flows - steady state

$$\dot{V} = \frac{\dot{m}}{\rho_p}$$
 
$$\rho_p = \rho \frac{T_\infty}{T_p}$$

T (deg K) Tp (deg K)	293 353					
ρ (gas) (kg/m3) =	1.203					
V (m3/s)	6.24					
Smoke level calculations						
Elapse time from sprinkler activation (s) Tas (s)	8550	Time fro	m start of fire (s)	8760		
$H_s = H_b - (V_s T_s + V_{totalAS}) / (B_L B_W)$						
Bottom elevation of smoke layer Hs (m) =	7.27		smoke height	4.27 m	+ 3 m =	7.27 m
Smoke layer contents calculations USED POLYURETHANE AS DATA Soot concentration (g/g) CO2 concentration (g/g)	we 0.133 1.55	ight moles 889868.18 20224	survibility	9029.59	0.90	% crtical at 2%
HCI concentration (g/g) HCN concentration (g/g)	0.0015 0.0006	5741.09 205   861.16 23   344.47 12	.04 .92 .76	91.54 10.68 crit 5.70 crit	ical = 100 ical = 180	ume(min)
Heat release Hch (kj/g) Volume (m3) Moles of air Mass consumption (g/s) Total mass soot concentration g/m3 Cs	18 53777 2239777 66 574109 1.397	is mass c	onsumed / volume			
Visibility Km K=Km soot	6.0 8.383					
Visibility of reflective signs	0.36	3 / (Km x	Cs)			

437.4715

#### PLATEFORM EXITING

#### Exiting times based on Ontario Building Code

$$T_{egress} = \left(H_p + \frac{V_p}{1.6} + \frac{H_m}{1.3} + 10N_{lg} + 5N_k\right) 1.5$$

Horizontal Travel Distance Rack Hp (m) vertical travel distance rack Vp (m) Horizontal Travel Distance floor Hm (m) Number of gates - Rack Nig number of crossing - stairs rack Nk	66 12 165.0 2 2	
time to get to the stairs (s)	unit 99	total 99
time to cross obstuctions	45	144
time to get to ground level (s)	30	174
time to exit ground level (s)	190	364

EXITING CALCULATIONS	MAIN FLOOR	SMOKE LEVEL 3 m	
BUILDING Building height Building length Building width	Bh Bl Bw	8.53 m 284 m 150 m	
Height of the base of fire	Zo	0.5 m	
HEAT RELEASE CALCULATIONS			
Fire groth $Q = \alpha t^2$			
Slow fire $a = 0.0066$ Medium fire $a = 0.02675$ Fast fire $a = 0.0469$ Ultra fast fire $a = 0.1876$ Time calculations to reach tempearture to activate Time 1 (s) a Q (kW) =	e sprinklers 210 0.02675 1179.68	AS activation 237	
Heat release rate	30 kw/m2	Heat release verification for smoke t	to reach ceiling
		$z_{max} = \left[ \rho^2 \right]$	$\frac{2}{3}\left(\frac{14.1}{2}-0.0026\right)^{3/5}$
Smoke height calculations Time	Ts		$\left(\Delta T_{min}\right)$
Smoke height	Sh	dTmin (deg C)= Qc (kW) =	2 1179.68
Coiling int temporature calculations		Zmax (m) =	55.14 au dessus du niveau du sol
Temperature ambient	T (deg C)	20	
Ceiling (sprinkler) height from floor Ceiling height from base of fire Horizontal distance from center of fire	Hr H r	8.2 Sprinkler height 7.7 1.5	
For r < 0.18 H $T_{max} = 16.9 \frac{Q^{2/3}}{H^{5/3}} + T_{\infty}$			
For r > 0.18 H $T_{max} = 5.38 \frac{Q^{2/3}/H^{5/3}}{(r/H)^{2/3}} + T_{\infty}$			
Maximum Temperature (deg C)	79.53	at ceiling (sprinkler) height	
Ceiling jet velocity calcualtions $(0)^{1/3}$			
for r<0.15 H $u_{max} = 0.96 \left(\frac{\mathbf{v}}{H}\right)$			
for r > 0.15 H $u_{max} = 0.195 \frac{(Q_{/H})}{(r_{/H})^{3}}$	<sup>1</sup> / <sub>3</sub> 5/ <sub>6</sub>		
Maximum jet velocity Umax =	4.08	at celing (sprinkler ) height	
Sprinkler activation calculations			
$t_r = \frac{RTI}{u^{1/2}} ln \left( \frac{T_g - T_a}{T_g - T_r} \right)$	)	STANDARD	80 TO 100
Sprinkler response factor RTI (98) Sprinkler activation temperature (deg C)	25 73	QR STANDARD ESFR	40 TO 50 25 TO 30
Time for sprinklers to open T 2 (s) Time for sprinklers to open from start of fire (s)	27 237	time calculated from time 1 time calculated T1 +T2	
Mass flows calculations			
$\dot{m} = 0.071 Q_c^{1/3} (z - z_0)^{5/3} \left[ 1 + 0.026 \right]$	$Q_c^{2/3}(z-z_0)^{-5/3}$		
Qc (kW) = 0.7Q = calculation of effective fire height z = Base of the fire height Zo Mass flow m (kg/s) =	825.77 3.73 0.50 <b>6.24</b>		

#### Volumetric flows calculations

Volume of smke at sprinkler activation T1+T2

Volumetric flows - steady state

$$\dot{V} = \frac{\dot{m}}{\rho_p}$$
 
$$\rho_p = \rho \frac{T_\infty}{T_p}$$

T (deg K)	293						
Tp (deg K)	353						
(max) (lawlor <b>O</b> )	4.000						
ρ (gas) (kg/m3) =	1.203						
V (m3/s)	6.24						
Smoke level calculations							
Elapse time from sprinkler activation (s) Tas (s)	37700		Time from	start of fire (s)	37910		
$H_s = H_b - (V_s T_s + V_{totalAS}) / (B_L B_W)$							
Bottom elevation of smoke layer Hs (m) =	3.00			smoke height	0 m	+ 3 m =	3 m
Smoke layer contents calculations							
USED POLYURETHANE AS DATA		weight	moles	survibility	ppm		
Soot concentration (g/g)	0.133						
CO2 concentration (g/g)	1.55	3851016.27	87523.1	0	8918.32	0.89	% crtical at 2%
CO concentration (g/g)	0.01	24845.27	887.3	33	90.42	387.10	time(min)
HCI concentration (g/g)	0.0015	3726.79	103.5	52	10.55 crit	ical = 100	
HCN concentration (g/g)	0.0006	1490.72	. 55.2	21	5.63 crit	ical = 180	
Heat release Hch (kj/g)	18						
Volume (m3)	235632						
Moles of air	9813857						
Mass consumption (g/s)	66						
Total mass	2484527						
soot concentration g/m3 Cs	1.397		is mass cor	nsumed / volume			
Visibility							
Km	6.0						
K=Km soot	8.383						
Visibility of reflective signs	0.36		3 / (Km x C	cs)			

437.4715

#### PLATEFORM EXITING

#### Exiting times based on Ontario Building Code

$$T_{egress} = \left(H_p + \frac{V_p}{1.6} + \frac{H_m}{1.3} + 10N_{lg} + 5N_k\right) 1.5$$

Horizontal Travel Distance Rack Hp (m) vertical travel distance rack Vp (m) Horizontal Travel Distance floor Hm (m)	0 0 140.0	
Number of gates - Rack Nig number of crossing - stairs rack Nk	2 2	
	unit	total
time to get to the stairs (s)	0	0
time to cross obstuctions	45	45
time to get to ground level (s)	0	45
time to exit ground level (s)	162	207

EXITING CALCULATIONS	4th LEVEL	SMOKE LEVEL 3 m	
BUILDING			
Building height	Bh	4.27 m	
Building length	BI	284 m	
Building width	Bw	150 m	
Height of the base of fire	Zo	0.5 m	
HEAT RELEASE CALCULATIONS			
Fire groth $Q = \alpha t^2$			
Slow fire $a = 0.0066$ Medium fire $a = 0.02675$ Fast fire $a = 0.0469$ Ultra fast fire $a = 0.1876$ Time calculations to reach tempearture to activate Time 1 (s)	sprinklers 120		
a	0.02675		
Q (kW) =	385.20	AS activation 155	
Heat release rate	30 kw/m2	Heat release verification for smoke to rea	ach ceiling
			14.1 \] <sup>3</sup>
Smoke height calculations		$z_{max} = \left[Q_C^{2/3}\right]_{L}$	$\frac{1}{\Delta T_{min}} = 0.0026$
Time	Ts		
Smoke height	Sh	d I min (deg C)= Qc (kW) =	2 385.20
Ceiling iet temperature calculations		Zmax (m) =	35.42 au dessus du niveau du sol
Temperature ambient	T (deg C)	20	
Ceiling (sprinkler) beight from floor	Hr	4 Sprinkler beight	
Ceiling height from base of fire	Н	3.5	
Horizontal distance from center of fire	r	1.5	
For r < 0.18 H $T_{max} = 16.9 \frac{Q^{2/3}}{H^{5/3}} + T_{\infty}$			
For r > 0.18 H $T_{max} = 5.38 \frac{Q^{2/3}/H^{5/3}}{\left(r/_{H}\right)^{2/3}} + T_{\infty}$			
Maximum Temperature (deg C)	82.10	at ceiling (sprinkler) height	
Ceiling jet velocity calcualtions			
for r<0.15 H $u_{max} = 0.96 \left(\frac{Q}{H}\right)^{1/3}$			
for r > 0.15 H $u_{max} = 0.195 \frac{\left(\frac{Q}{H}\right)^{1}}{\left(\frac{r}{H}\right)^{5}}$	/3		
Maximum jet velocity Umax =	1.89	at celing (sprinkler ) height	
Sprinkler activation calculations			
$t_r = \frac{RTI}{1/2} ln \left( \frac{T_g - T_a}{T_c - T_c} \right)$			
$u^{1/2}$ $(T_g - T_r)$		STANDARD	80 TO 100
Sprinkler response factor RTI (98) Sprinkler activation temperature (deg C)	25 73	QR STANDARD ESFR	40 TO 50 25 TO 30
Time for sprinklers to open T 2 (s) Time for sprinklers to open from start of fire (s)	35 155	time calculated from time 1 time calculated T1 +T2	
Mass flows calculations			
$\dot{m} = 0.071 Q_c^{1/3} (z - z_0)^{5/3} \left[ 1 + 0.026 Q_c^{1/3} \right]$	$\left[ \frac{2}{c}^{2}(z-z_{0})^{-5/3} \right]$		
Qc (kW) = 0.7Q =	269.64		
calculation of effective fire height $z =$ Base of the fire height Zo	2.65		
mass now in (ky/s) =	2.10		

#### Volumetric flows calculations

Volume of smke at sprinkler activation T1+T2

Volumetric flows - steady state

$$\dot{V} = \frac{\dot{m}}{\rho_p}$$
 
$$\rho_p = \rho \frac{T_\infty}{T_p}$$

T (deg K) Тр (deg K)	293 355						
ρ (gas) (kg/m3) =	1.203						
V (m3/s)	2.16						
Smoke level calculations							
Elapse time from sprinkler activation (s) Tas (s)	24900		Time from	start of fire (s)	25020		
$H_s = H_b - (V_s T_s + V_{totalAS}) / (B_L B_W)$							
Bottom elevation of smoke layer Hs (m) =	3.00			smoke height	0 m	+ 3 m =	3 m
Smoke layer contents calculations USED POLYURETHANE AS DATA	v 0.100	veight	moles	survibility	ppm		
Soot concentration (g/g) CO2 concentration (g/g) CO concentration (g/g)	0.133 1.55 0.01	829913.40 5354.28	18861.6 191.2	57 22	8394.44 85.10	0.84 % 411.26 tir	o crtical at 2% me(min)
HCI concentration (g/g) HCN concentration (g/g)	0.0015	803.14 321.26	11.9	90 10	9.93 cm 5.30 cri	tical = $100$	
Heat release Hch (kj/g)	18						
Volume (m3) Moles of air Mass consumption (g/s) Total mass soot concentration g/m3 Cs	53949 2246923 21 535428 1.316		is mass cor	nsumed / volume			
Visibility Km K=Km soot	6.0 7.898						

0.38

3 / (Km x Cs)

110.1716

# PLATEFORM

Visibility of reflective signs

#### EXITING

#### Exiting times based on Ontario Building Code

$$T_{egress} = \left(H_p + \frac{V_p}{0.6} + \frac{H_m}{1.3} + 10N_{lg} + 5N_k\right) 1.5$$

Horizontal Travel Distance Rack Hp (m) vertical travel distance rack Vp (m) Horizontal Travel Distance floor Hm (m)	0 0 140.0	
number of gates - Rack Nig number of crossing - stairs rack Nk	2	
	unit	total
time to get to the stairs (s)	0	0
time to cross obstuctions	45	45
time to get to ground level (s)	0	45
time to exit ground level (s)	162	207

APPENDIX C

PLANS





UND PIPING O JCTILE IRON W NUTS, BOLTS, HLY COATED W H CSA UL APP E ELBOWS ARI IESTED BY MA HE P.I.V.'S TO 'HE FINISHED OVIDE PULL B OF GRADE LE VINGS FOR DE	N SITE. VITH MECHANICA WASHERS, CLAN WITH A BITUMING E TO BE LONG RA NUFACTURER. C THE BUILDING. T FLOOR. INSTALL SOX AS REQUIRE VELS TO PROVIE TAILS, TRENCHIN	AL JOINTS. MPS, AND OTHER DUS OR OTHER FINGS FOR ADIUS. THE CONTRACTOR IS THE CONDUIT CAPS AT THE END D BY CODE AND DE ADEQUATE NG, COMPACTION					
	-2500 						
	л л л л л	л л л л л	I I I I I I	I I I I I I I			I I I I I I I
	I I I I I I I I	T T T T T T T T	I I I I I I I	I I I I I I I I		х 	
			I H H H H H H H H H H H H H H H H H H H				

R







<b>PRE</b> NC FOR	<b>ELIMINARY</b> T TO BE USED CONSTRUCTION

1	2020-03-18	ISSUED FOR OVERALL 33% REVIEW	MAL
No.	Date	Revision	Ву
	202	0-05-21 4:18:57 PM	

PYTHON

<text><section-header><section-header><section-header><section-header><text><text><text>

FOLIO: 2002-04A

C:\DATA-1\ARCHIVE mon ordi\2002-04A - PYTHON\REVIT SPA\FP\_PYTHON\_2002-04A\_MAIN MODEL\_2020.rvt 2020-05-21 4:18:57 PM

**FPU1** R1



2 PUMP ROOMS 3D (2)



# 1 PUMP ROOMS 3D



# **PRELIMINARY** NOT TO BE USED FOR CONSTRUCTION

No.	Date	Revision	By
	202	0-01-01 5·10·03 PM	
	202	0-04-01 J.40.05 PIVI	

PYTHON

Copyright Civelec Consultants inc Not to be used for any other
project without the engineer' written consent. All dimensions and conditions
nust be verified on site. Do not scale drawings. Any discrepancies or
omissions in the drawing shall be reported to the engineer immediately in
vriting. All work to conform to most recent applicable norms, bylaws and
odes for all given trades.

FIRE PROTECTION

PUMP ROOMS - 3D

DRAWN BY: M.A.L. CHECKED BY: P.L.

SCALE:

BIM 360://PYTHON/FP\_PYTHON\_2002-04A\_MAIN MODEL\_2020.rvt 2020-04-01 5:40:03 PM

FOLIO: 2002-04A **FP54** 









PUMP ROOMS <u>LEVEL</u> <u>98,933</u> <u>98,781</u>





PUMP ROOMS <u>LEVEL</u> + <u>98,933</u> <u>COUR</u>T + <u>98,781</u>

2 Section 30









PRE NC	<b>ELIMINARY</b> OT TO BE USED
FOR	CONSTRUCTION

No.	Date	Revision	Ву
	202	0-04-01 5:40:23 PM	

PYTHON

<b>copyright Civelec Consultants inc.</b> - Not to be used for any other roject without the engineer' written consent. All dimensions and conditions nust be verified on site. Do not scale drawings. Any discrepancies or missions in the drawing shall be reported to the engineer immediately in writing. All work to conform to most recent applicable norms, bylaws and odes for all given trades.

FIRE PROTECTION PUMP ROOMS - CROSS SECTIONS

DRAWN BY: M.A.L. CHECKED BY: P.L.

SCALE: 1:25

BIM 360://PYTHON/FP\_PYTHON\_2002-04A\_MAIN MODEL\_2020.rvt 2020-04-01 5:40:23 PM

FOLIO: 2002-04A **FP56** 

# FIRE PROTECTION STUDY FOR

# **PROJECT PYTHON**

OTTAWA, ONTARIO

ALTERNATIVE SOLUTION FOR FIRE RATING



FIRE PROTECTION STUDY FOR

# **PROJEC PYTHON**

# OTTAWA, ONTARIO

ALTERNATIVE SOLUTION FOR FIRE RATING

Prepared by

Civelec Consultants Inc. 3900 Cote Vertu, suite 200 St. Laurent, Québec H4R 1V4

Paul Lhotsky, PhD, P. Eng.



May 15 2020



1.	Executive Summary	1
2.	Building Description	2
3.	Description for floor structure	2
4.	Code Requirements	3
5	Code Compliance	4
6.	Requirements for Alternative Solution	4
7.	Fire resistance	5
7.1	Code requirements and objectives	5
7.2	Fire resistance proposal	7
7.3	Fire modeling	8
8.	Reliability analyses	11
9.	Design and Construction Requirements	11
10.	Conclusion	12
11.	Copyright	12

PLANS	APPENI	DIX "A"
-------	--------	---------



### 1. Executive Summary

- 1.1 The developer is planning to build a semi-automated light industrial sort center. The building will be approximately 58,222 m<sup>2</sup> on the ground floor including 3280 m2 of offices. The ground floor will have approximately 25,427 m2 of mezzanines. The building will also have additional 4 levels of robotic sorting platforms each having an area of 45,075 m2. The building is considered 6 storeys high (5 stories and mezzanine that is calculated as a floor in building height). The ground floor will be approximately 8.53 m (28 ft) high with mezzanine levels located at approximately 4.27 m (14 ft) height. The robotic platforms will be 4.27 m (14 ft) high and the top platform roof will be 4.57 m (15 ft) above the platform.
- 1.2 The ground floor and mezzanines will be used for packaging shipping and receiving. This area will have numerous conveyers and automated handling systems. 2<sup>nd</sup>, 3<sup>rd</sup> 4<sup>th</sup> and 5<sup>th</sup> floors (robotic platforms) will be used for a sorting area and manual picking sector on the perimeter of the building. The merchandise is placed in special pods that are 2.616 m (8 ft 7 in) high. The individual items are located in the pods. The pods are delivered to the picking stations by robots. The individual items are loaded into the pods or removed from the pods. The items are transported to the ground floor by conveyer systems typically in open plastic totes. The pods stationary and delivery area has restricted access and is not occupied during normal operation.
- 1.3 Due to the building and floor construction and use, the building structure will have an equivalent fire resistance rating of 2 hours. And the fire resistance shall be determined on the basis of the results of tests conducted in conformance with *CAN/ULC-S101*, *"Fire Endurance Tests of Building Construction and Materials"*. This alternative solution is for the Ontario Building Code article 3.2.2.67 and 3.1.7.1
- 1.4 Our alternative solution is to meet the Objectives and Functional Statements that are: An objective is to retard the effects of fire on areas beyond its point of origin and to retard failure or collapse due to the effects of fire.
- 1.5 Part B of OBC requires sprinkler protection and physical fire resistance rating that have the same objectives. In summary OBC requires a redundant system to control fire spread and collapse of the building.
- 1.6 The alternative solution is to use a special sprinkler head and high sprinkler density to extinguish the fire rather than to only control the fire.
- 1.7 The reliability of the sprinkler system will be increased by providing two independent water supplies, two fire pumps and water supply loops so that any one impairment in the water supplies can be isolated and provide adequate water supply to the sprinkler system.



1.8 For detailed code study see Appendix A.

## 2. Building Description

- 2.1 The building will be approximately 58,222 m<sup>2</sup> on the ground floor including 3280 m2 of offices. The ground floor will have approximately 25,427 m2 of mezzanines. The building will also have additional 4 levels of robotic sorting platforms each having an area of 45,075 m2. The building is considered 6 storeys high. The ground floor will be approximately 8.53 m (28 ft) high with mezzanine levels located at approximately 4.27 m (14 ft) height. The robotic platforms will be 4.27 m (14 ft) high and the top platform roof will be 4.57 m (15 ft) above the platform.
- 2.2 The ground floor will be used for packaging shipping and receiving. This area will have numerous conveyers and automated handling systems. 2<sup>nd</sup>, 3<sup>rd</sup>, 4<sup>th</sup> and 5<sup>th</sup> floors will be used for a sorting area and manual picking sector on the perimeter of the building. The merchandize is placed in special pods that are 2.616 m (8 ft 7 in) high. The individual items are stored in the pods. The pods are delivered to the picking stations by robots. The individual items are loaded into the pods or removed from the pods. The items are transported to the ground floor by conveyer systems typically in open plastic totes. The pods sorting and delivery area has restricted access and is not occupied during normal operation.
- 2.3 Typical merchandize consist of combination of class 2, 3, 4 and class A non-expanded cartooned plastics as defined by NFPA 13. Due to the plastic totes and pods, the commodity is classified as exposed non-expanded class A plastics.
- 2.5 The building will be approximately 28.65 m (94 ft) high.
- 2.6 The semi-automated conveyer system will be used for transport of goods. As the actual sorting and conveyer plans are not yet available, we have used plans for a similar use building that are provided in appendix D
- 2.7 See appendix C for plans.

# **3.** Description for floor structure

- 3.1 The floors for 2<sup>nd</sup>, 3<sup>rd</sup>, 4<sup>th</sup> and 5<sup>th</sup> level are to have a 7 in concrete slab on a beam and joist supporting structure.
- 3.2 The concrete slab will have approximately 2 to 2.5 hr. of fire resistance as per OBC.
- 3.3 The alternative solution is for the beams, joists as well as for the columns. The beams, joists and columns are to be steel.



#### 4. Code Requirements

- 4.1 The OBC 3.2.2.67. states: Group F, Division 2, Any Height, Any Area, Sprinklered
  - (1) Except as permitted by Articles 3.2.2.68. to 3.2.2.72., a building classified as Group *F*, Division 2 shall conform to Sentence (2).
  - (2) Except as permitted by Article 3.2.2.16., the building referred to in Sentence (1) shall be of noncombustible construction, and,
    - (a) except as permitted by Sentence 3.2.2.7.(1), the building shall be sprinklered,
    - (b) floor assemblies shall be fire separations with a fire resistance rating not less than 2 h,
    - (c) mezzanines shall have a fire-resistance rating not less 1 h, and
    - (d) loadbearing walls, columns and arches shall have a fire-resistance rating not less than that required for the supported assembly.
- 4.2 The OBC defines fire resistance as: *Fire-resistance rating means the time in minutes or hours that a material or assembly of materials will withstand the passage of flame and the transmission of heat when exposed to fire under specified conditions of test and performance criteria, or as determined by extension or interpretation of information derived from that test and performance as prescribed in this Code.*
- 4.3 The OBC article 3.1.7.1. Determination of Ratings states:
  - (1) Except as permitted by Sentence (2) and Article 3.1.7.2., the rating of a material, assembly of materials or a structural member that is required to have a fire-resistance rating, shall be determined on the basis of the results of tests conducted in conformance with CAN/ULC-S101, "Fire Endurance Tests of Building Construction and Materials".
- 4.2 Ontario Building Code has a special section that deals with "Shelf and Rack Storage Systems". Even though we do not consider the automated sorting system configuration to be a "Shelf and Rack Storage" the use is similar.
- 4.3 Ontario Building Code does not require fire resistance rating for a "Shelf and Rack Storage System."
- 4.4 OBC article 3.2.8.2 (3) states: *"If a closure in an opening in a fire separation would disrupt the nature of a manufacturing process, such as a continuous flow of material from storey to storey, the*



closure for the opening is permitted to be omitted provided precautions are taken to offset the resulting hazard."

4.5 Typical protection of openings between floors as described above is provided by installing "a water curtain" – sprinklers located at the perimeter of the opening at every 6 ft. where the opening can create a chimney effect.

# 5 Code Compliance

- 5.1 The OBC provides two alternatives to comply to the code.
- 5.2 One option is to use the descriptive design of Part B of the OBC and if this part B is used for the design it is assumed that the objectives of Part A of OBC are met.
- 5.3 The second option is to use the objectives and functional statements of the code. The design requires to present an alternative solution with a proof of meeting the objectives of Part A of OBC.

# 6. Requirements for Alternative Solution

6.1 The OBC article 1.2.1.1 states: Complience with Division B

(1) Complience with Division B shall be achieved,

- (a) by complying with the applicable acceptance solution in Division B, or
- (b) by using alternative solutions that will achieve the level of performance required by the applicable acceptable solutions in respect of objectives and functional statements attributed to the acceptable solutions in Supplementary Standard SA-1.
- (2) For the purposes of Clause (1)(b), the level of performance in respect of functional statement refers to the performance of the functional statements as it relates to the objective with which it is associated in Supplementary Standard SA-1.

Clause A-1.2.1.1.(1)(b) states: "Where a design differs from the acceptable solutions in Division B, then it should be treated as an "alternative solution." A proponent of an alternative solution must demonstrate that the alternative solution addresses the same issues as the applicable acceptable solutions in Division B and their attributed objectives and functional statements. However, because the objectives and functional statements are entirely qualitative, demonstrating compliance with them in isolation is not possible. Therefore, Clause 1.2.1.1.(1)(b) identifies the principle that Division B establishes the quantitative performance targets that alternative solutions must meet. In many cases, these targets are not defined very precisely by the acceptable solutions — certainly far less precisely than would be the case with a true performance code, which would have quantitative performance targets and prescribed methods of performance measurement



for all aspects of building performance. Nevertheless, Clause 1.2.1.1.(1)(b) makes it clear that an effort must be made to demonstrate that an alternative solution will perform as well as a design that would satisfy the applicable acceptable solutions in Division B – not "well enough" but "as well as."...

# Applicable Acceptable Solutions

In demonstrating that an alternative solution will perform as well as a design that would satisfy the applicable acceptable solutions in Division B, its evaluation should not be limited to comparison with the acceptable solutions to which an alternative is proposed. It is possible that acceptable solutions elsewhere in the Code also apply. The proposed alternative solution may be shown to perform as well as the most apparent acceptable solutions. For example, an innovative sheathing material may perform adequately as sheathing in a wall system that is braced by other means but may not perform adequately as sheathing in a wall system where the sheathing must provide the structural bracing. All applicable acceptable solutions."

# 7. Fire resistance

# 7.1 Code requirements and objectives

7.1.1 The applicable objectives and functional statements as summarized by the OBC SA-1 table 3 are the following:

3.2.2.67. Group F, Division 2, Any Height, Any Area, Sprinklered				
(2) d		[F3, F4–OP1.2] [F04-OP1.3]		
(2)d		[F3, F4–OS1.2] [F04-OS1.3]		

and

3.1.7.1. Determination of Ratings				
(1)	[F3–OP1.2] [F04-OP1.3]			
(1)	[F3–OS1.2] [F04-OS1.3]			

7.1.2 The objectives of the Code are achieved by measures, such as those described in the acceptable solutions in Division B, that are intended to allow the *building* or its elements to perform the following functions:



7.1.3 The functional statements are:

F03 To retard the effects of fire on areas beyond its point of origin.

F04 To retard failure or collapse due to the effects of fire.

7.1.4 The objectives are:

OP1 An *objective* of this Code is to limit the probability that, as a result of its damage due to fire.

OP1.2 An *objective* of this Code is to limit the probability that, as a result of its design or *construction*, a *building* will be exposed to an unacceptable risk of damage due to fire caused by fire or explosion impacting areas beyond its point of origin.

OP1.3 An *objective* of this Code is to limit the probability that, as a result of its design or *construction*, a *building* will be exposed to an unacceptable risk of damage due to fire caused by collapse of physical elements due to a fire or explosion.

OS 1 An *objective* of this Code is to limit the probability that, as a result of the design or *construction* of a *building*, a person in or adjacent to the *building* will be exposed to an unacceptable risk of injury due to fire.

OS1.2 An *objective* of this Code is to limit the probability that, as a result of the will be exposed to an unacceptable risk of injury due to fire caused by fire or explosion impacting areas beyond its point of origin.

OS1.3 An *objective* of this Code is to limit the probability that, as a result of the design or *construction* of a *building*, a person in or adjacent to the *building* will be exposed to an unacceptable risk of injury due to fire caused by the collapse of physical elements due to a fire or explosion

- 7.1.6 To summarize the code objectives, the fire resistance required by OBC is there to limit the fire spread and to provide protection from heat in case of fire to minimize the possibility of a structural failure that could eventually cause a collapse.
- 7.1.7 The OBC requires a redundancy in the control of the fire spread and structural failure.
- 7.1.8 The OBC part B uses passive protection is provided by using insulation to limit the temperature from affecting the structural strength of steel members and by limiting temperature on the non-fire-exposed side from igniting combustibles. This fire resistance requirement will not limit the fire spread horizontally and if the floors have openings as permitted by article 3.2.8.2 (3), the fire resistance rating will not limit the fire spread to adjacent floor.



- 7.1.9 The OBC part B uses sprinklers as active protection to limit the extend of the fire spread. OBC part B does not require to use sprinklers that will extinguish the fire but requires the sprinkler design to at least control the fire within the sprinkler operation design area.
- 7.1.10 To summarize, OBC uses sprinkler system to limit the fire spread and uses the passive fire resistance to prevent structural collapse and ignition of combustibles on non-fire-exposed surface of the fire rated division.

## 7.2 Fire resistance proposal

- 7.2.1 We propose to install a sprinkler system that is designed to extinguish that fire rather than to only control the fire. This alternative solution is to meet two objectives, one is to limit the spread of fire and the second one is to prevent a collapse.
- 7.2.2 Providing a fire resistance on beams, joists and columns does not prevent the fire spread on the same floor level or from spreading to another floor if there are openings as permitted by article 3.2.8.2(3). Providing a sprinkler system that will extinguish the fire, the fire spread is eliminated and the objectives to limit the fire spread are achieved and exceed the performance to the minimal design based on OBC part B.
- 7.2.3 We propose to provide two (2) independent water supplies, two (2) fire pumps, each able to provide adequate flow and pressure, totally redundant water supply piping that can provide adequate water supply with any one piping impairment. This system redundancy will provide structural collapse protection comparable to the physical protection provided by fire resistance coating when installed as per part B of OBC.
- 7.2.4 The combustible load on 2<sup>nd</sup> and 3<sup>rd</sup> floor is classified as class 4 commodity and cartooned type A plastics. The worst case scenario is to classify the storage as uncartoned class A plastics.
- 7.2.5 NFPA 13 2013 figure 15.2.2 provides guidance as to the application of table 15.2.6 (a) to determine the sprinkler density. The worst case classification is solid piled non-expanded, non-cartooned class A plastics that are not stable as the contents of pods would fall out as the pods would burn. The required sprinkler density as per column A of figure 15.2.2 of NFPA 13 is 0.20 gpm/ft<sup>2</sup>.
- 7.2.5 In order to provide better protection for the beams, joists and columns we have decided to use an extended coverage K25.2 sprinkler head that will provide larger percentage of water that will flow onto the structural elements beams, joists and columns.
- 7.2.6 NFPA 13 does not have specific design criteria for K25.2 extended coverage sprinkler. FM Global requirements for the design using pendent K 25.2 extended coverage fast response sprinklers are as follows:



To protect class 4 and cartooned plastics up to 12 ft with a 15 ft high ceiling, flow 6 sprinklers at 30 psi – In our case this translates to a minimum density of 1.19 gpm/ft<sup>2</sup> and flowing 828 gpm.

To protect un-cartooned plastics up to 12 ft with a 15 ft high ceiling, flow 12 sprinklers at 7 psi – In our case this translates to a minimum density of 0.57  $gpm/ft^2$  and flowing 800 gpm.

To protect un-cartooned plastics up to 17 ft with a 20 ft high ceiling, flow 8 sprinklers at 20 psi – In our case this translates to a minimum density of 0.97  $gpm/ft^2$  and flowing 902 gpm.

- 7.2.2 We propose to use K 25.2 EC QR sprinklers rated at 155 deg F. (see sprinkler data sheet Appendix "B"). The design should be flowing 8 sprinklers at 40 psi. This design will provide a minimum density of 1.12 gpm/ft<sup>2</sup>.
- 7.2.3 NFPA 13 article 17.1.4.1 states that the steel protection (fire rating) can be provided with sprinklers having a density of 0.68 gpm/ft<sup>2</sup> or by using CMSA or ESFR sprinklers. The K 25.2 EC QR is considered as ESFR and CMSA sprinkler.

# 7.3 Fire modeling

- 7.3.1 OBC requires that the fire resistance rating is based on CAN/ULC S101 test. The test consists of exposing the tested assembly to temperature that increases as per the standard time temperature curve. The temperature of the standard time temperature curve at 2 hr is 1750 deg F.
- 7.3.2 The heat transfer to the water flow protecting the structural elements can be calculated as:

Q = K(Ta-Ts)A

Where: K heat transfer coefficient approximately 50 w/m<sup>2</sup>K Ta air temperature (K) Ts water temperature (K) A surface  $m^2$ 

Q = 50 (1227-293)1 = 46,700 W/m<sup>2</sup>

Specific heat of water is 4.186 j/g

Therefore 1 L of water heated from 20 deg to 80 deg C will absorb 4.186 KJ x 60 = 251.15 KJ



If we want to limit the water temperature to maximum increase from 20 deg to 80 deg C we need to absorb 46,700 W / 60 = 778.4 W.

Therefore we need 778.4 / 4.186 = 185.9 g/s of water per m<sup>2</sup>.

0.1859 L = 0.0491 gal.

 $1 \text{ m}^2 = 10.76 \text{ ft}^2$ .

Therefore required density =  $60 \times 0.0491 / 10.76 = 0.2737$  gpm/ft<sup>2</sup>

As the proposed sprinkler density is  $1.12 \text{ gpm/ft}^2$  we need that 25% of the water be projected onto the surface. For this reason we have selected the extended coverage sprinklers.

- 7.3.3 The similar water cooling is also part of the OBC that has an option to provide 2 hr fire resistance using window sprinkler.
- 7.3.4 We have calculated the maximum air temperature at the ceiling level at the time of sprinkler activation. As per our calculations the maximum air temperature at the ceiling of the ground floor is 91 deg C and at the 2<sup>nd</sup>, 3<sup>rd</sup>, or 4<sup>th</sup> floor ceiling the maximum temperature is 86 deg C. See appendix E for calculations.
- 7.3.5 Our model is based on equations from graduate courses of Fire Dynamic at Carleton University for fire that is not oxygen controlled.
- 7.3.6 UL, Civelec Consultants and Harrington Group (fire protection consultants) have made a full scale test using the K25 EC QR pendent sprinkler and the proposed structural assembly at UL test center in Chicago. In the experiment using a full-scale test with the same structural configurations and elevations two (2) K25.2 EC QR sprinklers opened and extinguished the fire and the maximum air temperature and sprinkler activation times were very similar to our calculated results. During one series of tests, we have used 20 psi end head pressure and in another series of tests we have used 30 psi end head pressure. Similar results were obtained and in both series the fire was extinguished. (We propose to use 40 psi end head pressure).

# 7.3.7 Test Procedure

ULC, UL and NFPA provide standard procedures for evaluating performance of 7.3.1 materials, assemblies under fire conditions, for example CAN/ULC S101 test will evaluate the fire resistance of an assembly. ULC, UL, NFPA and FM also developed standards for testing heat release, smoke release and fire propagations. These test



standards are used to provide information if the use of these materials is acceptable with respect to the building codes.

- 7.3.2 The actual fire protection codes are developed based on fire modeling, small scale fire tests and large scale fire tests. There are no specific procedures developed for these tests as the objectives and configurations vary for majority of tests.
- 7.3.3 The full scale tests are usually performed in specially designed facilities that are equipped with sophisticated monitoring and measuring systems. In most of the cases, the tests are financed by insurance companies, by private organizations and by Governments. Some of the test results are not disclosed and some are published and used to developed fire protection standards.
- 7.3.4 In Canada the building codes use NFPA as a reference code for the design of fire protection systems. Most of the design criteria in NFPA is based on full scale fire tests that were conducted by different organizations, for example FM Global research (FMRC), Spacesaver Corporation, Southwest Research institute etc.
- 7.3.5 As we needed to determine the maximum temperatures at the ceiling level and also to determine the fire protection design criteria that would reduce the fire spread (based on NFPA 13 the standard sprinkler system will limit the fire spread to 2,500 ft2. In our case we have limited the fire spread to 260 ft2 (2 sprinklers operating) during the tests and are designing the sprinkler system up 1,150 ft2 (8 sprinklers operating).
- 7.3.6 Most of the test facilities use the same ignition procedure and calibration of monitoring systems. This was also the case for the UL test. The ignition was achieved with two standard half igniters, which are 76 mm x 76 mm (3 in. x 3 in.) cylinders of rolled cellu-cotton. Each igniter is soaked in 118 ml (4 oz.) of gasoline and sealed in a plastic bag, The igniters were placed in an offset ignition orientation, in the center transverse flue, between the pods. The igniters were lit with a flaming propane torch at the start of each test and the fires were allowed to develop naturally.

Documentation for each test included video, still photography, and pertinent measurements necessary to evaluate sprinkler performance. All instrumentation was calibrated in accordance with ISO 17025

- 7.3.7 We have also tested the sprinkler effectiveness with obstruction to the water distribution having 3 in sprinkler piping spaced at 6 in center to center obstructing water distribution from 3 sprinkler heads. The fire was extinguished with 3 sprinklers operating. We expect to use ESFR sprinkler obstruction rules, but the results demonstrate that if these rules cannot be adhered to 100% we still expect the system to extinguish the fire.
- 7.3.8 The sprinkler protection for structure is based on a fire that is controlled by the sprinkler system. The OBC requires the sprinkler protection as well as the passive protection by



providing an insulation that will protect the structure to reach temperatures close to 500 deg C - temperature when the structural elements strength is reduced.

7.3.9 The OBC passive protection of the structure will work relatively well if the fire is below the protected structure. The OBC does not require fire resistance protection for the roof and the structural elements supporting the roof. The OBC permits that possible collapse protection for the roof is solely provided by the sprinkler system. If the roof of the building collapses due to the fire, typically the floors below will also collapse as the structure is not normally designed to withstand the impact and forces caused by the collapsing roof structure. We can conclude that sprinkler system can provide an adequate protection against a collapse in case of a fire.

## 8. Reliability analyses

- 8.1 The OBC requires an additional structural fire protection using a passive protection and to provide sprinklers that will control the fire. To have an acceptable alternative solution, the probability of a structural collapse due to the fire should be comparable to the reliability when the design is based on the part B of OBC.
- 8.2 In case of a sprinkler system failure the structural protection from collapse is provided by the passive fire resistance of the structure. As mentioned before this passive protection is only applicable if the fire occurs below the protected structure.
- 8.3 The majority of sprinkler system failure is due to problems with the water supplies. In our case we will provide two independent water supplies, each adequate for the required sprinkler flows. The water supply mains will be arranged that any impairment can be isolated and the sprinkler system will be fully functional with the impairment. The water pressure will be increased using two diesel drivel fire pumps, each designed to provide adequate water pressure for the operation of the sprinkler system. The fire pumps will be in separate fire compartments 2 hr fire rated, in a pump house that is located outside of the building.
- 8.4 All sprinkler control valves, fire pump operation etc. will be monitored by the local fire alarm panel that will signal the trouble signal to the maintenance. In addition these trouble signals will be transmitted to the central station as per the OBC.
- 8.5 With the water supply redundancy, the risk of collapse of the structure is comparable or lower than the risk when the building fire resistance is designed to part B of OBC.

#### 9. Design and Construction Requirements

- 9.1 The design of the sprinkler system must meet the conditions of this report.
- 9.2 The system must be designed by a professional engineer licensed in Ontario.



9.3 The system must be inspected and certified by a P. Eng. representing our office.

## 10. Conclusion

10.1 This code equivalency report is based on OBC, NRC, UL full scale test using actual fire loads and configuration, FM Global data sheets and NFPA. The analyses are based on graduate courses – fire dynamics at Carleton University in fire protection. The calculations demonstrate that adequate collapse protection and fire spread protection will be provided if the sprinkler system and water supplies will be designed and installed as per this report.

# 11. Copyright

11.1 This document and its technical contents is a property of Civelec Consultants Inc. This document is confidential and is distributed under condition that the document not be reproduced, copied, circulated in part or in its entirety. It shall not be used in any matters that can cause prejudice directly or indirectly to Civelec Consultants Inc. and or be released to its competitors without the prior consent and written permission of Civelec Consultants Inc.



APPENDIX A

PLANS







UND PIPING O JCTILE IRON W NUTS, BOLTS, HLY COATED W H CSA UL APP E ELBOWS ARI IESTED BY MA HE P.I.V.'S TO 'HE FINISHED OVIDE PULL B OF GRADE LE VINGS FOR DE	N SITE. VITH MECHANICA WASHERS, CLAN WITH A BITUMING E TO BE LONG RA NUFACTURER. C THE BUILDING. T FLOOR. INSTALL SOX AS REQUIRE VELS TO PROVIE TAILS, TRENCHIN	AL JOINTS. MPS, AND OTHER DUS OR OTHER FINGS FOR ADIUS. THE CONTRACTOR IS THE CONDUIT CAPS AT THE END D BY CODE AND DE ADEQUATE NG, COMPACTION					
	-2500 						
	л л л л л	л л л л л	I I I I I I	I I I I I I I			I I I I I I I
	I I I I I I I I	T T T T T T T T	I I I I I I I	I I I I I I I I		х 	
			I H H H H H H H H H H H H H H H H H H H				

R







PRE NC FOR	<b>ELIMINARY</b> T TO BE USED CONSTRUCTION

1	2020-03-18	ISSUED FOR OVERALL 33% REVIEW	MAL	
No.	Date	Revision	Ву	
2020-05-21 4:18:57 PM				

PYTHON

<text><section-header><section-header><section-header><section-header><text><text><text><text>

FOLIO: 2002-04A

C:\DATA-1\ARCHIVE mon ordi\2002-04A - PYTHON\REVIT SPA\FP\_PYTHON\_2002-04A\_MAIN MODEL\_2020.rvt 2020-05-21 4:18:57 PM

**FPU1** R1



2 PUMP ROOMS 3D (2)



# 1 PUMP ROOMS 3D



# **PRELIMINARY** NOT TO BE USED FOR CONSTRUCTION

No.	Date	Revision	By			
	202	0-01-01 5·10·03 PM				
	202	2020-04-01 J.40.03 F W				

PYTHON

Copyright Civelec Consultants inc Not to be used for any other
project without the engineer' written consent. All dimensions and conditions
nust be verified on site. Do not scale drawings. Any discrepancies or
omissions in the drawing shall be reported to the engineer immediately in
vriting. All work to conform to most recent applicable norms, bylaws and
odes for all given trades.

FIRE PROTECTION

PUMP ROOMS - 3D

DRAWN BY: M.A.L. CHECKED BY: P.L.

SCALE:

BIM 360://PYTHON/FP\_PYTHON\_2002-04A\_MAIN MODEL\_2020.rvt 2020-04-01 5:40:03 PM

FOLIO: 2002-04A **FP54** 







PUMP ROOMS <u>LEVEL</u> <u>98,933</u> <u>98,781</u>





PUMP ROOMS <u>LEVEL</u> + <u>98,933</u> <u>COUR</u>T + <u>98,781</u>

2 Section 30









<b>PRELIMINARY</b> NOT TO BE USED						
FOR CONSTRUCTION						

No.	Date	Revision	Ву	
2020-04-01 5:40:23 PM				

PYTHON

<b>copyright Civelec Consultants inc.</b> - Not to be used for any other roject without the engineer' written consent. All dimensions and conditions nust be verified on site. Do not scale drawings. Any discrepancies or missions in the drawing shall be reported to the engineer immediately in writing. All work to conform to most recent applicable norms, bylaws and odes for all given trades.

FIRE PROTECTION PUMP ROOMS - CROSS SECTIONS

DRAWN BY: M.A.L. CHECKED BY: P.L.

SCALE: 1:25

BIM 360://PYTHON/FP\_PYTHON\_2002-04A\_MAIN MODEL\_2020.rvt 2020-04-01 5:40:23 PM

FOLIO: 2002-04A **FP56** 



# Appendix B

Sanitary Servicing Information



#### **Detailed Building Use Sanitary Flows**

#### Daily Demands from OBC Table 8.2.1.3

Establishment	Daily Demand Volume		
Industrial Building:	150	L/day/loading bay	
	950	L/day/bathroom	
Commercial Office:	75	L/day/9.3m <sup>2</sup> Floor area	

Daily Demands from City of Ottawa Sewer Design Guidelines				
Establishment Daily Demand Volume				
Avg Commercial Flow	28000 L/ha/day			
Avg Commercial Flow	28000 L/ha/day			

Commercial / Industrial Peaking Factors City of Ottawa Sewer Design Guidelines

Building Use	Peaking Factor	
Commercial	1.5	Sewer Design Guidelines Appendix 4A
Industrial	3.5	Sewer Design Guidelines Appendix 4B

#### **Proposed Building Sanitary Flows**

	Commercial Office	Industrial Building	Guard House	Future Guard House	Totals
Floor Area	1559	N/A	26.3	26.3	
No. Bathrooms	N/A	100	N/A	N/A	
No. Loading Bays	N/A	56	N/A	N/A	
Total Daily Volume (Liters)	12572.6	103400.0	1972.5	1972.5	119917.6
Peak Building Sanitary Flow (L/s)	0.218	4.189	0.034	0.034	4.48

#### Future Development Area

Area (ha)	3.0
Total Daily Volume (Liters)	84840.0
Peak Building Sanitary Flow (L/s)	1.47

#### **Extraneous Flows**

	Extraneous Flow	Total Extraneous Flows		
Total Site Area (ha)	Alottment (L/s/ha)	(L/s)		
25.94	0.33	8.56		

#### **Total Site Peak Sanitary Flows**

	Future Development		
Total Peak Building Sanitary Flows	Area Sanitary Flows	Total Extraneous Flows	Total Site Peak Flows
(L/s)	(L/s)	(L/s)	(L/s)
4.48	1.47	8.56	14.51



				SCAL
				1.100
5	REVISED PER CITY COMMENTS	JUNE 1/2020	MJH	1.100
4	ISSUED FOR INTERNAL REVIEW	MAY 19/2020	MJH	
3	ISSUED FOR FOUNDATION PERMIT	MAY 5/2020	MJH	1.400
2	ISSUED FOR DESIGN REVIEW	APR 20/2020	MJH	0 10 20
1	APPLICATION FOR SITE PLAN APPROVAL	APR 6/2020	MJH	
No.	REVISION	DATE	BY	
Project No. 120025 Project Name: Project Python Project Location: 222 Citigate Drive, Ottawa



### Sanitary Sewer Design Sheet

	LOCATION			COMMERC	IAL / INDUT	RIAL FLOW						PI	PE		
AREA ID	FROM	то	AREA (ha)	ACCUM AREA (ha)	PEAK FACTOR	PEAK FLOW (I/s)	ACCUM PEAK FLOW (I/s)	INFIL. FLOW (I/s)	TOTAL PEAK FLOW (I/s)	PIPE SIZE (mm)	PIPE SLOPE (%)	LENGTH (m)	CAPACITY (I/s)	VELOCITY (m/s)	Q/Qfull
A-01	MH 12	MH 11	3.38	3.38	1.5	0.034	0.03	1.12	1.15	200	3.00	41.4	56.8	1.8	2.0%
	MH 11	MH 10	0.00	3.38	0.0	0.000	0.03	1.12	1.15	200	0.30	93.3	17.9	0.6	6.4%
	MH 10	MH 9	0.00	3.38	0.0	0.000	0.03	1.12	1.15	200	0.30	74.7	17.9	0.6	6.4%
A-02**	MH 9	MH 8	4.72	8.10	3.5	1.396	1.43	2.67	4.10	250	0.30	104.2	32.5	0.7	12.6%
	MH 8	MH 7	0.00	8.10	0.0	0.000	1.43	2.67	4.10	250	0.30	16.9	32.5	0.7	12.6%
	MH 7	MH 6	0.00	8.10	0.0	0.000	1.43	2.67	4.10	250	0.30	83.2	32.5	0.7	12.6%
A-03**	MH 6	MH 5	4.86	12.96	Varies*	1.615	3.05	4.28	7.32	250	0.30	73.6	32.5	0.7	22.5%
	MH 5	MH 4	0.00	12.96	0.0	0.000	3.05	4.28	7.32	250	0.30	20.3	32.5	0.7	22.5%
A-04**	MH 4	MH 3	4.66	17.62	3.5	1.396	4.44	5.81	10.26	250	0.30	103.8	32.5	0.7	31.5%
	MH 3	MH 2	0.00	17.62	0.0	0.000	4.44	5.81	10.26	250	0.30	86.4	32.5	0.7	31.5%
A-05	MH 2	MH 1	5.28	22.90	1.5	0.034	4.48	7.56	12.04	250	2.50	70.4	93.9	1.9	12.8%
	MH 1	EX STUB	0.00	22.90	0.0	0.000	4.48	7.56	12.04	250	2.50	8.0	93.9	1.9	12.8%
Future	STUB	MH 16	3.03	3.03	1.5	1.500	1.47	1.00	2.47	250	0.30	15.5	32.5	0.7	7.6%
	MH 16	MH 15	0.00	3.03	0.0	0.000	1.47	1.00	2.47	250	0.30	90.1	32.5	0.7	7.6%
	MH 15	MH 14	0.00	3.03	0.0	0.000	1.47	1.00	2.47	250	0.30	16.6	32.5	0.7	7.6%
	MH 14	MH 13	0.00	3.03	0.0	0.000	1.47	1.00	2.47	250	0.30	74.0	32.5	0.7	7.6%
	MH 13	EXMH 101	0.00	3.03	0.0	0.000	1.47	1.00	2.47	250	0.30	30.8	32.5	0.7	7.6%
							5.95	8.56	14.51						

\* Area A-03 contains commercial and industrial land uses with peaking factors of 1.5 and 3.5 respectively. Refer to the detailed building use sanitary flows for a comprehensive breakdown.

\*\* The Industrial portion of the building was divided evenly between the 3 proposed building services (areas A-02, A-03, and A-04).

### **Design Parameters:**

City of Ottawa Sewer Design Guidelines (Appendix 4-A)		
- Extraneous Flows	0.33	l/s/ha
- Commercial Peaking Factor	1.5	
City of Ottawa Sewer Design Guidelines (Appendix 4-B)		
Industrial Peaking factor	3.5	



#### SANITARY SEWER DESIGN SHEET

Citi Gate 416 Corporate Campus Phase 1 - As-Built



NOVATECH FILE NO.: 109203-0 CITY FILE NO.: D07-16-12-0023

DESIGNED BY: LAB

CHECKED BY: MER/MSP

PREPARED March 31, 2014

REVISED: August 10, 2014 REVISED: September 25, 2015 

REV	ISED: September 25, 2015	AS-BUILI				Wastewate	er Flow Q(w)	Extraneou	s Flow Q(i)	Design Flow Q(d)			Pron	osed Sanitar	v Sewer		
Area I.D.	Street	Block Number	From MH	То МН	Area (ha)	Individual Peak Flow Rate 50,000 L/ha/d (L/s)	Cumulative Peak Flow Rate (L/s)	Individual Infiltration Rate 0.28 L/s/ha (L/s)	Cumulative Infiltration Rate (L/s)	Peak Design Flow (L/s)	Length (m)	Pipe Size (mm)	Type of Pipe	Grade %	Capacity (L/s)	Full Flow Velocity (m/s)	Percentage of Capacity
Sanitary Outlet A to St Plan Reference: Sanita	trandherd Drive at Maravista D ary Drainage Area Plan (10920	rive 3-CG-SAN1)															
A-1	Nortel Drive		201	203	0.40	0.35	0.35	0.11	0.11	0.46							
A-2	Nortel Drive	Block 1	201	203	3.49	3.03	3.38	0.98	1.09	4.47							
A-3	Nortel Drive	Block 16	201	203	2.50	2.17	5.55	0.70	1.79	7.34							
A-4	Nortel Drive		201	203	0.09	0.08	5.63	0.03	1.81	7.44	36.0	250	PVC	0.53	45.16	0.89	16%
		BLC	DCK 13 AL	LOTMENT													
A-5	Nortel Drive		203	205	0.13	0.11	5.74	0.04	1.85	7.59	57.5	250	PVC	0.28	32.83	0.65	23%
A-6	Nortel Drive	Block 17	205	101	1.17	1.02	6.75	0.33	2.18	8.93							
A-7	Nortel Drive		205	101	0.20	0.17	6.93	0.06	2.23	9.16	37.3	250	PVC	0.21	28.43	0.56	32%
Agr	Crosskey Race		101	207	0.92	0.80	773	0.20	7.54	15.27							
A-8	Crosskey Place	Block 14	101	207	18.03	15.65	23.38	5.05	5.05	28.43	29.0	300	PVC	0.17	41.59	0.57	68%
(																	
A-10	Nortel Drive	Block 15	207	209	<mark>7.98</mark>	<mark>6.93</mark>	30.30	2.23	9.77	40.08							
AIL	Northel Dhive	h	202	1209	<u>10.30</u>	10.26 L	30.50	L CAR	9.86	40.42	106.5	300	PVC	0.27	52.42	0.72	77%
A-12	Nortel Drive		209	211	0.31	0.27	30.83	0.09	9.95	40.78	118.8	300	PVC	0.29	54.33	0.74	75%
																	-
A-13	Nortel Drive		211	213	0.31	0.27	31.10	0.09	10.03	41.13	114.6	300	PVC	0.22	47.32	0.65	87%
-				-		-				-			_		-		
A-14	Systembouse Street		213	401	0.07	0.06	31.16	0.02	10.05	41.22	26.4	300	PVC	0.23	48.38	0.66	85%
			2.0		0.01	0.00	00	0.02		=	20.1			0.20			
A-15	Systembouse Street		401	403	0.21	0.18	31.35	0.06	10 11	41 46	86.8	300	PVC	0.28	53.38	0.73	78%
			101	100	0.21	0.10	01.00	0.00	10.111		00.0	000		0.20	00.00		1070
A-16	Systembouse Street		403	405	0.29	0.25	31.60	0.08	10.19	41 79	118.8	300	PVC.	0.32	57.07	0.78	73%
7/10			400	400	0.20	0.20	01.00	0.00	10.10	41.70	110.0	000	1.40	0.52	01.01	0.70	1070
Δ-17	Systembouse Street	Block 18	405	407	2 29	1 99	33 59	0.64	10.83	44 42							-
A-18	Systembouse Street	DIODICTO	405	407	0.20	0.17	33.76	0.06	10.89	44.65	80 4	375	PVC.	0 14	68 44	0.60	65%
7/10	Cystellinouse Street		400	-01	0.20	0.17	00.70	0.00	10.00	++.00	00.4	010	1.40	0.14	00.44	0.00	
A-19	Systembouse Street	Block 2	407	409	11.95	10.37	44 13	3.35	14.24	58.37	1			1		<u> </u>	+
A-20	Systemhouse Street	Block 3	407	409	5.28	4.58	48.72	1.48	15.71	64.43				1	1	1	1
A-21	Systemhouse Street		407	409	0.30	0.26	48.98	0.08	15.80	64.77	117.2	375	PVC	0.25	91.46	0.80	71%
					0.00	0.20		0.00		0		0.0		0.20	00		
A-22	Systembouse Street		409	101	0.16	0.14	49,11	0.04	15.84	64.96	54.8	375	PVC	024	89.61	0.79	72%
		+			0.10			0.01		04.00		0.0		V.2.7			/
								1		64.96							

Notes:

 $\overline{1. Q(d)} = Q(w) + Q(i)$ , where

2. Q(i) = 0.28 L/s/ha 3. Peaking Factor = 1.5

Q(d) = Design Flow (L/s) Q(w) = Peak Wastewater Flow (L/s)Q(i) = Extraneous Flow (L/s)

56.58

Legend 0.20

As-built pipe grade (%) or length (m)







#### SANITARY SEWER DESIGN SHEET

Citi Gate 416 Corporate Campus Phase 1 - As-Built



NOVATECH FILE NO.: 109203-0

CITY FILE NO.: D07-16-12-0023

DESIGNED BY: LAB

CHECKED BY: MER/MSP

DATE (Issued with report): March 31, 2014

REVISED : August 10, 2014 REVISED : September 25, 2015

AS-BUILT

		Location				Wastewate	r Flow Q(w)	Extraneou	s Flow Q(i)	Design Flow Q(d)			Pro	posed Sa	anitary Sew	er	
Area I.D.	Street	Block Number	From MH	То МН	Area (ha)	Individual Peak Flow Rate 50,000 L/ha/d (L/s)	Cumulative Peak Flow Rate (L/s)	Individual Infiltration Rate 0.28 L/s/ha (L/s)	Cumulative Infiltration Rate (L/s)	Peak Design Flow (L/s)	Length (m)	Pipe Size (mm)	Type of Pipe	Grade %	Capacity (L/s)	Full Flow Velocity (m/s)	Percentage of Capacity
Sanitary Outlet B to Strand Reference: Sanitary Draina	Iherd Drive at Kennevale I age Area Plan (109203-CG	Drive -SAN2)		Plan		·											
C-1	Nortel Drive	Lands Owned by Others	Fut	501	22.68	19.69	19.69	6.35	6.35	26.04	4.0	300	PVC	0.20	45.12	0.62	58%
B-1	Dealership Street	Lands Owned by Others	Fut	501	27.06	23.49	23.49	7.58	7.58	31.07	12.5	300	PVC	0.20	45.12	0.62	69%
B-2	Dealership Street	Block 11 Block 10	501	503	2.72	2.36	45.54	0.76	14.69	60.23							
B-3 B-4	Dealership Street	DIUCK TU	501	503	0.28	0.24	47.64	0.08	15.37	63.01	119.5	450	PVC	0.14	111.29	0.68	57%
B-5 B-6	Dealership Street Dealership Street	Block 9	503 503	505 505	1.84 0.29	1.60 0.25	49.24 49.49	0.52 0.08	15.88 15.96	65.12 65.45	119.2	450	PVC	0.16	118.97	0.72	55%
B-7	Dealership Street	Block 12 (SWM)	505	507	3.20	2.78	52.27	0.90	16.86	69.12							
B-8	Dealership Street	Block 8	505	507	1.64	1.42	53.69	0.46	17.32	71.01							
B-9	Dealership Street		505	507	0.20	0.17	53.86	0.06	17.37	71.24	85.7	450	PVC	0.12	103.03	0.63	69%
B-10	Dealership Street	Block 19	507	509	2.51	2.18	56.04	0.70	18.08	74.12							
B-11	Dealership Street		507	509	0.13	0.11	56.15	0.04	18.11	74.27	55.9	450	PVC	0.16	118.97	0.72	62%
B-12	Philsar Street	Block 6	603	601	1.62	1.41	1.41	0.45	0.45	1.86							
B-13	Philsar Street		603	601	0.23	0.20	1.61	0.06	0.52	2.12	41.2	250	PVC	0.19	27.04	0.53	8%
B-15	Philsar Street		601	509	0.19	0.16	1.77	0.05	0.57	2.34	101.2	250	PVC	0.25	31.02	0.61	8%
B-16	Dealership Street	Block 4	509	511	3 39	2.94	60.87	0.95	19.63	80.50							
B-17	Dealership Street		509	511	0.24	0.21	61.08	0.07	19.70	80.78	99.5	450	PVC	0.17	122.63	0.75	66%
B-14	Dealership Street	Block 5	511	513	2.14	1.86	62.93	0.60	20.30	83.23							
B-18	Dealership Street		511	513	0.20	0.17	63.11	0.06	20.36	83.46	75.9	450	PVC	0.20	133.02	0.81	63%
B-19	Outlet to Lift Station		513	515	0.04	0.03	63.14	0.01	20.37	83.51	35.5	450	PVC	0.42	192.76	1.17	43%

Notes:

1. Q(d) = Q(w) + Q(i), where

2. Q(i) = 0.28 L/s/ha

3. Peaking Factor = 1.5

Q(d) = Design Flow (L/s)Q(w) = Peak Wastewater Flow (L/s)

Q(i) = Extraneous Flow (L/s)

Legend:

0.20

As-built pipe grade (%) or length (m)







## Appendix C

Storm Servicing Information



## STORM SEWER DESIGN SHEET

#### (222 CITIGATE DR) FLOW RATES BASED ON RATIONAL METHOD

LO	CATION			ARE	A (ha)						FLOW	/			TOTAL FLOW				SE	NER DA	TA			
	From	То	Total Area	C =	C =	С	AC	Indiv	Accum	Time of	Rainfall Intensity	Rainfall Intensity	Rainfall Intensity	Peak Flow	Total Poak	Dia. (m)	Dia.	Type	Slope	Length	Capacity	Velocity	Flow	Ratio
AREA ID	Marchala	Manhala	(h = )	0.00	0.00		(h = )	0.70.40	0 70 4 0	Construction				(1 /=)	Flow, Q (L/s)	Astual	(	51 -	(0()	(	(1 /2)	(100 (0))	Time	
	Mannole	Mannole	(na)	0.20	0.90		(na)	2.78 AC	2.78 AC	Concentration		5 Year (mm/nr)	TO Year (mm/m)	(L/S)	- , - ( ,	Actual	(mm)		(%)	(m)	(L/S)	(m/s)	(min)	Q/Q IUI
			1				0.00	0.000	N		NG SYSTEM (1:5 YE	AR STORM EVE	=NI)			<b>I</b> 1							1	
Δ-19	STMMH 120	STMMH 119	0 470	0 155	0.315	0.67	0.00	0.000	0.000	10.00		104 19		91 1	91.1	0.305	300	PVC	2 60	97.3	162.5	2 23	0.73	56%
	01111111120	0111111111	0.110	0.100	0.010	0.07	0.00	0.000	0.000	10.00		101.10		01.1	0	0.000	000		2.00	01.0	102.0	2.20	0.10	0070
							0.00	0.000	0.000	10.73														
A-01	STMMH 119	STMMH 118	0.250	0.089	0.161	0.65	0.16	0.452	1.327	10.73		100.50		133.3	133.3	0.457	450	Conc	2.00	59.1	420.3	2.56	0.38	32%
							0.00	0.000	0.000	10.73														
							0.00	0.000	0.000	11.11		09.66		120.0	130.0	0.457	450	Conc	2.00	21.8	120.3	2.56	0.14	31%
	01101011110	01101011117					0.00	0.000	0.000	11 11		90.00		130.9	150.5	0.457	400	Conc	2.00	21.0	420.5	2.00	0.14	5170
							0.00	0.000	0.000															
							0.00	0.000	0.000	10.00														
FUT	STUB	STMMH 117	2.660	0.399	2.261	0.80	2.11	5.879	5.879	10.00		104.19		612.5	612.5	0.914	900	Conc	0.30	12.5	1,033.9	1.57	0.13	59%
							0.00	0.000	0.000	10.00					_									ļ
							0.00	0.000	0.000	11.25														
A-02	STMMH 117	STMMH 107	0.250	0.107	0.143	0.60	0.15	0.417	7.623	11.25		98.00		747.0	747.0	0.914	900	Conc	0.30	93.7	1,033.9	1.57	0.99	72%
							0.00	0.000	0.000	11.25														
							0.00	0.000	0.000	10.00														
Δ-20	STMMH 116	STMMH 115	0.230	0 131	0.000	0.50	0.00	0.000	0.000	10.00		10/ 19		33 /	33.4	0 305	300	PVC	2 80	48.9	168 7	2 31	0.35	20%
A 20	01101011110	0110101110	0.200	0.101	0.033	0.50	0.00	0.000	0.000	10.00		104.13		55.4	00.4	0.000	000	1.00	2.00	40.0	100.7	2.01	0.00	2070
							0.00	0.000	0.000	10.35														
A-21	STMMH 115	STMMH 114	0.300	0.086	0.214	0.70	0.21	0.583	0.904	10.35		102.37		92.5	92.5	0.533	525	Conc	1.00	31.0	448.4	2.01	0.26	21%
							0.00	0.000	0.000	10.35														
Δ-22	STMMH 114	STMMH 113	1 920	0 182	1 738	0.83	1 60	4 450	5 353	10.61		101.08		541 1	541.1	0.838	825	Conc	1 00	118 7	1 496 7	2 71	0.73	36%
A	011111	0111111111	1.020	0.102	1.700	0.00	0.00	0.000	0.000	10.61		101.00		011.1	0	0.000	020	Cono	1.00	110.1	1,100.1	2	0.10	0070
							0.00	0.000	0.000	11.34														
	STMMH 113	STMMH 110	0.000	0.000	0.000		0.00	0.000	5.353	11.34		97.61		522.6	522.6	0.838	825	Conc	1.00	22.8	1,496.7	2.71	0.14	35%
							0.00	0.000	0.000	11.34														
							0.00	0.000	0.000	10.00														
Δ-17	STMMH 111	STMMH 110	0 /20	0.000	0.420	0.90	0.00	0.000	1.051	10.00		10/ 19		109.5	109.5	0.457	450	Conc	1 40	76.8	351 7	2 14	0.60	31%
	0111111	011111111	0.420	0.000	0.420	0.00	0.00	0.000	0.000	10.00		104.10		100.0	100.0	0.107	100	Cono	1.40	10.0	001.7	2.14	0.00	0170
							0.00	0.000	0.000	11.48														
	STMMH 110	CBMH 109	0.000	0.000	0.000		0.00	0.000	6.404	11.48		96.98		621.1	621.1	0.838	825	Conc	1.00	8.8	1,496.7	2.71	0.05	41%
							0.00	0.000	0.000	11.48														
A 19			0.020	0.002	0.007	0.90	0.00	0.000	0.000	11.53		06 72		674.6	674.6	0 838	825	Conc	1 00	126	1 /06 7	2 71	0.26	15%
A-10	CBININ 109		0.230	0.003	0.227	0.09	0.20	0.000	0.000	11.53		90.73		074.0	074.0	0.050	020	Conc	1.00	42.0	1,490.7	2.71	0.20	4370
			1				0.00	0.000	0.000	11.80	1				1									
A-06	STMMH 108	STMMH 107	0.660	0.160	0.500	0.73	0.48	1.340	8.314	11.80		95.58		794.6	794.6	0.838	825	Conc	1.00	17.9	1,496.7	2.71	0.11	53%
						-	0.00	0.000	0.000	11.80	1				ļ									
			0.000	0.000	0.000		0.00	0.000	0.000	12.25	<u> </u>	00.00		4 400 0	1 400 0	1.007	1050	0	0.40	17.0	1 000 0	0.04	0.45	0.00/
	STIMIMH 107	STIVIVIH 106	0.000	0.000	0.000		0.00	0.000	15.937	12.25	+	93.66		1,492.6	1,492.6	1.067	1050	Conc	0.40	37.8	1,800.9	2.01	0.15	<b>ბ</b> კ%
		1	1	1	L		0.00	0.000	0.000	12.20						L							L	

![](_page_114_Picture_5.jpeg)

Engineers, Planners & Landscape Architects

## STORM SEWER DESIGN SHEET

#### (222 CITIGATE DR) FLOW RATES BASED ON RATIONAL METHOD

LOC	CATION			ARE	A (ha)						FLO	W			TOTAL FLOW				SE	WER DA	TA			
	From	То	Total Area	C =	C =	С	AC	Indiv	Accum	Time of	Rainfall Intensity	Rainfall Intensity	Rainfall Intensity	Peak Flow	Total Poak	Dia. (m)	Dia.	Type	Slope	Lenath	Capacity	Velocitv	Flow	Ratio
AREA ID	Manhala	Manhala	(h = )	0.00	0.00		(h a)	0.70.40	0 70 40	Constantion				(1. /)	Flow, Q (L/s)	Astual	(	51 -	(0()	(110)	(1 /a)	(	Time	
	Mannole	Mannole	(na)	0.20	0.90		(na)	2.78 AC	2.78 AC	Concentration		5 Year (mm/nr)	TO Year (mm/m)	(L/S)	- , - ( ,	Actual	(mm)		(%)	(m)	(L/S)	(m/s)	(min)	Q/Q Iuli
A 02	STMMH 106		0.100	0.050	0.050	0.55	0.00	0.000	0.000	12.39		02.05		1 407 1	1 /07 1	1.067	1050	Conc	0.40	38.2	1 800 0	2.01	0.32	830/
A-03			0.100	0.050	0.050	0.55	0.00	0.155	0.000	12.39		93.05		1,497.1	1,497.1	1.007	1050	Conc	0.40	30.2	1,000.9	2.01	0.52	0370
							0.00	0.000	0.000	12.00														<u> </u>
							0.00	0.000	0.000	10.00														
A-08	STMMH 105	STMMH 104	1.050	0.090	0.960	0.84	0.88	2.452	2.452	10.00		104.19		255.5	255.5	0.762	750	Conc	0.50	92.3	820.8	1.80	0.85	31%
							0.00	0.000	0.000	10.00														
							0.00	0.000	0.000	10.85								-						
A-07	STMMH 104	STMMH 103	1.040	0.134	0.906	0.81	0.84	2.341	4.793	10.85		99.89		478.8	478.8	0.762	750	Conc	1.00	87.8	1,160.8	2.55	0.57	41%
						-	0.00	0.000	0.000	10.85														<u> </u>
A-04. A-28	STMMH 103	STMMH 102	0.210	0.077	0.133	0.64	0.00	0.376	5.169	11.43		97.20		502.4	502.4	0.762	750	Conc	1.00	19.9	1.160.8	2.55	0.13	43%
			0.2.0	0.011	000	0.01	0.00	0.000	0.000	11.43		01120		00211	-						,			
							0.00	0.000	0.000	12.71														
	STMMH 102	STMMH 101	0.000	0.000	0.000		0.00	0.000	21.258	12.71		91.77		1,950.9	1,950.9	1.067	1050	Conc	0.60	37.2	2,205.7	2.47	0.25	88%
							0.00	0.000	0.000	12.71														
A 05			0.400	0.000	0.400	0.50	0.00	0.000	0.000	12.96		00.70		4.050.0	1.050.0	1.007	1050	Cana	0.00	21.1	0.005.7	0.47	0.01	0.00/
A-05	STIVIVIH 101	EXSININH	0.180	0.080	0.100	0.59	0.11	0.295	21.553	12.96		90.78		1,956.6	1,956.6	1.067	1050	Conc	0.60	31.1	2,205.7	2.47	0.21	89%
							0.00	0.000	0.000	12.90														
									6															
			<b>I</b> I			1	0.00	0.000	0.000			EAR STORINEVE			1				[					
A-23	STMMH 16	STMMH 15	2.730	1.100	1.630	0.62	1.69	4.690	4.690	10.00		104.19		488.7	488.7	0.914	900	Conc	0.30	102.5	1.033.9	1.57	1.09	47%
							0.00	0.000	0.000	10.00					-						,			
							0.00	0.000	0.000	11.09														
A-24	STMMH 15	STMMH 14	2.220	0.348	1.872	0.79	1.75	4.877	9.567	11.09		98.79		945.1	945.1	1.219	1200	Conc	0.30	120.0	2,226.9	1.91	1.05	42%
							0.00	0.000	0.000	11.09														──
A-25	STMMH 14	STMMH 13	1 590	0.381	1 209	0.73	1 16	3 237	12 804	12.13		94 13		1 205 2	1.205.2	1,219	1200	Conc	0.30	120.0	2.226.9	1.91	1.05	54%
	•	••••••	1.000	0.001	1.200	0.10	0.00	0.000	0.000	12.13		01110		1,200.2	.,			00110	0.00		_,010			0.70
							0.00	0.000	0.000	13.18														
A-27	STMMH 13	STMMH 12	1.930	0.576	1.325	0.68	1.31	3.635	16.439	13.18		89.93		1,478.4	1,478.4	1.219	1200	Conc	0.30	80.4	2,226.9	1.91	0.70	66%
							0.00	0.000	0.000	13.18														
A-26	STMMH 12	STMMH 11	1 930	0.072	1 858	0.87	0.00	0.000	0.000	13.88		87.34		1 8/15 /	1 845 4	1 219	1200	Conc	0.30	88.6	2 226 9	1 01	0.77	83%
A-20	0110101112	OT WINNET TT	1.550	0.072	1.000	0.07	0.00	0.000	0.000	13.88		07.54		1,040.4	1,040.4	1.210	1200	Conc	0.00	00.0	2,220.0	1.01	0.11	0070
							0.00	0.000	0.000	14.66														
A-14	STMMH 11	STMMH 06	0.420	0.085	0.335	0.76	0.32	0.885	22.013	14.66		84.68		1,864.0	1,864.0	1.219	1200	Conc	0.30	44.5	2,226.9	1.91	0.39	84%
							0.00	0.000	0.000	14.66														<u> </u>
																								<u> </u>
							0.00	0.000	0.000	10.00														
A-16A	STMMH 10B	STMMH 10A	0.820	0.000	0.820	0.90	0.74	2.052	2.052	10.00		104.19		213.8	213.8	0.610	600	Conc	1.00	72.4	640.2	2.19	0.55	33%
							0.00	0.000	0.000	10.00														
A-16B	STMMH 10A	STMMH 07	0.670	0.000	0.670	0,90	0.60	1.676	3.728	10.55		101.37		377.9	377.9	0.610	599	Conc	1.00	70.0	640.2	2.19	0.53	59%
							0.00	0.000	0.000	10.55														
							0.00	0.000	0.000	11.08														
	STMMH 09	STMMH 07	0.000	0.000	0.000	-	0.00	0.000	3.728	11.08		98.80		368.3	368.3	0.610	600	Conc	1.00	20.3	640.2	2.19	0.15	58%
		1			1	1	0.00	0.000	0.000	11.08	1	1			1				1	1			1	1

![](_page_115_Picture_5.jpeg)

Engineers, Planners & Landscape Architects

## STORM SEWER DESIGN SHEET

#### (222 CITIGATE DR) FLOW RATES BASED ON RATIONAL METHOD

1.00					(ha)						FLO	W/							SEV					
		_		ANL											TOTAL FLOW			_	Jei				Flow	
	From	То	Total Area	C =	C =	С	AC	Indiv	Accum	Time of	Rainfall Intensity	Rainfall Intensity	Rainfall Intensity	Peak Flow	Total Peak	Dia. (m)	Dia.	Туре	Slope	Length	Capacity	Velocity	Time	Ratio
AREAD	Manhole	Manhole	(ha)	0.20	0.90		(ha)	2.78 AC	2.78 AC	Concentration	2 Year (mm/hr)	5 Year (mm/hr)	10 Year (mm/hr)	(L/s)	Flow, Q (L/s)	Actual	(mm)		(%)	(m)	(L/s)	(m/s)	(min)	Q/Q full
							0.00	0.000	0.000	11.24														
A-15	STMMH 07	STMMH 06	0.610	0.011	0.599	0.89	0.54	1.505	5.233	11.24		98.09		513.3	513.3	0.610	600	Conc	1.00	106.6	640.2	2.19	0.81	80%
							0.00	0.000	0.000	11.24														<u> </u>
							0.00	0.000	0.000	15.05								-						
A-13	STMMH 06	STMMH 05	0.300	0.116	0.184	0.63	0.19	0.525	27.771	15.05		83.40		2,316.2	2,316.2	1.219	1200	Conc	0.70	81.9	3,401.6	2.91	0.47	68%
							0.00	0.000	0.000	15.05														
۵-12	STMMH 05	STMMH 02	0.450	0.276	0 174	0.47	0.00	0.000	28 360	15.52		81.02		2 222 1	2 323 1	1 210	1200	Conc	0.70	66.9	3 /01 6	2 01	0.38	68%
A 12	0110101100	0110101102	0.430	0.270	0.174	0.47	0.00	0.000	0.000	15.52		01.35		2,020.4	2,020.4	1.210	1200	Conc	0.70	00.5	0,401.0	2.01	0.00	0070
							0.00	0.000	0.000	10.02														
							0.00	0.000	0.000	10.00														
A-09	STMMH 04	STMMH 03	0.640	0.100	0.540	0.79	0.51	1.407	1.407	10.00		104.19		146.6	146.6	0.533	525	Conc	1.00	63.2	448.4	2.01	0.52	33%
							0.00	0.000	0.000	10.00											-	-		
							0.00	0.000	0.000	10.52														
A-10	STMMH 03	STMMH 02	0.880	0.050	0.830	0.86	0.76	2.104	3.511	10.52		101.50		356.4	356.4	0.610	600	Conc	1.50	116.0	784.0	2.69	0.72	45%
							0.00	0.000	0.000	10.52														
																								<b></b>
							0.00	0.000	0.000	15.90														
A-11	STMMH 02	STMMH 01	0.040	0.004	0.036	0.83	0.03	0.092	31.963	15.90		80.76		2,581.4	2,581.4	1.219	1200	Conc	0.60	15.0	3,149.3	2.70	0.09	82%
							0.00	0.000	0.000	15.90														
			0.000	0.000	0.000		0.00	0.000	0.000	15.99		80.40		0.570.0	2 572 6	1 210	1200	Cono	0.60	12.2	2 1 / 0 2	2 70	0.09	0.20/
			0.000	0.000	0.000		0.00	0.000	0.000	15.99		00.49		2,372.0	2,572.0	1.219	1200	CONC	0.00	12.2	5,145.5	2.70	0.00	02 /0
							0.00	0.000	0.000	10.00														
		I																						
											1				1									
Q = 2.78 AIC, where												Consul	tant:						N	lovatec	h			
Q = Peak Flow in Litres per S	Second (L/s)											Date	e:						May	y 25, 20	20			
A = Area in hectares (ha)												Desigr	n By:						Matthe	ew Hreh	noriak			
I = Rainfall Intensity (mm/hr)	, 5 year storm											Clier	nt:				Dwg.	Referen	ce:			Checke	d By:	
C = Runoff Coefficient																	12(	025-STM				1.5	3	

![](_page_116_Picture_5.jpeg)

Engineers, Planners & Landscape Architects

### **PROJECT INFORMATION**

ENGINEERED PRODUCT MANAGER:	HAIDER NASRULLAH 647-850-9417 HAIDER.NASRULLAH@ADS-PIPE.COM
ADS SALES REP:	MICHAEL REID 613-882-4186 MICHAEL.REID@ADS-PIPE.COM
PROJECT NO:	S181876
ADS SITE COORDINATOR:	MATTHEW BEGHIN 519-710-3687 MATTHEW.BEGHIN@ADS-PIPE.COM

![](_page_117_Picture_2.jpeg)

ADVANCED DRAINAGE SYSTEMS, INC.

# **PROJECT PYTHON** OTTAWA, ON.

## **MC-3500 STORMTECH CHAMBER SPECIFICATIONS**

- CHAMBERS SHALL BE STORMTECH MC-3500. 1.
- CHAMBERS SHALL BE ARCH-SHAPED AND SHALL BE MANUFACTURED FROM VIRGIN, IMPACT-MODIFIED POLYPROPYLENE 2. COPOLYMERS
- CHAMBERS SHALL BE CERTIFIED TO CSA B184, "POLYMERIC SUB-SURFACE STORMWATER MANAGEMENT STRUCTURES", AND MEET 3. THE REQUIREMENTS OF ASTM F2418-16a, "STANDARD SPECIFICATION FOR POLYPROPYLENE (PP) CORRUGATED WALL STORMWATER COLLECTION CHAMBERS" CHAMBER CLASSIFICATION 45x76 DESIGNATION SS.
- CHAMBER ROWS SHALL PROVIDE CONTINUOUS, UNOBSTRUCTED INTERNAL SPACE WITH NO INTERNAL SUPPORTS THAT WOULD 4. IMPEDE FLOW OR LIMIT ACCESS FOR INSPECTION.
- THE STRUCTURAL DESIGN OF THE CHAMBERS, THE STRUCTURAL BACKFILL, AND THE INSTALLATION REQUIREMENTS SHALL ENSURE THAT THE LOAD FACTORS SPECIFIED IN THE AASHTO LRFD BRIDGE DESIGN SPECIFICATIONS, SECTION 12.12, ARE MET FOR: 1) LONG-DURATION DEAD LOADS AND 2) SHORT-DURATION LIVE LOADS, BASED ON THE CSA S6 CL-625 TRUCK AND THE AASHTO DESIGN TRUCK WITH CONSIDERATION FOR IMPACT AND MULTIPLE VEHICLE PRESENCES.
- CHAMBERS SHALL BE DESIGNED, TESTED AND ALLOWABLE LOAD CONFIGURATIONS DETERMINED IN ACCORDANCE WITH ASTM F2787, 6 "STANDARD PRACTICE FOR STRUCTURAL DESIGN OF THERMOPLASTIC CORRUGATED WALL STORMWATER COLLECTION CHAMBERS". LOAD CONFIGURATIONS SHALL INCLUDE: 1) INSTANTANEOUS (<1 MIN) AASHTO DESIGN TRUCK LIVE LOAD ON MINIMUM COVER 2) MAXIMUM PERMANENT (75-YR) COVER LOAD AND 3) ALLOWABLE COVER WITH PARKED (1-WEEK) AASHTO DESIGN TRUCK.
- REQUIREMENTS FOR HANDLING AND INSTALLATION: 7
  - TO MAINTAIN THE WIDTH OF CHAMBERS DURING SHIPPING AND HANDLING, CHAMBERS SHALL HAVE INTEGRAL, INTERLOCKING STACKING LUGS.
  - TO ENSURE A SECURE JOINT DURING INSTALLATION AND BACKFILL, THE HEIGHT OF THE CHAMBER JOINT SHALL NOT BE LESS THAN 75 mm (3").
  - TO ENSURE THE INTEGRITY OF THE ARCH SHAPE DURING INSTALLATION, a) THE ARCH STIFFNESS CONSTANT AS DEFINED IN SECTION 6.2.8 OF ASTM F2418 SHALL BE GREATER THAN OR EQUAL TO 500 LBS/IN/IN. AND b) TO RESIST CHAMBER DEFORMATION DURING INSTALLATION AT ELEVATED TEMPERATURES (ABOVE 23° C / 73° F), CHAMBERS SHALL BE PRODUCED FROM REFLECTIVE GOLD OR YELLOW COLORS.
- ONLY CHAMBERS THAT ARE APPROVED BY THE SITE DESIGN ENGINEER WILL BE ALLOWED. UPON REQUEST BY THE SITE DESIGN ENGINEER OR OWNER. THE CHAMBER MANUFACTURER SHALL SUBMIT A STRUCTURAL EVALUATION FOR APPROVAL BEFORE DELIVERING CHAMBERS TO THE PROJECT SITE AS FOLLOWS:
  - THE STRUCTURAL EVALUATION SHALL BE SEALED BY A REGISTERED PROFESSIONAL ENGINEER.
  - THE STRUCTURAL EVALUATION SHALL DEMONSTRATE THAT THE SAFETY FACTORS ARE GREATER THAN OR EQUAL TO 1.95 FOR DEAD LOAD AND 1.75 FOR LIVE LOAD, THE MINIMUM REQUIRED BY ASTM F2787 AND BY SECTIONS 3 AND 12.12 OF THE AASHTO LRFD BRIDGE DESIGN SPECIFICATIONS FOR THERMOPLASTIC PIPE.
  - THE TEST DERIVED CREEP MODULUS AS SPECIFIED IN ASTM F2418 SHALL BE USED FOR PERMANENT DEAD LOAD DESIGN EXCEPT THAT IT SHALL BE THE 75-YEAR MODULUS USED FOR DESIGN.
- CHAMBERS AND END CAPS SHALL BE PRODUCED AT AN ISO 9001 CERTIFIED MANUFACTURING FACILITY. 9

**IMPORTANT - THIS PROJECT REQUIRES COMPACTION OF EMBEDMENT** STONE AND REQUIREMENTS FOR STONE HARDNESS AND SHAPE WHICH ARE NOT SPECIFIED IN OTHER STORMTECH DOCUMENTS. CONTRACTORS MUST FOLLOW THE SPECIAL PROVISIONS IN THIS PLAN SET.

### **IMPORTANT - NOTES FOR THE BIDDING AND INSTALLATION OF MC-3500 CHAMBER SYSTEM**

- STORMTECH MC-3500 CHAMBERS SHALL NOT BE INSTALLED UNTIL THE MANUFACTURER'S REPRESENTATIVE HAS COMPLETED A PRE-CONSTRUCTION MEETING WITH THE INSTALLERS.
- 2 STORMTECH MC-3500 CHAMBERS SHALL BE INSTALLED IN ACCORDANCE WITH THE "STORMTECH MC-3500/MC-4500 CONSTRUCTION GUIDE".
- CHAMBERS ARE NOT TO BE BACKFILLED WITH A DOZER OR AN EXCAVATOR SITUATED OVER THE CHAMBERS. 3. STORMTECH RECOMMENDS 3 BACKFILL METHODS:
  - STONESHOOTER LOCATED OFF THE CHAMBER BED.
  - BACKFILL AS ROWS ARE BUILT USING AN EXCAVATOR ON THE FOUNDATION STONE OR SUBGRADE.
  - BACKFILL FROM OUTSIDE THE EXCAVATION USING A LONG BOOM HOE OR EXCAVATOR.
- THE FOUNDATION STONE SHALL BE LEVELED AND COMPACTED PRIOR TO PLACING CHAMBERS. 4.
- JOINTS BETWEEN CHAMBERS SHALL BE PROPERLY SEATED PRIOR TO PLACING STONE. 5.
- MAINTAIN MINIMUM 230 mm (9") SPACING BETWEEN THE CHAMBER ROWS. 6.
- INLET AND OUTLET MANIFOLDS MUST BE INSERTED A MINIMUM OF 300 mm (12") INTO CHAMBER END CAPS. 7.
- EMBEDMENT STONE SURROUNDING CHAMBERS MUST BE A CLEAN, CRUSHED, ANGULAR STONE WELL GRADED BETWEEN <sup>3</sup>/<sub>4</sub>" AND 2" (20-50 mm). 8.
- 9. STONE MUST BE PLACED ON THE TOP CENTER OF THE CHAMBER TO ANCHOR THE CHAMBERS IN PLACE AND PRESERVE ROW SPACING.
- 10. THE CONTRACTOR MUST REPORT ANY DISCREPANCIES WITH CHAMBER FOUNDATION MATERIALS BEARING CAPACITIES TO THE SITE DESIGN FNGINFFR
- ADS RECOMMENDS THE USE OF "FLEXSTORM CATCH IT" INSERTS DURING CONSTRUCTION FOR ALL INLETS TO PROTECT THE SUBSURFACE 11. STORMWATER MANAGEMENT SYSTEM FROM CONSTRUCTION SITE RUNOFF.

#### NOTES FOR CONSTRUCTION EQUIPMENT

- STORMTECH MC-3500 CHAMBERS SHALL BE INSTALLED IN ACCORDANCE WITH THE "STORMTECH MC-3500/MC-4500 CONSTRUCTION GUIDE". 1
- THE USE OF EQUIPMENT OVER MC-3500 CHAMBERS IS LIMITED: 2
  - NO EQUIPMENT IS ALLOWED ON BARE CHAMBERS.
  - NO RUBBER TIRED LOADER, DUMP TRUCK, OR EXCAVATORS ARE ALLOWED UNTIL PROPER FILL DEPTHS ARE REACHED IN ACCORDANCE WITH THE "STORMTECH MC-3500/MC-4500 CONSTRUCTION GUIDE".
  - WEIGHT LIMITS FOR CONSTRUCTION EQUIPMENT CAN BE FOUND IN THE "STORMTECH MC-3500/MC-4500 CONSTRUCTION GUIDE".
- 3. FULL 900 mm (36") OF STABILIZED COVER MATERIALS OVER THE CHAMBERS IS REQUIRED FOR DUMP TRUCK TRAVEL OR DUMPING.

BACKFILL METHOD. ANY CHAMBERS DAMAGED BY USING THE "DUMP AND PUSH" METHOD ARE NOT COVERED UNDER THE STORMTECH STANDARD WARRANTY.

CONTACT STORMTECH AT 1-888-892-2694 WITH ANY QUESTIONS ON INSTALLATION REQUIREMENTS OR WEIGHT LIMITS FOR CONSTRUCTION EQUIPMENT.

02013 ADS INC

![](_page_117_Picture_47.jpeg)

## USE OF A DOZER TO PUSH EMBEDMENT STONE BETWEEN THE ROWS OF CHAMBERS MAY CAUSE DAMAGE TO CHAMBERS AND IS NOT AN ACCEPTABLE

### **MC-4500 STORMTECH CHAMBER SPECIFICATIONS**

- CHAMBERS SHALL BE STORMTECH MC-4500 1.
- CHAMBERS SHALL BE ARCH-SHAPED AND SHALL BE MANUFACTURED FROM VIRGIN, IMPACT-MODIFIED POLYPROPYLENE 2. COPOLYMERS
- CHAMBERS SHALL BE CERTIFIED TO CSA B184, "POLYMERIC SUB-SURFACE STORMWATER MANAGEMENT STRUCTURES", AND MEET 3. THE REQUIREMENTS OF ASTM F2418-16a, "STANDARD SPECIFICATION FOR POLYPROPYLENE (PP) CORRUGATED WALL STORMWATER COLLECTION CHAMBERS" CHAMBER CLASSIFICATION 60x101.
- 4. CHAMBER ROWS SHALL PROVIDE CONTINUOUS, UNOBSTRUCTED INTERNAL SPACE WITH NO INTERNAL SUPPORTS THAT WOULD IMPEDE FLOW OR LIMIT ACCESS FOR INSPECTION.
- THE STRUCTURAL DESIGN OF THE CHAMBERS, THE STRUCTURAL BACKFILL, AND THE INSTALLATION REQUIREMENTS SHALL ENSURE THAT THE LOAD FACTORS SPECIFIED IN THE AASHTO LRFD BRIDGE DESIGN SPECIFICATIONS, SECTION 12.12, ARE MET FOR: 1) LONG-DURATION DEAD LOADS AND 2) SHORT-DURATION LIVE LOADS, BASED ON THE CSA S6 CL-625 TRUCK AND THE AASHTO DESIGN TRUCK WITH CONSIDERATION FOR IMPACT AND MULTIPLE VEHICLE PRESENCES.
- CHAMBERS SHALL BE DESIGNED, TESTED AND ALLOWABLE LOAD CONFIGURATIONS DETERMINED IN ACCORDANCE WITH ASTM F2787, 6 "STANDARD PRACTICE FOR STRUCTURAL DESIGN OF THERMOPLASTIC CORRUGATED WALL STORMWATER COLLECTION CHAMBERS". LOAD CONFIGURATIONS SHALL INCLUDE: 1) INSTANTANEOUS (<1 MIN) AASHTO DESIGN TRUCK LIVE LOAD ON MINIMUM COVER 2) MAXIMUM PERMANENT (75-YR) COVER LOAD AND 3) ALLOWABLE COVER WITH PARKED (1-WEEK) AASHTO DESIGN TRUCK.
- REQUIREMENTS FOR HANDLING AND INSTALLATION:
  - TO MAINTAIN THE WIDTH OF CHAMBERS DURING SHIPPING AND HANDLING, CHAMBERS SHALL HAVE INTEGRAL, INTERLOCKING STACKING LUGS
  - TO ENSURE A SECURE JOINT DURING INSTALLATION AND BACKFILL, THE HEIGHT OF THE CHAMBER JOINT SHALL NOT BE LESS THAN 75 mm (3").
  - TO ENSURE THE INTEGRITY OF THE ARCH SHAPE DURING INSTALLATION, a) THE ARCH STIFFNESS CONSTANT AS DEFINED IN SECTION 6.2.8 OF ASTM F2418 SHALL BE GREATER THAN OR EQUAL TO 500 LBS/IN/IN. AND b) TO RESIST CHAMBER DEFORMATION DURING INSTALLATION AT ELEVATED TEMPERATURES (ABOVE 23° C / 73° F), CHAMBERS SHALL BE PRODUCED FROM REFLECTIVE GOLD OR YELLOW COLORS.
- ONLY CHAMBERS THAT ARE APPROVED BY THE SITE DESIGN ENGINEER WILL BE ALLOWED. UPON REQUEST BY THE SITE DESIGN ENGINEER OR OWNER. THE CHAMBER MANUFACTURER SHALL SUBMIT A STRUCTURAL EVALUATION FOR APPROVAL BEFORE DELIVERING CHAMBERS TO THE PROJECT SITE AS FOLLOWS:
  - THE STRUCTURAL EVALUATION SHALL BE SEALED BY A REGISTERED PROFESSIONAL ENGINEER.
  - THE STRUCTURAL EVALUATION SHALL DEMONSTRATE THAT THE SAFETY FACTORS ARE GREATER THAN OR EQUAL TO 1.95 FOR DEAD LOAD AND 1.75 FOR LIVE LOAD, THE MINIMUM REQUIRED BY ASTM F2787 AND BY SECTIONS 3 AND 12.12 OF THE AASHTO LRFD BRIDGE DESIGN SPECIFICATIONS FOR THERMOPLASTIC PIPE.
  - THE TEST DERIVED CREEP MODULUS AS SPECIFIED IN ASTM F2418 SHALL BE USED FOR PERMANENT DEAD LOAD DESIGN EXCEPT THAT IT SHALL BE THE 75-YEAR MODULUS USED FOR DESIGN.
- CHAMBERS AND END CAPS SHALL BE PRODUCED AT AN ISO 9001 CERTIFIED MANUFACTURING FACILITY. 9

**IMPORTANT - THIS PROJECT REQUIRES COMPACTION OF EMBEDMENT** STONE AND REQUIREMENTS FOR STONE HARDNESS AND SHAPE WHICH ARE NOT SPECIFIED IN OTHER STORMTECH DOCUMENTS. CONTRACTORS MUST FOLLOW THE SPECIAL PROVISIONS IN THIS PLAN SET.

### **IMPORTANT - NOTES FOR THE BIDDING AND INSTALLATION OF MC-4500 CHAMBER SYSTEM**

- STORMTECH MC-4500 CHAMBERS SHALL NOT BE INSTALLED UNTIL THE MANUFACTURER'S REPRESENTATIVE HAS COMPLETED A PRE-CONSTRUCTION MEETING WITH THE INSTALLERS.
- STORMTECH MC-4500 CHAMBERS SHALL BE INSTALLED IN ACCORDANCE WITH THE "STORMTECH MC-3500/MC-4500 CONSTRUCTION GUIDE". 2.
- CHAMBERS ARE NOT TO BE BACKFILLED WITH A DOZER OR EXCAVATOR SITUATED OVER THE CHAMBERS. 3. STORMTECH RECOMMENDS 3 BACKFILL METHODS:
  - STONESHOOTER LOCATED OFF THE CHAMBER BED.
  - BACKFILL AS ROWS ARE BUILT USING AN EXCAVATOR ON THE FOUNDATION STONE OR SUBGRADE.
  - BACKFILL FROM OUTSIDE THE EXCAVATION USING A LONG BOOM HOE OR EXCAVATOR.
- 4. THE FOUNDATION STONE SHALL BE LEVELED AND COMPACTED PRIOR TO PLACING CHAMBERS.
- JOINTS BETWEEN CHAMBERS SHALL BE PROPERLY SEATED PRIOR TO PLACING STONE. 5.
- MAINTAIN MINIMUM 230 mm (9") SPACING BETWEEN THE CHAMBER ROWS. 6.
- INLET AND OUTLET MANIFOLDS MUST BE INSERTED A MINIMUM OF 300 mm (12") INTO CHAMBER END CAPS. 7.
- EMBEDMENT STONE SURROUNDING CHAMBERS MUST BE A CLEAN, CRUSHED, ANGULAR STONE WELL GRADED BETWEEN 3/4" AND 2" (20-50 mm). 8.
- 9. STONE SHALL BE BROUGHT UP EVENLY AROUND CHAMBERS SO AS NOT TO DISTORT THE CHAMBER SHAPE. STONE DEPTHS SHOULD NEVER DIFFER BY MORE THAN 300 mm (12") BETWEEN ADJACENT CHAMBER ROWS.
- STONE MUST BE PLACED ON THE TOP CENTER OF THE CHAMBER TO ANCHOR THE CHAMBERS IN PLACE AND PRESERVE ROW SPACING. 10
- 11. THE CONTRACTOR MUST REPORT ANY DISCREPANCIES WITH CHAMBER FOUNDATION MATERIAL BEARING CAPACITIES TO THE SITE DESIGN ENGINEER.
- 12. ADS RECOMMENDS THE USE OF "FLEXSTORM CATCH IT" INSERTS DURING CONSTRUCTION FOR ALL INLETS TO PROTECT THE SUBSURFACE STORMWATER MANAGEMENT SYSTEM FROM CONSTRUCTION SITE RUNOFF.

#### NOTES FOR CONSTRUCTION EQUIPMENT

- STORMTECH MC-4500 CHAMBERS SHALL BE INSTALLED IN ACCORDANCE WITH THE "STORMTECH MC-3500/MC-4500 CONSTRUCTION GUIDE". 1.
- THE USE OF EQUIPMENT OVER MC-4500 CHAMBERS IS LIMITED: 2.
  - NO EQUIPMENT IS ALLOWED ON BARE CHAMBERS.
  - NO RUBBER TIRED LOADER, DUMP TRUCK, OR EXCAVATORS ARE ALLOWED UNTIL PROPER FILL DEPTHS ARE REACHED IN ACCORDANCE WITH THE "STORMTECH MC-3500/MC-4500 CONSTRUCTION GUIDE".
  - WEIGHT LIMITS FOR CONSTRUCTION EQUIPMENT CAN BE FOUND IN THE "STORMTECH MC-3500/MC-4500 CONSTRUCTION GUIDE".
- 3. FULL 900 mm (36") OF STABILIZED COVER MATERIALS OVER THE CHAMBERS IS REQUIRED FOR DUMP TRUCK TRAVEL OR DUMPING.

#### USE OF A DOZER TO PUSH EMBEDMENT STONE BETWEEN THE ROWS OF CHAMBERS MAY CAUSE DAMAGE TO CHAMBERS AND IS NOT AN ACCEPTABLE BACKFILL METHOD. ANY CHAMBERS DAMAGED BY USING THE "DUMP AND PUSH" METHOD ARE NOT COVERED UNDER THE STORMTECH STANDARD WARRANTY

CONTACT STORMTECH AT 1-888-892-2694 WITH ANY QUESTIONS ON INSTALLATION REQUIREMENTS OR WEIGHT LIMITS FOR CONSTRUCTION EQUIPMENT.

![](_page_118_Picture_43.jpeg)

#### STORMTECH MC-3500 CHAMBERS 37 STORMTECH MC-3500 END CAPS 10 . STONE ABOVE (mm) 305 COMPONENTS IN THE FIELD. 229 STONE BELOW (mm) % STONE VOID 40 INSTALLED SYSTEM VOLUME (m<sup>3</sup>) (PERIMETER STONE INCLUDED) 218.3

![](_page_119_Figure_3.jpeg)

![](_page_120_Figure_0.jpeg)

						JLTIMATE
ADDITIONAL PIPE TO STANDARD MANIFOLD	Z		RCT	OWI	У Мо	IT IS THE L
ARE MET. IGINEER IS RESPONSIBLE FOR DETERMINING CREASED ONCE THIS INFORMATION IS	онтүс	A,ON.	RAWN:			<b>ASTRUCTION</b> .
ER SYSTEM SHOULD BE DESIGNED BY A	PROJECT F	OTTAW/	DATE: 05/05/20 D	DBC IECT # S181876		ALL REVIEW THIS DRAWING PRIOR TO CON
P GATE ON UNDERDRAIN AT STRUCTURE ENGINEER / PROVIDED BY OTHERS)						IENGINEER SHA
N-12 DUAL WALL D HDPE UNDERDRAIN / ENGINEER / IDE PERIMETER STONE)			Q REVISED SYSTEM 1&4	Q NEW SITE PLAN/MARKUPS	KD DESCRIPTION	- REPRESENTATIVE. THE SITE DESIGN EGULATIONS, AND PROJECT REQUIRE
IAL CUT END CAP, DIEPP24BC OR MC3500IEPP24BW IC-3500 600 mm BOTTOM CONNECTIONS DR ROWS			06/01/20 RCT JM	05/28/20 RCT JM	DATE DRWN CHI	JEER OR OTHER PROJECT ALL APPLICABLE LAWS, RI
w		StormTech.	Detention • Retention • Water Quality	520 CROMWELL AVENUE   ROCKY HILL   CT   06067	860-529-8188   888-892-2694   WWW.STORMTECH.COM	LED TO ADS UNDER THE DIRECTION OF THE SITE DESIGN ENGN E PRODUCT(S) DEPICTED AND ALL ASSOCIATED DETAILS MEET
PORT	HILLARD OH 43056	ADVANCED PRANAGE SYSTEMS, INC.		SCALE = 1 : 250		THIS DRAWING HAS BEEN PREPARED BASED ON INFORMATION PROVIDEI. RESPONSIBILITY OF THE SITE DESIGN ENGINEER TO ENSURE THAT THE P
	4	si • (	HEE DF	Т	1	6

#### **PROPOSED LAYOUT - SYSTEM 3**

72	STORMTECH MC-3500 CHAMBERS
8	STORMTECH MC-3500 END CAPS
305	STONE ABOVE (mm)
600	STONE BELOW (mm)
40	% STONE VOID
455.7	INSTALLED SYSTEM VOLUME (m <sup>3</sup> ) (PERIMETER STONE INCLUDED)
348.7	INSTALLED SYSTEM VOLUME (m <sup>3</sup> ) ABOVE ELEVATION 97.652
	(PERIMETER STONE INCLUDED)
388.1	SYSTEM AREA (m <sup>2</sup> )

#### **PROPOSED ELEVATIONS - SYSTEM 3**

102.000	MAXIMUM ALLOWABLE GRADE (TOP OF PAVEMENT/UNPAVED):
99.353	MINIMUM ALLOWABLE GRADE (UNPAVED WITH TRAFFIC):
99.200	MINIMUM ALLOWABLE GRADE (UNPAVED NO TRAFFIC):
99.200	MINIMUM ALLOWABLE GRADE (BASE OF FLEXIBLE PAVEMENT):
99.200	MINIMUM ALLOWABLE GRADE (TOP OF RIGID PAVEMENT):
99.048	TOP OF STONE:
98.743	TOP OF MC-3500 CHAMBER:
98.109	450 mm TOP MANIFOLD INVERT:
97.652	600 mm ISOLATOR ROW INVERT:
97.600	BOTTOM OF MC-3500 CHAMBER:
97.000	BOTTOM OF STONE:

#### NOTES

- MANIFOLD SIZE TO BE DETERMINED BY SITE DESIGN ENGINEER. SEE TECHNICAL NOTE 6.32 FOR MANIFOLD SIZING GUIDANCE.
- DUE TO THE ADAPTATION OF THIS CHAMBER SYSTEM TO SPECIFIC SITE AND DESIGN CONSTRAINTS, IT MAY BE NECESSARY TO CUT AND COUPL COMPONENTS IN THE FIELD.
- THE SITE DESIGN ENGINEER MUST REVIEW ELEVATIONS AND IF NECESSARY ADJUST GRADING TO ENSURE THE CHAMBER COVER REQUIREMENT
- THIS CHAMBER SYSTEM WAS DESIGNED WITHOUT SITE-SPECIFIC INFORMATION ON SOIL CONDITIONS OR BEARING CAPACITY. THE SITE DESIGN THE SUITABILITY OF THE SOIL AND PROVIDING THE BEARING CAPACITY OF THE INSITU SOILS. THE BASE STONE DEPTH MAY BE INCREASED OR PROVIDED
- ADS DOES NOT DESIGN OR PROVIDE MEMBRANE LINER SYSTEMS. TO MINIMIZE THE LEAKAGE POTENTIAL OF LINER SYSTEMS, THE MEMBRANE I KNOWLEDGEABLE GEOTEXTILE PROFESSIONAL AND INSTALLED BY A QUALIFIED CONTRACTOR.
- MOT FOR CONSTRUCTION: THIS LAYOUT IS FOR DIMENSIONAL PURPOSES ONLY TO PROVE CONCEPT & THE REQUIRED STORAGE \

#### **TIER 1 DEEP COVER SPECIAL PROVISIONS**

- 1. INSTALLATION REQUIREMENTS SHALL BE AS SPECIFIED IN THE STORMTECH DESIGN MANUALS AND CONSTRUCTION GUIDES EXCEPT AS MODI
- ATTENTION IS CALLED TO "TABLE 1 ACCEPTABLE FILL MATERIALS" IN THE STORMTECH CONSTRUCTION GUIDE AND ALL OTHER APPEARANCE AREAS OF THE SYSTEM WITH COVER ABOVE 7 FEET (2.1 m) FOR THE MC-4500 AND ABOVE 8 FEET (2.4 m) FOR THE MC-3500, EMBEDMENT STON BEHIND VIBRATORY PLATE COMPACTOR OR JUMPING JACK IN 12" (300 mm) LIFTS.
- STONE SHALL HAVE RELATIVELY FLAT SIDES AND SHARP EDGES (ANGULAR) OR RELATIVELY FLAT SIDES AND ROUNDED EDGES AND SHALL CO PARTICLES. FLAT OR ELONGATED STONE IS UNACCEPTABLE. FOR DESCRIPTIONS OF ANGULARITY SEE ASTM D2488 "STANDARD PRACTICE FOR (VISUAL-MANUAL PROCEDURE)".
- 4. STONE SHALL BE HARD AND DURABLE. IT IS THE ENGINEER'S OR CONTRACTOR'S RESPONSIBILITY TO SELECT HARD AND DURABLE STONE. STOLESS THAN OR EQUAL TO 30 TO BE HARD STONE.
- 5. FOUNDATION STONE SHALL BE MECHANICALLY COMPACTED WITH A VIBRATORY ROLLER OR VIBRATORY PLATE IN 6" (152 mm) LIFTS.
- 6. EMBEDMENT STONE MUST BE DUMPED IN PLACE BY A STONE SHOOTER OR CONVEYOR OR EXCAVATOR.
- INSPECTION DURING THE INSTALLATION BY THE ENGINEER, OWNER OR OTHER REPRESENTATIVE IS RECOMMENDED. THE INSPECTION SHALL I
- SYMMETRY DURING BACKFILLING TO ENSURE THE CONTRACTOR'S METHODS ARE NOT CAUSING UNACCEPTABLE DISTORTION OF THE CHAMBE 8. AN ADS FIELD TECHNICIAN WILL CONDUCT A PRE-CONSTRUCTION MEETING TO TRAIN REPRESENTATIVES OF THOSE RESPONSIBLE FOR CONS THE MANDATORY INSPECTIONS OF THE INSTALLATION.

![](_page_121_Figure_20.jpeg)

PLE ADDITIONAL PIPE TO STANDARD MANIFOLD SITS ARE MET. N ENGINEER IS RESPONSIBLE FOR DETERMINING DECREASED ONCE THIS INFORMATION IS LINER SYSTEM SHOULD BE DESIGNED BY A VOLUME CAN BE ACHIEVED ON SITE. IFIED IN THESE SPECIAL PROVISIONS. IS OF THE "ACCEPTABLE FILL MATERIALS TABLE. FOR IE SHALL BE COMPACTED WITH 3 PASSES OF A WALK ONTAIN LESS THAN 20% FLAT OR ELONGATED R DESCRIPTION AND IDENTIFICATION OF SOILS TORMTECH CONSIDERS AN LA ABRASION VALUE OF INCLUDE OBSERVATIONS OF THE CHAMBER STRUCTING THE SYSTEM AND THOSE CONDUCTING INCLUDE OBSERVATIONS OF THE CHAMBER STRUCTING THE SYSTEM AND THOSE CONDUCTING INCLUDE OBSERVATIONS OF THE CHAMBER STRUCTING THE SYSTEM AND THOSE CONDUCTING INCLUDE OBSERVATIONS OF THE CHAMBER STRUCTING THE SYSTEM AND THOSE CONDUCTING INCLUDE OBSERVATIONS OF THE CHAMBER STRUCTING THE SYSTEM AND THOSE CONDUCTING INCLUDE OBSERVATIONS OF THE CHAMBER STRUCTING THE SYSTEM AND THOSE CONDUCTING INCLUDE OBSERVATIONS OF THE CHAMBER STRUCTING THE SYSTEM AND THOSE CONDUCTING INCLUDE OBSERVATIONS OF THE CHAMBER STRUCTING THE SYSTEM AND THOSE CONDUCTING INCLUDE OBSERVATIONS OF THE CHAMBER STRUCTING THE SYSTEM AND THOSE CONDUCTING INCLUDE OBSERVATIONS OF THE CHAMBER STRUCTING THE SYSTEM AND THOSE CONDUCTING INCLUDE OBSERVATIONS OF THE CHAMBER STRUCTING THE SYSTEM AND THOSE CONDUCTING INCLUDE OBSERVATIONS OF THE CHAMBER STRUCTING THE SYSTEM STRUCTING THE SYSTEM AND THOSE CONDUCTING INCLUDE OBSERVATIONS OF THE CHAMBER STRUCTING THE SYSTEM STRUCTURE S	Stormiech. Ottawa,on.	Detertion-Meter Cuality 06/01/20 RCT JMQ REVISED SYSTEM 184 DATE: 05/05/20 DRAWN: RCT	200 520 CROMMELL AVENUE   ROCKY HILL   CT   06067 05/28/20 RCT JMQ NEW SITE PLANMARKUPS 860-529-8188   888-892-2594   WWW STORMTECH.COM DATE DRWN (CHKD) DESCRIPTION DESCRIPTION PROJECT #: S181876 CHECKED: JMQ	INFORMATION PROVIDED TO ADS UNDER THE DIRECTION OF THE SITE DESIGN ENGINEER OR OTHER PROJECT REPRESENTATIVE. THE SITE DESIGN ENGINEER SHALL REVIEW THIS DRAWING PRIOR TO CONSTRUCTION. IT IS THE ULTIMATE

#### 

FROFUS	
261	STORMTECH MC-4500 CHAMBERS
12	STORMTECH MC-4500 END CAPS
305	STONE ABOVE (mm)
229	STONE BELOW (mm) STANDARD PARAMETERS
750	STONE BELOW (mm) TIER 1 PARAMETERS
40	% STONE VOID
1,503.7	INSTALLED SYSTEM VOLUME (m <sup>3</sup> ) (PERIMETER STONE INCLUDED)
1,298.1	INSTALLED SYSTEM VOLUME (m <sup>3</sup> ) ABOVE ELEVATION 95.75 (PERIMETER STONE INCLUDED)
988.0	SYSTEM AREA (m <sup>2</sup> )
166.6	SYSTEM PERIMETER (m)
PROPOS	ED ELEVATIONS - SYSTEM 4
100.400	MAXIMUM GRADE PER ENGINEERS PLANS (TIER 1 PARAMETERS):
99.603	MAXIMUM GRADE PER ENGINEERS PLANS (STANDARD PARAMETERS):
98.265	MINIMUM ALLOWABLE GRADE (UNPAVED WITH TRAFFIC):
98.113	MINIMUM ALLOWABLE GRADE (UNPAVED NO TRAFFIC):
98.113	MINIMUM ALLOWABLE GRADE (BASE OF FLEXIBLE PAVEMENT):
98.113	MINIMUM ALLOWABLE GRADE (TOP OF RIGID PAVEMENT):
97 808	TOP OF STONE

- MANIFOLD SIZE TO BE DETERMINED BY SITE DESIGN ENGINEER. SEE TECHNICAL NOTE 6.32 FOR MANIFOLD SIZING GUIDANCE

- BEHIND VIBRATORY PLATE COMPACTOR OR JUMPING JACK IN 12" (300 mm) LIFTS.
- LESS THAN OR EQUAL TO 30 TO BE HARD STONE.

- THE MANDATORY INSPECTIONS OF THE INSTALLATION.

![](_page_122_Figure_17.jpeg)

#### PROPOSED LAYOUT - SYSTEM 5

I	164	STORMTECH MC-4500 CHAMBERS
	8	STORMTECH MC-4500 END CAPS
I	305	STONE ABOVE (mm)
I	229	STONE BELOW (mm)
	40	% STONE VOID
I	822.4	INSTALLED SYSTEM VOLUME (m <sup>3</sup> ) (PERIMETER STONE INCLUDED)
I	632.6	SYSTEM AREA (m <sup>2</sup> )
I	131.9	SYSTEM PERIMETER (m)

#### **PROPOSED ELEVATIONS - SYSTEM 5**

101.900	MAXIMUM ALLOWABLE GRADE (TOP OF PAVEMENT/UNPAVED):
100.315	MINIMUM ALLOWABLE GRADE (UNPAVED WITH TRAFFIC):
100.163	MINIMUM ALLOWABLE GRADE (UNPAVED NO TRAFFIC):
100.163	MINIMUM ALLOWABLE GRADE (BASE OF FLEXIBLE PAVEMENT):
100.163	MINIMUM ALLOWABLE GRADE (TOP OF RIGID PAVEMENT):
99.858	TOP OF STONE:
99.553	TOP OF MC-4500 CHAMBER:
98.614	600 mm TOP MANIFOLD INVERT:
98.086	600 mm ISOLATOR ROW INVERT:
98.029	BOTTOM OF MC-4500 CHAMBER:
97.800	UNDERDRAIN INVERT:
97.800	BOTTOM OF STONE:

#### NOTES

- MANIFOLD SIZE TO BE DETERMINED BY SITE DESIGN ENGINEER. SEE TECHNICAL NOTE 6.32 FOR MANIFOLD SIZING GUIDANCE.
- DUE TO THE ADAPTATION OF THIS CHAMBER SYSTEM TO SPECIFIC SITE AND DESIGN CONSTRAINTS, IT MAY BE NECESSARY TO CUT AND COUPL COMPONENTS IN THE FIELD.
- THE SITE DESIGN ENGINEER MUST REVIEW ELEVATIONS AND IF NECESSARY ADJUST GRADING TO ENSURE THE CHAMBER COVER REQUIREMENT
- THIS CHAMBER SYSTEM WAS DESIGNED WITHOUT SITE-SPECIFIC INFORMATION ON SOIL CONDITIONS OR BEARING CAPACITY. THE SITE DESIGN THE SUITABILITY OF THE SOIL AND PROVIDING THE BEARING CAPACITY OF THE INSITU SOILS. THE BASE STONE DEPTH MAY BE INCREASED OR PROVIDED
- ADS DOES NOT DESIGN OR PROVIDE MEMBRANE LINER SYSTEMS. TO MINIMIZE THE LEAKAGE POTENTIAL OF LINER SYSTEMS, THE MEMBRANE I KNOWLEDGEABLE GEOTEXTILE PROFESSIONAL AND INSTALLED BY A QUALIFIED CONTRACTOR.
- NOT FOR CONSTRUCTION: THIS LAYOUT IS FOR DIMENSIONAL PURPOSES ONLY TO PROVE CONCEPT & THE REQUIRED STORAGE V

#### **TIER 1 DEEP COVER SPECIAL PROVISIONS**

- 1. INSTALLATION REQUIREMENTS SHALL BE AS SPECIFIED IN THE STORMTECH DESIGN MANUALS AND CONSTRUCTION GUIDES EXCEPT AS MODII 2. ATTENTION IS CALLED TO "TABLE 1 - ACCEPTABLE FILL MATERIALS" IN THE STORMTECH CONSTRUCTION GUIDE AND ALL OTHER APPEARANCE
- AREAS OF THE SYSTEM WITH COVER ABOVE 7 FEET (2.1 m) FOR THE MC-4500 AND ABOVE 8 FEET (2.4 m) FOR THE MC-3500, EMBEDMENT STONE BEHIND VIBRATORY PLATE COMPACTOR OR JUMPING JACK IN 12" (300 mm) LIFTS.
- STONE SHALL HAVE RELATIVELY FLAT SIDES AND SHARP EDGES (ANGULAR) OR RELATIVELY FLAT SIDES AND ROUNDED EDGES AND SHALL CO PARTICLES. FLAT OR ELONGATED STONE IS UNACCEPTABLE. FOR DESCRIPTIONS OF ANGULARITY SEE ASTM D2488 "STANDARD PRACTICE FOR (VISUAL-MANUAL PROCEDURE)".
- 4. STONE SHALL BE HARD AND DURABLE. IT IS THE ENGINEER'S OR CONTRACTOR'S RESPONSIBILITY TO SELECT HARD AND DURABLE STONE. STOLESS THAN OR EQUAL TO 30 TO BE HARD STONE.
- 5. FOUNDATION STONE SHALL BE MECHANICALLY COMPACTED WITH A VIBRATORY ROLLER OR VIBRATORY PLATE IN 6" (152 mm) LIFTS.
- 6. EMBEDMENT STONE MUST BE DUMPED IN PLACE BY A STONE SHOOTER OR CONVEYOR OR EXCAVATOR.
- INSPECTION DURING THE INSTALLATION BY THE ENGINEER, OWNER OR OTHER REPRESENTATIVE IS RECOMMENDED. THE INSPECTION SHALL SYMMETRY DURING BACKFILLING TO ENSURE THE CONTRACTOR'S METHODS ARE NOT CAUSING UNACCEPTABLE DISTORTION OF THE CHAMBI
- 8. AN ADS FIELD TECHNICIAN WILL CONDUCT A PRE-CONSTRUCTION MEETING TO TRAIN REPRESENTATIVES OF THOSE RESPONSIBLE FOR CONS THE MANDATORY INSPECTIONS OF THE INSTALLATION.

![](_page_123_Figure_20.jpeg)

<b>_</b> _			D ADVANCED DRAINAGE SYSTEM		SCAL		THIS DRAWING HAS BEEN F RESPONSIBILITY OF THE SI
	4640 TRUEMAN BLVD	HILLIARD, OH 43026	s, INC.		E = 1 : 250		PREPARED BASED ON INFORMATION PROV TE DESIGN ENGINEER TO ENSURE THAT TI
10.845 m		3		Detention • Retention • Water Quality	520 CROMWELL AVENUE   ROCKY HILL   CT   06067	860-529-8188   888-892-2694   WWW.STORMTECH.COM	'IDED TO ADS UNDER THE DIRECTION OF THE SITE DESIGN ENGINE HE PRODUCT(S) DEPICTED AND ALL ASSOCIATED DETAILS MEET A
				06/01/20 RCT	05/28/20 RCT	DATE DRWN	ER OR OTHER PRO. L APPLICABLE LAW
ERS. TRUCTING THE SYSTEM AND THOSE CONDUCTING				JMQ REVISED SYSTEM 18	JMQ NEW SITE PLAN/MAR	CHKD	IECT REPRESENTATIVE. THE S, REGULATIONS, AND PROJ
ONTAIN LESS THAN 20% FLAT OR ELONGATED R DESCRIPTION AND IDENTIFICATION OF SOILS ORMTECH CONSIDERS AN LA ABRASION VALUE OF INCLUDE OBSERVATIONS OF THE CHAMBER				(4	KUPS	ESCRIPTION	E SITE DESIGN ENGINEER SHA JECT REQUIREMENTS.
PLE ADDITIONAL PIPE TO STANDARD MANIFOLD NTS ARE MET. N ENGINEER IS RESPONSIBLE FOR DETERMINING DECREASED ONCE THIS INFORMATION IS LINER SYSTEM SHOULD BE DESIGNED BY A VOLUME CAN BE ACHIEVED ON SITE. FIED IN THESE SPECIAL PROVISIONS. IS OF THE "ACCEPTABLE FILL MATERIALS TABLE. FOR E SHALL BE COMPACTED WITH 3 PASSES OF A WALK	PROJECT PYTHON		OTTAWA,ON.	DATE: 05/05/20 DRAWN: RC			L REVIEW THIS DRAWING PRIOR TO CONSTRUCTION. IT IS T
							HE ULTIMATE

## ACCEPTABLE FILL MATERIALS: STORMTECH MC-3500 CHAMBER SYSTEMS

MATERIAL LOCATION			DESCRIPTION	AASHTO MATERIAL CLASSIFICATIONS	COMP
	D	<b>FINAL FILL</b> : FILL MATERIAL FOR LAYER 'D' STARTS FROM THE TOP OF THE 'C' LAYER TO THE BOTTOM OF FLEXIBLE PAVEMENT OR UNPAVED FINISHED GRADE ABOVE. NOTE THAT PAVEMENT SUBBASE MAY BE PART OF THE 'D' LAYER	ANY SOIL/ROCK MATERIALS, NATIVE SOILS, OR PER ENGINEER'S PLANS. CHECK PLANS FOR PAVEMENT SUBGRADE REQUIREMENTS.	N/A	PREPA INSTAI
	с	INITIAL FILL: FILL MATERIAL FOR LAYER 'C' STARTS FROM THE TOP OF THE EMBEDMENT STONE ('B' LAYER) TO 24" (600 mm) ABOVE THE TOP OF THE CHAMBER. NOTE THAT PAVEMENT SUBBASE MAY BE A PART OF THE 'C' LAYER.	GRANULAR WELL-GRADED SOIL/AGGREGATE MIXTURES, <35% FINES OR PROCESSED AGGREGATE. MOST PAVEMENT SUBBASE MATERIALS CAN BE USED IN LIEU OF THIS LAYER.	AASHTO M145 <sup>1</sup> A-1, A-2-4, A-3 OR AASHTO M43 <sup>1</sup> 3, 357, 4, 467, 5, 56, 57, 6, 67, 68, 7, 78, 8, 89, 9, 10	BEGIN CO THE CHAMI 12" (300 mr WELL GF
	В	<b>EMBEDMENT STONE:</b> FILL SURROUNDING THE CHAMBERS FROM THE FOUNDATION STONE ('A' LAYER) TO THE 'C' LAYER ABOVE.	CLEAN, CRUSHED, ANGULAR STONE	AASHTO M43 <sup>1</sup> 3, 4	
	A	FOUNDATION STONE: FILL BELOW CHAMBERS FROM THE SUBGRADE UP TO THE FOOT (BOTTOM) OF THE CHAMBER.	CLEAN, CRUSHED, ANGULAR STONE	AASHTO M43 <sup>1</sup> 3, 4	PLATE C

PLEASE NOTE:

1. THE LISTED AASHTO DESIGNATIONS ARE FOR GRADATIONS ONLY. THE STONE MUST ALSO BE CLEAN, CRUSHED, ANGULAR. FOR EXAMPLE, A SPECIFICATION FOR #4 STONE WOULD STATE: "CLEAN, CRUSHED, ANGULAR NO. 4 (AASHTO M43) STONE".

2. STORMTECH COMPACTION REQUIREMENTS ARE MET FOR 'A' LOCATION MATERIALS WHEN PLACED AND COMPACTED IN 9" (230 mm) (MAX) LIFTS USING TWO FULL COVERAGES WITH A VIBRATORY COMPACTOR.

3. WHERE INFILTRATION SURFACES MAY BE COMPROMISED BY COMPACTION, FOR STANDARD DESIGN LOAD CONDITIONS, A FLAT SURFACE MAY BE ACHIEVED BY RAKING OR DRAGGING WITHOUT COMPACTION EQUIPMENT. FOR SPECIAL LOAD DESIGNS, CONTACT STORMTECH FOR COMPACTION REQUIREMENTS.

4. ONCE LAYER 'C' IS PLACED, ANY SOIL/MATERIAL CAN BE PLACED IN LAYER 'D' UP TO THE FINISHED GRADE. MOST PAVEMENT SUBBASE SOILS CAN BE USED TO REPLACE THE MATERIAL REQUIREMENTS OF LAYER 'C' OR 'D' AT THE SITE DESIGN ENGINEER'S DISCRETION.

![](_page_124_Figure_7.jpeg)

## NOTES:

- 1. CHAMBERS SHALL MEET THE REQUIREMENTS OF ASTM F2418-16a, "STANDARD SPECIFICATION FOR POLYPROPYLENE (PP) CORRUGATED WALL STORMWATER COLLECTION CHAMBERS" CHAMBER CLASSIFICATION 45x76 DESIGNATION SS.
- 2. MC-3500 CHAMBERS SHALL BE DESIGNED IN ACCORDANCE WITH ASTM F2787 "STANDARD PRACTICE FOR STRUCTURAL DESIGN OF THERMOPLASTIC CORRUGATED WALL STORMWATER COLLECTION CHAMBERS".
- 3. THE SITE DESIGN ENGINEER IS RESPONSIBLE FOR ASSESSING THE BEARING RESISTANCE (ALLOWABLE BEARING CAPACITY) OF THE SUBGRADE SOILS AND THE DEPTH OF FOUNDATION STONE WITH CONSIDERATION FOR THE RANGE OF EXPECTED SOIL MOISTURE CONDITIONS.
- 4. PERIMETER STONE MUST BE EXTENDED HORIZONTALLY TO THE EXCAVATION WALL FOR BOTH VERTICAL AND SLOPED EXCAVATION WALLS.
- 5. REQUIREMENTS FOR HANDLING AND INSTALLATION:
  - TO MAINTAIN THE WIDTH OF CHAMBERS DURING SHIPPING AND HANDLING, CHAMBERS SHALL HAVE INTEGRAL, INTERLOCKING STACKING LUGS.
  - TO ENSURE A SECURE JOINT DURING INSTALLATION AND BACKFILL, THE HEIGHT OF THE CHAMBER JOINT SHALL NOT BE LESS THAN 3".
  - TO ENSURE THE INTEGRITY OF THE ARCH SHAPE DURING INSTALLATION, a) THE ARCH STIFFNESS CONSTANT AS DEFINED IN SECTION 6.2.8 OF ASTM F2418 SHALL BE GREATER THAN OR EQUAL TO 500 LBS/IN/IN. AND b) TO RESIST CHAMBER DEFORMATION DURING INSTALLATION AT ELEVATED TEMPERATURES (ABOVE 73° F / 23° C), CHAMBERS SHALL BE PRODUCED FROM REFLECTIVE GOLD OR YELLOW COLORS.

## QMI RCT PYTHON PACTION / DENSITY REQUIREMENT CHECKED DRAWN: OTTAWA,ON. ARE PER SITE DESIGN ENGINEER'S PLANS. PAVED LLATIONS MAY HAVE STRINGENT MATERIAL AND C PREPARATION REQUIREMENTS. 05/05/20 S181876 PROJEC MPACTIONS AFTER 24" (600 mm) OF MATERIAL OVER BERS IS REACHED. COMPACT ADDITIONAL LAYERS IN PROJECT #: m) MAX LIFTS TO A MIN. 95% PROCTOR DENSITY FOR RÁDED MATERIAL AND 95% RELATIVE DENSITY FOR DATE: PROCESSED AGGREGATE MATERIALS. NO COMPACTION REQUIRED. COMPACT OR ROLL TO ACHIEVE A FLAT SURFACE.<sup>2,3</sup> a a RCT 8' 18" (450 mm) (2.4 m) MAX MIN\* \*\*THIS CROSS SECTION DETAIL REPRESENTS Storm MINIMUM REQUIREMENTS FOR INSTALLATION. PLEASE SEE THE LAYOUT SHEET(S) FOR PROJECT SPECIFIC REQUIREMENTS. DEPTH OF STONE TO BE DETERMINED BY SITE DESIGN ENGINEER 9" (230 mm) MIN 4640 TRUEMAN BLVD HILLIARD, OH 43026 4 SHEET 8 16 OF

## ACCEPTABLE FILL MATERIALS: STORMTECH MC-3500 CHAMBER SYSTEMS

	MATERIAL LOCATION	DESCRIPTION	AASHTO MATERIAL CLASSIFICATIONS	COMF	
D	<b>FINAL FILL:</b> FILL MATERIAL FOR LAYER 'D' STARTS FROM THE TOP OF THE 'C' LAYER TO THE BOTTOM OF FLEXIBLE PAVEMENT OR UNPAVED FINISHED GRADE ABOVE. NOTE THAT PAVEMENT SUBBASE MAY BE PART OF THE 'D' LAYER	ANY SOIL/ROCK MATERIALS, NATIVE SOILS, OR PER ENGINEER'S PLANS. CHECK PLANS FOR PAVEMENT SUBGRADE REQUIREMENTS.	N/A	PREPA	
С	INITIAL FILL: FILL MATERIAL FOR LAYER 'C' STARTS FROM THE TOP OF THE EMBEDMENT STONE ('B' LAYER) TO 24" (600 mm) ABOVE THE TOP OF THE CHAMBER. NOTE THAT PAVEMENT SUBBASE MAY BE A PART OF THE 'C' LAYER.	GRANULAR WELL-GRADED SOIL/AGGREGATE MIXTURES, <35% FINES OR PROCESSED AGGREGATE. MOST PAVEMENT SUBBASE MATERIALS CAN BE USED IN LIEU OF THIS LAYER.	AASHTO M145' A-1, A-2-4, A-3 OR AASHTO M43' 3, 357, 4, 467, 5, 56, 57, 6, 67, 68, 7, 78, 8, 89, 9, 10	BEGIN CO THE CHAM 12" (300 m WELL GF	
В	<b>EMBEDMENT STONE</b> : FILL SURROUNDING THE CHAMBERS FROM THE FOUNDATION STONE ('A' LAYER) TO THE 'C' LAYER ABOVE.	CLEAN, CRUSHED, ANGULAR STONE	AASHTO M431 3, 4		
А	FOUNDATION STONE: FILL BELOW CHAMBERS FROM THE SUBGRADE UP TO THE FOOT (BOTTOM) OF THE CHAMBER.	CLEAN, CRUSHED, ANGULAR STONE	AASHTO M43 <sup>1</sup> 3, 4	PLATE C	

PLEASE NOTE:

1. THE LISTED AASHTO DESIGNATIONS ARE FOR GRADATIONS ONLY. THE STONE MUST ALSO BE CLEAN, CRUSHED, ANGULAR. FOR EXAMPLE, A SPECIFICATION FOR #4 STONE WOULD STATE: "CLEAN, CRUSHED, ANGULAR NO. 4 (AASHTO M43) STONE".

2. STORMTECH COMPACTION REQUIREMENTS ARE MET FOR 'A' LOCATION MATERIALS WHEN PLACED AND COMPACTED IN 9" (230 mm) (MAX) LIFTS USING TWO FULL COVERAGES WITH A VIBRATORY COMPACTOR.

3. WHERE INFILTRATION SURFACES MAY BE COMPROMISED BY COMPACTION, FOR STANDARD DESIGN LOAD CONDITIONS, A FLAT SURFACE MAY BE ACHIEVED BY RAKING OR DRAGGING WITHOUT COMPACTION EQUIPMENT. FOR SPECIAL LOAD DESIGNS, CONTACT STORMTECH FOR COMPACTION REQUIREMENTS.

4. ONCE LAYER 'C' IS PLACED, ANY SOIL/MATERIAL CAN BE PLACED IN LAYER 'D' UP TO THE FINISHED GRADE. MOST PAVEMENT SUBBASE SOILS CAN BE USED TO REPLACE THE MATERIAL REQUIREMENTS OF LAYER 'C' OR 'D' AT THE SITE DESIGN ENGINEER'S DISCRETION.

1 LAYER OF ADS GEOSYNTHETICS NON-WOVEN GEOTEXTILE ON BOTH SIDES OF THERMOPLASTIC LINER ALL AROUND CLEAN, CRUSHED, ANGULAR STONE IN A & B LAYERS. \_ SEE ADS TECHNICAL NOTE 6.50 FOR NON-WOVEN WEIGHT RECOMMENDATIONS. / - 1 LAYER OF ADS GEOSYNTHETICS NON-WOVEN GEOTEXTILE BETWEEN COVER STONE AND C LAYER.

![](_page_125_Figure_9.jpeg)

## NOTES:

- 1. CHAMBERS SHALL MEET THE REQUIREMENTS OF ASTM F2418-16a, "STANDARD SPECIFICATION FOR POLYPROPYLENE (PP) CORRUGATED WALL STORMWATER COLLECTION CHAMBERS" CHAMBER CLASSIFICATION 45x76 DESIGNATION SS.
- 2. MC-3500 CHAMBERS SHALL BE DESIGNED IN ACCORDANCE WITH ASTM F2787 "STANDARD PRACTICE FOR STRUCTURAL DESIGN OF THERMOPLASTIC CORRUGATED WALL STORMWATER COLLECTION CHAMBERS".
- 3. THE SITE DESIGN ENGINEER IS RESPONSIBLE FOR ASSESSING THE BEARING RESISTANCE (ALLOWABLE BEARING CAPACITY) OF THE SUBGRADE SOILS AND THE DEPTH OF FOUNDATION STONE WITH CONSIDERATION FOR THE RANGE OF EXPECTED SOIL MOISTURE CONDITIONS.
- 4. PERIMETER STONE MUST BE EXTENDED HORIZONTALLY TO THE EXCAVATION WALL FOR BOTH VERTICAL AND SLOPED EXCAVATION WALLS.
- 5. REQUIREMENTS FOR HANDLING AND INSTALLATION:
  - TO MAINTAIN THE WIDTH OF CHAMBERS DURING SHIPPING AND HANDLING, CHAMBERS SHALL HAVE INTEGRAL, INTERLOCKING STACKING LUGS.
  - TO ENSURE A SECURE JOINT DURING INSTALLATION AND BACKFILL, THE HEIGHT OF THE CHAMBER JOINT SHALL NOT BE LESS THAN 3".
  - TO ENSURE THE INTEGRITY OF THE ARCH SHAPE DURING INSTALLATION, a) THE ARCH STIFFNESS CONSTANT AS DEFINED IN SECTION 6.2.8 OF ASTM F2418 SHALL BE GREATER THAN OR EQUAL TO 500 LBS/IN/IN. AND b) TO RESIST CHAMBER DEFORMATION DURING INSTALLATION AT ELEVATED TEMPERATURES (ABOVE 73° F / 23° C), CHAMBERS SHALL BE PRODUCED FROM REFLECTIVE GOLD OR YELLOW COLORS.

![](_page_125_Figure_19.jpeg)

## ACCEPTABLE FILL MATERIALS: STORMTECH MC-3500 CHAMBER SYSTEMS

	MATERIAL LOCATION	DESCRIPTION	AASHTO MATERIAL CLASSIFICATIONS	COMP
D	FINAL FILL: FILL MATERIAL FOR LAYER 'D' STARTS FROM THE TOP OF THE 'C' LAYER TO THE BOTTOM OF FLEXIBLE PAVEMENT OR UNPAVED FINISHED GRADE ABOVE. NOTE THAT PAVEMENT SUBBASE MAY BE PART OF THE 'D' LAYER	ANY SOIL/ROCK MATERIALS, NATIVE SOILS, OR PER ENGINEER'S PLANS. CHECK PLANS FOR PAVEMENT SUBGRADE REQUIREMENTS.	N/A	PREPA INSTAI
С	INITIAL FILL: FILL MATERIAL FOR LAYER 'C' STARTS FROM THE TOP OF THE EMBEDMENT STONE ('B' LAYER) TO 24" (600 mm) ABOVE THE TOP OF THE CHAMBER. NOTE THAT PAVEMENT SUBBASE MAY BE A PART OF THE 'C' LAYER.	GRANULAR WELL-GRADED SOIL/AGGREGATE MIXTURES, <35% FINES OR PROCESSED AGGREGATE. MOST PAVEMENT SUBBASE MATERIALS CAN BE USED IN LIEU OF THIS LAYER.	AASHTO M145 <sup>1</sup> A-1, A-2-4, A-3 OR AASHTO M43 <sup>1</sup> 3, 357, 4, 467, 5, 56, 57, 6, 67, 68, 7, 78, 8, 89, 9, 10	BEGIN CO THE CHAMI 12" (300 mr WELL GF
В	<b>EMBEDMENT STONE:</b> FILL SURROUNDING THE CHAMBERS FROM THE FOUNDATION STONE ('A' LAYER) TO THE 'C' LAYER ABOVE.	CLEAN, CRUSHED, ANGULAR STONE	AASHTO M431 3, 4	COMPAC
A	FOUNDATION STONE: FILL BELOW CHAMBERS FROM THE SUBGRADE UP TO THE FOOT (BOTTOM) OF THE CHAMBER.	CLEAN, CRUSHED, ANGULAR STONE	AASHTO M43 <sup>1</sup> 3, 4	PLATE C

PLEASE NOTE:

1. THE LISTED AASHTO DESIGNATIONS ARE FOR GRADATIONS ONLY. THE STONE MUST ALSO BE CLEAN, CRUSHED, ANGULAR. FOR EXAMPLE, A SPECIFICATION FOR #4 STONE WOULD STATE: "CLEAN, CRUSHED, ANGULAR NO. 4 (AASHTO M43) STONE".

2. STORMTECH COMPACTION REQUIREMENTS ARE MET FOR 'A' LOCATION MATERIALS WHEN PLACED AND COMPACTED IN 9" (230 mm) (MAX) LIFTS USING TWO FULL COVERAGES WITH A VIBRATORY COMPACTOR.

3. WHERE INFILTRATION SURFACES MAY BE COMPROMISED BY COMPACTION, FOR STANDARD DESIGN LOAD CONDITIONS, A FLAT SURFACE MAY BE ACHIEVED BY RAKING OR DRAGGING WITHOUT COMPACTION EQUIPMENT. FOR SPECIAL LOAD DESIGNS, CONTACT STORMTECH FOR COMPACTION REQUIREMENTS.

4. ONCE LAYER 'C' IS PLACED, ANY SOIL/MATERIAL CAN BE PLACED IN LAYER 'D' UP TO THE FINISHED GRADE. MOST PAVEMENT SUBBASE SOILS CAN BE USED TO REPLACE THE MATERIAL REQUIREMENTS OF LAYER 'C' OR 'D' AT THE SITE DESIGN ENGINEER'S DISCRETION.

1 LAYER OF ADS GEOSYNTHETICS NON-WOVEN GEOTEXTILE ON BOTH SIDES OF THERMOPLASTIC LINER ALL AROUND CLEAN, CRUSHED, ANGULAR STONE IN A & B LAYERS. \_ SEE ADS TECHNICAL NOTE 6.50 FOR NON-WOVEN WEIGHT RECOMMENDATIONS. / - 1 LAYER OF ADS GEOSYNTHETICS NON-WOVEN GEOTEXTILE BETWEEN COVER STONE AND C LAYER.

![](_page_126_Figure_9.jpeg)

## **PROJECT PYTHON SYSTEM 3 CROSS SECTION**

## NOTES:

- 1. CHAMBERS SHALL MEET THE REQUIREMENTS OF ASTM F2418-16a, "STANDARD SPECIFICATION FOR POLYPROPYLENE (PP) CORRUGATED WALL STORMWATER COLLECTION CHAMBERS" CHAMBER CLASSIFICATION 45x76 DESIGNATION SS.
- 2. MC-3500 CHAMBERS SHALL BE DESIGNED IN ACCORDANCE WITH ASTM F2787 "STANDARD PRACTICE FOR STRUCTURAL DESIGN OF THERMOPLASTIC CORRUGATED WALL STORMWATER COLLECTION CHAMBERS".
- 3. THE SITE DESIGN ENGINEER IS RESPONSIBLE FOR ASSESSING THE BEARING RESISTANCE (ALLOWABLE BEARING CAPACITY) OF THE SUBGRADE SOILS AND THE DEPTH OF FOUNDATION STONE WITH CONSIDERATION FOR THE RANGE OF EXPECTED SOIL MOISTURE CONDITIONS.
- 4. PERIMETER STONE MUST BE EXTENDED HORIZONTALLY TO THE EXCAVATION WALL FOR BOTH VERTICAL AND SLOPED EXCAVATION WALLS.
- 5. REQUIREMENTS FOR HANDLING AND INSTALLATION:
  - TO MAINTAIN THE WIDTH OF CHAMBERS DURING SHIPPING AND HANDLING, CHAMBERS SHALL HAVE INTEGRAL, INTERLOCKING STACKING LUGS.
  - TO ENSURE A SECURE JOINT DURING INSTALLATION AND BACKFILL, THE HEIGHT OF THE CHAMBER JOINT SHALL NOT BE LESS THAN 3".
  - TO ENSURE THE INTEGRITY OF THE ARCH SHAPE DURING INSTALLATION, a) THE ARCH STIFFNESS CONSTANT AS DEFINED IN SECTION 6.2.8 OF ASTM F2418 SHALL BE GREATER THAN OR EQUAL TO 500 LBS/IN/IN. AND b) TO RESIST CHAMBER DEFORMATION DURING INSTALLATION AT ELEVATED TEMPERATURES (ABOVE 73° F / 23° C), CHAMBERS SHALL BE PRODUCED FROM REFLECTIVE GOLD OR YELLOW COLORS.

![](_page_126_Figure_20.jpeg)

## ACCEPTABLE FILL MATERIALS: STORMTECH MC-4500 CHAMBER SYSTEMS

	MATERIAL LOCATION	DESCRIPTION	AASHTO MATERIAL CLASSIFICATIONS	COMP
D	FINAL FILL: FILL MATERIAL FOR LAYER 'D' STARTS FROM THE TOP OF THE 'C' LAYER TO THE BOTTOM OF FLEXIBLE PAVEMENT OR UNPAVED FINISHED GRADE ABOVE. NOTE THAT PAVEMENT SUBBASE MAY BE PART OF THE 'D' LAYER	ANY SOIL/ROCK MATERIALS, NATIVE SOILS, OR PER ENGINEER'S PLANS. CHECK PLANS FOR PAVEMENT SUBGRADE REQUIREMENTS.	N/A	PREPAI
С	INITIAL FILL: FILL MATERIAL FOR LAYER 'C' STARTS FROM THE TOP OF THE EMBEDMENT STONE ('B' LAYER) TO 24" (600 mm) ABOVE THE TOP OF THE CHAMBER. NOTE THAT PAVEMENT SUBBASE MAY BE A PART OF THE 'C' LAYER.	GRANULAR WELL-GRADED SOIL/AGGREGATE MIXTURES, <35% FINES OR PROCESSED AGGREGATE. MOST PAVEMENT SUBBASE MATERIALS CAN BE USED IN LIEU OF THIS LAYER.	AASHTO M145 <sup>1</sup> A-1, A-2-4, A-3 OR AASHTO M43 <sup>1</sup> 3, 357, 4, 467, 5, 56, 57, 6, 67, 68, 7, 78, 8, 89, 9, 10	BEGIN COI THE CHAME 12" (300 mr WELL GR
В	<b>EMBEDMENT STONE</b> : FILL SURROUNDING THE CHAMBERS FROM THE FOUNDATION STONE ('A' LAYER) TO THE 'C' LAYER ABOVE.	CLEAN, CRUSHED, ANGULAR STONE	AASHTO M43 <sup>1</sup> 3, 4	COMPAC
A	FOUNDATION STONE: FILL BELOW CHAMBERS FROM THE SUBGRADE UP TO THE FOOT (BOTTOM) OF THE CHAMBER.	CLEAN, CRUSHED, ANGULAR STONE	AASHTO M43 <sup>1</sup> 3, 4	PLATE CO

PLEASE NOTE:

1. THE LISTED AASHTO DESIGNATIONS ARE FOR GRADATIONS ONLY. THE STONE MUST ALSO BE CLEAN, CRUSHED, ANGULAR. FOR EXAMPLE, A SPECIFICATION FOR #4 STONE WOULD STATE: "CLEAN, CRUSHED, ANGULAR NO. 4 (AASHTO M43) STONE".

2. STORMTECH COMPACTION REQUIREMENTS ARE MET FOR 'A' LOCATION MATERIALS WHEN PLACED AND COMPACTED IN 9" (230 mm) (MAX) LIFTS USING TWO FULL COVERAGES WITH A VIBRATORY COMPACTOR.

3. WHERE INFILTRATION SURFACES MAY BE COMPROMISED BY COMPACTION, FOR STANDARD DESIGN LOAD CONDITIONS, A FLAT SURFACE MAY BE ACHIEVED BY RAKING OR DRAGGING WITHOUT COMPACTION EQUIPMENT. FOR SPECIAL LOAD DESIGNS, CONTACT STORMTECH FOR COMPACTION REQUIREMENTS.

4. ONCE LAYER 'C' IS PLACED, ANY SOIL/MATERIAL CAN BE PLACED IN LAYER 'D' UP TO THE FINISHED GRADE. MOST PAVEMENT SUBBASE SOILS CAN BE USED TO REPLACE THE MATERIAL REQUIREMENTS OF LAYER 'C' OR 'D' AT THE SITE DESIGN ENGINEER'S DISCRETION.

![](_page_127_Figure_7.jpeg)

## **PROJECT PYTHON SYSTEM 4 CROSS SECTION**

## NOTES:

- 1. CHAMBERS SHALL MEET THE REQUIREMENTS OF ASTM F2418-16a, "STANDARD SPECIFICATION FOR POLYPROPYLENE (PP) CORRUGATED WALL STORMWATER COLLECTION CHAMBERS" CHAMBER CLASSIFICATION 60x101
- 2. MC-4500 CHAMBERS SHALL BE DESIGNED IN ACCORDANCE WITH ASTM F2787 "STANDARD PRACTICE FOR STRUCTURAL DESIGN OF THERMOPLASTIC CORRUGATED WALL STORMWATER COLLECTION CHAMBERS".
- 3. THE SITE DESIGN ENGINEER IS RESPONSIBLE FOR ASSESSING THE BEARING RESISTANCE (ALLOWABLE BEARING CAPACITY) OF THE SUBGRADE SOILS AND THE DEPTH OF FOUNDATION STONE WITH CONSIDERATION FOR THE RANGE OF EXPECTED SOIL MOISTURE CONDITIONS.
- 4. PERIMETER STONE MUST BE EXTENDED HORIZONTALLY TO THE EXCAVATION WALL FOR BOTH VERTICAL AND SLOPED EXCAVATION WALLS.
- 5. REQUIREMENTS FOR HANDLING AND INSTALLATION:
  - TO MAINTAIN THE WIDTH OF CHAMBERS DURING SHIPPING AND HANDLING, CHAMBERS SHALL HAVE INTEGRAL, INTERLOCKING STACKING LUGS.
  - TO ENSURE A SECURE JOINT DURING INSTALLATION AND BACKFILL, THE HEIGHT OF THE CHAMBER JOINT SHALL NOT BE LESS THAN 3".
  - TO ENSURE THE INTEGRITY OF THE ARCH SHAPE DURING INSTALLATION, a) THE ARCH STIFFNESS CONSTANT AS DEFINED IN SECTION 6.2.8 OF ASTM F2418 SHALL BE GREATER THAN OR EQUAL TO 500 LBS/IN/IN. AND b) TO RESIST CHAMBER DEFORMATION DURING INSTALLATION AT ELEVATED TEMPERATURES (ABOVE 73° F / 23° C), CHAMBERS SHALL BE PRODUCED FROM REFLECTIVE GOLD OR YELLOW COLORS.

## RCT QMI PYTHON ACTION / DENSITY REQUIREMENT CHECKED DRAWN: OTTAWA,ON. RE PER SITE DESIGN ENGINEER'S PLANS, PAVED LLATIONS MAY HAVE STRINGENT MATERIAL AND C PREPARATION REQUIREMENTS. 05/05/20 S181876 PROJEC MPACTIONS AFTER 24" (600 mm) OF MATERIAL OVER BERS IS REACHED. COMPACT ADDITIONAL LAYERS IN PROJECT #: m) MAX LIFTS TO A MIN. 95% PROCTOR DENSITY FOR ADED MATERIAL AND 95% RELATIVE DENSITY FOR DATE: PROCESSED AGGREGATE MATERIALS. TION REQUIRED. SEE SPECIAL REQUIREMENTS ON LAYOUT PAGE OMPACT OR ROLL TO ACHIEVE A FLAT SURFACE.<sup>2,3</sup> a a RCT 100.40 MAXIMUM 24" (600 mm) MIN\* ELEVATION \*\*THIS CROSS SECTION DETAIL REPRESENTS Storm MINIMUM REQUIREMENTS FOR INSTALLATION. PLEASE SEE THE LAYOUT SHEET(S) FOR PROJECT SPECIFIC REQUIREMENTS. DEPTH OF STONE TO BE DETERMINED BY SITE DESIGN ENGINEER 9" (230 mm) MIN 4640 TRUEMAN BLVD HILLIARD, OH 43026 J p SHEET 11 <sub>OF</sub> 16

## ACCEPTABLE FILL MATERIALS: STORMTECH MC-4500 CHAMBER SYSTEMS

	MATERIAL LOCATION	DESCRIPTION	AASHTO MATERIAL CLASSIFICATIONS	COMF
D	<b>FINAL FILL:</b> FILL MATERIAL FOR LAYER 'D' STARTS FROM THE TOP OF THE 'C' LAYER TO THE BOTTOM OF FLEXIBLE PAVEMENT OR UNPAVED FINISHED GRADE ABOVE. NOTE THAT PAVEMENT SUBBASE MAY BE PART OF THE 'D' LAYER	ANY SOIL/ROCK MATERIALS, NATIVE SOILS, OR PER ENGINEER'S PLANS. CHECK PLANS FOR PAVEMENT SUBGRADE REQUIREMENTS.	N/A	PREPA INSTAI
С	INITIAL FILL: FILL MATERIAL FOR LAYER 'C' STARTS FROM THE TOP OF THE EMBEDMENT STONE ('B' LAYER) TO 24" (600 mm) ABOVE THE TOP OF THE CHAMBER. NOTE THAT PAVEMENT SUBBASE MAY BE A PART OF THE 'C' LAYER.	GRANULAR WELL-GRADED SOIL/AGGREGATE MIXTURES, <35% FINES OR PROCESSED AGGREGATE. MOST PAVEMENT SUBBASE MATERIALS CAN BE USED IN LIEU OF THIS LAYER.	AASHTO M145 <sup>1</sup> A-1, A-2-4, A-3 OR AASHTO M43 <sup>1</sup> 3, 357, 4, 467, 5, 56, 57, 6, 67, 68, 7, 78, 8, 89, 9, 10	BEGIN CO THE CHAMI 12" (300 mr WELL GF
В	<b>EMBEDMENT STONE:</b> FILL SURROUNDING THE CHAMBERS FROM THE FOUNDATION STONE ('A' LAYER) TO THE 'C' LAYER ABOVE.	CLEAN, CRUSHED, ANGULAR STONE	AASHTO M431 3, 4	COMPAC
A	FOUNDATION STONE: FILL BELOW CHAMBERS FROM THE SUBGRADE UP TO THE FOOT (BOTTOM) OF THE CHAMBER.	CLEAN, CRUSHED, ANGULAR STONE	AASHTO M431 3, 4	PLATE C

PLEASE NOTE:

1. THE LISTED AASHTO DESIGNATIONS ARE FOR GRADATIONS ONLY. THE STONE MUST ALSO BE CLEAN, CRUSHED, ANGULAR. FOR EXAMPLE, A SPECIFICATION FOR #4 STONE WOULD STATE: "CLEAN, CRUSHED, ANGULAR NO. 4 (AASHTO M43) STONE".

2. STORMTECH COMPACTION REQUIREMENTS ARE MET FOR 'A' LOCATION MATERIALS WHEN PLACED AND COMPACTED IN 9" (230 mm) (MAX) LIFTS USING TWO FULL COVERAGES WITH A VIBRATORY COMPACTOR.

3. WHERE INFILTRATION SURFACES MAY BE COMPROMISED BY COMPACTION, FOR STANDARD DESIGN LOAD CONDITIONS, A FLAT SURFACE MAY BE ACHIEVED BY RAKING OR DRAGGING WITHOUT COMPACTION EQUIPMENT. FOR SPECIAL LOAD DESIGNS, CONTACT STORMTECH FOR COMPACTION REQUIREMENTS.

4. ONCE LAYER 'C' IS PLACED, ANY SOIL/MATERIAL CAN BE PLACED IN LAYER 'D' UP TO THE FINISHED GRADE. MOST PAVEMENT SUBBASE SOILS CAN BE USED TO REPLACE THE MATERIAL REQUIREMENTS OF LAYER 'C' OR 'D' AT THE SITE DESIGN ENGINEER'S DISCRETION.

![](_page_128_Figure_7.jpeg)

## **PROJECT PYTHON SYSTEM 5 CROSS SECTION**

## NOTES:

- 1. CHAMBERS SHALL MEET THE REQUIREMENTS OF ASTM F2418-16a, "STANDARD SPECIFICATION FOR POLYPROPYLENE (PP) CORRUGATED WALL STORMWATER COLLECTION CHAMBERS" CHAMBER CLASSIFICATION 60x101
- 2. MC-4500 CHAMBERS SHALL BE DESIGNED IN ACCORDANCE WITH ASTM F2787 "STANDARD PRACTICE FOR STRUCTURAL DESIGN OF THERMOPLASTIC CORRUGATED WALL STORMWATER COLLECTION CHAMBERS".
- 3. THE SITE DESIGN ENGINEER IS RESPONSIBLE FOR ASSESSING THE BEARING RESISTANCE (ALLOWABLE BEARING CAPACITY) OF THE SUBGRADE SOILS AND THE DEPTH OF FOUNDATION STONE WITH CONSIDERATION FOR THE RANGE OF EXPECTED SOIL MOISTURE CONDITIONS.
- 4. PERIMETER STONE MUST BE EXTENDED HORIZONTALLY TO THE EXCAVATION WALL FOR BOTH VERTICAL AND SLOPED EXCAVATION WALLS.
- 5. REQUIREMENTS FOR HANDLING AND INSTALLATION:
  - TO MAINTAIN THE WIDTH OF CHAMBERS DURING SHIPPING AND HANDLING, CHAMBERS SHALL HAVE INTEGRAL, INTERLOCKING STACKING LUGS.
  - TO ENSURE A SECURE JOINT DURING INSTALLATION AND BACKFILL, THE HEIGHT OF THE CHAMBER JOINT SHALL NOT BE LESS THAN 3".
  - TO ENSURE THE INTEGRITY OF THE ARCH SHAPE DURING INSTALLATION, a) THE ARCH STIFFNESS CONSTANT AS DEFINED IN SECTION 6.2.8 OF ASTM F2418 SHALL BE GREATER THAN OR EQUAL TO 500 LBS/IN/IN. AND b) TO RESIST CHAMBER DEFORMATION DURING INSTALLATION AT ELEVATED TEMPERATURES (ABOVE 73° F / 23° C), CHAMBERS SHALL BE PRODUCED FROM REFLECTIVE GOLD OR YELLOW COLORS.

![](_page_128_Figure_18.jpeg)

![](_page_129_Figure_0.jpeg)

![](_page_130_Figure_0.jpeg)

![](_page_131_Figure_0.jpeg)

![](_page_132_Figure_0.jpeg)

С

PARTIAL CUT HOLES AT TOP OF END CAP FOR PART NUMBERS ENDING WITH "T" END CAPS WITH A PREFABRICATED WELDED STUB END WITH "W" END CAPS WITH A WELDED CROWN PLATE END WITH "C" PART # STUB B MC3500IEPP06T 33.21" (844 mm)

MC3500IEPP06T		33.21" (844 mm)		
	6" (16() mm)			
MC3500IEPP06B	0 (150 mm)		0.66" (17 mm)	
MC3500IEPP08T	8" (200 mm)	31.16" (791 mm)		
MC3500IEPP08B			0.81" (21 mm)	
MC3500IEPP10T	10" (250 mm)	29.04" (738 mm)		
MC3500IEPP10B			0.93" (24 mm)	
MC3500IEPP12T	12" (300 mm)	26.36" (670 mm)		
MC3500IEPP12B			1.35" (34 mm)	
MC3500IEPP15T	15" (375 mm)	23.39" (594 mm)		
MC3500IEPP15B	15 (375 mm)		1.50" (38 mm)	
MC3500IEPP18TC	18" <i>(1</i> 50 mm)	20.03" (509 mm)		
MC3500IEPP18TW		20.03 (303 mm)		
MC3500IEPP18BC			1 77" ( <i>1</i> 5 mm)	
MC3500IEPP18BW			1.77 ( <del>4</del> 0 mm)	
MC3500IEPP24TC		14 48" (368 mm)		
MC3500IEPP24TW	24" (600 mm)	14.40 (500 1111)		
MC3500IEPP24BC			2.06" (52 mm)	
MC3500IEPP24BW			2.00 (32 11111)	
MC3500IEPP30BC	30" (750 mm)		2.75" (70 mm)	

CUSTOM PARTIAL CUT INVERTS ARE AVAILABLE UPON REQUEST. INVENTORIED MANIFOLDS INCLUDE 12-24" (300-600 mm) SIZE ON SIZE AND 15-48" (375-1200 mm) ECCENTRIC MANIFOLDS. CUSTOM INVERT LOCATIONS ON THE MC-3500 END CAP CUT IN THE FIELD ARE NOT RECOMMENDED FOR PIPE SIZES GREATER THAN 10" (250 mm). THE INVERT LOCATION IN COLUMN 'B' ARE THE HIGHEST POSSIBLE FOR THE PIPE SIZE.

PART # STUB В 42.54" (1081 mm) MC4500IEPP06T 6" (150 mm) MC4500IEPP06B MC4500IEPP08T 40.50" (1029 mm) 8" (200 mm) MC4500IEPP08B MC4500IEPP10T 38.37" (975 mm) 10" (250 mm) MC4500IEPP10B MC4500IEPP12T 35.69" (907 mm) 12" (300 mm) MC4500IEPP12B ---MC4500IEPP15T 32.72" (831 mm) 15" (375 mm) MC4500IEPP15B ----MC4500IEPP18T 29.36" (746 mm) MC4500IEPP18TW 18" (450 mm) MC4500IEPP18B ----MC4500IEPP18BW MC4500IEPP24T 23.05" (585 mm) MC4500IEPP24TW 24" (600 mm) MC4500IEPP24B ---MC4500IEPP24BW 30" (750 mm) MC4500IEPP30BW ---36" (900 mm) MC4500IEPP36BW ---42" (1050 mm) MC4500IEPP42BW

NOTE: ALL DIMENSIONS ARE NOMINAL

![](_page_132_Figure_7.jpeg)

![](_page_133_Figure_0.jpeg)

#### Project: Project Python Rev2 System 1

![](_page_134_Figure_1.jpeg)

Height of	Incremental Single	Incremental	Incremental	Incremental End	Incremental	Incremental	Cumulative	
System	Chamber	Single End Cap	Chambers	Сар	Stone	Chamber, End	System	Elevation
( <i>mm</i> ) 1676	(cubic meters)	(cubic meters)	(cubic meters)	(cubic meters)	(CUDIC meters)	(CUDIC meters)	(CUDIC meters)	(meters)
1651	0.00	0.00	0.00	0.00	2.222	2.22	216.30	99.00
1626	0.00	0.00	0.00	0.00	2.222	2.22	213.86	99.63
1600	0.00	0.00	0.00	0.00	2.222	2.22	211.64	99.60
1575	0.00	0.00	0.00	0.00	2.222	2.22	209.42	99.57
1549	0.00	0.00	0.00	0.00	2.222	2.22	207.19	99.55
1524	0.00	0.00	0.00	0.00	2.222	2.22	204.97	99.52
1499	0.00	0.00	0.00	0.00	2.222	2.22	202.75	99.50
1473	0.00	0.00	0.00	0.00	2.222	2.22	200.53	99.47
1448	0.00	0.00	0.00	0.00	2.222	2.22	198.31	99.45
1422	0.00	0.00	0.00	0.00	2.222	2.22	190.08	99.42
1372	0.00	0.00	0.00	0.00	2.222	2.22	191 64	99.37
1346	0.00	0.00	0.20	0.01	2.138	2.35	189.38	99.35
1321	0.01	0.00	0.31	0.01	2.094	2.41	187.03	99.32
1295	0.01	0.00	0.42	0.01	2.047	2.48	184.62	99.30
1270	0.02	0.00	0.72	0.02	1.926	2.67	182.14	99.27
1245	0.03	0.00	1.08	0.02	1.781	2.88	179.47	99.24
1219	0.04	0.00	1.31	0.03	1.686	3.03	176.59	99.22
1194	0.04	0.00	1.49	0.04	1.612	3.14	173.56	99.19
1108	0.04	0.00	1.05	0.04	1.540	3.24	170.42	99.17
1143	0.05	0.00	1.79	0.05	1.400	3.32	163.87	99.14 00.12
1092	0.05	0.01	2.03	0.06	1.387	3.47	160.46	99.09
1067	0.06	0.01	2.14	0.06	1.342	3.54	156.99	99.07
1041	0.06	0.01	2.24	0.07	1.301	3.60	153.45	99.04
1016	0.06	0.01	2.33	0.07	1.261	3.66	149.84	99.02
991	0.07	0.01	2.42	0.08	1.225	3.72	146.18	98.99
965	0.07	0.01	2.50	0.08	1.191	3.77	142.46	98.97
940	0.07	0.01	2.58	0.08	1.158	3.82	138.70	98.94
914	0.07	0.01	2.05	0.09	1.127	3.80	134.88	98.91
864	0.07	0.01	2.72	0.09	1.098	3.95	127 11	98.86
838	0.08	0.01	2.84	0.10	1.045	3.99	123.16	98.84
813	0.08	0.01	2.90	0.10	1.020	4.03	119.17	98.81
787	0.08	0.01	2.96	0.11	0.996	4.06	115.15	98.79
762	0.08	0.01	3.01	0.11	0.973	4.09	111.09	98.76
737	0.08	0.01	3.06	0.11	0.952	4.13	106.99	98.74
711	0.08	0.01	3.11	0.12	0.931	4.16	102.86	98.71
686	0.09	0.01	3.16	0.12	0.912	4.19	98.71	98.69
635	0.09	0.01	3.20	0.12	0.694	4.21	94.52	90.00
610	0.09	0.01	3 28	0.12	0.859	4 27	86.06	98.61
584	0.09	0.01	3.32	0.13	0.843	4.29	81.80	98.58
559	0.09	0.01	3.35	0.13	0.828	4.31	77.51	98.56
533	0.09	0.01	3.39	0.14	0.813	4.33	73.19	98.53
508	0.09	0.01	3.42	0.14	0.800	4.36	68.86	98.51
483	0.09	0.01	3.45	0.14	0.787	4.37	64.50	98.48
457	0.09	0.01	3.48	0.14	0.774	4.39	60.13	98.46
432	0.09	0.01	3.50	0.15	0.762	4.41	55.73	98.43
400	0.10	0.01	3.55	0.15	0.751	4.43	01.02 46.80	90.41
356	0.10	0.01	3.58	0.15	0.730	4 46	42.45	98.36
330	0.10	0.02	3.60	0.15	0.720	4.47	37.99	98.33
305	0.10	0.02	3.62	0.16	0.711	4.49	33.52	98.30
279	0.10	0.02	3.64	0.16	0.701	4.50	29.03	98.28
254	0.10	0.02	3.67	0.17	0.686	4.53	24.52	98.25
229	0.00	0.00	0.00	0.00	2.222	2.22	20.00	98.23
203	0.00	0.00	0.00	0.00	2.222	2.22	17.78	98.20
178	0.00	0.00	0.00	0.00	2.222	2.22	15.55	98.18
152	0.00	0.00	0.00	0.00	2.222	2.22	13.33	98.15 08 12
102	0.00	0.00	0.00	0.00	2.222	2.22	11.11 8.80	90.13 08 10
76	0.00	0.00	0.00	0.00	2.222	2.22	6.67	98.08
51	0.00	0.00	0.00	0.00	2.222	2.22	4.44	98.05
25	0.00	0.00	0.00	0.00	2.222	2.22	2.22	98.03

#### Project: Project Python Rev 1 Bed 2

![](_page_135_Figure_1.jpeg)

Height of	Incremental Single	Incremental	Incremental	Incremental End	Incremental	Incremental	Cumulative	
System	Chamber	Single End Cap	Chambers	Cap	Stone	Chamber, End	System	Elevation
1676	0.00	0.00	0.00	0.00	10 359	10.36	1054 57	99.88
1651	0.00	0.00	0.00	0.00	10.359	10.36	1044.21	99.85
1626	0.00	0.00	0.00	0.00	10.359	10.36	1033.85	99.83
1600	0.00	0.00	0.00	0.00	10.359	10.36	1023.49	99.80
1575	0.00	0.00	0.00	0.00	10.359	10.36	1013.13	99.77
1549	0.00	0.00	0.00	0.00	10.359	10.36	1002.77	99.75
1524	0.00	0.00	0.00	0.00	10.359	10.36	992.41	99.72
1499	0.00	0.00	0.00	0.00	10.359	10.36	982.05	99.70
1473	0.00	0.00	0.00	0.00	10.359	10.30	971.70	99.07
1422	0.00	0.00	0.00	0.00	10.359	10.36	950.98	99.62
1397	0.00	0.00	0.00	0.00	10.359	10.36	940.62	99.60
1372	0.00	0.00	0.32	0.00	10.231	10.55	930.26	99.57
1346	0.01	0.00	1.07	0.02	9.923	11.01	919.71	99.55
1321	0.01	0.00	1.62	0.03	9.699	11.35	908.70	99.52
1295	0.01	0.00	2.23	0.04	9.452	11.72	897.35	99.50
1270	0.02	0.00	3.79	0.05	8.821	12.67	885.63	99.47
1245	0.03	0.00	5.00	0.06	0.002 7.568	13.00	859 16	99.44 00.42
1194	0.04	0.00	7.85	0.00	7 180	15 13	844 61	99.39
1168	0.04	0.00	8.69	0.11	6.842	15.63	829.48	99.37
1143	0.05	0.00	9.43	0.12	6.540	16.09	813.85	99.34
1118	0.05	0.01	10.10	0.13	6.267	16.50	797.76	99.32
1092	0.05	0.01	10.70	0.15	6.020	16.87	781.26	99.29
1067	0.06	0.01	11.27	0.16	5.787	17.22	764.40	99.27
1041	0.06	0.01	11.79	0.17	5.575	17.54	747.18	99.24
1016	0.06	0.01	12.28	0.18	5.373	17.84	729.64	99.22
965	0.07	0.01	12.74	0.20	5.009	18.38	693.69	99.19
940	0.07	0.01	13.58	0.22	4.841	18.64	675.30	99.14
914	0.07	0.01	13.96	0.23	4.684	18.87	656.67	99.11
889	0.07	0.01	14.32	0.24	4.536	19.09	637.80	99.09
864	0.08	0.01	14.67	0.25	4.394	19.31	618.70	99.06
838	0.08	0.01	14.99	0.26	4.260	19.51	599.40	99.04
813	0.08	0.01	15.30	0.27	4.132	19.70	579.89	99.01
787 762	0.08	0.01	15.60	0.27	4.010	19.88	560.19	98.99
737	0.08	0.01	16.00	0.20	3 784	20.00	520.25	98.90
711	0.08	0.01	16.40	0.30	3.679	20.38	500.03	98.91
686	0.09	0.01	16.63	0.31	3.582	20.52	479.65	98.89
660	0.09	0.01	16.86	0.32	3.489	20.66	459.13	98.86
635	0.09	0.01	17.09	0.32	3.395	20.81	438.46	98.84
610	0.09	0.01	17.29	0.33	3.312	20.93	417.66	98.81
584	0.09	0.01	17.48	0.34	3.231	21.05	396.73	98.78
559	0.09	0.01	17.67	0.35	3.154	21.17	375.68	98.76
508	0.09	0.01	18.01	0.36	3 011	21.20	333.23	98.73
483	0.09	0.01	18.17	0.37	2.945	21.48	311.85	98.68
457	0.09	0.01	18.32	0.37	2.881	21.58	290.37	98.66
432	0.09	0.01	18.47	0.38	2.821	21.67	268.80	98.63
406	0.10	0.01	18.60	0.38	2.765	21.75	247.13	98.61
381	0.10	0.01	18.73	0.39	2.710	21.83	225.38	98.58
356	0.10	0.02	18.85	0.40	2.659	21.91	203.55	98.56
330	0.10	0.02	18.98	0.40	2.608	21.99	181.04	98.53
279	0.10	0.02	19.09	0.40	2.500	22.00	137.60	98.48
254	0.10	0.02	19.35	0.44	2.442	22.23	115.47	98.45
229	0.00	0.00	0.00	0.00	10.359	10.36	93.23	98.43
203	0.00	0.00	0.00	0.00	10.359	10.36	82.87	98.40
178	0.00	0.00	0.00	0.00	10.359	10.36	72.51	98.38
152	0.00	0.00	0.00	0.00	10.359	10.36	62.15	98.35
127	0.00	0.00	0.00	0.00	10.359	10.36	51.80	98.33
102	0.00	0.00	0.00	0.00	10.359	10.36	41.44	98.30 08 20
51	0.00	0.00	0.00	0.00	10.359	10.36	20.72	98 25
25	0.00	0.00	0.00	0.00	10.359	10.36	10.36	98.23

#### Project: Project Python Rev 1 Bed 3

Г

roject:	Project Python Rev 1	Bed 3	_		
Chamber Model	-	MC-3500		31	onniech
Units -		Metric	Click Here for	Imperial	Detention - Retention - Water Quality
Number of Char	nbers -	72			A division of
Number of End	Caps -	8			
Voids in the stor	ne (porosity) -	40	%		
Base of Stone E	levation -	97.00	m		
Amount of Ston	e Above Chambers -	305	mm	Include Perime	eter Stone in Calculations
Amount of Ston	e Below Chambers -	600	mm		
Amount of Ston	e Between Chambers -	152	mm		
		388.1	sq.meters	Min. Area	- 343.553 sq.meters

Terr         Terr<	Hoight of	Incremental Circuit	In oron t-1	Incremented	In a rama stal E.	In or one set of	In orons suited	Cumuristics	
International problem         Internatiproblem         International problem <thi< th=""><th>Height of</th><th>Chamber</th><th>Incremental Single End Con</th><th>Chambara</th><th>Incremental End</th><th>Incremental</th><th>Incremental Chamber End</th><th>Cumulative</th><th>Floyetian</th></thi<>	Height of	Chamber	Incremental Single End Con	Chambara	Incremental End	Incremental	Incremental Chamber End	Cumulative	Floyetian
200         100 <th>(mm)</th> <th>(cubic meters)</th> <th>(meters)</th>	(mm)	(cubic meters)	(cubic meters)	(cubic meters)	(cubic meters)	(cubic meters)	(cubic meters)	(cubic meters)	(meters)
2022         0.00         0.00         0.00         3.841         3.844         .447.88         98.05           2007         0.00         0.00         0.00         3.841         3.844         .447.88         98.01           1965         0.00         0.00         0.00         3.841         3.844         .445.84         98.01           1965         0.00         0.00         0.00         3.841         3.844         .445.17         98.86           1965         0.00         0.00         0.00         3.841         3.844         .422.17         98.86           1864         0.00         0.00         0.00         3.841         3.844         .422.29         98.85           1829         0.00         0.00         0.00         3.841         3.844         .442.29         98.85           1772         0.01         0.00         0.00         3.841         3.844         .441.44         98.73           1772         0.01         0.00         0.01         3.781         4.41         .444.92         98.65           1626         0.02         0.01         3.781         4.41         .449.873         .477           1772         0.01	2057	0.00	0.00	0.00	0.00	3.941	3.94	455 76	99.06
2007         0.00         0.00         0.00         0.00         3.441         3.44         4.47.84         98.86           1968         0.00         0.00         0.00         3.941         3.44         440.00         98.66           1968         0.00         0.00         0.00         3.941         3.44         440.00         98.66           1968         0.00         0.00         0.00         3.941         3.44         420.17         98.85           1969         0.00         0.00         0.00         3.941         3.44         420.23         98.85           1969         0.00         0.00         0.00         3.941         3.44         440.34         98.85           1973         0.00         0.00         0.00         3.941         3.44         440.34         98.75           1972         0.01         0.00         0.40         0.01         3.668         4.31         400.27         98.75           1972         0.01         0.00         0.40         0.01         3.667         98.68           1966         0.03         2.71         0.767         5.76         3.77.44         98.57           1977         0.61	2032	0.00	0.00	0.00	0.00	3.941	3.94	451.82	99.03
1981         0.00         0.00         0.00         0.00         3.941         3.94         4.43.94         0.44.900         98.98           1985         0.00         0.00         0.00         3.941         3.84         4.45.00         98.95           1980         0.00         0.00         0.00         3.941         3.84         4.42.01         7         98.95           1980         0.00         0.00         0.00         0.00         3.941         3.84         4.42.02         98.85           1983         0.00         0.00         0.00         0.00         3.941         3.84         4.42.02         98.85           1983         0.00         0.00         0.00         0.00         3.941         3.84         4.43.94         98.85           1778         0.00         0.00         0.00         0.01         3.841         3.44         44.34         98.85         98.65           1772         0.01         0.00         0.82         0.01         3.667         4.41         3.84         44.34         98.67         98.65           1651         0.01         3.73         0.02         3.73         0.02         3.73         0.02         98.75<	2007	0.00	0.00	0.00	0.00	3.941	3.94	447.88	99.01
1956         0.00 <th< td=""><td>1981</td><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td><td>3.941</td><td>3.94</td><td>443.94</td><td>98.98</td></th<>	1981	0.00	0.00	0.00	0.00	3.941	3.94	443.94	98.98
1935         0.00         0.00         0.00         0.00         3.941         3.94         4.800         98.93           1955         0.00         0.00         0.00         0.00         3.941         3.941         4.2211         98.93           1929         0.00         0.00         0.00         0.00         3.941         3.941         4.211         98.73           1929         0.00         0.00         0.00         0.00         3.941         3.941         4.112.41         98.76           1775         0.00         0.00         0.00         0.00         3.941         4.01         4.402.27         98.75           1777         0.00         0.00         0.00         0.01         3.984         4.01         4.402.27         98.70           1777         0.01         0.00         0.82         0.01         3.984         4.01         4.402.27         98.73           1707         0.01         0.00         2.20         0.02         3.937         4.44         3.937.53         98.65           1655         0.02         0.373         0.02         2.945         5.93         337.54         98.69           1644         0.06	1956	0.00	0.00	0.00	0.00	3.941	3.94	440.00	98.96
1960         0.00         0.00         0.00         3.941         3.84         4.22.17         98.85           1960         0.00         0.00         0.00         3.941         3.64         4.42.17         98.85           1963         0.00         0.00         0.00         3.941         3.944         44.23         98.85           1963         0.00         0.00         0.00         3.941         3.944         44.24         98.75           1773         0.00         0.00         0.10         3.781         4.81         44.94.4         98.75           1777         0.01         0.00         0.40         0.01         3.771         4.84         49.46.7         98.75           1777         0.01         0.00         2.00         3.751         4.79         99.57         98.65           1626         0.02         0.00         2.00         2.375         4.79         99.57         98.65           1547         0.02         0.00         2.40         0.01         2.470         6.80         3.94.4         98.65           1547         0.05         0.01         3.73         0.04         2.534         6.34         352.01         98.41 </td <td>1930</td> <td>0.00</td> <td>0.00</td> <td>0.00</td> <td>0.00</td> <td>3.941</td> <td>3.94</td> <td>436.06</td> <td>98.93</td>	1930	0.00	0.00	0.00	0.00	3.941	3.94	436.06	98.93
1864         0.00         0.00         0.00         3.841         3.84         428.17         98.88           1854         0.00         0.00         0.00         3.841         3.84         442.23         98.88           1859         0.00         0.00         0.00         3.841         3.84         441.53         98.85           1778         0.00         0.00         0.00         3.841         3.844         440.87         98.75           1727         0.01         0.00         0.40         0.01         3.864         4.81         400.27         98.75           1727         0.01         0.00         0.40         0.01         3.869         4.81         400.27         98.75           1676         0.02         0.00         2.201         0.38         4.74         3.98.75         98.65           1620         0.04         0.00         2.201         0.03         2.770         5.70         376.44         98.52           1544         0.05         0.00         3.43         0.04         2.234         6.55         384.49         98.52           1544         0.06         0.01         4.53         0.06         2.144         6.70 <td>1905</td> <td>0.00</td> <td>0.00</td> <td>0.00</td> <td>0.00</td> <td>3.941</td> <td>3.94</td> <td>432.11</td> <td>98.91</td>	1905	0.00	0.00	0.00	0.00	3.941	3.94	432.11	98.91
Ins         U.00         U.00         3.941         3.944         4.24.29         88.63           1759         0.00         0.00         0.00         3.841         3.944         4.20.29         88.63           1779         0.00         0.00         0.00         3.841         3.94         4.20.29         88.63           1772         0.01         0.00         0.00         3.841         4.18         444.44         88.70           1772         0.01         0.00         0.60         0.01         3.869         4.31         400.27         88.70           1676         0.01         0.00         0.60         0.01         3.607         4.44         369.79         86.65           1616         0.02         2.001         3.607         4.74         3.91.53         86.65           1640         0.00         2.90         0.03         2.70         5.70         376.04         86.57           1549         0.04         0.00         3.24         0.63         3.64.48         86.52           1542         0.05         0.01         4.73         0.06         2.036         6.80         322.19         88.44           1572         0.05	1880	0.00	0.00	0.00	0.00	3.941	3.94	428.17	98.88
1 ac.o         0 add         0 add         3 bd         4 412 bd         98 bd           1773         0 00         0 00         0 00         3 bd4         4 10 dd         4 bd 2 bd         98 bd           1723         0 00         0 00         0 00         3 bd4         4 01         4 bd 2 bd         98 bd           1727         0 01         0 00         0 00         3 bd4         4 01         4 bd 4 bd         98 bd           1727         0 01         0 00         0 00         0 00         3 bd4         4 01         4 bd 4 bd         98 bd           1676         0 01         0 00         0 00         2 bd         0 01         3 bd6         3 bd         4 bd         3 bd 5 bd         98 bd <td< td=""><td>1854</td><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td><td>3.941</td><td>3.94</td><td>424.23</td><td>98.85</td></td<>	1854	0.00	0.00	0.00	0.00	3.941	3.94	424.23	98.85
1	1829	0.00	0.00	0.00	0.00	3.941	3.94	420.29	98.83
	1003	0.00	0.00	0.00	0.00	3.941	3.94	410.35	98.80 98.78
1172         101         0.00         0.01         3.781         1.18         VALA         98.70           1772         0.01         0.00         0.62         0.01         3.607         4.44         395.77         86.85           1651         0.02         0.00         1.40         0.02         3.695         5.21         386.77         98.65           1620         0.03         0.00         2.90         0.03         2.770         5.70         376.44         98.65           1575         0.04         0.00         2.90         0.03         2.770         5.70         376.44         98.55           1549         0.05         0.01         3.73         0.04         2.433         6.34         98.52           1473         0.05         0.01         3.73         0.04         2.433         6.34         98.42           1372         0.06         0.01         4.16         0.05         2.257         6.47         345.86         98.42           1372         0.06         0.01         4.53         0.06         2.104         6.70         332.40         98.42           1372         0.07         0.01         4.53         0.06         <	1753	0.00	0.00	0.00	0.00	3.941	3.94 4 01	412.41	98.75
$\begin{array}{c c c c c c c c c c c c c c c c c c c $	1727	0.01	0.00	0.40	0.01	3,781	4,18	404.46	98.73
1976         0.01         0.02         0.01         3.807         4.44         98.57         98.85           1051         0.02         3.075         4.79         391.53         98.65           1020         0.04         0.00         2.55         0.02         3.095         5.21         396.64         98.65           1575         0.04         0.00         2.90         0.03         2.244         5.86         370.34         98.65           1549         0.04         0.00         3.21         0.03         2.244         5.86         370.34         98.55           1473         0.04         0.00         3.21         0.05         2.433         6.50         398.40         98.47           1448         0.06         0.011         4.15         0.05         2.179         6.47         338.24         98.47           1422         0.06         0.011         4.53         0.06         1.971         6.00         3.26.12         98.37           1344         0.07         0.011         4.53         0.06         1.971         6.00         3.36.22         98.33           1372         0.07         0.011         5.42         0.08         1.771 </td <td>1702</td> <td>0.01</td> <td>0.00</td> <td>0.60</td> <td>0.01</td> <td>3.698</td> <td>4.31</td> <td>400.27</td> <td>98.70</td>	1702	0.01	0.00	0.60	0.01	3.698	4.31	400.27	98.70
1651         0.02         0.03         0.00         2.10         0.02         3.376         4.79         386.74         98.65           1600         0.04         0.00         2.55         0.02         2.912         5.48         386.74         98.65           1544         0.04         0.00         3.21         0.03         2.770         5.70         376.04         98.57           1544         0.04         0.00         3.21         0.03         2.770         5.70         376.04         98.57           1544         0.05         0.01         3.43         0.05         2.343         6.53         384.46         98.45           1442         0.06         0.01         4.55         0.05         2.179         6.58         332.61         98.45           1327         0.07         0.01         4.53         0.06         2.104         6.60         332.61         98.35           1321         0.07         0.01         5.15         0.07         1.369         6.69         319.24         98.35           1321         0.07         0.01         5.54         0.08         1.655         7.1         28.36         98.22           1346	1676	0.01	0.00	0.82	0.01	3.607	4.44	395.97	98.68
1626         0.03         0.00         2.10         0.02         3.065         5.21         5.44         381.52           1575         0.04         0.00         2.90         0.03         2.770         5.70         376.64         98.55           1544         0.05         0.00         3.44         0.04         2.544         6.05         386.44         98.55           1479         0.05         0.01         3.73         0.04         2.433         6.20         386.44         98.57           1472         0.06         0.01         3.95         0.05         2.179         6.56         352.49         98.42           1372         0.06         0.01         4.35         0.06         2.104         6.70         332.41         98.40           1372         0.07         0.01         4.70         0.06         2.036         6.80         32.61         98.32           1280         0.07         0.01         5.01         0.71         1.971         7.61         28.68         98.27           1241         0.08         0.01         5.42         0.08         1.045         7.31         28.48         98.32           1271         0.03	1651	0.02	0.00	1.40	0.02	3.375	4.79	391.53	98.65
1600         0.04         0.00         2.55         0.02         2.912         5.48         381.52         98.57           1543         0.04         0.00         3.21         0.03         2.770         5.70         376.04         98.57           1544         0.05         0.00         3.42         0.03         2.453         6.65         384.46         98.57           1449         0.05         0.00         3.47         0.05         2.277         6.70         335.84         18.95           1442         0.06         0.01         4.35         0.06         2.179         6.58         332.61         98.45           1372         0.07         0.01         4.70         0.06         1.014         6.69         312.42         98.35           1321         0.07         0.01         5.15         0.07         1.399         6.69         312.42         98.35           1321         0.07         0.01         5.55         0.06         1.646         7.31         28.86         98.22           1370         0.08         0.01         5.55         0.08         1.664         7.31         28.36         98.22           1414         0.08	1626	0.03	0.00	2.10	0.02	3.095	5.21	386.74	98.63
$\begin{array}{c c c c c c c c c c c c c c c c c c c $	1600	0.04	0.00	2.55	0.02	2.912	5.48	381.52	98.60
1 = b         0.04         0.03         2.645         5.89         370.34         88.55           1449         0.05         0.00         3.73         0.04         2.453         6.05         364.41         86.50           1470         0.05         0.01         3.75         0.06         2.457         6.34         352.20         86.47           1422         0.06         0.01         4.55         0.05         2.147         6.56         339.40         98.42           1337         0.06         0.01         4.53         0.06         2.036         6.80         332.61.2         98.37           1346         0.07         0.01         5.15         0.07         1.851         7.08         335.43         98.32           1225         0.07         0.01         5.42         0.82         0.87         7.1         7.98         332.64         98.22           1245         0.08         0.01         5.54         0.08         1.644         7.45         2.28.56         88.12           1184         0.08         0.01         5.56         0.08         1.644         7.45         2.26.5         86.19           1184         0.08         0.01	1575	0.04	0.00	2.90	0.03	2.770	5.70	376.04	98.57
1a2*         0.05         0.00         3.40         0.44         2.534         6.03         384.45         B8.22           1479         0.05         0.01         3.57         0.04         2.243         6.20         356.41         685.0           1442         0.05         0.01         4.16         0.05         2.179         6.47         345.60         864.41           1427         0.06         0.01         4.53         0.05         2.179         6.47         345.60         864.41           1372         0.07         0.01         4.66         0.06         1.971         6.80         332.21         983.52           1324         0.07         0.01         5.15         0.07         1.861         7.08         99.312.2         983.52           1270         0.07         0.01         5.24         0.08         1.747         7.16         298.36         98.24           1219         0.08         0.01         5.54         0.08         1.648         7.33         285.66         89.24           1143         0.08         0.01         5.56         0.08         1.648         7.31         285.66         89.24           1143         0.08 </td <td>1549</td> <td>0.04</td> <td>0.00</td> <td>3.21</td> <td>0.03</td> <td>2.645</td> <td>5.89</td> <td>370.34</td> <td>98.55</td>	1549	0.04	0.00	3.21	0.03	2.645	5.89	370.34	98.55
$\begin{array}{c c c c c c c c c c c c c c c c c c c $	1524	0.05	0.00	3.48 3.72	0.04	2.534	0.05 6 20	304.40	98.52
1420.060.014.160.05 $2.277$ 0.47345.66984.7614220.0660.014.350.0652.1196.58330.40984.4213720.060.014.700.0662.0366.80326.1298.3513460.070.014.860.061.9716.90319.4298.3512210.070.015.150.071.8517.0899.9312.4298.3512700.070.015.150.071.7977.16298.3698.2412850.070.015.540.081.7457.24291.2098.2412190.080.015.560.081.6487.33283.6698.2211440.080.015.660.091.5207.57254.3188.1411430.080.015.660.091.5207.57254.3188.1411430.080.016.360.091.4827.63246.7498.06410670.090.016.310.101.3787.79223.6986.0410410.090.016.590.111.2897.9220.0097.949440.090.016.590.111.3787.79223.6986.0410470.090.016.590.111.2897.79223.6986.0410410.090.016.590.11	1499	0.05	0.01	3.73	0.04	2.433	6.34	352 20	98.30
$\begin{array}{cccccccccccccccccccccccccccccccccccc$	1448	0.06	0.01	4,16	0.05	2.257	6.47	345.86	98.45
$\begin{array}{cccccccccccccccccccccccccccccccccccc$	1422	0.06	0.01	4.35	0.05	2.179	6.58	339.40	98.42
$\begin{array}{cccccccccccccccccccccccccccccccccccc$	1397	0.06	0.01	4.53	0.06	2.104	6.70	332.81	98.40
1346       0.07       0.01       4.86       0.06       1.971       6.99       312.42       98.32         1295       0.07       0.01       5.15       0.07       1.851       7.06       306.43       98.32         1270       0.02       0.01       5.42       0.06       1.745       7.24       291.20       98.22         1245       0.08       0.01       5.54       0.08       1.648       7.34       229.6       98.22         1144       0.08       0.01       5.65       0.08       1.644       7.45       2.66.27       98.19         1143       0.08       0.01       5.66       0.09       1.520       7.57       2.64.31       98.12         1067       0.08       0.01       6.66       0.09       1.442       7.68       2.31.1       98.02         1067       0.08       0.01       6.62       0.10       1.374       7.78       2.26.9       98.02         1041       0.09       0.01       6.33       0.10       1.374       7.83       2.16.31       98.02         9940       0.09       0.01       6.52       0.11       1.289       7.92       202.02       97.94	1372	0.07	0.01	4.70	0.06	2.036	6.80	326.12	98.37
1221       0.07       0.01       5.01       0.07       1.909       6.99       312.42       98.30         1270       0.07       0.01       5.29       0.07       1.797       7.16       298.36       98.30         1245       0.08       0.01       5.42       0.08       1.745       7.24       291.20       98.24         1219       0.08       0.01       5.64       0.08       1.665       7.31       233.96       98.24         1184       0.08       0.01       5.76       0.08       1.604       7.45       269.27       98.17         1143       0.08       0.01       5.96       0.09       1.520       7.57       254.31       98.14         11902       0.08       0.01       6.14       0.09       1.446       7.68       239.11       98.04         1067       0.09       0.01       6.31       0.10       1.417       7.83       218.48       98.04         1016       0.09       0.01       6.32       0.10       1.347       7.83       216.91       97.99         940       0.09       0.01       6.45       0.10       1.347       7.88       200.20       97.84	1346	0.07	0.01	4.86	0.06	1.971	6.90	319.32	98.35
$\begin{array}{cccccccccccccccccccccccccccccccccccc$	1321	0.07	0.01	5.01	0.07	1.909	6.99	312.42	98.32
$\begin{array}{c c c c c c c c c c c c c c c c c c c $	1295	0.07	0.01	5.15	0.07	1.851	7.08	305.43	98.30
L4*0         UUB         UU1         5.42         UUB         1.745         7.24         291.20         98.24           11219         0.08         0.01         5.65         0.08         1.648         7.33         276.65         98.19           1148         0.08         0.01         5.76         0.08         1.664         7.45         299.17           1143         0.08         0.01         5.86         0.09         1.551         7.51         281.33         98.14           1118         0.08         0.01         6.06         0.09         1.442         7.63         246.74         98.09           1067         0.09         0.01         6.23         0.10         1.412         7.73         231.43         98.04           1016         0.09         0.01         6.38         0.10         1.347         7.73         231.43         98.04           1040         0.09         0.01         6.52         0.11         1.289         7.94         29.02.09         97.94           940         0.09         0.01         6.57         0.11         1.237         8.00         194.32         97.84           889         0.09         0.01	1270	0.07	0.01	5.29	0.07	1.797	7.16	298.36	98.27
$\begin{array}{cccccccccccccccccccccccccccccccccccc$	1245	0.08	0.01	5.42	0.08	1.745	7.24	291.20	98.24
$\begin{array}{cccccccccccccccccccccccccccccccccccc$	1219	0.08	0.01	0.04 5.65	0.08 0.08	1.095	7.31	203.90 276.65	90.22 Q8 10
$\begin{array}{cccccccccccccccccccccccccccccccccccc$	1168	0.00	0.01	5.05	0.08	1.040	7 45	269.00	98 17
1118 $0.0$ $0.01$ $5.06$ $0.09$ $1.520$ $7.57$ $254.31$ $98.12$ 1092 $0.08$ $0.01$ $6.06$ $0.09$ $1.482$ $7.63$ $246.74$ $98.09$ 1067 $0.09$ $0.01$ $6.14$ $0.09$ $1.446$ $7.68$ $223.11$ $98.07$ 1041 $0.09$ $0.01$ $6.23$ $0.10$ $1.412$ $7.73$ $223.43$ $98.02$ 991 $0.09$ $0.01$ $6.38$ $0.10$ $1.347$ $7.83$ $215.91$ $97.99$ 965 $0.09$ $0.01$ $6.52$ $0.11$ $1.283$ $7.96$ $192.28$ $97.91$ 940 $0.09$ $0.01$ $6.52$ $0.11$ $1.283$ $7.96$ $192.8$ $97.91$ 889 $0.09$ $0.01$ $6.76$ $0.11$ $1.283$ $7.96$ $192.8$ $97.84$ 813 $0.09$ $0.01$ $6.76$ $0.11$ $1.189$ $8.07$ $168.29$ $97.84$ $613$ $0.09$ $0.01$ $6.76$ $0.11$ $1.189$ $8.07$ $168.29$ $97.84$ $613$ $0.09$ $0.01$ $6.87$ $0.12$ $1.147$ $8.13$ $152.12$ $97.79$ $762$ $0.10$ $0.01$ $6.87$ $0.12$ $1.167$ $8.16$ $143.99$ $97.76$ $777$ $7.01$ $0.02$ $7.06$ $0.12$ $1.167$ $8.16$ $143.99$ $97.74$ $711$ $0.10$ $0.02$ $7.05$ $0.12$ $1.167$ $8.16$ $143.99$ $97.76$ <	1143	0.08	0.01	5.86	0.09	1.561	7,51	261.83	98.14
$\begin{array}{c c c c c c c c c c c c c c c c c c c $	1118	0.08	0.01	5.96	0.09	1.520	7.57	254.31	98.12
$\begin{array}{c c c c c c c c c c c c c c c c c c c $	1092	0.08	0.01	6.06	0.09	1.482	7.63	246.74	98.09
$\begin{array}{c c c c c c c c c c c c c c c c c c c $	1067	0.09	0.01	6.14	0.09	1.446	7.68	239.11	98.07
$\begin{array}{c c c c c c c c c c c c c c c c c c c $	1041	0.09	0.01	6.23	0.10	1.412	7.73	231.43	98.04
991 $0.09$ $0.01$ $6.38$ $0.10$ $1.347$ $7.83$ $215.91$ $97.99$ 965 $0.09$ $0.01$ $6.45$ $0.10$ $1.318$ $7.84$ $208.08$ $97.97$ 940 $0.09$ $0.01$ $6.52$ $0.11$ $1.263$ $7.96$ $192.28$ $97.91$ 889 $0.09$ $0.01$ $6.65$ $0.11$ $1.237$ $8.00$ $184.32$ $97.84$ 884 $0.09$ $0.01$ $6.76$ $0.11$ $1.133$ $8.03$ $176.33$ $97.86$ 838 $0.09$ $0.01$ $6.76$ $0.11$ $1.189$ $8.07$ $188.29$ $97.84$ 813 $0.09$ $0.01$ $6.82$ $0.12$ $1.167$ $8.10$ $160.22$ $97.81$ 762 $0.10$ $0.01$ $6.82$ $0.12$ $1.168$ $8.16$ $143.99$ $97.76$ 737 $0.10$ $0.02$ $7.05$ $0.12$ $1.068$ $8.19$ $135.82$ $97.74$ 711 $0.10$ $0.02$ $7.09$ $0.13$ $1.054$ $8.27$ $111.17$ $97.69$ 660 $0.10$ $0.02$ $7.09$ $0.13$ $1.054$ $8.27$ $111.17$ $97.64$ 610 $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $90.65$ $97.84$ 559 $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $96.59$ $97.51$ 533 $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $96.65$ $97.58$ 559 $0.00$ $0.00$ $0.00$	1016	0.09	0.01	6.31	0.10	1.378	7.79	223.69	98.02
965 $0.09$ $0.01$ $6.45$ $0.10$ $1.318$ $7.88$ $208.08$ $97.97$ $940$ $0.09$ $0.01$ $6.52$ $0.11$ $1.289$ $7.92$ $200.20$ $97.94$ $849$ $0.09$ $0.01$ $6.65$ $0.11$ $1.283$ $7.96$ $192.28$ $97.91$ $864$ $0.09$ $0.01$ $6.71$ $0.11$ $1.213$ $8.00$ $184.32$ $97.84$ $813$ $0.09$ $0.01$ $6.76$ $0.11$ $1.189$ $8.07$ $168.29$ $97.84$ $813$ $0.09$ $0.01$ $6.82$ $0.12$ $1.147$ $8.13$ $152.12$ $97.79$ $762$ $0.10$ $0.01$ $6.82$ $0.12$ $1.147$ $8.13$ $152.12$ $97.74$ $777$ $0.10$ $0.02$ $7.06$ $0.12$ $1.108$ $8.19$ $135.82$ $97.74$ $711$ $0.10$ $0.02$ $7.05$ $0.12$ $1.069$ $8.22$ $17.63$ $97.71$ $666$ $0.10$ $0.02$ $7.05$ $0.12$ $1.071$ $8.25$ $119.41$ $97.66$ $635$ $0.10$ $0.02$ $7.05$ $0.13$ $1.054$ $8.27$ $111.17$ $97.66$ $635$ $0.10$ $0.00$ $0.00$ $3.941$ $3.94$ $94.59$ $97.61$ $584$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $94.59$ $97.51$ $584$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $94.59$ $97.51$ $584$ $0.00$	991	0.09	0.01	6.38	0.10	1.347	7.83	215.91	97.99
9+00.090.01 $0.52$ 0.11 $1.289$ $7.92$ $220.20$ $97.94$ 8890.090.01 $6.55$ 0.11 $1.237$ $8.00$ $184.32$ $97.91$ 8840.090.01 $6.71$ 0.11 $1.213$ $8.03$ $176.33$ $97.86$ 8380.090.01 $6.76$ 0.11 $1.213$ $8.03$ $176.33$ $97.84$ 8130.090.01 $6.76$ 0.11 $1.147$ $8.13$ $156.29$ $97.84$ 8130.090.01 $6.82$ $0.12$ $1.167$ $8.10$ $160.22$ $97.84$ 7620.100.01 $6.82$ $0.12$ $1.167$ $8.16$ $143.99$ $97.76$ 7370.100.02 $7.05$ $0.12$ $1.108$ $8.19$ $135.82$ $97.74$ 7110.100.02 $7.05$ $0.12$ $1.071$ $8.25$ $119.41$ $97.66$ 6550.100.02 $7.15$ $0.13$ $1.029$ $8.31$ $102.90$ $97.64$ 6100.000.000.00 $3.941$ $3.94$ $94.59$ $97.55$ 5580.000.000.00 $3.941$ $3.94$ $86.70$ $97.53$ 5080.000.000.00 $3.941$ $3.94$ $74.86$ $97.44$ 4530.000.00 $0.00$ $3.941$ $3.94$ $74.86$ $97.53$ 5080.000.000.00 $3.941$ $3.94$ $74.86$ $97.53$ 533	965	0.09	0.01	6.45	0.10	1.318	7.88	208.08	97.97
0.77 $0.03$ $0.01$ $0.03$ $0.11$ $1.203$ $1.92$ $192.28$ $97.81$ 889 $0.09$ $0.01$ $6.71$ $0.11$ $1.213$ $8.03$ $176.33$ $97.86$ 884 $0.09$ $0.01$ $6.76$ $0.11$ $1.11$ $1.213$ $8.03$ $176.33$ $97.86$ 813 $0.09$ $0.01$ $6.76$ $0.11$ $1.167$ $8.10$ $160.22$ $97.81$ $777$ $0.10$ $0.01$ $6.82$ $0.12$ $1.167$ $8.10$ $160.22$ $97.81$ $787$ $0.10$ $0.01$ $6.82$ $0.12$ $1.167$ $8.10$ $160.22$ $97.81$ $777$ $0.10$ $0.01$ $6.82$ $0.12$ $1.168$ $8.19$ $135.82$ $97.76$ $737$ $0.10$ $0.02$ $7.05$ $0.12$ $1.071$ $8.25$ $119.41$ $97.69$ $660$ $0.10$ $0.02$ $7.05$ $0.12$ $1.071$ $8.25$ $119.41$ $97.69$ $660$ $0.10$ $0.02$ $7.05$ $0.12$ $1.071$ $8.25$ $119.41$ $97.69$ $660$ $0.10$ $0.02$ $7.05$ $0.12$ $1.071$ $8.25$ $119.41$ $97.69$ $660$ $0.10$ $0.00$ $0.00$ $3.941$ $3.94$ $94.59$ $97.61$ $610$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $96.65$ $97.58$ $558$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $78.82$ $97.51$ $483$ <td>940</td> <td>0.09</td> <td>0.01</td> <td>6.52</td> <td>0.11</td> <td>1.289</td> <td>7.92</td> <td>200.20</td> <td>97.94</td>	940	0.09	0.01	6.52	0.11	1.289	7.92	200.20	97.94
3864 $0.09$ $0.01$ $6.71$ $0.11$ $1.213$ $8.00$ $104.32$ $97.86$ $838$ $0.09$ $0.01$ $6.76$ $0.11$ $1.189$ $8.07$ $168.29$ $97.84$ $813$ $0.09$ $0.01$ $6.87$ $0.12$ $1.167$ $8.10$ $160.22$ $97.84$ $877$ $0.10$ $0.01$ $6.87$ $0.12$ $1.147$ $8.13$ $152.12$ $97.79$ $762$ $0.10$ $0.01$ $6.92$ $0.12$ $1.126$ $8.16$ $143.99$ $97.76$ $737$ $0.10$ $0.02$ $7.01$ $0.12$ $1.098$ $8.22$ $127.63$ $97.74$ $711$ $0.10$ $0.02$ $7.05$ $0.12$ $1.071$ $8.25$ $119.41$ $97.69$ $666$ $0.10$ $0.02$ $7.05$ $0.12$ $1.071$ $8.25$ $119.41$ $97.66$ $635$ $0.10$ $0.02$ $7.05$ $0.12$ $1.071$ $8.25$ $119.41$ $97.66$ $635$ $0.10$ $0.02$ $7.15$ $0.13$ $1.029$ $8.31$ $102.90$ $97.64$ $635$ $0.10$ $0.00$ $0.00$ $3.941$ $3.94$ $96.65$ $97.58$ $559$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $96.65$ $97.58$ $559$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $74.88$ $97.48$ $457$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $76.82$ $97.51$ $433$ $0.00$ $0.00$	914 880	0.09	0.01	6.65	0.11	1.203	008.1	18/ 22	97.91
838 $0.09$ $0.01$ $6.76$ $0.11$ $1.180$ $8.05$ $168.29$ $97.84$ $813$ $0.09$ $0.01$ $6.82$ $0.12$ $1.167$ $8.10$ $160.22$ $97.84$ $787$ $0.10$ $0.01$ $6.82$ $0.12$ $1.147$ $8.13$ $152.12$ $97.79$ $762$ $0.10$ $0.01$ $6.92$ $0.12$ $1.146$ $8.16$ $143.99$ $97.76$ $737$ $0.10$ $0.02$ $6.96$ $0.12$ $1.108$ $8.19$ $135.82$ $97.74$ $737$ $0.10$ $0.02$ $7.05$ $0.12$ $1.071$ $8.25$ $119.41$ $97.69$ $666$ $0.10$ $0.02$ $7.09$ $0.13$ $1.054$ $8.27$ $111.17$ $97.66$ $655$ $0.10$ $0.02$ $7.15$ $0.13$ $1.029$ $8.31$ $102.90$ $97.64$ $610$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $94.59$ $97.61$ $584$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $96.65$ $97.58$ $559$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $96.65$ $97.56$ $533$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $96.70$ $97.56$ $533$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $74.82$ $97.51$ $483$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $74.82$ $97.43$ $496$ $0.00$ $0.00$ </td <td>864</td> <td>0.09</td> <td>0.01</td> <td>6,71</td> <td>0.11</td> <td>1.213</td> <td>8.03</td> <td>176.33</td> <td>97.86</td>	864	0.09	0.01	6,71	0.11	1.213	8.03	176.33	97.86
813 $0.09$ $0.01$ $6.82$ $0.12$ $1.167$ $8.10$ $160.25$ $97.81$ $787$ $0.10$ $0.01$ $6.87$ $0.12$ $1.147$ $8.13$ $152.12$ $97.79$ $762$ $0.10$ $0.01$ $6.92$ $0.12$ $1.147$ $8.16$ $143.99$ $97.76$ $737$ $0.10$ $0.02$ $6.96$ $0.12$ $1.108$ $8.19$ $135.82$ $97.74$ $711$ $0.10$ $0.02$ $7.01$ $0.12$ $1.071$ $8.25$ $119.41$ $97.76$ $660$ $0.10$ $0.02$ $7.09$ $0.13$ $1.054$ $8.27$ $111.17$ $97.66$ $635$ $0.10$ $0.02$ $7.15$ $0.13$ $1.029$ $8.31$ $102.90$ $97.64$ $610$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $90.65$ $97.58$ $559$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $82.76$ $97.53$ $508$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $82.76$ $97.53$ $508$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $74.88$ $97.46$ $432$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $74.88$ $97.46$ $432$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $74.88$ $97.46$ $432$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $51.12$ $97.33$ $306$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ </td <td>838</td> <td>0.09</td> <td>0.01</td> <td>6.76</td> <td>0.11</td> <td>1.189</td> <td>8.07</td> <td>168.29</td> <td>97.84</td>	838	0.09	0.01	6.76	0.11	1.189	8.07	168.29	97.84
7870.100.016.870.121.1478.13152.1297.79 $762$ 0.100.016.920.121.1268.16143.9997.76 $737$ 0.100.026.960.121.1088.19135.8297.74 $711$ 0.100.027.010.121.0898.22127.6397.71 $686$ 0.100.027.050.121.0718.25119.4197.69 $660$ 0.100.027.150.131.0548.27111.1797.66 $635$ 0.100.027.150.131.0298.31102.9097.64 $610$ 0.000.000.003.9413.9494.5997.58 $559$ 0.000.000.000.003.9413.9486.7097.56 $533$ 0.000.000.003.9413.9474.8297.51 $483$ 0.000.000.003.9413.9474.8297.48 $457$ 0.000.000.003.9413.9467.0097.43 $406$ 0.000.000.003.9413.9463.0697.43 $406$ 0.000.000.003.9413.9463.0697.36 $330$ 0.000.000.003.9413.9455.1897.36 $330$ 0.000.000.003.9413.9451.2397.30 $279$ 0.000.000.00 </td <td>813</td> <td>0.09</td> <td>0.01</td> <td>6.82</td> <td>0.12</td> <td>1.167</td> <td>8.10</td> <td>160.22</td> <td>97.81</td>	813	0.09	0.01	6.82	0.12	1.167	8.10	160.22	97.81
7620.100.016.920.121.1268.16143.9997.76 $737$ 0.100.026.960.121.1088.19135.8297.74 $711$ 0.100.027.010.121.0898.22127.6397.71 $686$ 0.100.027.050.121.0718.25119.4197.69 $660$ 0.100.027.090.131.0548.27111.1797.64 $610$ 0.000.000.003.9413.9494.5997.64 $610$ 0.000.000.003.9413.9490.6597.58 $559$ 0.000.000.003.9413.9486.7097.56 $533$ 0.000.000.003.9413.9486.7697.53 $508$ 0.000.000.003.9413.9478.8297.48 $457$ 0.000.000.003.9413.9478.8297.46 $432$ 0.000.000.003.9413.9470.9497.46 $432$ 0.000.000.003.9413.9459.1297.38 $356$ 0.000.000.003.9413.9463.0667.41 $311$ 0.000.000.003.9413.9443.2597.33 $305$ 0.000.000.003.9413.9451.2397.38 $356$ 0.000.000.003.9413.9447.29 </td <td>787</td> <td>0.10</td> <td>0.01</td> <td>6.87</td> <td>0.12</td> <td>1.147</td> <td>8.13</td> <td>152.12</td> <td>97.79</td>	787	0.10	0.01	6.87	0.12	1.147	8.13	152.12	97.79
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	762	0.10	0.01	6.92	0.12	1.126	8.16	143.99	97.76
711 $0.10$ $0.02$ $7.01$ $0.12$ $1.089$ $8.22$ $127.63$ $97.71$ $686$ $0.10$ $0.02$ $7.05$ $0.12$ $1.071$ $8.25$ $119.41$ $97.69$ $660$ $0.10$ $0.02$ $7.09$ $0.13$ $1.054$ $8.27$ $111.17$ $97.66$ $635$ $0.10$ $0.02$ $7.15$ $0.13$ $1.029$ $8.31$ $102.90$ $97.64$ $610$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $94.59$ $97.61$ $584$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $96.65$ $97.58$ $559$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $86.70$ $97.56$ $533$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $78.82$ $97.51$ $483$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $78.82$ $97.48$ $457$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $74.88$ $97.48$ $457$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $74.88$ $97.48$ $457$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $74.88$ $97.48$ $457$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $67.00$ $97.43$ $466$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $67.00$ $97.43$ $356$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $51.23$ $97.33$	737	0.10	0.02	6.96	0.12	1.108	8.19	135.82	97.74
beb $0.10$ $0.02$ $7.05$ $0.12$ $1.071$ $8.25$ $119.41$ $97.69$ $660$ $0.10$ $0.02$ $7.09$ $0.13$ $1.054$ $8.27$ $111.17$ $97.66$ $635$ $0.10$ $0.02$ $7.15$ $0.13$ $1.029$ $8.31$ $102.90$ $97.64$ $610$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $94.59$ $97.61$ $584$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $96.65$ $97.58$ $559$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $86.70$ $97.56$ $533$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $82.76$ $97.53$ $508$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $78.82$ $97.51$ $483$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $74.88$ $97.48$ $457$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $76.94$ $97.46$ $432$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $67.00$ $97.43$ $456$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $67.10$ $97.43$ $336$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $51.12$ $97.33$ $356$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $43.35$ $97.25$ $229$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ <	711	0.10	0.02	7.01	0.12	1.089	8.22	127.63	97.71
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	686	0.10	0.02	7.05	0.12	1.071	8.25	119.41	97.69
0.50 $0.70$ $0.02$ $1.71$ $0.13$ $1.029$ $0.31$ $102.90$ $97.61$ $584$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $90.65$ $97.58$ $559$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $86.70$ $97.56$ $533$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $82.76$ $97.53$ $508$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $76.82$ $97.51$ $483$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $76.82$ $97.46$ $432$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $70.94$ $97.46$ $432$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $67.00$ $97.43$ $406$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $65.18$ $97.38$ $356$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $55.18$ $97.36$ $330$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $47.29$ $97.30$ $279$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $43.35$ $97.28$ $254$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $43.35$ $97.28$ $229$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $43.35$ $97.28$ $224$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ <t< td=""><td>000</td><td>0.10</td><td>0.02</td><td>7.09</td><td>0.13</td><td>1.054</td><td>0.27 8 21</td><td>111.17</td><td>97.00</td></t<>	000	0.10	0.02	7.09	0.13	1.054	0.27 8 21	111.17	97.00
512 $5100$ $5100$ $5100$ $5100$ $5100$ $5101$ $5141$ $5143$ $5143$ $5143$ $5143$ $5143$ $5143$ $5143$ $5143$ $5143$ $5143$ $5143$ $5143$ $5163$ $559$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $86.70$ $97.56$ $533$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $82.76$ $97.56$ $533$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $78.22$ $97.51$ $483$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $70.94$ $97.48$ $457$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $67.00$ $97.43$ $406$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $67.00$ $97.43$ $406$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $65.12$ $97.38$ $356$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $51.18$ $97.36$ $330$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $47.29$ $97.30$ $279$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $47.29$ $97.32$ $203$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $35.47$ $97.25$ $229$ $0.00$ $0.00$ $0.00$ $0.00$ $3.941$ $3.94$ $35.47$ $97.25$ $229$ $0.00$	610	0.10	0.02	0.00	0.13	3.941	3.94	94 59	97.64
$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$	584	0.00	0.00	0.00	0.00	3,941	3,94	90.65	97.58
$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$	559	0.00	0.00	0.00	0.00	3.941	3.94	86.70	97.56
$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$	533	0.00	0.00	0.00	0.00	3.941	3.94	82.76	97.53
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	508	0.00	0.00	0.00	0.00	3.941	3.94	78.82	97.51
$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$	483	0.00	0.00	0.00	0.00	3.941	3.94	74.88	97.48
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	457	0.00	0.00	0.00	0.00	3.941	3.94	70.94	97.46
$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$	432	0.00	0.00	0.00	0.00	3.941	3.94	67.00	97.43
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	406	0.00	0.00	0.00	0.00	3.941	3.94	63.06	97.41
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	381	0.00	0.00	0.00	0.00	3.941	3.94	59.12	97.38
0.00         0.00         0.00         0.00         0.00         3.941         3.94         31.23         97.33           305         0.00         0.00         0.00         0.00         3.941         3.94         47.29         97.30           279         0.00         0.00         0.00         3.941         3.94         43.35         97.28           254         0.00         0.00         0.00         3.941         3.94         35.47         97.23           203         0.00         0.00         0.00         3.941         3.94         35.47         97.23           203         0.00         0.00         0.00         3.941         3.94         27.59         97.18           152         0.00         0.00         0.00         3.941         3.94         23.65         97.15           127         0.00         0.00         0.00         3.941         3.94         19.71         97.18           122         0.00         0.00         0.00         3.941         3.94         19.71         97.18           127         0.00         0.00         0.00         3.941         3.94         11.82         97.08           102	356	0.00	0.00	0.00	0.00	3.941	3.94	55.18	97.36
0.00         0.00         0.00         0.00         0.00         3.941         3.94         47.29         97.30           279         0.00         0.00         0.00         0.00         3.941         3.94         43.35         97.28           254         0.00         0.00         0.00         0.00         3.941         3.94         39.41         97.25           229         0.00         0.00         0.00         0.00         3.941         3.94         35.47         97.28           203         0.00         0.00         0.00         0.00         3.941         3.94         31.53         97.20           178         0.00         0.00         0.00         3.941         3.94         27.59         97.18           152         0.00         0.00         0.00         0.00         3.941         3.94         15.76         97.15           127         0.00         0.00         0.00         3.941         3.94         15.76         97.10           76         0.00         0.00         0.00         3.941         3.94         15.76         97.10           76         0.00         0.00         0.00         3.941         3.94	305	0.00	0.00	0.00	0.00	3.941	3.94 3.04	01.23 47.20	91.33
1.1         1.00         0.00         0.00         0.00         3.941         3.94         39.41         97.25           229         0.00         0.00         0.00         0.00         3.941         3.94         35.47         97.25           229         0.00         0.00         0.00         0.00         3.941         3.94         35.47         97.25           203         0.00         0.00         0.00         0.00         3.941         3.94         31.53         97.23           178         0.00         0.00         0.00         3.941         3.94         27.59         97.18           152         0.00         0.00         0.00         0.00         3.941         3.94         23.65         97.15           127         0.00         0.00         0.00         0.00         3.941         3.94         19.71         97.13           102         0.00         0.00         0.00         3.941         3.94         15.76         97.10           76         0.00         0.00         0.00         3.941         3.94         11.82         97.08           51         0.00         0.00         0.00         3.941         3.94	279	0.00	0.00	0.00	0.00	3.941	3.94	43.35	97 28
229         0.00         0.00         0.00         3.941         3.94         35.47         97.23           203         0.00         0.00         0.00         0.00         3.941         3.94         35.47         97.23           203         0.00         0.00         0.00         0.00         3.941         3.94         35.47         97.23           178         0.00         0.00         0.00         0.00         3.941         3.94         27.59         97.18           152         0.00         0.00         0.00         0.00         3.941         3.94         23.65         97.15           127         0.00         0.00         0.00         0.00         3.941         3.94         15.76         97.10           76         0.00         0.00         0.00         3.941         3.94         11.82         97.08           51         0.00         0.00         0.00         3.941         3.94         11.82         97.08           51         0.00         0.00         0.00         3.941         3.94         7.88         97.05           95         0.00         0.00         0.00         3.941         3.94         7.88	254	0.00	0.00	0.00	0.00	3.941	3.94	39.41	97.25
203         0.00         0.00         0.00         0.00         3.941         3.94         31.53         97.20           178         0.00         0.00         0.00         0.00         3.941         3.94         27.59         97.18           152         0.00         0.00         0.00         0.00         3.941         3.94         27.59         97.18           152         0.00         0.00         0.00         3.941         3.94         23.65         97.15           127         0.00         0.00         0.00         3.941         3.94         19.71         97.13           102         0.00         0.00         0.00         3.941         3.94         15.76         97.10           76         0.00         0.00         0.00         3.941         3.94         11.82         97.08           51         0.00         0.00         0.00         3.941         3.94         7.88         97.05           55         0.00         0.00         0.00         3.941         3.94         7.88         97.05	229	0.00	0.00	0.00	0.00	3.941	3.94	35.47	97.23
178         0.00         0.00         0.00         3.941         3.94         27.59         97.18           152         0.00         0.00         0.00         0.00         3.941         3.94         23.65         97.15           127         0.00         0.00         0.00         3.941         3.94         19.71         97.13           102         0.00         0.00         0.00         3.941         3.94         15.76         97.10           76         0.00         0.00         0.00         3.941         3.94         15.76         97.10           76         0.00         0.00         0.00         3.941         3.94         15.76         97.10           76         0.00         0.00         0.00         3.941         3.94         15.76         97.10           76         0.00         0.00         0.00         3.941         3.94         7.88         97.05           51         0.00         0.00         0.00         3.941         3.94         7.88         97.05           95         0.00         0.00         0.00         3.941         3.94         7.88         97.05	203	0.00	0.00	0.00	0.00	3.941	3.94	31.53	97.20
152         0.00         0.00         0.00         3.941         3.94         23.65         97.15           127         0.00         0.00         0.00         0.00         3.941         3.94         19.71         97.13           102         0.00         0.00         0.00         3.941         3.94         19.71         97.13           102         0.00         0.00         0.00         3.941         3.94         15.76         97.10           76         0.00         0.00         0.00         3.941         3.94         11.82         97.08           51         0.00         0.00         0.00         3.941         3.94         7.88         97.05           95         0.00         0.00         0.00         3.941         3.94         7.88         97.05	178	0.00	0.00	0.00	0.00	3.941	3.94	27.59	97.18
127         0.00         0.00         0.00         3.941         3.94         19.71         97.13           102         0.00         0.00         0.00         3.941         3.94         15.76         97.10           76         0.00         0.00         0.00         3.941         3.94         11.82         97.08           51         0.00         0.00         0.00         3.941         3.94         7.88         97.05           95         0.00         0.00         0.00         0.00         3.941         3.94         7.88         97.05	152	0.00	0.00	0.00	0.00	3.941	3.94	23.65	97.15
102         0.00         0.00         0.00         3.941         3.94         15.76         97.10           76         0.00         0.00         0.00         3.941         3.94         11.82         97.08           51         0.00         0.00         0.00         3.941         3.94         7.88         97.05           55         0.00         0.00         0.00         3.941         3.94         7.88         97.05	127	0.00	0.00	0.00	0.00	3.941	3.94	19.71	97.13
76         0.00         0.00         0.00         3.941         3.94         11.82         97.08           51         0.00         0.00         0.00         3.941         3.94         7.88         97.05           55         0.00         0.00         0.00         3.941         3.94         7.88         97.05	102	0.00	0.00	0.00	0.00	3.941	3.94	15.76	97.10
51 U.UU U.UU U.UU 0.00 3.941 3.94 7.88 97.05	76	0.00	0.00	0.00	0.00	3.941	3.94	11.82	97.08
	51	0.00	0.00	0.00	0.00	3.941	3.94	7.88	97.05

#### Project: Project Python Rev2 System 4

Chamber Model -Units -Number of Chambers -Number of End Caps -Volds in the stone (porosity) -Base of Stone Elevation -Amount of Stone Above Chambers -Amount of Stone Below Chambers -

MC-4500 Metric 261 12 40 95.23 305 750 % m mm mm 988

StormTech Click Here for Imperial A division of Include Perimeter Stone in Calculations

1

924.577 sq.meters sq.meters Min. Area -

Height of	Incremental Single	Incremental	Incremental	Incremental End	Incremental	Incremental	Cumulative	
System	Chamber	Single End Cap	Chambers	Сар	Stone	Chamber, End	System	Elevation
( <i>mm</i> ) 2591	(cubic meters)	(cubic meters)	(cubic meters)	(cubic meters)	(cubic meters)	(cubic meters)	(cubic meters)	97.82
2565	0.00	0.00	0.00	0.00	10.033	10.03	1493.70	97.79
2540	0.00	0.00	0.00	0.00	10.033	10.03	1483.66	97.77
2515	0.00	0.00	0.00	0.00	10.033	10.03	1473.63	97.74
2489	0.00	0.00	0.00	0.00	10.033	10.03	1403.00	97.72
2438	0.00	0.00	0.00	0.00	10.033	10.03	1443.53	97.67
2413	0.00	0.00	0.00	0.00	10.033	10.03	1433.50	97.64
2388	0.00	0.00	0.00	0.00	10.033	10.03	1423.47	97.62
2362	0.00	0.00	0.00	0.00	10.033	10.03	1413.43	97.59
2337	0.00	0.00	0.00	0.00	10.033	10.03	1403.40	97.57
2286	0.00	0.00	0.30	0.00	9.910	10.03	1383.33	97.52
2261	0.00	0.00	0.86	0.01	9.685	10.55	1373.12	97.49
2235	0.00	0.00	1.22	0.02	9.539	10.77	1362.56	97.46
2210	0.01	0.00	1.54	0.02	9.407	10.97	1351.79	97.44
2164	0.01	0.00	3.35	0.03	9.220	12.06	1329.58	97.41
2134	0.02	0.00	4.92	0.04	8.048	13.01	1317.51	97.36
2108	0.02	0.00	5.91	0.05	7.649	13.61	1304.50	97.34
2083	0.03	0.01	6.71	0.06	7.323	14.10	1290.89	97.31
2057	0.03	0.01	7.41	0.07	7.038	14.52	12/6.80	97.29
2002	0.03	0.01	8.60	0.09	6.556	15.25	1247.37	97.24
1981	0.03	0.01	9.12	0.10	6.344	15.57	1232.12	97.21
1956	0.04	0.01	9.61	0.11	6.146	15.86	1216.55	97.18
1930	0.04	0.01	10.06	0.12	5.961	16.14	1200.69	97.16
1880	0.04	0.01	10.49	0.13	5.622	16.65	1168.14	97.13
1854	0.04	0.01	11.27	0.15	5.464	16.89	1151.49	97.08
1829	0.04	0.01	11.64	0.16	5.315	17.11	1134.61	97.06
1803	0.05	0.01	11.98	0.17	5.172	17.32	1117.50	97.03
1753	0.05	0.01	12.31	0.18	5.036 4.906	17.53	100.17	97.01 96.98
1727	0.05	0.02	12.93	0.19	4.782	17.91	1064.92	96.96
1702	0.05	0.02	13.22	0.20	4.663	18.09	1047.01	96.93
1676	0.05	0.02	13.50	0.21	4.548	18.26	1028.93	96.91
1626	0.05	0.02	14.03	0.21	4.438	10.43	992.24	96.85
1600	0.05	0.02	14.28	0.23	4.230	18.74	973.66	96.83
1575	0.06	0.02	14.52	0.24	4.131	18.89	954.92	96.80
1549	0.06	0.02	14.75	0.25	4.037	19.03	936.04	96.78
1524	0.06	0.02	14.97	0.25	3.945	19.16	917.01	96.75
1473	0.06	0.02	15.38	0.27	3.773	19.42	878.55	96.70
1448	0.06	0.02	15.58	0.27	3.692	19.54	859.12	96.68
1422	0.06	0.02	15.77	0.28	3.613	19.66	839.58	96.65
1372	0.06	0.02	16.95	0.28	3.557	19.76	800 14	96.60
1346	0.06	0.02	16.30	0.29	3.396	19.99	780.25	96.58
1321	0.06	0.03	16.46	0.30	3.327	20.09	760.27	96.55
1295	0.06	0.03	16.62	0.31	3.262	20.19	740.17	96.52
12/0	0.06	0.03	16.77	0.31	3.199	20.28	699.70	96.50
1219	0.07	0.03	17.06	0.32	3.082	20.46	679.33	96.45
1194	0.07	0.03	17.19	0.32	3.027	20.54	658.87	96.42
1168	0.07	0.03	17.32	0.33	2.974	20.62	638.33	96.40
1143	0.07	0.03	17.44	0.33	2.923	20.70	597.01	96.37
1092	0.07	0.03	17.67	0.34	2.828	20.84	576.24	96.32
1067	0.07	0.03	17.78	0.34	2.784	20.91	555.40	96.30
1041	0.07	0.03	17.88	0.35	2.742	20.97	534.49	96.27
1016 901	0.07	0.03	17.98	0.35	2.702	21.03	513.53 492.50	96.25 96.22
965	0.07	0.03	18.16	0.36	2.628	21.14	471.41	96.19
940	0.07	0.03	18.24	0.36	2.594	21.19	450.27	96.17
914	0.07	0.03	18.32	0.36	2.564	21.24	429.08	96.14
864	0.07	0.03	18.39	0.36	2.533	21.28	407.84 386 56	96.12 96.00
838	0.07	0.03	18.53	0.37	2.476	21.37	365.23	96.07
813	0.07	0.03	18.59	0.37	2.451	21.41	343.86	96.04
787	0.07	0.03	18.68	0.38	2.412	21.46	322.46	96.02
/62 737	0.00	0.00	0.00	0.00	10.033	10.03	300.99	95.99
711	0.00	0.00	0.00	0.00	10.033	10.03	280.92	95.94
686	0.00	0.00	0.00	0.00	10.033	10.03	270.89	95.91
660	0.00	0.00	0.00	0.00	10.033	10.03	260.86	95.89
635	0.00	0.00	0.00	0.00	10.033	10.03	250.83	95.86
584	0.00	0.00	0.00	0.00	10.033	10.03	240.79 230.76	95.84
559	0.00	0.00	0.00	0.00	10.033	10.03	220.73	95.79
533	0.00	0.00	0.00	0.00	10.033	10.03	210.69	95.76
508	0.00	0.00	0.00	0.00	10.033	10.03	200.66	95.74
483 457	0.00	0.00	0.00	0.00	10.033	10.03	190.63	95.71
432	0.00	0.00	0.00	0.00	10.033	10.03	170.56	95.66
406	0.00	0.00	0.00	0.00	10.033	10.03	160.53	95.64
381	0.00	0.00	0.00	0.00	10.033	10.03	150.50	95.61
356	0.00	0.00	0.00	0.00	10.033	10.03	140.46	95.58
305	0.00	0.00	0.00	0.00	10.033	10.03	120.40	95.53
279	0.00	0.00	0.00	0.00	10.033	10.03	110.36	95.51
254	0.00	0.00	0.00	0.00	10.033	10.03	100.33	95.48
229	0.00	0.00	0.00	0.00	10.033	10.03	90.30	95.46
203 178	0.00	0.00	0.00	0.00	10.033	10.03	80.26 70.23	95.43 95.41
152	0.00	0.00	0.00	0.00	10.033	10.03	60.20	95.38
127	0.00	0.00	0.00	0.00	10.033	10.03	50.17	95.36
102	0.00	0.00	0.00	0.00	10.033	10.03	40.13	95.33
76 51	0.00	0.00	0.00	0.00	10.033	10.03	30.10	95.31
25	0.00	0.00	0.00	0.00	10.033	10.03	10.03	95.25

96.75

#### Project: Project Python Rev 1 Bed 5

roject:	Project Python Rev	1 Bed 5	_		
				Sta	rmTooh
Chamber Model	-	MC-4500		30	mecn
Units -		Metric	Click Here for	Imperial	Detention - Retention - Water Quality
Number of Char	nbers -	164			A division of
Number of End	Caps -	8			
Voids in the stor	ne (porosity) -	40	%		
Base of Stone E	levation -	97.80	m		
Amount of Stone	e Above Chambers -	305	mm	✓ Include Perimeter S	Stone in Calculations
Amount of Stone	e Below Chambers -	229	mm		
		632.6	sq.meters	Min. Area -	582.409 sq.meters

Hoight of	In anomantal Oire	Incremental	Incremented	In anomartal Ex. 1	Inoron-stat	In oron	Cumulation	
Height of System	Chamber	Single End Can	Chambers	Cap	Stope	Chamber End	System	Elevation
(mm)	(cubic meters)	(cubic meters)	(cubic meters)	(cubic meters)	(cubic meters)	(cubic meters)	(cubic meters)	(meters)
2057	0.00	0.00	0.00	0.00	6.424	6.42	822.49	99.86
2032	0.00	0.00	0.00	0.00	6.424	6.42	816.06	99.83
2007	0.00	0.00	0.00	0.00	6.424	6.42	809.64	99.81
1981	0.00	0.00	0.00	0.00	6.424	6.42	803.22	99.78
1956	0.00	0.00	0.00	0.00	6.424	6.42	796.79	99.76
1905	0.00	0.00	0.00	0.00	6 4 2 4	6.42	783.94	99.73
1880	0.00	0.00	0.00	0.00	6.424	6.42	777.52	99.68
1854	0.00	0.00	0.00	0.00	6.424	6.42	771.10	99.65
1829	0.00	0.00	0.00	0.00	6.424	6.42	764.67	99.63
1803	0.00	0.00	0.00	0.00	6.424	6.42	758.25	99.60
17752	0.00	0.00	0.00	0.00	6.424	6.42	751.82	99.58
1727	0.00	0.00	0.54	0.00	6.205	6.75	738.86	99.53
1702	0.00	0.00	0.77	0.01	6.113	6.89	732.11	99.50
1676	0.01	0.00	0.97	0.01	6.030	7.01	725.22	99.48
1651	0.01	0.00	1.25	0.02	5.918	7.18	718.20	99.45
1626	0.01	0.00	2.10	0.02	5.573	7.70	711.02	99.43
1600	0.02	0.00	3.09	0.03	0.170	8.30	703.32 605.02	99.40
1549	0.02	0.00	4.22	0.04	4.720	8.98	686.35	99.35
1524	0.03	0.01	4.66	0.05	4.541	9.25	677.37	99.32
1499	0.03	0.01	5.05	0.06	4.382	9.49	668.12	99.30
1473	0.03	0.01	5.40	0.06	4.238	9.70	658.64	99.27
1448	0.03	0.01	5.73	0.07	4.104	9.90	648.93	99.25
1422	0.04	0.01	6.04 6.32	0.07	3.980	10.09	639.03 628.04	99.22
1372	0.04	0.01	6.59	0.09	3.754	10.43	618.68	99.17
1346	0.04	0.01	6.84	0.09	3.650	10.58	608.25	99.15
1321	0.04	0.01	7.08	0.10	3.551	10.73	597.66	99.12
1295	0.04	0.01	7.31	0.11	3.457	10.87	586.93	99.10
1270	0.05	0.01	7.53	0.11	3.367	11.01	576.05	99.07
1245	0.05	0.01	7.74	0.12	3.282	11.14	565.04	99.04
1219	0.05	0.02	8 13	0.12	3.122	11.20	542 65	98.99
1168	0.05	0.02	8.31	0.13	3.047	11.49	531.27	98.97
1143	0.05	0.02	8.49	0.14	2.975	11.60	519.78	98.94
1118	0.05	0.02	8.65	0.14	2.905	11.70	508.18	98.92
1092	0.05	0.02	8.82	0.15	2.839	11.80	496.48	98.89
1067	0.05	0.02	8.97	0.15	2.774	11.90	484.68	98.87
1041	0.00	0.02	9.12	0.10	2.712	12.08	472.70	98.82
991	0.06	0.02	9.40	0.17	2.595	12.00	448.71	98.79
965	0.06	0.02	9.54	0.17	2.540	12.25	436.54	98.77
940	0.06	0.02	9.67	0.18	2.486	12.33	424.29	98.74
914	0.06	0.02	9.79	0.18	2.435	12.41	411.96	98.71
889	0.06	0.02	9.91	0.19	2.386	12.48	399.55	98.69
838	0.06	0.02	10.02	0.19	2.330	12.55	374 52	98.60
813	0.06	0.02	10.14	0.19	2.249	12.69	361.89	98.61
787	0.06	0.03	10.35	0.20	2.205	12.75	349.21	98.59
762	0.06	0.03	10.44	0.20	2.165	12.81	336.46	98.56
737	0.06	0.03	10.54	0.21	2.125	12.87	323.64	98.54
711	0.06	0.03	10.63	0.21	2.089	12.93	310.77	98.51
000	0.07	0.03	10.72	0.21	2.001 2.017	12.98 13.03	297.84 284.86	90.49 98.46
635	0.07	0.03	10.88	0.22	1.983	13.09	271.83	98.44
610	0.07	0.03	10.96	0.22	1.951	13.13	258.74	98.41
584	0.07	0.03	11.03	0.22	1.923	13.18	245.61	98.38
559	0.07	0.03	11.10	0.23	1.892	13.22	232.43	98.36
533	0.07	0.03	11.17	0.23	1.864	13.26	219.21	98.33
208	0.07	0.03	11.24	0.23	1.838	13.30	205.95	98.31
457	0.07	0.03	11.35	0.23	1.788	13.38	179.30	98.20 98.26
432	0.07	0.03	11.41	0.24	1.766	13.41	165.92	98.23
406	0.07	0.03	11.46	0.24	1.744	13.44	152.51	98.21
381	0.07	0.03	11.51	0.24	1.725	13.47	139.07	98.18
356	0.07	0.03	11.56	0.24	1.706	13.50	125.60	98.16
33U 305	0.07	0.03	11.60	0.24	1.087	13.53	98.57	98.13
279	0.07	0.03	11.68	0.25	1.654	13,58	85.01	98.08
254	0.07	0.03	11.74	0.25	1.630	13.62	71.43	98.05
229	0.00	0.00	0.00	0.00	6.424	6.42	57.82	98.03
203	0.00	0.00	0.00	0.00	6.424	6.42	51.39	98.00
178	0.00	0.00	0.00	0.00	6.424	6.42	44.97	97.98
152	0.00	0.00	0.00	0.00	6.424	6.42	38.54	97.95
102	0.00	0.00	0.00	0.00	6.424	0.42 6.42	32.12 25.70	97.93 97.90
76	0.00	0.00	0.00	0.00	6.424	6.42	19.27	97.88
51	0.00	0.00	0.00	0.00	6.424	6.42	12.85	97.85
25	0.00	0.00	0.00	0.00	6.424	6.42	6.42	97.83

### Citi Gate: 416 Corporate Campus - Phase 1 Junctions

## AutoDesk Storm and Sanitary Analysis Chicago 100-year 3-hour Storm Model Output Results

MH208 Q100yr (3-hour Chic.) = 3,412.51 L/s

SN	Element ID	Description	Invert Elevation	Ground/Rim (Max) Elevation	Ground/Rim (Max) Offset	Initial Water Elevation	Initial Water Depth	Surcharge Elevation	Surcharge Depth	Ponded Area	Minimum Pipe Cover	Peak Inflow	Peak Lateral Inflow	Maximum HGL Elevation	Maximum HGL Depth Attained	Maximum Surcharge Depth Attained	Minimum Freeboard Attained	Average HGL Elevation	Average HGL Depth	Time of Maximum HGL Occurrence	Time of Peak Flooding	Total Flooded Volume	Total Time Flooded
			(m)	(m)	(m)	(m)	(m)	(m)	(m)	(m²)	(mm)	(lps)	(lps)	(m)	(m)	(m)	(m)	(m)	(m)	(davs hh:mm)	(davs hh:mm)	(ha-mm)	(minutes)
1	100	Mcon MH - Concentric	96.08	101.08	5.00	96.08	0.00	101.08	0.00	0.00	3672.00	71.74	0.00	96.61	0.53	0.00	4.48	96.37	0.29	0 01:30	0 00:00	0.00	0.00
2	100a		96.33	100.80	4.47	96.33	0.00	100.80	0.00	0.00	0.00	173.88	0.00	96.59	0.26	0.00	4.28	96.35	0.02	0 01:30	0 00:00	0.00	0.00
3	100b		96.27	100.60	4.33	96.27	0.00	100.60	0.00	0.00	870.00	182.79	0.00	96.55	0.28	0.00	4.05	96.29	0.02	0 01:26	0 00:00	0.00	0.00
4	102	Mcon MH - Concentric	97.94	100.70	2.76	97.94	0.00	100.70	0.00	0.00	1732.00	20.82	0.00	98.33	0.39	0.00	2.38	98.23	0.29	0 01:20	0 00:00	0.00	0.00
5	102a		97.83	100.40	2.57	97.83	0.00	100.40	0.00	0.00	1060.00	53.88	0.00	98.00	0.17	0.00	2.40	97.84	0.01	0 01:20	0 00:00	0.00	0.00
6	104	Mcon MH - Concentric	97.35	100.35	3.00	97.35	0.00	100.35	0.00	0.00	839.00	65.02	0.00	97.81	0.46	0.00	2.54	97.65	0.30	0 01:20	0 00:00	0.00	0.00
7	104a		97.41	100.20	2.79	97.41	0.00	100.20	0.00	0.00	910.00	116.82	0.00	97.61	0.20	0.00	2.59	97.42	0.01	0 01:20	0 00:00	0.00	0.00
8	104b		97.16	100.00	2.84	97.16	0.00	100.00	0.00	0.00	2388.00	175.84	0.00	97.45	0.29	0.00	2.55	97.18	0.02	0 01:20	0 00:00	0.00	0.00
9 10	106	Micon MH - Concentric	95.82	99.93	4.11	95.82	0.00	99.93	0.00	0.00	2559.00	312.52	0.00	96.46	0.64	0.00	3.47	96.14	0.32	0 01:24	0 00:00	0.00	0.00
10	106a 106b		95.91	99.72	3.81	95.91	0.00	99.72	0.00	0.00	1000.00	549.10 107 37	0.00	96.29	0.58	0.00	5.45 3.17	95.94	0.03	0 01.25	0 00.00	0.00	0.00
12	108	Mcon MH - Concentric	94 90	99.11	4 21	94 90	0.00	99.11	0.00	0.00	900.00	457 53	0.00	96.25	1 35	0.00	2.86	95.00	0.05	0 01:25	0 00:00	0.00	0.00
13	108a		94.92	98.86	3.95	94.92	0.00	98.86	0.00	0.00	860.00	491.55	0.00	96.18	1.26	0.00	2.68	94.96	0.04	0 01:25	0 00:00	0.00	0.00
14	108b		94.63	98.59	3.96	94.63	0.00	98.59	0.00	0.00	790.00	547.60	0.00	96.12	1.49	0.00	2.47	94.68	0.05	0 01:24	0 00:00	0.00	0.00
15	110	Mcon MH - Concentric	93.86	98.42	4.56	93.86	0.00	98.42	0.00	0.00	3218.00	487.31	0.00	96.06	2.20	0.00	2.36	94.24	0.38	0 01:24	0 00:00	0.00	0.00
16	110a		94.10	98.34	4.24	94.10	0.00	98.34	0.00	0.00	800.00	548.83	0.00	96.03	1.93	0.00	2.31	94.24	0.14	0 01:24	0 00:00	0.00	0.00
17	110b		94.06	98.26	4.20	94.06	0.00	98.26	0.00	0.00	2510.00	599.41	0.00	96.03	1.97	0.00	2.23	94.23	0.17	0 01:24	0 00:00	0.00	0.00
18	110c		93.98	98.12	4.14	93.98	0.00	98.12	0.00	0.00	2440.00	630.57	0.00	96.01	2.03	0.00	2.11	94.21	0.23	0 01:24	0 00:00	0.00	0.00
19	110d		93.94	98.06	4.12	93.94	0.00	98.06	0.00	0.00	1019.00	652.32	0.00	95.99	2.05	0.00	2.07	94.19	0.25	0 01:24	0 00:00	0.00	0.00
20	110e		93.87	97.93	4.06	93.87	0.00	97.93	0.00	0.00	1434.00	680.89	0.00	95.96	2.09	0.00	1.97	94.19	0.32	0 01:24	0 00:00	0.00	0.00
21	112	Mcon MH - Concentric	93.43	97.81	4.38	93.43	0.00	97.81	0.00	0.00	990.00	712.57	0.00	95.91	2.48	0.00	1.90	94.16	0.73	0 01:24	0 00:00	0.00	0.00
22	112a 112b		93.62	97.60	3.99	93.62	0.00	97.60	0.00	0.00	1037.00	743.80	0.00	95.85	2.24	0.00	1.75	94.16	0.55	0 01:24	0 00:00	0.00	0.00
23	1120	Mcon MH Concentric	93.50	97.39	3.90	93.50	0.00	97.39	0.00	0.00	1024.00	705 27	0.00	95.80	2.30	0.00	1.59	94.10	0.00	0 01:24	0 00:00	0.00	0.00
24 25	114 114a	WCON WH - Concentric	93.15	97.27	4.14	93.13	0.00	97.27	0.00	0.00	983.00	877 49	0.00	95.75	2.02	0.00	1.52	94.14 94 14	0.79	0 01.24	0 00.00	0.00	0.00
26	114a 114b		93.26	96.99	3.73	93.30	0.04	96.99	0.00	0.00	819.00	859.83	0.00	95.65	2.34	0.00	1.34	94.14	0.88	0 01:24	0 00:00	0.00	0.00
27	114c		93.21	96.90	3.69	93.30	0.09	96.90	0.00	0.00	763.00	867.87	0.00	95.62	2.41	0.00	1.28	94.14	0.93	0 01:24	0 00:00	0.00	0.00
28	115		96.06	96.36	0.30	96.06	0.00	96.36	0.00	0.00	100.00	0.00	0.00	96.06	0.00	0.00	0.35	96.06	0.00	0 00:00	0 00:00	0.00	0.00
29	116	Mcon MH - Concentric	92.83	96.76	3.93	93.30	0.47	96.76	0.00	0.00	830.00	912.72	0.00	95.55	2.72	0.00	1.21	94.13	1.30	0 01:24	0 00:00	0.00	0.00
30	116a		92.98	96.47	3.49	93.30	0.32	96.47	0.00	0.00	739.00	934.91	0.00	95.43	2.45	0.00	1.04	94.13	1.15	0 01:24	0 00:00	0.00	0.00
31	116b		92.89	96.30	3.41	93.30	0.41	96.30	0.00	0.00	1630.00	951.86	0.00	95.39	2.50	0.00	0.91	94.13	1.24	0 01:23	0 00:00	0.00	0.00
32	118	Mcon MH - Concentric	92.46	96.26	3.80	93.30	0.84	96.26	0.00	0.00	700.00	966.25	0.00	95.31	2.85	0.00	0.95	94.13	1.67	0 01:23	0 00:00	0.00	0.00
33	118a		92.71	96.17	3.46	93.30	0.59	96.17	0.00	0.00	777.00	1000.57	0.00	95.25	2.54	0.00	0.92	94.12	1.41	0 01:23	0 00:00	0.00	0.00
34	118b		92.63	96.03	3.40	93.30	0.67	96.03	0.00	0.00	809.00	1064.86	0.00	95.21	2.58	0.00	0.82	94.12	1.49	0 01:23	0 00:00	0.00	0.00
35	118c		92.59	95.96	3.37	93.30	0.71	95.96	0.00	0.00	980.00	1204.47	0.00	95.18	2.59	0.00	0.78	94.12	1.53	0 01:23	0 00:00	0.00	0.00
30	120	Micon MH - Concentric	92.21	95.84	3.63	93.30	1.09	95.84	0.00	0.00	1200.00	12/1.39	0.00	95.08	2.87	0.00	0.76	94.12	1.91	0 01:23	0 00:00	0.00	0.00
32	1208	Mcon MH - Concentric	92.47	95.80	3.55	93.30	0.85	95.80	0.00	0.00	2256.00	1302.95	0.00	95.00	2.55	0.00	0.80	94.1Z 0/ 11	1.05 2.15	0 01.24	0 00.00	0.00	0.00
39	122		92 19	95.62	3 43	93 30	1.54	95.62	0.00	0.00	2230.00	1300.77	0.00	94.78	2.02	0.00	0.75	94.11	1 92	0 01:29	0 00:00	0.00	0.00
40	124	Mcon MH - Concentric	91.66	95.78	4.12	93.30	1.64	95.78	0.00	0.00	2772.00	1298.40	0.00	94.53	2.87	0.00	1.26	94.10	2.44	0 01:42	0 00:00	0.00	0.00
41	126	Mcon MH - Concentric	91.44	95.75	4.31	93.30	1.86	95.75	0.00	0.00	2958.00	1298.37	0.00	94.45	3.01	0.00	1.29	94.09	2.65	0 01:55	0 00:00	0.00	0.00
42	1308 (STM MH3)	Strandherd ID: RELOCATED EX. STM MH3Citi Gate ID: 1308	95.05	97.99	2.94	95.05	0.00	98.29	0.30	0.00	970.00	2370.63	0.00	96.66	1.61	0.00	1.33	96.49	1.44	0 01:20	0 00:00	0.00	0.00
43	200		96.76	98.53	1.77	96.76	0.00	98.83	0.30	0.00	0.00	106.81	0.00	97.85	1.09	0.00	0.68	97.54	0.78	0 01:23	0 00:00	0.00	0.00
44	202		96.59	98.65	2.06	96.59	0.00	98.95	0.30	0.00	1235.00	106.74	0.00	97.79	1.20	0.00	0.86	97.54	0.95	0 00:26	0 00:00	0.00	0.00
45	204		96.28	98.29	2.01	96.28	0.00	98.59	0.30	0.00	0.00	146.72	0.00	97.68	1.40	0.00	0.61	97.53	1.25	0 01:22	0 00:00	0.00	0.00
46	206		95.62	98.34	2.72	95.62	0.00	98.64	0.30	0.00	1255.00	147.36	0.00	97.65	2.03	0.00	0.69	97.53	1.91	0 01:33	0 00:00	0.00	0.00
47	206A		96.05	98.39	2.34	96.05	0.00	98.69	0.30	0.00	1050.00	281.24	0.00	97.57	1.52	0.00	0.82	97.53	1.48	0 01:38	0 00:00	0.00	0.00
48	208		94.46	98.17	3.71	94.76	0.30	98.47	0.30	0.00	1280.00	3412.51	0.00	98.13	3.67	0.00	0.04	94.96	0.50	0 01:43	0 00:00	0.00	0.00
49 50	2-1/2-2		97.05	98.25	1.20	97.05	0.00	98.55	0.30	0.00	0.00	227.88	11.83	98.46	1.41	0.00	0.14	97.56	0.51	0 01:23	0 00:00	0.00	0.00
5U 51	∠⊥∪ 2_11/2_12		94.3U Q1 Q2	97.93	5.03 1.61	94.30 Q1 QQ	0.00	90.23 96 70	0.30	0.00	0.00	5441.94 1/15 10	0.00 55 / Q	97.90	5.00 1.60	0.00	0.10	94.78 97 90	0.48	0 01:42		0.00	0.00
52	2-11/2-12		94,03	97.82	3,79	94 03	0.00	98.12	0.30	0.00	0.00	4959.05	0.00	97 79	3.76	0.00	0.22	94 53	0.50	0 01.23	0 00.00	0.00	0.00
53	2-13/2-14		94.61	96.11	1.50	94.91	0.30	96.41	0.30	0.00	0.00	167.36	99.29	96.23	1.62	0.00	0.18	94.66	0.05	0 01:27	0 00:00	0.00	0.00

![](_page_139_Picture_7.jpeg)

### Citi Gate: 416 Corporate Campus - Phase 1 Junctions

## AutoDesk Storm and Sanitary Analysis Chicago 100-year 3-hour Storm Model Output Results

MH214 Q100yr (3-hour Chic.) = 4,586.32 L/s

SN	Element ID	Description	Invert Elevation	Ground/Rim (Max) Elevation	Ground/Rim (Max) Offset	Initial Water Elevation	Initial Water Depth	Surcharge Elevation	Surcharge Depth	Ponded Area	Minimum Pipe Cover	Peak Inflow	Peak Lateral Inflow	Maximum HGL Elevation	Maximum HGL Depth	Maximum Surcharge Depth	Minimum Freeboard Attained	Average HGL Elevation	Average HGL Depth	Time of Maximum HGL	Time of Peak Flooding	Total Flooded Volume	Total Time Flooded
			(m)	(m)	(m)	(m)	(m)	(m)	(m)	(m²)	(mm)	(lps)	(lps)	Attained (m)	Attained (m)	Attained (m)	(m)	Attained (m)	Attained (m)	(days hh:mm)	(days hh:mm)	(ha-mm)	(minutes
54	<mark>214</mark>		94.05	97.78	3.73	94.05	0.00	98.08	0.30	0.00	1870.00	4586.32	0.00	97.43	3.38	0.00	0.35	94.26	0.21	0 01:41	0 00:00	0.00	0.00
55	2-3/2-4		96.98	98.18	1.20	96.98	0.00	98.48	0.30	0.00	0.00	84.51	84.51	98.30	1.32	0.00	0.18	97.57	0.59	0 01:27	0 00:00	0.00	0.00
56	230		94.17	97.09	2.92	95.47	1.30	97.39	0.30	0.00	2120.00	122.67	0.00	96.66	2.49	0.00	0.43	94.50	0.33	0 01:17	0 00:00	0.00	0.00
57	232		93.40	96.71	3.31	93.70	0.30	97.01	0.30	0.00	0.00	772.97	0.00	97.01	3.61	0.30	0.00	93.89	0.49	0 01:15	0 01:15	0.02	0.00
58	2-5/2-0 2-7/2-8		96.80	98.00	1.20	96.80	0.00	98.30	0.30	0.00	0.00	293.51 67.15	96.38 67.15	98.23	1.43	0.00	0.07	96.85	0.05	0 01:43	0 00:00	0.00	0.00
59 60	2-7/2-8		96.03	97.83	1.20	96.03	0.00	98.13	0.30	0.00	0.00	89 34	89 34	97.90 97.80	1.35	0.00	0.10	96.55	0.04	0 01.43	0 00:00	0.00	0.00
61	300		95.12	98.06	2.94	95.12	0.00	98.36	0.30	0.00	2160.00	120.95	0.00	96.17	1.05	0.00	1.89	96.08	0.96	0 01:23	0 00:00	0.00	0.00
62	302		95.32	98.26	2.94	95.32	0.00	98.56	0.30	0.00	0.00	120.97	0.00	96.37	1.05	0.00	1.89	96.09	0.77	0 01:16	0 00:00	0.00	0.00
63	304		95.54	98.08	2.54	95.54	0.00	98.38	0.30	0.00	0.00	71.28	0.00	96.49	0.95	0.00	1.59	96.09	0.55	0 01:16	0 00:00	0.00	0.00
64	306		95.72	98.31	2.59	95.72	0.00	98.61	0.30	0.00	1915.00	33.33	0.00	96.51	0.79	0.00	1.80	96.09	0.37	0 01:16	0 00:00	0.00	0.00
65	308		95.99	97.81	1.82	95.99	0.00	98.11	0.30	0.00	0.00	15.93	0.00	96.49	0.50	0.00	1.32	96.29	0.30	0 01:25	0 00:00	0.00	0.00
66	3-3/3-4		96.71	97.91	1.20	96.85	0.14	98.21	0.30	0.00	0.00	88.58	88.58	98.00	1.29	0.00	0.21	96.75	0.04	0 01:23	0 00:00	0.00	0.00
6/	3-5/3-6		96.45	97.65	1.20	96.45	0.00	97.95	0.30	0.00	0.00	22.93	22.93	97.66	1.21	0.00	0.34	96.48	0.03	0 01:23	0 00:00	0.00	0.00
69	400		93.97	97.27	3.30	93.97	0.00	97.57	0.30	0.00	1410.00	4602.19	0.00	97.23	3.20	0.00	0.04	94.18 94.01	0.21	0 01:33	0 00:00	0.00	0.00
70	404		93.46	96.93	3.47	93.46	0.00	97.23	0.30	0.00	1640.00	4629.51	0.00	96.61	3.15	0.00	0.32	93.93	0.47	0 01:34	0 00:00	0.00	0.00
71	406		93.81	97.05	3.24	93.81	0.00	97.35	0.30	0.00	2366.00	422.80	0.00	94.69	0.88	0.00	2.36	94.18	0.37	0 02:00	0 00:00	0.00	0.00
72	408		93.41	96.99	3.58	93.41	0.00	97.29	0.30	0.00	0.00	65.54	0.00	94.69	1.28	0.00	2.30	94.36	0.95	0 02:00	0 00:00	0.00	0.00
73	4-1/4-2		95.77	96.97	1.20	95.77	0.00	97.27	0.30	0.00	0.00	71.34	71.34	97.16	1.39	0.00	0.11	95.84	0.07	0 01:51	0 00:00	0.00	0.00
74	410		94.35	96.09	1.74	94.35	0.00	96.39	0.30	0.00	0.00	11.15	0.00	94.72	0.37	0.00	1.37	94.64	0.29	0 01:21	0 00:00	0.00	0.00
75	412		93.82	97.22	3.40	93.82	0.00	97.52	0.30	0.00	2536.00	408.71	0.00	94.69	0.87	0.00	2.53	94.18	0.36	0 02:07	0 00:00	0.00	0.00
76	4-3/4-4		95.64	96.84	1.20	95.64	0.00	97.14	0.30	0.00	0.00	66.88	66.88	96.95	1.31	0.00	0.19	95.69	0.05	0 01:42	0 00:00	0.00	0.00
// 70	4-5/4-6		95.59 05.49	96.79	1.20	95.59	0.00	97.09	0.30	0.00	0.00	14.25	0.00	96.41	0.82	0.00	0.71	95.61 05.52	0.02	0 01:32	0 00:00	0.00	0.00
78	4-7/4-0 198		93.40	97.53	1.20 4.40	93.48	0.00	97.04	0.30	0.00	0.00	93.05 1376.67	95.05	90.80	2.60	0.00	1.80	93.35	0.03	0 01.24	0 00:00	0.00	0.00
80	500		93.08	96.42	3.34	93.08	0.00	96.72	0.30	0.00	1720.00	2226.63	0.00	95.55	2.00	0.00	0.87	93.83	0.75	0 01:10	0 00:00	0.00	0.00
81	502		92.81	95.67	2.86	92.81	0.00	95.97	0.30	0.00	115.00	3025.00	0.00	94.90	2.09	0.00	0.77	93.81	1.00	0 01:24	0 00:00	0.00	0.00
82	504		92.60	95.72	3.12	92.60	0.00	96.02	0.30	0.00	1740.00	3025.50	0.00	94.37	1.77	0.00	1.35	93.78	1.18	0 01:23	0 00:00	0.00	0.00
83	506		92.61	95.61	3.00	92.61	0.00	95.91	0.30	0.00	1210.00	1490.22	0.00	94.31	1.70	0.00	1.30	93.77	1.16	0 02:34	0 00:00	0.00	0.00
84	508		93.04	95.70	2.66	93.04	0.00	96.00	0.30	0.00	1270.00	70.47	0.00	94.30	1.26	0.00	1.40	93.81	0.77	0 02:39	0 00:00	0.00	0.00
85	510		92.60	95.92	3.32	92.60	0.00	96.22	0.30	0.00	2565.00	76.40	0.00	93.69	1.09	0.00	2.23	93.09	0.49	0 02:00	0 00:00	0.00	0.00
86 97	5-11/5-12		93.76	94.95	1.19	93.76	0.00	95.25	0.30	0.00	0.00	40.15	40.15	95.05	1.29	0.00	0.20	93.80	0.04	0 01:24	0 00:00	0.00	0.00
67 88	512		92.95	96.17	5.22 1.98	92.95	0.00	90.47 95.49	0.50	0.00	0.00	74.35 27 79	0.00	93.75	0.78	0.00	2.44	93.51	0.50	0 02:01	0 00:00	0.00	0.00
89	520		92.73	95.71	2.98	92.73	0.00	96.01	0.30	0.00	2110.00	1399.94	0.00	94.32	1.59	0.00	1.31	93.78	1.05	0 02:37	0 00:00	0.00	0.00
90	5-3/5-4		94.30	95.50	1.20	94.30	0.00	95.80	0.30	0.00	0.00	2099.63	97.37	95.73	1.43	0.00	0.57	94.52	0.22	0 01:33	0 00:00	0.00	0.00
91	5-5/5-6		94.31	95.51	1.20	94.31	0.00	95.81	0.30	0.00	0.00	53.35	53.35	94.82	0.51	0.00	1.49	94.32	0.01	0 01:20	0 00:00	0.00	0.00
92	5-7/5-8		94.34	95.54	1.20	94.34	0.00	95.84	0.30	0.00	0.00	64.78	64.78	95.08	0.74	0.00	0.76	94.36	0.02	0 01:20	0 00:00	0.00	0.00
93	5-9/5-10		94.41	95.61	1.20	94.41	0.00	95.91	0.30	0.00	0.00	84.51	84.51	95.71	1.30	0.00	0.20	94.46	0.05	0 01:24	0 00:00	0.00	0.00
94	600		92.31	95.02	2.71	92.31	0.00	95.32	0.30	0.00	0.00	86.02	0.00	93.66	1.35	0.00	1.36	92.96	0.65	0 02:01	0 00:00	0.00	0.00
95	602		92.15	94.36	2.21	92.15	0.00	94.66	0.30	0.00	0.00	147.71	0.00	93.64	1.49	0.00	0.72	92.93	0.78	0 02:01	0 00:00	0.00	0.00
96	6-3/6-4 700		93.15	94.35	1.20	93.15	0.00	94.65	0.30	0.00	0.00	103.06	62.87	94.40	1.25	0.00	0.25	93.20	0.11	0 01:20	0 00:00	0.00	0.00
97 98	700		93.41	97.00	5.59 4 11	95.41	0.00	97.30 97.30	0.30	0.00	0.00	5423 20	0.00	90.42 96.11	3.01	0.00	0.38	93.92	1 00	0 01.32	0 00:00	0.00	0.00
99	702 MAJ		95.80	96.05	0.25	95.80	0.00	96.05	0.00	0.00	0.00	617.05	0.00	96.09	0.29	0.00	2.92	95.81	0.01	0 01:32	0 00:00	0.00	0.00
100	704		92.67	96.80	4.13	92.67	0.00	97.10	0.30	0.00	0.00	6074.32	0.00	95.74	3.07	0.00	1.06	93.86	1.19	0 01:33	0 00:00	0.00	0.00
101	704 MAJ		95.53	95.83	0.30	95.53	0.00	95.83	0.00	0.00	0.00	565.39	0.00	95.75	0.22	0.00	2.94	95.53	0.00	0 01:33	0 00:00	0.00	0.00
102	706		92.60	95.37	2.77	92.60	0.00	95.67	0.30	0.00	0.00	7067.79	0.00	95.12	2.52	0.00	0.63	93.82	1.22	0 01:32	0 00:00	0.00	0.00
103	706 MAJ		95.25	95.50	0.25	95.25	0.00	95.50	0.00	0.00	0.00	257.62	0.00	95.41	0.16	0.00	2.99	95.26	0.01	0 01:40	0 00:00	0.00	0.00
104	708		92.27	95.55	3.28	92.27	0.00	95.85	0.30	0.00	0.00	7067.74	0.00	94.63	2.36	0.00	0.92	93.79	1.52	0 01:32	0 00:00	0.00	0.00
105	710		92.18	95.25	3.07	92.18	0.00	95.55	0.30	0.00	1150.00	4341.19	0.00	94.30	2.12	0.00	0.95	93.77	1.59	0 02:34	0 00:00	0.00	0.00
106	800		92.27	95.38	3.11	92.27	0.00	95.68 06 59	0.30	0.00	0.00	4507.35	0.00	94.31	2.04	0.00	1.07	93.//	1.50	0 02:45	0 00:00	0.00	0.00
101	002		92.21	90.28	4.07	92.21	0.00	90.58	0.30	0.00	2070.00	2003.48	0.00	94.30	2.09	0.00	1.98	95.70	1.55	0 02:32	0 00:00	0.00	0.00

![](_page_140_Picture_7.jpeg)

## Appendix D

Stormwater Management Modeling

![](_page_142_Figure_0.jpeg)

222 CITIGATE DRIVE, CITY OF OTTAWA STORMWATER MANAGEMENT

![](_page_142_Picture_3.jpeg)

		038
PROJECT No.		မျ
	120025	20
REV		
	REV #5	, , -
DRAWING No.		$\sim$
120025 -	SWM	
PLAN #	18129	

### 222 CitiGate Drive – Project Python (120025) PCSWMM Model Schematics

![](_page_143_Picture_1.jpeg)

#### **Overall Model Schematic**

![](_page_143_Figure_3.jpeg)
#### 222 CitiGate Drive – Project Python (120025) PCSWMM Model Schematics







#### 222 CitiGate Drive – Project Python (120025) PCSWMM Model Schematics







EPA STORM WATER MANAGEMENT MODEL - VERSION 5.1 (Build 5.1.013)

* * * * * * * * * * * *							
Element Count ************************************	1 nts 44 53 57 0 0						
**************************************							
Name	Data Source			Data Type	Recordin Interval	ng L	
Raingagel	C3hr-100yr			INTENSITY	10 min.		
**************************************							
Name	Area	Width	%Imperv	%Slope	Rain Gage	e 	Outlet
A-01 A-02	0.25	125.00	57.10	1.5000	Raingage Raingage	L	MH119 MH117 MH106
A-04	0.10	100.00	65.70	1.5000	Raingage	L	MH100 MH103
A-05 A-06	0.18	264.00	55.70 75.70	1.5000	Raingage: Raingage:	L	MH101 MH108
A-07 A-08	1.04	173.33 161.54	87.10 91.40	1.5000	Raingage: Raingage:	L	MH104 MH105
A-09 A-10	0.64	128.00	84.30	1.5000	Raingage!	L	MH05
A-11	0.04	40.00	90.00	1.5000	Raingage		MH02
A-13	0.45	120.00	61.40	1.5000	Raingage		MH07
A-14a A-14b	0.35	140.00 35.00	100.00	1.5000	Raingage: Raingage:	L	MHII MH11
A-15a	0.25	125.00	95.70	1.5000	Raingage:	L	MH08
A-15b A-16a A-16b A-17a A-17b A-18 A-29 A-20 A-21a A-21b A-22a A-22b A-22a A-22b A-22a A-22b A-22a A-22b A-23b A-24a A-24b A-25b A-25b A-25b A-26a A-27a A-27b A-27b A-28 CG-DR-EXT D-01 D-02 D-03 FUT	0.36 0.82 0.67 0.17 0.25 0.23 0.47 0.23 0.25 0.05 1.16 1.06 1.11 0.48 1.27 0.66 1.84 0.65 1.14 1.06 1.11 0.48 1.27 0.66 1.84 0.08 0.11 0.52 0.25 0.53 0.04 2.66	$\begin{array}{c} 72.00\\ 102.50\\ 111.67\\ 68.00\\ 62.50\\ 115.00\\ 188.00\\ 76.67\\ 125.00\\ 33.33\\ 193.33\\ 193.33\\ 116.92\\ 297.14\\ 81.25\\ 210.91\\ 132.50\\ 222.00\\ 80.00\\ 211.67\\ 94.29\\ 306.67\\ 40.00\\ 55.00\\ 13.87\\ 40.00\\ 55.00\\ 13.87\\ 40.00\\ 55.00\\ 13.87\\ 40.00\\ 251.33\\ 80.00\\ 231.30\\ \end{array}$	$\begin{array}{c} 100.00\\ 100.00\\ 98.60\\ 98.60\\ 98.60\\ 00.00\\ 84.30\\ 100.00\\ 84.30\\ 100.00\\ 47.10\\ 100.00\\ 47.10\\ 100.00\\ 65.70\\ 100.00\\ 65.70\\ 100.00\\ 65.70\\ 100.00\\ 65.70\\ 100.00\\ 65.70\\ 100.00\\ 65.70\\ 100.00\\ 85.00\\ 85.00\\ \end{array}$	1.5000 1.5000	Raingage Raingage		MH08 MH10B MH10A MH111 MH111 MH110 MH120 MH115 MH115 MH115 MH15 MH14 MH16 MH16 MH16 MH16 MH15 MH14 MH12 MH12 MH12 MH12 MH13 MH13 MH13 MH13 EX-MH214 EX-MH214 EX-MH214 EX-MH214 EX-MH214 EX-MH214 EX-MH214
Node Summary ************* Name	Туре	II I	nvert Slev.	Max. 1 Depth	Ponded Area	External Inflow	
EX-MH208	OUTFALL		95.57	1.05	0.0		
EX-MH214 HP-MH01	OUTFALL OUTFALL	0	94.65 98.00	1.20 1.00	0.0		
HP-MH05 CBMH109	OUTFALL STORAGE	10	00.00 97.59	1.00 4.41	0.0		
CBMH201 CBMH211	STORAGE STORAGE	0	98.12 97.57	2.43 3.24	0.0		
FUT-Dummy MH01	STORAGE	0	96.75	4.25	0.0		
MH01-Dummy	STORAGE		94.72	3.35	0.0		

MH02	STORAGE	94.84	3.53	0.0
MH04	STORAGE	97.33	3.57	0.0
MH05	STORAGE	98.04	3.38	0.0
MH06	STORAGE	95.42	5.18	0.0
MH07	STORAGE	96.50	5.61	0.0
MH08	STORAGE	98.20	4.50	0.0
MH09	STORAGE	98.46	3.92	0.0
MH101	STORAGE	95.76	2.86	0.0
MH102	STORAGE	96.01	3.84	0.0
MH103	STORAGE	96.52	4.17	0.0
MH103-Dummy	STORAGE	96.52	4.17	0.0
MH104	STORAGE	97.43	4.45	0.0
MH105	STORAGE	97.90	2.70	0.0
MH106	STORAGE	96.17	4.52	0.0
MH107	STORAGE	96.27	4.57	0.0
MH108	STORAGE	97.15	3.79	0.0
MH108-Dummy	STORAGE	97.15	3.79	0.0
MH10A	STORAGE	99.22	3.41	0.0
MH10B	STORAGE	99.95	2.56	0.0
MH11	STORAGE	97.09	4.16	0.0
MH110	STORAGE	97.69	4.60	0.0
MH111	STORAGE	99.88	2.85	0.0
MH113	STORAGE	97.95	4.34	0.0
MH114	STORAGE	99.17	3.41	0.0
MH115	STORAGE	99.79	2.45	0.0
MH116	STORAGE	101.38	2.17	0.0
MH117	STORAGE	96.70	3.17	0.0
MH118	STORAGE	97.59	2.44	0.0
MH118-Dummy	STORAGE	97.59	2.44	0.0
MH119	STORAGE	98.85	2.80	0.0
MH11-Dummy	STORAGE	97.09	4.16	0.0
MH12	STORAGE	97.42	4.12	0.0
MH120	STORAGE	101.78	2.54	0.0
MH13	STORAGE	97.67	3.89	0.0
MH14	STORAGE	98.09	3.49	0.0
MH15	STORAGE	98.46	3.11	0.0
MH16	STORAGE	98.78	3.25	0.0
Storage-FUT	STORAGE	99.00	2.30	0.0
Storage-N01	STORAGE	98.00	2.03	0.0
Storage-N02	STORAGE	98.20	2.35	0.0
Storage-N03	STORAGE	97.60	3.21	0.0
Storage-S01	STORAGE	97.80	3.80	0.0
Storage-S02	STORAGE	95.75	2.32	0.0

\*\*\*\*\*

Link Summary	
Name From Node To Node Type Length %Slope Ro	oughness
CBMH109-MH108 CBMH109 MH108 CONDUIT 42.5 1.0116	0.0130
CBMH201-MH108 CBMH201 MH108 CONDUIT 40.8 1.0054	0.0130
CBMH211-MH103 CBMH211 MH103 CONDUTT 8.0 1.9929	0.0130
FUT-Dummy Storage-FUT FUT-Dummy CONDUIT 10.0 0.3000	0.0130
FUT-MH117 FUT-Dummy MH117 CONDUIT 12.5 0.3205	0.0130
MH-01 MH01 HP-MH01 CONDUIT 3.0 2.3340	0.0150
MH01-EX-MH214 MH01-Dummy EX-MH214 CONDUIT 12.2 0.5714	0.0130
MH02-MH01 MH02 MH01 CONDUIT 15.0 0.6000	0.0130
MH04-MH02 MH04 MH02 CONDUIT 116.0 1.4914	0.0130
MH05 MH05 HP-MH05 CONDUIT 3.0 14.1393	0.0150
MH05-MH04 MH05 MH04 CONDUIT 63.2 0.9966	0.0130
Mb06-MH02 MH06 MH02 CONDUIT 66.9 0.6730	0.0130
MH07-MH06 MH07 MH06 CONDUIT 81.9 0.7079	0.0130
MH08-MH07 MH08 MH07 CONDUIT 106.6 1.0319	0.0130
MH09-MH08 MH09 MH08 CONDUIT 20.3 0.9833	0.0130
MH101-MH100 MH101 EX-MH208 CONDUIT 31.1 0.6107	0.0130
MH102_MH101 MH102 MH101 CONDUIT 37.2 0.5908	0.0130
MH103-MH102 MH103-Dummy MH102 CONDUIT 19.9 1.0031	0.0130
MH104-MH103 MH104 MH103 CONDUIT 87.8 1.0028	0.0130
MH105-MH104 MH105 MH104 CONDUIT 92.3 0.4982	0.0130
MH106-MH102 MH106 MH102 CONDUIT 38.2 0.3926	0.0130
MH107-MH106 MH107 MH106 CONDUIT 17.8 0.3937	0.0130
MH108-MH107 MH108-Dummy MH107 CONDUIT 17.9 1.0040	0.0130
MH10A-MH09 MH10A MH09 CONDUIT 70.0 1.0001	0.0130
MH10B-MH10A MH10B MH10A CONDUIT 72.5 0.9938	0.0130
MH110-CBMH109 MH110 CBMH109 CONDUIT 8.8 1.0205	0.0130
MH111-MH110 MH111 MH110 CONDUIT 76.8 1.4060	0 0130
MH113-MH110 MH113 MH110 CONDUTT 22.8 1.0075	0 0130
MH114 - MH113 MH114 MH113 CONDUTT 118.7 1 00.28	0 0130
MH115-MH114 MH115 MH114 CONDUIT 31.0 0.9994	0.0130
MH116-MH115 MH116 MH115 CONDUIT 48.9 2.8016	0.0130
MH117-MH107 MH117 MH107 CONDUIT 93.7 0.2988	0.0130
MH118-MH117 MH118-Dummy MH117 CONDUIT 21.8 2.0178	0.0130
MH119-MH118 MH119 MH118 CONDUIT 59.1.1.9967	0 0130
MH11-MH07 MH11-Dummy MH07 CONDUTT 26.8 0.4853	0 0130
MH120-MH119 MH120 MH119 CONDUTT 97.4 2.5478	0 0130
MH12 MH11 CONDULT 106.3 0.3010	0.0130
MH12_MH12_MH13_MH12_CONDUTT80.4_0.2986	0 0130
MH14 MH13 CONDUIT 120.0 0.3000	0.0130
MH15_MH14 MH15 MH14 CONDUIT 120.0 0.3000	0.0130
MH16-MH15 MH16 MH15 CONDUIT 102.5 0.3025	0.0130
Storage-N01-MH118 Storage-N01 MH118 CONDUIT 2.0 1.0001	0.0130

Storage-S02-MH01 MH01-Orifice1 MH01-Orifice3 MH103-Orifice MH108-Orifice MH118-ICD MH11-Orifice1 MH11-Orifice3 MH11-Orifice3 MH01-Weir MH11-Weir	Storage-S02 MH01 MH01 MH103 MH108 MH118 MH11 MH11 MH11 MH11 MH11 MH11	MH01 MH01-Dummy MH01-Dummy MH01-Dummy MH103-Dummy MH108-Dummy MH11-Dummy MH11-Dummy MH11-Dummy MH01-Dummy MH01-Dummy	COND ORIF ORIF ORIF ORIF ORIF ORIF ORIF WEIR WEIR	UIT ICE ICE ICE ICE ICE ICE ICE ICE ICE	4.0	1.0102 0.0130
**************************************	**** mmary ****	Full	Full	Hyd.	Max. No.	of Full
Conduit	Shape	Depth	Area	Rad.	Width Barr	els Flow
CEMH109-MH108 CEMH201-MH108 CEMH201-MH103 FUT-Dummy FUT-MH117 MH-01 MH01-EX-MH214 MH02-MH01 MH05-MH02 MH05-MH04 MH05-MH04 MH05-MH04 MH07-MH06 MH09-MH08 MH101-MH100 MH102-MH101 MH103-MH102 MH104-MH103 MH105-MH104 MH105-MH104 MH105-MH104 MH107-MH106 MH107-MH106 MH107-MH107	CIRCULAR CIRCULAR CIRCULAR CIRCULAR RECTOPEN CIRCULAR	0.82 0.75 0.68 0.45 0.90 1.20 1.20 1.20 1.20 1.20 1.20 1.20 1.2	0.53 0.44 0.36 0.16 0.64 3.00 1.13 1.13 0.28 3.00 0.22 1.13 1.13 0.28 0.22 0.22 0.22 0.28 0.22 0.28 0.28	0.21 0.19 0.17 0.11 0.23 0.75 0.30 0.30 0.30 0.30 0.30 0.30 0.30 0.3	0.82 0.75 0.68 0.45 0.90 3.00 1.20 1.20 0.60 3.00 0.53 1.20 1.20 1.20 0.60 0.60 1.05 0.75 0.75 0.75 1.05 1.05 0.82	1 1443.81 1 116.37 1 1186.74 1 156.17 1 1024.95 1 25223.84 1 2947.36 1 3020.15 1 749.90 1 62083.59 1 429.35 1 3198.49 1 3280.35 1 608.91 1 2134.20 1 209.01 1 1115.05 1 1114.89 1 785.85 1 771.352 1 1438.36
MH10A-MH09 MH10B-MH10A MH110-CBMH109 MH111-MH110 MH113-MH110 MH115-MH114 MH115-MH113 MH115-MH114 MH116-MH115 MH119-MH118 MH12-MH17 MH120-MH119 MH12-MH11 MH13-MH12 MH13-MH14 MH16-MH15 Storage-N01-CBMH1 Storage-S01-MH11 Storage-S01-MH11	CIRCULAR CIRCULAR CIRCULAR CIRCULAR CIRCULAR CIRCULAR CIRCULAR CIRCULAR CIRCULAR CIRCULAR CIRCULAR CIRCULAR CIRCULAR CIRCULAR CIRCULAR CIRCULAR 201 CIRCULAR CIRCULAR CIRCULAR CIRCULAR CIRCULAR CIRCULAR CIRCULAR CIRCULAR	0.60 0.82 0.45 0.82 0.53 0.30 0.45 1.20 1.20 1.20 1.20 1.20 1.20 1.20 1.20	0.28 0.28 0.53 0.53 0.52 0.07 0.16 0.16 0.16 1.13 0.07 1.13 1.13 1.13 1.13 1.13 0.16 0.36 0.87	$\begin{array}{c} 0.15\\ 0.15\\ 0.21\\ 0.21\\ 0.21\\ 0.23\\ 0.11\\ 0.13\\ 0.07\\ 0.30\\ 0.30\\ 0.30\\ 0.30\\ 0.30\\ 0.30\\ 0.30\\ 0.30\\ 0.11\\ 0.19\\ 0.26\\ \end{array}$	0.60 0.60 0.82 0.82 0.53 0.30 0.90 0.45 0.45 0.45 1.20 0.45 0.75 0.68 1.05	1 614.06 1 612.15 1 1450.13 1 338.09 1 1447.89 1 1437.55 1 429.96 1 611.87 1 989.67 1 405.02 1 405.02 1 405.02 1 402.89 1 2716.05 1 2139.03 1 2130.63 1 2135.56 1 2135.56 1 2135.56 1 2135.56 1 2135.56 1 2135.56 1 2144.43 1 2820.53 1 2744.72

NOTE: The summary statistics displayed in this report are based on results found at every computational time step, not just on results from each reporting time step.

 Surcharge Method
 EXTRAN

 Starting Date
 03/18/2020 00:00:00

 Ending Date
 03/19/2020 00:00:00

 Antecedent Dry Days
 0.0

 Report Time Step
 00:01:00

 Wet Time Step
 00:05:00

 Dry Time Step
 00:05:00

 Routing Time Step
 2.00 sec

 Variable Time Step
 YES

 Maximum Trials
 8

 Number of Threads
 4

 Head Tolerance
 0.001500 m

* * * * * * * * * * * * * * * * * * * *	Volume	Depth
Runoff Quantity Continuity	hectare-m	mm
* * * * * * * * * * * * * * * * * * * *		
Total Precipitation	1.901	71.667
Evaporation Loss	0.000	0.000
Infiltration Loss	0.257	9.699
Surface Runoff	1.639	61.778
Final Storage	0.022	0.821
Continuity Error (%)	-0.879	
* * * * * * * * * * * * * * * * * * * *	Volume	Volume
Flow Routing Continuity	hectare-m	10^6 ltr
* * * * * * * * * * * * * * * * * * * *		
Dry Weather Inflow	0.000	0.000
Wet Weather Inflow	1.639	16.395
Groundwater Inflow	0.000	0.000
RDII Inflow	0.000	0.000
External Inflow	0.000	0.000
External Outflow	1.641	16.413
Flooding Loss	0.000	0.000
Evaporation Loss	0.000	0.000
Exfiltration Loss	0.000	0.000
Initial Stored Volume	0.000	0.000
Final Stored Volume	0.001	0.006
Continuity Error (%)	-0.150	



A-01	71.67	0.00	0.00	16.03	45.23	10.03	55.26	0.14	108.07	0.771
A-02	71.67	0.00	0.00	19.17	40.10	12.25	52.35	0.13	107.69	0.731
A-03	71.67	0.00	0.00	22.42	35.11	14.12	49.23	0.05	41.10	0.687
A-04	71.67	0.00	0.00	15.13	46.11	10.43	56.53	0.06	46.64	0.789
A-05	71.67	0.00	0.00	19.81	39.12	12.62	51.74	0.09	76.86	0.722
A-06	71.67	0.00	0.00	10.79	53.24	7.11	60.35	0.40	308.33	0.842
A-07	71.67	0.00	0.00	5.75	61.53	3.71	65.24	0.68	496.29	0.910
A-08	71.67	0.00	0.00	3.81	64.59	2.53	67.12	0.70	509.57	0.937
A-09	71.67	0.00	0.00	7.00	59.50	4.51	64.01	0.41	302.98	0.893
A-10	71.67	0.00	0.00	2.51	66.52	1.78	68.30	0.60	432.48	0.953
A-11	71.67	0.00	0.00	4.38	63.18	3.24	66.42	0.03	19.55	0.927
A-12	71.67	0.00	0.00	27.87	27.10	16.76	43.86	0.20	160.59	0.612
A-13	71.67	0.00	0.00	17.29	43.15	10.93	54.08	0.16	129.62	0.755
A-14a	71.67	0.00	0.00	10.79	53.24	7.11	60.35	0.21	163.51	0.842
A-14b	71.67	0.00	0.00	0.00	71.91	0.00	71.91	0.05	34.72	1.003
A-15a	71.67	0.00	0.00	1.88	67.31	1.40	68.71	0.17	123.21	0.959
A-15b	71.67	0.00	0.00	0.00	72.19	0.00	72.19	0.26	178.35	1.007
A-16a	71.67	0.00	0.00	0.00	72.28	0.00	72.28	0.59	404.07	1.009
A-16b	71.67	0.00	0.00	0.00	72.23	0.00	72.23	0.48	331.52	1.008
A-17a	71.67	0.00	0.00	0.61	69.42	0.46	69.88	0.12	84.14	0.975
A-17b	71.67	0.00	0.00	0.00	72.12	0.00	72.12	0.18	123.95	1.006
A-18	71.67	0.00	0.00	0.61	69.36	0.46	69.82	0.16	113.84	0.974
A-19	71.67	0.00	0.00	14.69	47.17	9.42	56.60	0.27	210.32	0.790
A-20	71.67	0.00	0.00	26.02	30.14	15.44	45.58	0.10	82.32	0.636
A-21a	71.67	0.00	0.00	15.26	46.15	9.95	56.11	0.14	112.92	0.783
A-21b	71.67	0.00	0.00	0.00	71.84	0.00	71.84	0.04	24.80	1.002
A-22a	71.67	0.00	0.00	7.03	59.54	4.45	64.00	0.74	545.12	0.893
A-22b	71.67	0.00	0.00	0.00	72.25	0.00	72.25	0.55	375.75	1.008
A-23a	71.67	0.00	0.00	25.06	33.21	13.12	46.32	0.96	654.46	0.646
A-23b	71.67	0.00	0.00	0.00	72.28	0.00	72.28	0.47	320.30	1.009
A-24a	71.67	0.00	0.00	13.65	49.39	8.14	57.53	0.67	492.87	0.803
A-24b	71.67	0.00	0.00	0.00	72.28	0.00	72.28	0.77	522.34	1.009
A-25a	71.67	0.00	0.00	15.63	46.32	9.27	55.59	0.62	458.35	0.776
A-25b	71.67	0.00	0.00	0.00	72.23	0.00	72.23	0.35	237.51	1.008
A-26a	71.67	0.00	0.00	2.51	66.63	1.73	68.36	0.87	622.55	0.954
A-26b	71.67	0.00	0.00	0.00	72.26	0.00	72.26	0.48	325.99	1.008
A-27a	71.67	0.00	0.00	15.08	47.35	8.78	56.13	1.03	753.99	0.783
A-27b	71.67	0.00	0.00	0.00	71.91	0.00	71.91	0.06	39.68	1.003
A-28	71.67	0.00	0.00	17.21	43.13	11.11	54.23	0.06	48.58	0.757
CG-DR-EXT	71.67	0.00	0.00	7.32	60.00	3.48	63.48	0.33	197.58	0.886
D-01	71.67	0.00	0.00	43.50	2.05	27.49	29.53	0.07	83.60	0.412
D-02	71.67	0.00	0.00	32.75	19.02	20.45	39.47	0.21	192.90	0.551
D-03	71.67	0.00	0.00	44.28	0.00	29.64	29.64	0.01	15.66	0.414
FUT	71.67	0.00	0.00	6.84	60.78	4.05	64.84	1.72	1209.08	0.905

Node	Туре	Average Depth Meters	Maximum Depth Meters	Maximum HGL Meters	Time Occu days	of Max urrence hr:min	Reported Max Depth Meters
EX-MH208	OUTFALL	0.10	0.71	96.28	0	01:11	0.71
EX-MH214	OUTFALL	0.10	0.90	95.55	0	01:24	0.90
HP-MH01	OUTFALL	0.00	0.00	98.00	0	00:00	0.00
HP-MH05	OUTFALL	0.00	0.00	100.00	0	00:00	0.00
CBMH109	STORAGE	0.29	3.01	100.60	0	01:11	3.00
CBMH201	STORAGE	0.17	1.41	99.53	0	01:31	1.41
CBMH211	STORAGE	0.06	1.47	99.04	0	01:19	1.47
FUT-Dummy	STORAGE	0.06	0.68	97.43	0	01:10	0.68
MH01	STORAGE	0.21	2.81	97.53	0	01:24	2.81
MH01-Dummy	STORAGE	0.15	1.45	96.17	0	01:24	1.45
MH02	STORAGE	0.19	2.79	97.63	0	01:23	2.79
MH04	STORAGE	0.05	1.39	98.72	0	01:11	1.39
MH05	STORAGE	0.03	0.92	98.96	0	01:10	0.92
MH06	STORAGE	0.15	2.57	97.99	0	01:19	2.57
MH07	STORAGE	0.12	2.27	98.77	0	01:15	2.27
MH08	STORAGE	0.07	2.10	100.30	0	01:12	2.09
MH09	STORAGE	0.07	2.28	100.74	0	01:12	2.27
MH101	STORAGE	0.10	0.76	96.52	0	01:11	0.76
MH102	STORAGE	0.10	0.76	96.77	0	01:11	0.76
MH103	STORAGE	0.18	2.52	99.04	0	01:19	2.52
MH103-Dummy	STORAGE	0.05	0.41	96.93	0	01:16	0.41
MH104	STORAGE	0.10	1.98	99.41	0	01:11	1.97
MH105	STORAGE	0.07	1.64	99.54	0	01:10	1.64
MH106	STORAGE	0.10	0.72	96.89	0	01:11	0.72
MH107	STORAGE	0.10	0.73	97.00	0	01:11	0.73
MH108	STORAGE	0.41	3.14	100.29	0	01:11	3.14
MH108-Dummy	STORAGE	0.08	0.36	97.51	0	01:11	0.36
MH10A	STORAGE	0.07	2.39	101.61	0	01:11	2.38
MH10B	STORAGE	0.05	1.85	101.80	0	01:11	1.83
MH11	STORAGE	0.14	2.24	99.33	0	01:15	2.24
MH110	STORAGE	0.27	2.97	100.66	0	01:11	2.96
MH111	STORAGE	0.03	1.13	101.01	0	01:11	1.13
MH113	STORAGE	0.22	2.88	100.83	0	01:11	2.87
MH114	STORAGE	0.07	2.26	101.43	Ō	01:10	2.26
MH115	STORAGE	0.04	1.70	101.49	Ō	01:11	1.70
MH116	STORAGE	0.01	0.43	101.81	Ō	01:11	0.42
MH117	STORAGE	0.07	0.70	97.40	Ō	01:10	0.70

MH118	STORAGE	0.40	1.94	99.53	0	01:35	1.94
MH118-Dummy	STORAGE	0.03	0.10	97.69	0	01:35	0.10
MH119	STORAGE	0.06	0.69	99.54	0	01:34	0.69
MH11-Dummy	STORAGE	0.12	2.14	99.23	0	01:15	2.14
MH12	STORAGE	0.13	2.55	99.97	0	01:12	2.54
MH120	STORAGE	0.03	1.07	102.85	0	01:11	1.06
MH13	STORAGE	0.12	2.68	100.35	0	01:12	2.68
MH14	STORAGE	0.11	2.87	100.96	0	01:11	2.87
MH15	STORAGE	0.09	2.71	101.17	0	01:11	2.67
MH16	STORAGE	0.07	2.42	101.20	0	01:11	2.42
Storage-FUT	STORAGE	0.08	1.29	100.29	0	01:12	1.29
Storage-N01	STORAGE	0.25	1.53	99.53	0	01:35	1.53
Storage-N02	STORAGE	0.15	1.33	99.53	0	01:31	1.33
Storage-N03	STORAGE	0.06	1.44	99.04	0	01:19	1.44
Storage-S01	STORAGE	0.05	1.53	99.33	0	01:15	1.53
Storage-S02	STORAGE	0.08	1.78	97.53	0	01:24	1.78

\* \* \* \* \* \* \* \* \* \* \* \* \* \* \* \* \* \* \* Node Inflow Summary

\_\_\_\_\_ \_\_\_\_\_ ------Maximum Maximum 
 Maximum
 Lateral
 Total

 Total
 Time of Max
 Inflow
 Inflow

 Inflow
 Occurrence
 Volume
 Volume
 Flow Lateral Inflow Balance Error Inflow Type LPS Node Percent 
 OUTFALL
 83.60
 1775.26

 OUTFALL
 406.15
 2801.06

 OUTFALL
 0.00
 0.00

 OUTFALL
 0.00
 0.00

 STORAGE
 0.00
 1151.61

 STORAGE
 0.00
 644.47

 STORAGE
 0.00
 3932.90

 Y
 STORAGE
 0.00
 2674.32

 STORAGE
 0.00
 2793
 37074.54
 0.000 EX-MH208 EX-MH214 HP-MH01 0.000 ltr HP-MH05 CBMH109 0.000 ltr CBMH201 -0.015 0.013 CBMH211 0 01:07 0 01:12 0 01:12 0 01:24 0 01:12 0 01:09 1.72 10.7 9.45 9.43 1.01 FUT-Dummy 0.012 MH01 MH01-Dummy 0.031 -0.031 
 0.00
 2674.32

 19.55
 3974.54

 432.48
 711.44

 302.98
 302.98

 160.59
 3414.60
 MH02 MH04 STORAGE 0.0266 0.601 -0.202 0.061 STORAGE STORAGE STORAGE STORAGE 0 01:10 0 01:12 0.41 0.197 0.41 8.38 MH05 0.214 MH06 -0.228 0 01:12 0 01:12 0 01:07 0 01:08 0 01:11 129.62 3355.13 301.57 857.42 0.00 601.55 8.18 1.51 MH07 0.162 0.027 0.162 0.432 0 0.0932 MH08 1.356 MH09 MH101 STORAGE 1.08 -0.223 76.86 1706.60 STORAGE 6.34 0.013

MH102	STORAGE	0.00	1647.41	0	01:11	0	6.25	0.011
MH103	STORAGE	95.22	983.11	0	01:10	0.116	1.85	-0.050
MH103-Dummy	STORAGE	0.00	354.41	0	01:19	0	1.5	-0.042
MH104	STORAGE	496.29	964.03	0	01:10	0.679	1.38	-0.025
MH105	STORAGE	509.57	509.57	0	01:10	0.705	0.705	-0.018
MH106	STORAGE	41.10	1307.77	0	01:11	0.0492	4.74	-0.041
MH107	STORAGE	0.00	1274.41	0	01:11	0	4.69	-0.031
MH108	STORAGE	308.33	1485.43	0	01:10	0.398	3.43	0.053
MH108-Dummy	STORAGE	0.00	316.82	0	01:11	0	2.43	-0.001
MH10A	STORAGE	331.52	688.18	0	01:10	0.484	1.08	0.091
MH10B	STORAGE	404.07	404.07	0	01:10	0.593	0.593	0.023
MH11	STORAGE	198.23	3682.10	0	01:10	0.262	7.23	-0.021
MH110	STORAGE	113.84	1248.33	0	01:10	0.161	2.04	-0.226
MH111	STORAGE	208.09	208.09	0	01:10	0.299	0.299	0.776
MH113	STORAGE	0.00	1019.91	0	01:10	0	1.57	-0.622
MH114	STORAGE	920.87	1099.19	0	01:10	1.29	1.57	0.280
MH115	STORAGE	137.72	207.76	0	01:09	0.176	0.281	0.120
MH116	STORAGE	82.32	82.32	0	01:10	0.105	0.105	0.278
MH117	STORAGE	107.69	959.43	0	01:10	0.131	2.26	0.105
MH118	STORAGE	0.00	265.11	0	01:10	0	0.623	-0.365
MH118-Dummy	STORAGE	0.00	33.46	0	01:35	0	0.406	-0.013
MH119	STORAGE	108.07	280.48	0	01:10	0.138	0.403	-0.243
MH11-Dummy	STORAGE	0.00	2561.26	0	01:15	0	6.53	0.040
MH12	STORAGE	948.54	3614.17	0	01:10	1.35	6.27	0.019
MH120	STORAGE	210.32	210.32	0	01:10	0.266	0.266	0.389
MH13	STORAGE	793.67	2846.10	0	01:10	1.09	4.92	-0.022
MH14	STORAGE	695.86	2352.77	0	01:08	0.964	3.83	-0.024
MH15	STORAGE	1015.20	2126.19	0	01:07	1.43	2.87	0.068
MH16	STORAGE	974.76	974.76	0	01:10	1.43	1.43	-0.066
Storage-FUT	STORAGE	1209.08	1209.08	0	01:10	1.73	1.73	0.033
Storage-N01	STORAGE	0.00	227.16	0	01:10	0	0.219	-0.006
Storage-N02	STORAGE	0.00	1144.52	0	01:11	0	0.977	-0.017
Storage-N03	STORAGE	0.00	638.51	0	01:07	0	0.349	-0.037
Storage-S01	STORAGE	0.00	1301.81	0	01:06	0	0.697	-0.055
Storage-S02	STORAGE	0.00	1669.70	0	01:11	0	1.27	-0.067

Node Surcharge Summary

No nodes were surcharged.

Node Flooding Summary

Date: 06/02/20

No nodes were flooded.

	Average Volume	Avg Pont	Evap E Pont	xfil Pont	Maximum Volume	Max Pont	Time of Max Occurrence	Maximu Outflo
Storage Unit	1000 m3	Full	Loss	Loss	1000 m3	Full	days hr:min	LP
BMH109	0.000	7	0	0	0.003	68	0 01:11	1222.8
BMH201	0.000	7	0	0	0.002	58	0 01:31	1144.5
BMH211	0.000	2	0	0	0.002	45	0 01:19	638.5
UT-Dummy	0.000	1	0	0	0.001	16	0 01:10	842.6
H01	0.000	5	0	0	0.003	65	0 01:24	3926.1
H01-Dummy	0.000	4	0	0	0.002	43	0 01:24	2674.3
102	0.000	5	0	0	0.003	79	0 01:23	3932.9
104	0.000	1	0	0	0.002	39	0 01:11	647.6
105	0.000	1	0	0	0.001	27	0 01:10	282.0
106	0.000	3	0	0	0.003	50	0 01:19	3369.5
107	0.000	2	0	0	0.003	40	0 01:15	3307.3
108	0.000	1	0	0	0.002	47	0 01:12	797.4
109	0.000	2	0	0	0.003	58	0 01:12	563.1
1101	0.000	4	0	0	0.001	27	0 01:11	1706.8
1102	0.000	3	0	0	0.001	20	0 01:11	1649.4
1103	0.000	4	0	0	0.003	60	0 01:19	946.3
H103-Dummy	0.000	1	0	0	0.000	10	0 01:16	358.6
1104	0.000	2	0	0	0.002	44	0 01:11	889.6
1105	0.000	3	0	0	0.002	61	0 01:10	468.4
1106	0.000	2	0	0	0.001	16	0 01:11	1307.0
1107	0.000	2	0	0	0.001	16	0 01:11	1274.1
1108	0.000	11	0	0	0.004	83	0 01:11	1467.8
1108-Dummy	0.000	2	0	0	0.000	9	0 01:11	316.8
110A	0.000	2	0	0	0.003	70	0 01:11	601.5
110B	0.000	2	0	0	0.002	72	0 01:11	359.5
111	0.000	3	0	0	0.003	54	0 01:15	3617.6
1110	0.000	6	0	0	0.003	65	0 01:11	1227.9
H111	0.000	1	0	0	0.001	40	0 01:11	194.9
H113	0.000	5	0	0	0.003	66	0 01:11	968.1
H114	0.000	2	0	0	0.003	66	0 01:10	1019.9
H115	0.000	1	0	0	0.002	69	0 01:11	193.0
H116	0.000	1	0	0	0.000	20	0 01:11	76.0
1117	0.000	2	0	0	0.001	22	0 01:10	958.9
1118-Dummy	0.000	1	0	0	0 0002	4	0 01.35	200.2
4119	0.000	2	0	0	0 001	25	0 01.33	265 1
111-Dummy	0.000	3	0	ő	0.002	51	0 01:15	2560 6
112	0.000	3	ñ	0 0	0 003	62	0 01.12	3501 8
120	0.000	1	ñ	0	0 001	42	0 01.12	175 -
113	0.000	3	0	0	0.001	74 69	0 01.11	2767 9
114	0.000	2	0	0	0.003	60	0 01:12	21/0/.0
115	0.000	2	0	0	0.003	87	0 01.11	1690 1
116	0.000	3 2	0	0	0.003	0 / 7 /	0 01.11	1167 3
orage-FUT	0.000	1	0	0	0.005	0.2	0 01.11	840 C
orage=N01	0.002	10	0	0	0.140	100	0 01.12	042.U 22.1
orage-N01	0.030	10	0	0	0.219	100	0 01:30	151 0
LOT AGE NOS	0.110	TU	0	0	0.3/7	92 00	0 01.10	160 1
LOTAGE-NUS	0.013	4	0	0	0.34/	99	0 01.15	100.1
corage-S01 corage-S02	0.021	3	0	0	0.693	84 98	0 01:15	486.3 802.9
******************************								
all Loading Summary								

Outfall Node	Flow	Avg	Max	Total
	Freq	Flow	Flow	Volume
	Pcnt	LPS	LPS	10^6 ltr
EX-MH208	99.04	138.08	1775.26	6.414
EX-MH214	99.13	200.97	2801.06	10.000
HP-MH01	0.00	0.00	0.00	0.000
HP-MH05	0.00	0.00	0.00	0.000
System	49.54	339.05	0.00	16.413

Link Flow Summary

		Maximum	Time of Max	Maximum	Max/	Max/					
		Flow	Occurrence	Veloc	Full	Full					
Link	Type	LPS	days hr:min	m/sec	Flow	Depth					
CBMH109-MH108	CONDUIT	1222.89	0 01:11	2.29	0.85	1.00					

CBMH201-MH108	CONDUIT	1151.61	0	01:11	2.61	1.03	1.00
CBMH211-MH103	CONDUIT	644.47	0	01:07	1.93	0.54	1.00
FUT-Dummy	CONDUIT	842.03	0	01:12	5.29	5.39	1.00
FUT-MH117	CONDUIT	842.62	0	01:12	1.69	0.82	0.76
MH-01	CONDUIT	0.00	0	00:00	0.00	0.00	0.00
MH01-EX-MH214	CONDUIT	2674.33	0	01:24	2.55	0.91	0.87
MH02-MH01	CONDUIT	3932.90	0	01:12	3.48	1.30	1.00
MH04-MH02	CONDUIT	647.62	0	01:10	2.29	0.86	1.00
MH05	CONDUIT	0.00	0	00:00	0.00	0.00	0.00
MH05-MH04	CONDUIT	282.08	0	01:06	1.79	0.66	1.00
Mh06-MH02	CONDUIT	3369.57	0	01:12	2.98	1.05	1.00
MH07-MH06	CONDUIT	3307.31	0	01:13	2.92	1.01	1.00
MH08-MH07	CONDUIT	797.44	0	01:08	2.83	1.28	1.00
MH09-MH08	CONDUIT	563.16	0	01:11	1.99	0.92	1.00
MH101-MH100	CONDUIT	1706.89	0	01:11	2.64	0.80	0.70
MH102-MH101	CONDUIT	1649.41	0	01:12	2.53	0.79	0.71
MH103-MH102	CONDUIT	358.61	0	01:22	1.79	0.32	0.57
MH104-MH103	CONDUIT	889.66	0	01:10	2.01	0.80	1.00
MH105-MH104	CONDUIT	468.47	0	01:10	1.36	0.60	1.00
MH106-MH102	CONDUIT	1307.05	0	01:11	2.02	0.76	0.70
MH107-MH106	CONDUIT	1274.19	0	01:11	2.05	0.74	0.68
MH108-MH107	CONDUIT	316.82	0	01:11	1.72	0.22	0.38
MH10A-MH09	CONDUIT	601.55	0	01:08	2.13	0.98	1.00
MH10B-MH10A	CONDUIT	359.58	0	01:05	1.53	0.59	1.00
MH110-CBMH109	CONDUIT	1227.93	0	01:11	2.30	0.85	1.00
MH111-MH110	CONDUIT	194.90	0	01:05	1.83	0.58	1.00
MH113-MH110	CONDUIT	968.10	0	01:11	1.81	0.67	1.00
MH114-MH113	CONDUIT	1019.91	0	01:10	1.91	0.71	1.00
MH115-MH114	CONDUIT	193.09	0	01:13	1.78	0.45	1.00
MH116-MH115	CONDUIT	76.06	0	01:12	2.04	0.47	1.00
MH117-MH107	CONDUIT	958.93	0	01:11	1.97	0.97	0.72
MH118-MH117	CONDUIT	33.45	0	01:35	1.43	0.08	0.37
MH119-MH118	CONDUIT	265.11	0	01:10	1.82	0.66	1.00
MH11-MH07	CONDUIT	2560.66	0	01:15	2.26	0.94	1.00
MH120-MH119	CONDUIT	175.77	0	01:11	2.59	1.14	1.00
MH12-MH11	CONDUIT	3501.83	0	01:10	3.10	1.64	1.00
MH13-MH12	CONDUIT	2767.80	0	01:11	2.45	1.30	1.00
MH14-MH13	CONDUIT	2148.07	0	01:11	1.90	1.01	1.00
MH15-MH14	CONDUIT	1690.14	0	01:08	1.57	0.79	1.00
MH16-MH15	CONDUIT	1167.30	0	01:07	1.23	0.54	1.00
Storage-N01-MH118	CONDUIT	227.16	0	01:10	1.46	0.80	1.00
Storage-N02-CBMH201	CONDUIT	1144.52	0	01:11	3.30	1.04	1.00
Storage-N03-CBMH211	CONDUIT	638.51	0	01:07	3.76	1.07	1.00
Storage-S01-MH11	CONDUIT	1301.81	0	01:06	2.89	0.46	1.00
Storage-S02-MH01	CONDUIT	1669.70	0	01:11	3.45	0.61	1.00
MH01-Orifice1	ORIFICE	891.44	0	01:24			1.00

MH01-Orifice2	ORIFICE	891.44	0	01:24	1.00
MH01-Orifice3	ORIFICE	891.44	0	01:24	1.00
MH103-Orifice	ORIFICE	354.41	0	01:19	1.00
MH108-Orifice	ORIFICE	316.82	0	01:11	1.00
MH118-ICD	ORIFICE	33.46	0	01:35	1.00
MH11-Orifice1	ORIFICE	521.05	0	01:06	1.00
MH11-Orifice2	ORIFICE	521.05	0	01:06	1.00
MH11-Orifice3	ORIFICE	521.05	0	01:06	1.00
MH01-Weir	WEIR	0.00	0	00:00	0.00
MH11-Weir	WEIR	1832.17	0	01:15	0.31

#### 

	Adjusted			Fract	ion of	Time	in Flo	w Clas	s	Trlet
Conduit	/ACLUAL Length	Dry	Dru	Dru	Crit	Crit	Crit	Crit	Ltd	Ctrl
CBMH109-MH108	1.00	0.01	0.00	0.00	0.58	0.00	0.00	0.41	0.36	0.00
CBMH201-MH108	1.00	0.03	0.01	0.00	0.20	0.00	0.00	0.76	0.01	0.00
CBMH211-MH103	1.00	0.04	0.00	0.00	0.07	0.00	0.00	0.88	0.00	0.00
FUT-Dummy	1.00	0.01	0.00	0.00	0.00	0.00	0.00	0.99	0.00	0.00
FUT-MH117	1.00	0.01	0.00	0.00	0.49	0.00	0.00	0.50	0.06	0.00
MH-01	1.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
MH01-EX-MH214	1.00	0.01	0.00	0.00	0.99	0.00	0.00	0.00	0.67	0.00
MH02-MH01	1.00	0.01	0.00	0.00	0.21	0.02	0.00	0.76	0.00	0.00
MH04-MH02	1.00	0.01	0.00	0.00	0.06	0.01	0.00	0.92	0.02	0.00
MH05	1.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
MH05-MH04	1.00	0.01	0.00	0.00	0.03	0.01	0.00	0.95	0.01	0.00
Mh06-MH02	1.00	0.01	0.00	0.00	0.08	0.01	0.00	0.90	0.00	0.00
MH07-MH06	1.00	0.01	0.00	0.00	0.05	0.00	0.00	0.94	0.00	0.00
MH08-MH07	1.00	0.01	0.00	0.00	0.03	0.00	0.00	0.96	0.01	0.00
MH09-MH08	1.00	0.01	0.00	0.00	0.03	0.00	0.00	0.96	0.00	0.00
MH101-MH100	1.00	0.01	0.00	0.00	0.61	0.38	0.00	0.00	0.68	0.00
MH102-MH101	1.00	0.01	0.00	0.00	0.01	0.02	0.00	0.96	0.00	0.00
MH103-MH102	1.00	0.01	0.00	0.00	0.03	0.00	0.00	0.96	0.00	0.00
MH104-MH103	1.00	0.01	0.00	0.00	0.22	0.01	0.00	0.76	0.08	0.00
MH105-MH104	1.00	0.01	0.00	0.00	0.22	0.08	0.00	0.70	0.07	0.00
MH106-MH102	1.00	0.01	0.00	0.00	0.10	0.16	0.00	0.73	0.00	0.00
MH107-MH106	1.00	0.01	0.00	0.00	0.03	0.00	0.00	0.96	0.00	0.00
MH108-MH107	1.00	0.01	0.00	0.00	0.00	0.00	0.00	0.99	0.00	0.00
MH10A-MH09	1.00	0.01	0.00	0.00	0.03	0.00	0.00	0.96	0.00	0.00
MH10B-MH10A	1.00	0.01	0.00	0.00	0.03	0.20	0.00	0.76	0.12	0.00

1.00	0.01	0.00	0.00	0.21	0.00	0.00	0.78	0.00	0.00
1.00	0.01	0.00	0.00	0.10	0.01	0.00	0.89	0.06	0.00
1.00	0.01	0.00	0.00	0.21	0.00	0.00	0.78	0.00	0.00
1.00	0.01	0.00	0.00	0.20	0.00	0.00	0.79	0.06	0.00
1.00	0.01	0.00	0.00	0.02	0.00	0.00	0.97	0.00	0.00
1.00	0.01	0.00	0.00	0.02	0.00	0.00	0.97	0.00	0.00
1.00	0.01	0.00	0.00	0.10	0.00	0.00	0.89	0.00	0.00
1.00	0.01	0.00	0.00	0.03	0.00	0.00	0.96	0.01	0.00
1.00	0.01	0.00	0.00	0.35	0.00	0.00	0.64	0.11	0.00
1.00	0.01	0.00	0.00	0.03	0.00	0.00	0.97	0.00	0.00
1.00	0.01	0.00	0.00	0.03	0.02	0.00	0.95	0.03	0.00
1.00	0.01	0.00	0.00	0.48	0.00	0.00	0.52	0.08	0.00
1.00	0.01	0.00	0.00	0.44	0.00	0.00	0.55	0.09	0.00
1.00	0.01	0.00	0.00	0.06	0.00	0.00	0.93	0.00	0.00
1.00	0.01	0.00	0.00	0.41	0.00	0.00	0.58	0.12	0.00
1.00	0.01	0.00	0.00	0.37	0.00	0.00	0.62	0.14	0.00
1.00	0.03	0.00	0.00	0.30	0.02	0.00	0.65	0.00	0.00
1.00	0.03	0.00	0.00	0.16	0.03	0.00	0.78	0.00	0.00
1.00	0.04	0.00	0.00	0.06	0.01	0.00	0.89	0.00	0.00
1.00	0.04	0.00	0.00	0.04	0.01	0.00	0.91	0.00	0.00
1.00	0.04	0.00	0.00	0.05	0.02	0.00	0.90	0.00	0.00
	1.00 1.00 1.00 1.00 1.00 1.00 1.00 1.00	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$


Conduit	Both Ends	Hours Full Upstream	Dnstream	Hours Above Full Normal Flow	Hours Capacity Limited
CBMH109-MH108 CBMH201-MH108 CBMH211-MH103 FUT-Dummy MH01-EX-MH214 MH02-MH01 MH04-MH02 MH05-MH04 MH05-MH04 MH05-MH06 MH08-MH07 MH09-MH08 MH04-MH103	2.19 1.51 0.62 0.33 0.01 0.78 0.15 0.08 0.66 0.41 0.25 0.29 0.72	2.19 1.51 0.62 0.40 0.55 0.78 0.15 0.08 0.66 0.41 0.31 0.31	2.50 2.12 0.75 0.33 0.01 0.81 0.74 0.15 0.75 0.50 0.41 0.30	0.01 0.05 0.01 0.70 0.01 0.25 0.01 0.01 0.11 0.04 0.20 0.01	0.01 0.01 0.33 0.01 0.34 0.01 0.15 0.23 0.13 0.23 0.13
MH105-MH104	0.49	0.49	0.72	0.01	0.01

MH10A-MH09	0.25	0.25	0.30	0.01	0.15
MH10B-MH10A	0.16	0.16	0.25	0.01	0.01
MH110-CBMH109	2.05	2.05	2.18	0.01	0.01
MH111-MH110	0.12	0.12	0.99	0.01	0.01
MH113-MH110	1.67	1.67	2.01	0.01	0.01
MH114-MH113	0.19	0.19	1.63	0.01	0.01
MH115-MH114	0.16	0.16	0.19	0.01	0.01
MH116-MH115	0.04	0.04	0.16	0.01	0.01
MH119-MH118	1.02	1.02	3.83	0.01	0.01
MH11-MH07	0.29	0.33	0.29	0.01	0.29
MH120-MH119	0.08	0.15	0.08	0.17	0.08
MH12-MH11	0.44	0.44	0.51	0.21	0.20
MH13-MH12	0.38	0.38	0.44	0.13	0.14
MH14-MH13	0.31	0.31	0.37	0.02	0.13
MH15-MH14	0.24	0.24	0.31	0.01	0.01
MH16-MH15	0.17	0.17	0.24	0.01	0.01
Storage-N01-MH118	2.88	2.88	2.96	0.01	0.01
Storage-N02-CBMH201	1.30	1.30	1.41	0.05	0.01
Storage-N03-CBMH211	0.60	0.60	0.61	0.08	0.01
Storage-S01-MH11	0.25	0.25	0.29	0.01	0.01
Storage-S02-MH01	0.48	0.49	0.53	0.01	0.07
Analysis begun on: Tue J	'un 2 12:3	6:59 2020			

Analysis begun on: Tue Jun 2 12:36:59 2020 Analysis ended on: Tue Jun 2 12:37:04 2020 Total elapsed time: 00:00:05

# Appendix E

**Development Servicing Checklist** 

# 4. Development Servicing Study Checklist

The following section describes the checklist of the required content of servicing studies. It is expected that the proponent will address each one of the following items for the study to be deemed complete and ready for review by City of Ottawa Infrastructure Approvals staff.

The level of required detail in the Servicing Study will increase depending on the type of application. For example, for Official Plan amendments and re-zoning applications, the main issues will be to determine the capacity requirements for the proposed change in land use and confirm this against the existing capacity constraint, and to define the solutions, phasing of works and the financing of works to address the capacity constraint. For subdivisions and site plans, the above will be required with additional detailed information supporting the servicing within the development boundary.

## 4.1 General Content

- N/A Executive Summary (for larger reports only).
  - X Date and revision number of the report.
  - X Location map and plan showing municipal address, boundary, and layout of proposed development.
  - X Plan showing the site and location of all existing services.
  - ☑ Development statistics, land use, density, adherence to zoning and official plan, and reference to applicable subwatershed and watershed plans that provide context to which individual developments must adhere.
  - Summary of Pre-consultation Meetings with City and other approval agencies.
  - Reference and confirm conformance to higher level studies and reports (Master Servicing Studies, Environmental Assessments, Community Design Plans), or in the case where it is not in conformance, the proponent must provide justification and develop a defendable design criteria.
  - X Statement of objectives and servicing criteria.
  - Identification of existing and proposed infrastructure available in the immediate area.
  - X Identification of Environmentally Significant Areas, watercourses and Municipal Drains potentially impacted by the proposed development (Reference can be made to the Natural Heritage Studies, if available).

- X <u>Concept level master grading plan</u> to confirm existing and proposed grades in the development. This is required to confirm the feasibility of proposed stormwater management and drainage, soil removal and fill constraints, and potential impacts to neighbouring properties. This is also required to confirm that the proposed grading will not impede existing major system flow paths.
- N/A Identification of potential impacts of proposed piped services on private services (such as wells and septic fields on adjacent lands) and mitigation required to address potential impacts.
- N/A Proposed phasing of the development, if applicable.
  - X Reference to geotechnical studies and recommendations concerning servicing.
  - X All preliminary and formal site plan submissions should have the following information:
    - Metric scale
    - North arrow (including construction North)
    - Key plan
    - Name and contact information of applicant and property owner
    - Property limits including bearings and dimensions
    - Existing and proposed structures and parking areas
    - Easements, road widening and rights-of-way
    - Adjacent street names

### 4.2 Development Servicing Report: Water

- X Confirm consistency with Master Servicing Study, if available
- X Availability of public infrastructure to service proposed development
- N/A Identification of system constraints
  - X Identify boundary conditions
  - X Confirmation of adequate domestic supply and pressure
  - X Confirmation of adequate fire flow protection and confirmation that fire flow is calculated as per the Fire Underwriter's Survey. Output should show available fire flow at locations throughout the development.
  - X Provide a check of high pressures. If pressure is found to be high, an assessment is required to confirm the application of pressure reducing valves.
- N/A Definition of phasing constraints. Hydraulic modeling is required to confirm servicing for all defined phases of the project including the ultimate design
  - X Address reliability requirements such as appropriate location of shut-off valves
- N/A Check on the necessity of a pressure zone boundary modification.

XReference to water supply analysis to show that major infrastructure is capable of<br/>delivering sufficient water for the proposed land use. This includes data that shows<br/>that the expected demands under average day, peak hour and fire flow conditions<br/>provide water within the required pressure range

☑ Description of the proposed water distribution network, including locations of proposed connections to the existing system, provisions for necessary looping, and appurtenances (valves, pressure reducing valves, valve chambers, and fire hydrants) including special metering provisions.

- N/A Description of off-site required feedermains, booster pumping stations, and other water infrastructure that will be ultimately required to service proposed development, including financing, interim facilities, and timing of implementation.
  - X Confirmation that water demands are calculated based on the City of Ottawa Design Guidelines.
  - Provision of a model schematic showing the boundary conditions locations, streets, parcels, and building locations for reference.

## 4.3 Development Servicing Report: Wastewater

- Summary of proposed design criteria (Note: Wet-weather flow criteria should not deviate from the City of Ottawa Sewer Design Guidelines. Monitored flow data from relatively new infrastructure cannot be used to justify capacity requirements for proposed infrastructure).
- X Confirm consistency with Master Servicing Study and/or justifications for deviations.
- N/A Consideration of local conditions that may contribute to extraneous flows that are higher than the recommended flows in the guidelines. This includes groundwater and soil conditions, and age and condition of sewers.
  - Description of existing sanitary sewer available for discharge of wastewater from proposed development.
  - X Verify available capacity in downstream sanitary sewer and/or identification of upgrades necessary to service the proposed development. (Reference can be made to previously completed Master Servicing Study if applicable)
  - Calculations related to dry-weather and wet-weather flow rates from the development in standard MOE sanitary sewer design table (Appendix 'C') format.
  - Description of proposed sewer network including sewers, pumping stations, and forcemains.

- N/A Discussion of previously identified environmental constraints and impact on servicing (environmental constraints are related to limitations imposed on the development in order to preserve the physical condition of watercourses, vegetation, soil cover, as well as protecting against water quantity and quality).
- N/A Pumping stations: impacts of proposed development on existing pumping stations or requirements for new pumping station to service development.
- N/A Forcemain capacity in terms of operational redundancy, surge pressure and maximum flow velocity.
- N/A Identification and implementation of the emergency overflow from sanitary pumping stations in relation to the hydraulic grade line to protect against basement flooding.
  - Special considerations such as contamination, corrosive environment etc.

### 4.4 Development Servicing Report: Stormwater Checklist

- Description of drainage outlets and downstream constraints including legality of outlets (i.e. municipal drain, right-of-way, watercourse, or private property)
- N/A Analysis of available capacity in existing public infrastructure.
  - A drawing showing the subject lands, its surroundings, the receiving watercourse, existing drainage patterns, and proposed drainage pattern.
  - X Water quantity control objective (e.g. controlling post-development peak flows to pre-development level for storm events ranging from the 2 or 5 year event (dependent on the receiving sewer design) to 100 year return period); if other objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into account long-term cumulative effects.
  - Water Quality control objective (basic, normal or enhanced level of protection based on the sensitivities of the receiving watercourse) and storage requirements.
  - $\boxed{X}$  Description of the stormwater management concept with facility locations and descriptions with references and supporting information.
- N/A Set-back from private sewage disposal systems.
  - X Watercourse and hazard lands setbacks.
- N/A Record of pre-consultation with the Ontario Ministry of Environment and the Conservation Authority that has jurisdiction on the affected watershed.
  - Confirm consistency with sub-watershed and Master Servicing Study, if applicable study exists.

X	Storage requirements (complete with calculations) and conveyance capacity for minor events (1:5 year return period) and major events (1:100 year return period).
X	Identification of watercourses within the proposed development and how watercourses will be protected, or, if necessary, altered by the proposed development with applicable approvals.
X	Calculate pre and post development peak flow rates including a description of existing site conditions and proposed impervious areas and drainage catchments in comparison to existing conditions.
N/A	Any proposed diversion of drainage catchment areas from one outlet to another.
X	Proposed minor and major systems including locations and sizes of stormwater trunk sewers, and stormwater management facilities.
N/A 🗌	If quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100-year return period storm event.
	Identification of potential impacts to receiving watercourses
	Identification of municipal drains and related approval requirements.
X	Descriptions of how the conveyance and storage capacity will be achieved for the development.
	100 year flood levels and major flow routing to protect proposed development from flooding for establishing minimum building elevations (MBE) and overall grading.
N/A 🗌	Inclusion of hydraulic analysis including hydraulic grade line elevations.
X	Description of approach to erosion and sediment control during construction for the protection of receiving watercourse or drainage corridors.
N/A 🗌	Identification of floodplains – proponent to obtain relevant floodplain information from the appropriate Conservation Authority. The proponent may be required to delineate floodplain elevations to the satisfaction of the Conservation Authority if such information is not available or if information does not match current conditions.
N/A 🗌	Identification of fill constraints related to floodplain and geotechnical investigation.

# 4.5 Approval and Permit Requirements: Checklist

The Servicing Study shall provide a list of applicable permits and regulatory approvals necessary for the proposed development as well as the relevant issues affecting each approval. The approval and permitting shall include but not be limited to the following:

☑ Conservation Authority as the designated approval agency for modification of floodplain, potential impact on fish habitat, proposed works in or adjacent to a watercourse, cut/fill permits and Approval under Lakes and Rivers Improvement Act. The Conservation Authority is not the approval authority for the Lakes and Rivers Improvement Act. Where there are Conservation Authority regulations in place, approval under the Lakes and Rivers Improvement Act is not required, except in cases of dams as defined in the Act.



N/A Changes to Municipal Drains.

N/A Other permits (National Capital Commission, Parks Canada, Public Works and Government Services Canada, Ministry of Transportation etc.)

### 4.6 Conclusion Checklist

- X Clearly stated conclusions and recommendations
- N/A Comments received from review agencies including the City of Ottawa and information on how the comments were addressed. Final sign-off from the responsible reviewing agency.
  - X All draft and final reports shall be signed and stamped by a professional Engineer registered in Ontario

## Appendix F Drawings