



**Goodkey, Weedmark
& Associates Limited**

Consulting Engineers

1688 Woodward Dr.
Ottawa, ON
Canada
K2C 3R8

Tel. 613-727-5111
Fax 613-727-5115
info@gwal.com

Principals & Associates

A. Bogdanowicz, P.Eng.
M.G. Carriere, C.E.T.
R.J. McIntyre, P.Eng.
F.W.A. Bann, P.Eng.
R. Lefebvre, P.Eng.
D.R. Vyas, P.Eng., MIEEE
S. Hamilton, P.Eng.
J. Moffat, P.Eng.
E. Pérusse, P.Eng., ing.
R. Boivin, P.Eng., ing.
R. Leonard, P.Eng.
M. Sarasin, P.Eng.

October 8, 2020

VIA E-MAIL

Techo-Bloc Inc.
c/o: Thomas Fuller Construction Co. Limited
2700 Queensview Drive
Ottawa, Ontario
K2B 8H6

ATTENTION: MR. SHAWN GIOVANETTI

**SUBJECT: HAWTHORNE ROAD, OTTAWA
TECHO-BLOC DEVELOPMENT
OUR PROJECT NO. 2020-412**

Dear Sir:

We have designed the site lighting for the new warehouse/showroom building, located at Hawthorne Road, Ottawa, in accordance with the following guidelines as requested by the City of Ottawa:

1. It must be designed using only fixtures that meet the criteria for Full Cut-Off (Sharp cut-off) Classification, as recognized by the Illuminating Engineering Society of North America (IESNA or IES), and;
2. It must result in minimal light spillage onto adjacent properties. As a guideline, 0.5 fc is normally the maximum allowable spillage.

Yours very truly,

GOODKEY, WEEDMARK & ASSOCIATES LIMITED



Divyakant (Raj) Vyas, P.Eng., MIEEE
Associate Partner

DRV/cb

e.c.: Jordan Jackson (NOVATECH Engineers, Planners & Landscape Architects)

