

Symbol	Label	Quantity	Manufacturer	Catalog Number	Description	Lamp	Number Lamps	Filename	Lumens Per Lamp	Light Loss Factor	Wattage
—	A	2	COOPER LIGHTING SOLUTIONS - LUMARK (FORMERLY EATON)	NFLD-L-C100-D-UNV-66	NIGHT CONDOR LED FLOODLIGHT WIDE OPTIC	(4) 4000K CCT, 70 CRI LEDS ABSOLUTE PHOTOMETRY IS BASED ON CALIBRATION FACTORS CREATED USING LAB LUMEN STANDARDS IN GONIOPHOTOMETER WITH TEST DISTANCE OF 28.75 FEET Statue, Flood, Wet Location	4	NFLD-L-C100-D-UNV-66.ies	8459	0.9	252
□	B	4	COOPER LIGHTING SOLUTIONS - LUMARK (FORMERLY EATON)	PRV-PA1B-740-U-T4W-HSS	PREVALE AREA AND ROADWAY LUMINAIRE (1) 70 CRI, 4000K, 930mA LIGHT ENGINE WITH 24 LEDS AND TYPE IV WIDE OPTICS WITH HOUSE SIDE SHIELD Retail, Roadway, Sidewalk, Site, Street, Substation, Security, Corrosion Resistant, Vandal Resistant, Wet Location	ABSOLUTE PHOTOMETRY IS BASED ON CALIBRATION FACTORS CREATED USING LAB LUMEN STANDARDS IN GONIOPHOTOMETER WITH TEST DISTANCE OF 28.75 FEET	48	PRV-PA1B-740-U-T4W-HSS.ies	147	0.9	74
□	C	6	COOPER LIGHTING SOLUTIONS - MCGRAW-EDISON (FORMERLY EATON)	GWC-AF-01-LED-E1-T4FT-800	GALLEON WALL LUMINAIRE (1) 70 CRI, 4000K, 800mA LIGHTSQUARE WITH 16 LEDS EACH AND TYPE IV FORWARD THROW OPTICS Industrial, Landscape, Library, Office, Parking, Parks, Pathway, Pedestrian, Prison, Recreation, Residential Retail, Roadway, Sidewalk, Site, Street, Substation, Security, Corrosion Resistant, Vandal Resistant, Wet Location	ABSOLUTE PHOTOMETRY IS BASED ON CALIBRATION FACTORS CREATED USING LAB LUMEN STANDARDS IN GONIOPHOTOMETER WITH TEST DISTANCE OF 28.75 FEET	16	GWC-AF-01-LED-E1-T4FT-800.ies	330	0.9	44
---	D	2	COOPER LIGHTING SOLUTIONS - LUMARK (FORMERLY EATON)	NFLD-L-C100-D-UNV-66	NIGHT CONDOR LED FLOODLIGHT WIDE OPTIC	(4) 4000K CCT, 70 CRI LEDS ABSOLUTE PHOTOMETRY IS BASED ON CALIBRATION FACTORS CREATED USING LAB LUMEN STANDARDS IN GONIOPHOTOMETER WITH TEST DISTANCE OF 28.75 FEET Statue, Flood, Wet Location	4	NFLD-L-C100-D-UNV-66.ies	8459	0.9	504

Statistics						
Description	Symbol	Avg	Max	Min	Max/Min	Avg/Min
Front Parking	+	21 lux	60 lux	6 lux	10.0:1	3.5:1
North Side	+	20 lux	53 lux	1 lux	53.0:1	20.0:1
Property Line	+	0.4 lux	3.1 lux	0.0 lux	N/A	N/A
Site	+	10 lux	563 lux	0 lux	N/A	N/A
South Side	+	35 lux	251 lux	2 lux	125.5:1	17.5:1

