



CROSSING CONFLICT TABLE		
LOCATION	DESCRIPTION	SEPARATION
1	150mØb STM SERVICE OVB 119.57	0.41
	525mØb STM SEWER INV 119.98	
2	150mØb STM SERVICE OVB 119.11	0.50
	150mØb WTR SERVICE INV 119.11	
3	150mØb STM SERVICE OVB 119.61	0.30
	150mØb STM SERVICE OVB 119.31	
4	150mØb STM SERVICE INV 119.31	0.30
	150mØb WTR SERVICE OVB 119.31	
5	150mØb WTR SERVICE OVB 118.61	0.38
	300mØb STM SERVICE INV 118.90	
6	150mØb STM SERVICE INV 119.11	0.31
	750mØb STM SEWER OVB 118.69	
7	150mØb WTR SERVICE INV 119.29	0.58
	300mØb STM SEWER INV 119.29	
8	150mØb WTR SERVICE INV 119.31	0.30
	250mØb STM SEWER INV 119.01	
9	200mØb STM SERVICE OVB 119.49	0.51
	150mØb STM SERVICE INV 120.00	
10	200mØb STM SERVICE OVB 119.49	0.53
	200mØb STM SEWER INV 119.49	
11	150mØb STM SERVICE INV 119.20	0.50
	150mØb WTR SERVICE OVB 118.70	
12	150mØb STM SEWER INV 118.70	0.41
	150mØb WTR SERVICE OVB 118.70	

SAN STRUCTURE TABLE				
NAME	RIM ELEV.	INVERT IN	INVERT OUT	DESCRIPTION
MH1A	121.73	NW119.410	NE119.368	COVER CITY STD 524 FRAME CITY STD 525 STRUC. OPSD 701.010
MH2A	121.86	SW119.038	NE118.962	COVER CITY STD 524 FRAME CITY STD 525 STRUC. OPSD 701.010

ROOF DRAIN (B2B)			
TYPE OF CONTROL DEVICE	WATTS DRAINAGE RD-100-A-ADJ (FULLY EXPOSED)		
NUMBER OF ROOF DRAINS	1		
	2-YEAR	5-YEAR	100-YR
ROOFTOP STORAGE (m³)	3.45	4.58	8.68
DEPTH OF FLOW (m)	0.025	0.035	0.065
FLOW PER ROOF DRAIN (L/s)	0.32	0.44	0.82
TOTAL FLOW	0.32	0.44	0.82


ROOF DRAIN (B3)			
TYPE OF CONTROL DEVICE	WATTS DRAINAGE RD-100-A-ADJ (FULLY EXPOSED)		
NUMBER OF ROOF DRAINS	1		
	2-YEAR	5-YEAR	100-YR
ROOFTOP STORAGE (m³)	0	0	0
DEPTH OF FLOW (m)	0	0	0
FLOW PER ROOF DRAIN (L/s)	NA	NA	NA
TOTAL FLOW	NA	NA	NA



**FOR REVIEW ONLY**  
*NOT FOR CONSTRUCTION*


Check and verify all dimensions before proceeding with the work Do not scale drawings

SCALE 1 : 250




0 5 10 15 20 25 Metres

**McINTOSH PERRY**  
115 Walgreen Road, RR3, Carp, ON K0A 1L0  
Tel: 613-836-2184 Fax: 613-836-3742  
[www.mcintoshperry.com](http://www.mcintoshperry.com)



Stamp:



Client: **INVERNESS HOMES**  
38 AURIGA DRIVE, SUITE 200  
OTTAWA, ON K2E8A5

Project:

**MIXED USE DEVELOPMENT**  
1518-1526 STITTSVILLE MAIN STREET

Drawing Title:

**SITE SERVICING, SEDIMENT & EROSION  
CONTROL PLAN**

Scale:	1:250	Project Number:	CP-19-0608
Drawn By:	N.B.V.		
Checked By:	T.D.F.	Drawing Number:	C102
Designed By:	N.B.V.		