

1. GENERAL

1.1 USE BAR SCALE TO CONFIRM ACTUAL PLOT SCALE. EXISTING AND NEW ELEVATIONS AND INVERTS SHOWN ARE GEODETIC AND ARE IN METERS. ALL PIPE DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE NOTED.

1.2 UNLESS OTHERWISE STATED, REFER TO D.B. GRAY ENGINEERING INC.

1.3 EXISTING ELEVATIONS AND LOCATIONS, INVERTS AND SIZES OF EXISTING SERVICES & UTILITIES ARE NOT NECESSARILY SHOWN ON PLAN AND THOSE SHOWN ARE DERIVED FROM AVAILABLE INFORMATION AND MUST BE CONFIRMED ON SITE BEFORE COMMENCING CONSTRUCTION. REPORT ANY DIFFERENCES TO ENGINEER. UNDERGROUND LOCATIONS (INCLUDING ONTARIO ONE CALL 1-800-400-4000) SHALL BE CONDUCTED PRIOR TO THE COMMENCEMENT OF ANY EXCAVATION.

1.4 SITE BOUNDARIES AND OTHER FEATURES DERIVED FROM TOPOGRAPHIC SURVEY PREPARED BY FARLEY, SMITH & DENIS SURVEYING LTD. FILE NO. 37-17. IT IS THE RESPONSIBILITY OF THE USER OF THE SURVEY PLAN AND THESE DRAWINGS TO VERIFY THAT THE JOB BENCHMARK HAS NOT BEEN ALTERED OR DISTURBED AND THAT THE RELATIVE ELEVATION AND DESCRIPTION AGREE WITH THE INFORMATION SHOWN ON SURVEY PLAN AND THESE DRAWINGS.

1.5 REFER TO ARCHITECTURAL AND LANDSCAPE SITE PLANS FOR EXACT LOCATIONS OF BUILDINGS, PAVED AREAS, SIDEWALKS, PLANTERS ETC.

1.6 REFERENCE THE LATEST REVISION AND ALL ADDENDUMS OF THE GEOTECHNICAL INVESTIGATION BY FISHER ENVIRONMENTAL LTD. FILE #P-71771 G01. SITE PREPARATION INCLUDING BUILDING LITE-GRADE PREPARATION AND PAVEMENT SUB-GRADE PREPARATION AND CONSTRUCTION OF THE PAVEMENT STRUCTURE AND EXCAVATION AND BACKFILLING, INCLUDING COMPACTION OF MATERIALS, SHALL CONFORM TO THE GEOTECHNICAL INVESTIGATION TO THE SATISFACTION OF THE GEOTECHNICAL ENGINEER.

1.7 DRAWINGS ARE TO BE READ IN CONJUNCTION WITH SERVING BREE & STORMWATER MANAGEMENT REPORT NO. 19058 PREPARED BY D.B. GRAY ENGINEERING INC.

1.8 REINSTATE ADJACENT PROPERTIES TO PRE-CONSTRUCTION CONDITIONS.

1.9 EXISTANTIE CITY PROPERTIES TO CITY STANDARDS AND TO CITY OF OTTAWA'S SATISFACTION.

1.10 ALL RELEVANT WORK SHALL BE DONE IN ACCORDANCE WITH CURRENT CITY STANDARDS AND SPECIFICATIONS.

1.11 ONTARIO PROVINCIAL STANDARDS & SPECIFICATIONS WILL APPLY WHERE NO CITY STANDARDS ARE AVAILABLE.

1.12 ALL PROPOSED RETAINING WALLS SHALL BE SETBACK A MINIMUM 0.15m FROM PROPERTY LINE. ALL PROPOSED RETAINING WALLS GREATER THAN 1.0m IN HEIGHT SHALL BE DESIGNED BY A PROFESSIONAL ENGINEER REGISTERED IN ONTARIO.

2. EROSION AND SEDIMENT CONTROL PLAN

2.1 THE EROSION AND SEDIMENT CONTROL PLAN IS A "LIVING DOCUMENT" AND SHALL BE REVISED IN THE EVENT THE SPECIFIED CONTROL MEASURES ARE NOT SUFFICIENT. THE CONTRACTOR SHALL IMPLEMENT BEST MANAGEMENT PRACTICES TO PROVIDE PROTECTION OF THE AREA DRAINAGE SYSTEM AND THE RECEIVING WATER COURSE DURING CONSTRUCTION ACTIVITIES. THIS INCLUDES LIMITING THE AMOUNT OF EXPOSED SOIL, USING SEDIMENT CAPTURE FILTER SOCK INSERTS IN CATCH BASINS AND MANHOLES AND INSTALLING SILT FENCES AND OTHER EFFECTIVE SEDIMENT TRAPS. THE CONTRACTOR ACKNOWLEDGES THAT FAILURE TO IMPLEMENT APPROPRIATE EROSION AND SEDIMENT CONTROL MEASURES MAY BE SUBJECT TO PENALTIES IMPOSED BY ANY APPLICABLE REGULATORY AGENCY. SPECIFICALLY THE CONTRACTOR SHALL INSTALL THE EROSION AND SEDIMENT CONTROL MEASURES AND MAINTAIN AND MONITOR THE CONTROL MEASURES.

2.2 PRIOR TO COMMENCEMENT OF CONSTRUCTION AT ALL MUNICIPAL CATCH BASINS ADJACENT TO THE SITE AND AT ANY MANHOLES OR CATCH BASINS THAT WILL RECEIVE DISCHARGE FROM DE-WATERING OPERATIONS AND ALL NEW CATCH BASINS AS THEY ARE INSTALLED, INSTALL SEDIMENT CAPTURE FILTER SOCK INSERTS (TETRATEX GEOTECHNICS INC. SILSACK OR APPROVED EQUIVALENT). INSPECT AT THE END OF EACH DAY AND AFTER EACH RAINFALL. REMOVE SEDIMENT AS RECOMMENDED BY THE MANUFACTURER. IMMEDIATELY REPAIR OR REPLACE ANY DAMAGED FILTER SOCK INSERTS. DO NOT REMOVE UNTIL CONSTRUCTION IS COMPLETE.

2.3 INSTALL A FENCE BARRIER AROUND STOCKPILED SOIL OR SOIL PRIOR TO COMMENCEMENT OF CONSTRUCTION. INSTALL A SILT FENCE BARRIER AS SHOWN ON PLANS. INSPECT ALL SILT FENCES AT THE END OF EACH DAY AND AFTER EACH RAINFALL. REMOVE SEDIMENT DEPOSITS WHEN THE LEVEL OF DEPOSITS REACHES ONE THIRD THE HEIGHT OF THE FENCE. IMMEDIATELY REPAIR OR REPLACE ANY DAMAGED SECTIONS OF FENCE. DO NOT REMOVE ANY SILT FENCES IN ANY PHASE UNTIL CONSTRUCTION IS COMPLETE.

2.4 ANY MATERIAL DEPOSITED ON A PUBLIC ROAD SHALL BE REMOVED BY SWEEPING AND SHOVELING OR VACUUMING AND DISPOSING SEDIMENT IN A CONTROLLED AREA. DO NOT SWEEP OR HOSE MATERIAL INTO ANY STORMWATER CONVEYANCE SYSTEM.

2.5 CONSTRUCTION IS CONSIDERED COMPLETE WHEN THE FOLLOWING CONDITIONS HAVE BEEN MET:

a. ALL STRUCTURES HAVE BEEN BUILT.

b. ALL HARD SURFACES HAVE BEEN CONSTRUCTED.

c. ALL PROPOSED GRASED AREAS ARE EITHER SODDED OR HAVE A FULL COVERAGE OF WELL ESTABLISHED TURF AND HAVE HAD A MINIMUM OF ONE FULL GROWING SEASON (MAY 15TH TO SEPTEMBER 15TH).

d. THERE ARE NO AREAS OF EXPOSED EARTH.

2.6 REMOVE EROSION AND SEDIMENT CONTROL MEASURES WHEN CONSTRUCTION IS COMPLETE.

3. GRADING & DRAINAGE

3.1 NEW GRADES TO MATCH EXISTING AT PROPERTY LINE. NO EXCESS DRAINAGE WILL BE DIRECTED TOWARDS THE ADJACENT PROPERTIES DURING AND AFTER CONSTRUCTION. THERE WILL BE NO ALTERATION TO EXISTING GRADE AND DRAINAGE PATTERNS ON PROPERTY LINE.

3.2 ALL AREAS SHALL BE GRADED TO ENSURE ADEQUATE DRAINAGE AWAY FROM BUILDINGS TO CATCH BASINS, SWALES, DITCHES AND OTHER APPROVED DISPOSAL AREAS. GRADING SHALL BE GRADUAL BETWEEN FINISHED SPOT ELEVATIONS SHOWN ON DRAWINGS TO PREVENT PONDING (OTHER THAN PONDING REQUIRED FOR STORMWATER MANAGEMENT).

3.3 GEOTEXTILE FABRIC TO OPSS 1860. WOVEN SYNTHETIC FIBRE FABRIC SHALL BE USED IN SILT FENCE BARRIER. NON-WOVEN SYNTHETIC FIBRE FABRIC 1.75mm THICK, 200g/90cm, SHALL BE USED FOR MATERIAL SEPARATION. GEOTEXTILE FILTER FABRIC SHALL BE FREE OF TENDENCY TO DETERIORATE BY ULTRA-VIOLET AND HEAT EXPOSURE.

3.4 PLACE GEOTEXTILE MATERIAL BY UNROLLING ONTO GRADED SURFACE, SMOOTH AND FREE OF TENSION STRESS, FOLDS, WRINKLES AND CREASES. PLACE GEOTEXTILE MATERIAL ON SLOPING SURFACES IN ONE CONTINUOUS LENGTH FROM TOE OF SLOPE TO UPPER EXTENT OF GEOTEXTILE. OVERLAP OF GEOTEXTILE SHALL BE 300mm OVER PREVIOUSLY LAID STRIP IN DIRECTION OF FLOW. ALTERNATIVELY THE FABRIC MAY BE LAPPED A MINIMUM OF 300mm AND PINNED TOGETHER. PROTECT INSTALLED GEOTEXTILE MATERIAL FROM DISPLACEMENT, DAMAGE OR DEFORMATION BEFORE DURING AND AFTER PLACEMENT OF MATERIAL LAYERS AFTER INSTALLATION. COVER WITH OVERLAYING LAYER WITHIN 4 HOURS OF PLACEMENT. DURING DELIVERY AND STORAGE, PROTECT GEOTEXTILES FROM DIRECT SUNLIGHT, ULTRAVIOLET RAYS, EXCESSIVE HEAT, MUD, DIRT, DUST, DEBRIS AND ROCKS. VEHICULAR TRAFFIC NOT PERMITTED DIRECTLY ON GEOTEXTILE. AVOID PUNCTURING GEOTEXTILE. REPLACE DAMAGED OR DETERIORATED GEOTEXTILE.

4. SITE SERVICES

4.1 EXISTING SEWER SERVICE CONNECTIONS SHALL BE DECOMMISSIONED AS PER CITY OF OTTAWA STANDARDS S11.4.

4.2 CONNECTION TO WATERMAIN BY CITY OF OTTAWA FORCES, CONTRACTOR SHALL PROVIDE EXCAVATION, BACKFILL AND REINSTATEMENT.

4.3 THE WATER PRESSURE IS EXPECTED TO BE ABOVE 80 PSI. INSTALL A PRESSURE REDUCING VALVE (PRV) IN EACH BUILDING IMMEDIATELY AFTER THE WATER METER.

4.4 WATER METERS SHALL BE INSTALLED AS PER CITY OF OTTAWA DWG. NO. W31.

4.5 ALL WATER SERVICE MATERIALS AND CONSTRUCTION METHODS TO CITY OF OTTAWA STANDARDS AND ONTARIO PROVINCIAL STANDARDS SPECIFICATIONS (OPSS & OPSO). WATER SERVICES MATERIALS SHALL BE PEX TUBING SDR 11 TO AWWA C-904 TO CITY OF OTTAWA STANDARDS. METALLIC WARNING TAPE SHALL BE INSTALLED OVER ALL WATERMAINS.

4.6 PROVIDE THRUST BLOCKS AS PER CITY OF OTTAWA DWG. NO. W02.1 & W02.4 AT ALL VALVES, TEES, CAPS, BENDS, REDUCERS AND HYDRANTS OR OTHER FITTINGS WHERE CHANGES OCCUR IN PIPE DIAMETER OR DIRECTION. RESTRAINING AS PER AS PER CITY OF OTTAWA STANDARDS. RESTRAINT ROADS AND VALVE BOLTS TO BE STAINLESS STEEL. CATHODIC PROTECTION & ANODE INSTALLATION AS PER CITY OF OTTAWA DWG. NO. 40, 42, 44 & 47.

4.7 PROVIDE A MINIMUM 2.4 m COVER OVER WATER SERVICE CONNECTIONS AND WATERMAIN. WHERE THE MINIMUM COVER IS NOT POSSIBLE INSULATE AS PER CITY OF OTTAWA DWG. NO. W02.

4.8 WHERE LESS THAN 2.4 m CLEARANCE FROM AN OPEN STRUCTURE (EG. MANHOLES & CATCH BASINS) PLACE INSULATION AROUND WATERMAIN OR WATER SERVICE CONNECTIONS AS PER CITY OF OTTAWA DWG. NO. W03.

4.9 WATERMAIN OR 150mm WATER SERVICE INSTALLED PARALLEL TO A SEWER SHALL BE LAID WITH A MINIMUM 2.5m BARREL TO BARREL HORIZONTAL SEPARATION FROM SEWERS.

4.10 PEX WATER SERVICE CONNECTIONS INSTALLED PARALLEL TO A SEWER CONNECTION OF A SEWER SHALL BE CONSTRUCTED OF A SINGLE RUN OF PEX WITH NO JOINTS OR FITTINGS BETWEEN THE POINT OF CONNECTION AND THE CURB STOP AND BETWEEN THE CURB STOP AND THE INSIDE FACE OF THE BUILDING.

4.11 THE WATERMAIN (AND WATER SERVICE CONNECTIONS (LARGER) SHALL CROSS ABOVE THE SEWER AS PER CITY OF OTTAWA DRAWING NO. W02.2. PROVIDE A MINIMUM 250mm BARRELL TO BARRELL VERTICAL SEPARATION. IF IT IS NOT POSSIBLE FOR THE WATERMAIN TO CROSS ABOVE A SEWER THE WATERMAIN SHALL CROSS BELOW THE SEWER AS PER CITY OF OTTAWA DRAWING NO. W02.1. PROVIDE A MINIMUM 50mm BARREL TO BARREL VERTICAL SEPARATION AND ENSURE THAT THE WATER PIPE IS CENTERED AT THE POINT OF CROSSING SO JOINTS ARE AS FAR AS POSSIBLE FROM THE SEWER.

4.12 LOCATE FIRE HYDRANT (FH) IN CITY OF OTTAWA DWG. NO. W18. INSTALL FIRE HYDRANT AS PER CITY OF OTTAWA DWG. NO. W19. LOCATE FIRE HYDRANT FH-1 A MINIMUM 0.6m FROM EDGE OF SIDEWALK. LOCATE FIRE HYDRANT FH-2 2.0m FROM FACE OF CURB. LOCATE FIRE HYDRANT LEAD 2m FROM OUTSIDE EDGE OF CATCH BASINS AND MANHOLES. THERE SHALL BE NO VEGETATION OR OTHER OBSTRUCTIONS WITHIN 1.5m OF FIRE HYDRANT. THE FIRE HYDRANT SHALL BE RED WITH WHITE BONNETS AND CAPS TO CITY STANDARDS. AT THE END OF CONSTRUCTION PERFORM A FIRE FLOW TEST AND SUBMIT REPORT TO THE ENGINEER AND COLOUR CODE THE BONNETS AND CAPS AS PER CITY OF OTTAWA AND NTPA STANDARDS.

4.13 INSTALL CLEANOUTS ON THE STORM BUILDING DRAIN AND SANITARY BUILDING DRAIN AS CLOSE AS PRACTICAL TO THE WHERE THE SANITARY AND STORM DRAINS LEAVE THE BUILDING.

4.14 ALL SEWER MATERIALS AND CONSTRUCTION METHODS TO CITY OF OTTAWA STANDARDS AND ONTARIO PROVINCIAL STANDARDS SPECIFICATIONS (OPSS & OPSO). SEWER MATERIAL SHALL BE PVC SDR-35 (OR SDR-26 FOR DIAMETERS 150mm OR LESS) AND SHALL CONFORM TO CSA B182.2 AND SHALL HAVE BELL AND SPIGOT JOINTS WITH RUBBER GASKETS.

4.15 PROVIDE A MINIMUM 2.0m COVER OVER SEWERS. WHERE THE MINIMUM COVER IS NOT POSSIBLE INSULATE AS INDICATED AND AS PER DETAIL.

4.16 PERFORATED 250mm SUB-DRAINS SHALL BE HDPE. INTERIOR SMOOTH WALLED WITH FILTER SOCK; BOSS 2000 OR EQUAL.

4.17 LANDSCAPE CATCH BASINS (CB-Ts & CB-Ls) SHALL BE HDPE. INTERIOR SMOOTH WALLED PIPE "T" SECTION, 375mm IN DIAMETER, AND SHALL HAVE A CAST IRON FRAME AND COVER WITH THE COVER BOLTED TO THE FRAME AS PER CITY DRAWING S30 & S31.

4.18 MANHOLES & CATCH BASINS:

A. PRECAST MANHOLE UNITS: TO OPSS 1351 AND OPSO 701.010 WITH BASE SLAB OR MONOLITHIC BASE. TOP SECTIONS ECCENTRIC CONE OR FLAT LAB TOP TYPE WITH OPENING OFFSET FOR VERTICAL DRAIN INSTALLATION.

B. MANHOLE STEPS: TO OPSS 405.01

C. ADJUSTING RINGS: TO ASTM C 478M.

ALUMINUM SURFACES IN CONTACT WITH OR CAST INTO CONCRETE SHALL HAVE POLYETHYLENE ANODE INSULATING SLEEVES.

D. PRECAST CATCH BASIN SECTIONS: TO OPSS 1351

E. JOINTS: SHALL BE MADE WATERIGHT USING BUTYL BASED, FLEXIBLE WATERSTOP/JOINT SEALANT MATERIAL.

F. SANITARY SEWERS: BENCH TO PROVIDE A SMOOTH U-SHAPED CHANNEL PER OPSO 701.021. SLOPE INVERT TO ESTABLISH SEWER GRADE.

G. STORM SEWERS: MANHOLES SHALL HAVE A 300mm SLUMP AND CATCH BASINS AND DITCH INLETS SHALL HAVE A 600mm SLUMP.

FRAMES:

GRATES AND COVERS TO CITY OF OTTAWA DRAWINGS OR OPSO 401.010

GRATES AND COVERS TO BEAT EVENLY ON FRAMES. PAINTED WITH ONE SHIP COAT OF ASPHALT OR TAR BASE BLACK. ALL JOINTS AND CREVICES SHALL BE THOROUGHLY COATED.

I. GRANULAR BEDDING AND BACKFILL: OPSS GRANULAR A. RE-CYCLED GRANULAR MATERIALS ARE NOT PERMITTED.

1. PROVIDE MINIMUM 3m LONG, 150mm PERFORATED SUB-BASE WITH SUB-BASE MATERIAL TO DENSITY NOT LESS THAN 95% CORRECTED MAXIMUM DRY DENSITY.

2. ROOF DRAINS SHALL BE FLOW CONTROL TYPE EACH INSTALLED WITH A WER WITH A PARABOLIC SLOT. EACH SLOT SHALL RELEASE 5 LSPM/CM. WATER ROOF DRAIN WITH THRETS ACCORDING WITH RD-100-01 OR EQUAL. ROOF DRAINS SHALL BE INSTALLED AT THE LOW POINTS OF THE ROOF WHICH SHALL BE 150mm LOWER THAN THE PERIMETER OF THE ROOF. SCUPPERS SHALL BE INSTALLED ON THE ROOF WITH A MINIMUM DEPTH OF GUTTER ON THE ROOF EXCEEDING 140mm. REFER TO DRAWING C-6 FOR MINIMUM NUMBER OF SCUPPERS AND THE MINIMUM WIDTH. REFER TO ARCHITECTS PLAN FOR EXACT LOCATION AND DETAILS. THE ROOF SHALL BE DESIGNED FOR A 50mm DEPTH OF WATER AT THE SCUPPER (REFER TO STRUCTURAL ENGINEER).

4.21 RAINWATER LEADERS INSIDE MOTOR SPORTS WORLD BUILDING SHALL BE CONSTRUCTED WITH PVC PIPE WITH WELDED JOINTS AND THE LEADERS SHALL BE COVERED WITH WATERIGHT GASKETS. THE BOTTOM SHALL BE CONSTRUCTED TO WITHSTAND THE PRESSURE FROM A WATER COLUMN APPROXIMATELY 25 FT HIGH. CONDUCT A PRESSURE TEST ON THE SYSTEM AS PER THE MECHANICAL ENGINEER'S INSTRUCTIONS (SEE MECHANICAL).

4.22 THE INLET CONTROL DEVICES (ICD) LOCATED IN THE OUTLET PIPE OF CATCH BASIN / MANHOLE CB/MH-7 AND MANHOLE MH-10 SHALL BE HYDROVEX VHM-1 VERTICAL VORTEX FLOW REGULATORS AND MODEL C24 BY THE MANUFACTURER FOR A DISCHARGE RATE AS INDICATED ON PLAN. PRIOR TO INSTALLATION SUBMIT SHOP DRAWING TO ENGINEER FOR APPROVAL.

4.23 THE INLET CONTROL DEVICE (ICD) LOCATED IN THE OUTLET PIPE OF CATCH BASIN / MANHOLE CB/MH-3 SHALL BE PLUG STYLE WITH A WITH TRASH BASKET AND A ROUND ORIFICE MANUFACTURED BY PEDRO PLASTICS MANUFACTURED BY PEDRO PLASTICS (OR APPROVED EQUIVALENT BY PED) AND SIZED BY THE MANUFACTURER FOR A DISCHARGE RATE AS INDICATED ON PLAN. PRIOR TO INSTALLATION SUBMIT SHOP DRAWING TO ENGINEER FOR APPROVAL.

5. CONSTRUCTION

5.1 PRIOR TO COMMENCING WORK:

A. OBTAIN AND PAY FOR ALL NECESSARY PERMITS AND APPROVALS FROM THE AUTHORITIES.

B. SIZE, DEPTH AND LOCATION OF EXISTING SERVICES, UTILITIES AND STRUCTURES AS INDICATED ON THE DRAWINGS ARE FOR GUIDANCE ONLY. ALL EXISTING SERVICES, UTILITIES AND STRUCTURES ARE NOT NECESSARILY SHOWN ON THE DRAWINGS. COMPLETENESS AND ACCURACY ARE NOT GUARANTEED. NOTIFY APPLICABLE OWNERS, UTILITY COMPANIES AND AUTHORITIES HAVING JURISDICTION OF PROPOSED WORK AND LOCATE AND CLEARLY IDENTIFY ALL EXISTING SERVICES, UTILITIES AND STRUCTURES ON AND ADJACENT TO THE SITE. UNDERGROUND LOCATIONS (INCLUDING ONTARIO ONE CALL 1-800-400-4000) SHALL BE CONDUCTED PRIOR TO THE COMMENCEMENT OF ANY EXCAVATION. CONFIRM LOCATIONS OF BURIED SERVICES AND UTILITIES BY CAREFUL TEST EXCAVATIONS AND REPORT ANY DIFFERENCES TO THE ENGINEER.

C. EXISTING GRADE ELEVATIONS INDICATED ON THE DRAWINGS ARE FOR GUIDANCE ONLY. COMPLETENESS AND ACCURACY ARE NOT GUARANTEED. CONFIRM EXISTING GRADE ELEVATIONS AND REPORT ANY DIFFERENCES TO THE ENGINEER.

D. COORDINATE AND SCHEDULE WORK WITH THE AUTHORITIES AND OTHER TRADES.

E. SCHEDULE WORK TO PROVIDE THE MINIMUM DISRUPTION TO SERVICES.

5.2 MAINTAIN AND PROTECT FROM DAMAGE, SERVICES, UTILITIES AND STRUCTURES ENCOUNTERED.

5.3 PROTECT EXISTING BUILDINGS, TREES AND OTHER PLANTS, LAWS, FENCING, SERVICE POLES, WIRES, PAVEMENT, SURVEY BENCH MARKS AND MONUMENTS AND OTHER SURFACE FEATURES FROM DAMAGE WHILE WORK IS IN PROGRESS. DO NOT DISTURB SOIL WITHIN BRANCH SPREAD OF TREES OR SHRUBS THAT ARE TO REMAIN.

5.4 PROVIDE TRAFFIC CONTROL AND SAFETY MEASURES INCLUDING ANY NECESSARY PERSONNEL AND THE SUPPLY, INSTALLATION, REMOVAL AND REPLACEMENT OF ALL NECESSARY SIGNAGE AND BARRIERS AS REQUIRED BY THE AUTHORITIES. IF APPLICABLE, PROVIDE TRAFFIC MANAGEMENT PLAN AS PER CITY OF OTTAWA REQUIREMENTS.

5.6 REMOVE OBSTRUCTIONS, ICE AND SNOW, FROM SURFACES TO BE EXCAVATED.

5.7 CUT PAVEMENT AND / OR SIDEWALK NEATLY ALONG LIMITS OF PROPOSED EXCAVATION IN ORDER THAT SURFACE MAY BREAK EVENLY AND CLEARLY.

5.8 COORDINATE AND PAY FOR GEOTECHNICAL INSPECTIONS AND COMPACTION TESTS OF SUB-GRADE, PIPE BEDDING AND EACH LAYER OF SURROUNDING MATERIAL. BACKFILL, SUB-BASE, BASE AND ASPHALT TO THE SATISFACTION OF THE GEOTECHNICAL CONSULTANT AND ENGINEER. SUBMIT GEOTECHNICAL INSPECTIONS AND COMPACTION REPORTS TO ENGINEER.

5.9 CUT AND FILL AS NECESSARY TO ACHIEVE THE REQUIRED SUB-GRADE ELEVATION. DISPOSE OF SURPLUS AND UNSUITABLE EXCAVATED MATERIAL OFF SITE. FILL MATERIAL AND THE PLACEMENT AND COMPACTION OF THE FILL MATERIAL AS PER THE GEOTECHNICAL REPORT AND TO THE SATISFACTION OF THE GEOTECHNICAL CONSULTANT. STOCKPILE GRANULAR AND FILL MATERIALS IN MANNER TO PREVENT SEGRIGATION AND PROTECT FROM CONTAMINATION.

5.10 EXCAVATION, TRENCHING & BACKFILL:

A. SHORE AND BRACE EXCAVATIONS, PROTECT SLOPES AND BANKS AND PERFORM ALL WORK IN ACCORDANCE WITH ONTARIO REGULATION #2 UNDER THE ONTARIO OCCUPATIONAL HEALTH AND SAFETY ACT AND OTHER AUTHORITIES HAVING JURISDICTION.

B. KEEP EXCAVATIONS FREE OF WATER WHILE WORK IS IN PROGRESS. PROTECT OPEN EXCAVATIONS AGAINST FLOODING AND DAMAGE DUE TO SURFACE RUN-OFF.

C. EXCAVATION MUST NOT INTERFERE WITH BEARING CAPACITY OF ADJACENT FOUNDATIONS.

D. DO NOT OBSTRUCT FLOW OF SURFACE DRAINAGE OR NATURAL WATERCOURSES.

E. EXCAVATE TO LINES, GRADES, ELEVATIONS AND DIMENSIONS AS INDICATED ON THE DRAWINGS.

F. EARTH BOTTOMS OF EXCAVATIONS TO BE UNDISTURBED SOIL, LEVEL, FREE FROM LOOSE, SOFT OR ORGANIC MATERIAL.

G. ALL STRUCTURES WITHIN PAVED AREAS SHALL HAVE 4:1 FROST TAPERS FROM FROST LINE TO SUB-GRADE.

H. CORRECT OVER-EXCAVATION WITH GRANULAR A COMPACTED TO NOT LESS THAN 95% OF CORRECTED MAXIMUM DRY DENSITY.

I. SURGRADE AND AREAS TO BE BACKFILLED TO BE FREE FROM DEBRIS, SNOW, ICE, WATER AND FROZEN GROUND.

J. DO NOT USE BACKFILL MATERIAL WHICH IS FROZEN OR CONTAINS ICE, SNOW OR DEBRIS.

K. BEDDING AND SURROUND MATERIAL FOR SEWERS SHALL BE OPSS GRANULAR A. BEDDING AND SURROUND MATERIAL FOR WATERMAIN AND WATER SERVICE CONNECTIONS SHALL BE OPSS GRANULAR A OR OPSS GRANULAR M. RE-CYCLED GRANULAR MATERIALS ARE NOT PERMITTED.

L. DO NOT USE BEDDING, SURROUND OR BACKFILL MATERIAL WHICH IS FROZEN OR CONTAINS ICE, SNOW OR DEBRIS.

M. PIPE BEDDING SHALL BE 150mm THICK. SHAPE BED TRUE TO GRADE AND TO PROVIDE CONTINUOUS, UNIFORM BEARING SURFACE FOR PIPE.

N. PLACE SURROUND MATERIAL AROUND PIPES TO FILL WIDTH OF TRENCH AND TO 300mm ABOVE PIPES.

O. PLACE BEDDING AND SURROUND MATERIAL IN UNIFORM LAYERS NOT EXCEEDING 150mm COMPACTED THICKNESS. PLACE FILL AND BACKFILL MATERIAL IN UNIFORM LAYERS NOT EXCEEDING 300mm.

P. COMPACT EACH LAYER TO 95% OF CORRECTED DRY DENSITY BEFORE PLACING SUCCEEDING LAYER.

Q. DO NOT BACKFILL AROUND OR OVER CAST-IN-PLACE CONCRETE WITHIN 24 HOURS AFTER PLACING OF CONCRETE.

R. BACKFILL MATERIALS WITHIN 1.5m OF PROPOSED GRADE SHALL MATCH THE MATERIALS EXPOSED ON THE TRENCH WALLS. BACKFILL BELOW 1.5m OF THE PROPOSED CAN CONSIST OF EITHER ACCEPTABLE NATIVE MATERIAL, ROCK, OR IMPROVED GRANULAR MATERIALS CONFORMING TO CITY OF OTTAWA STANDARDS.

S. THE UPPER SURFACE OF THE ROCK FILL SHALL BE COVERED WITH 150mm LAYER OF COMPACTED, WELL GRADED CRUSHED STONE PLACED ON GEOTEXTILE FABRIC.

5.11 PIPES:

A. HANDLE PIPE USING METHODS APPROVED BY MANUFACTURER.

B. LAY, CUT AND JOIN PIPES IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS.

C. USE ONLY FITTINGS AS RECOMMENDED BY PIPE MANUFACTURER.

D. LAY PIPES ON PREPARED BED TRUE TO LINE AND GRADE AND ENSURE BARREL OF EACH PIPE IS IN CONTACT WITH SHAPED BED THROUGHOUT ITS FULL LENGTH, FREE OF SAGS OR HIGH POINTS.

E. DO NOT EXCEED MAXIMUM JOINT DEFLECTION RECOMMENDED BY PIPE MANUFACTURER.

F. WHENEVER WORK IS INTERRUPTED, INSTALL REMOVABLE WATERIGHT BULKHEAD AT OPEN END OF LAST PIPE LAID TO PREVENT ENTRY OF FOREIGN MATERIALS.

G. WHEN STOPPAGE OF WORK OCCURS, BLOCK PIPES TO PREVENT CREEP DURING DOWN TIME. MAKE WATERIGHT CONNECTIONS TO MANHOLES.

H. JOINTS SHALL BE STRUCTURALLY SOUND AND WATERIGHT.

I. REPAIR OR REPLACE PIPE, PIPE JOINT OR BEDDING FOUND DEFECTIVE.

5.12 SEWERS AND SEWER SERVICES:

A. CONSTRUCT SEWER TRENCHES AS PER CITY DWG S6 & S7.

B. RIGID STRUCTURES, INSTALL PIPE JOINTS NOT MORE THAN 1.2m FROM SIDE OF STRUCTURE.

C. MAINTAIN EXISTING SEWER FLOWS DURING CONSTRUCTION.

D. PERFORM FIELD TESTS FOR QUALITY CONTROL OF ALL SANITARY SEWERS. SPECIFICALLY, THE LEAKAGE TESTING SHALL BE COMPLETED IN ACCORDANCE WITH OPSS 410. A REPAIR AND RETEST SEWER LINE AS REQUIRED. REPAIR VISIBLE LEAKS RECONSTRUCT TWO JOINT INSPECTIONS OF SEWERS. FIRST INSPECTION AFTER COMPLETION OF CONSTRUCTION, SECOND INSPECTION IMMEDIATELY PRIOR TO END OF WARRANTY PERIOD. A PAN AND TILT CAMERA SHALL BE USED. REPAIR SEWER LINE AS REQUIRED. SUBMIT REPORT TO THE ENGINEER.

F. CONDUCT DYE TEST OF SANITARY SEWERS AND COORDINATE WITH ENGINEER. DYE TEST SHALL BE WITNESSED BY ENGINEER.

5.13 WATERMAIN AND 150mm WATER SERVICES:

A. INSTALL AND TEST TRACKER WIRE ON THE WATER SERVICE CONNECTION AS PER 4.3.12 OF THE CITY OF OTTAWA WATER DISTRIBUTION DESIGN GUIDELINES AND DRAWING W06.

B. PRESSURE TESTING AS PER AWWA C-605-05 AND CITY OF OTTAWA DESIGN GUIDELINES - WATER DISTRIBUTION SECTION 4.6.13.

C. CHLORINATION AS PER AWWA C-651-05 AND CITY OF OTTAWA DESIGN GUIDELINES - WATER DISTRIBUTION SECTION 4.6.13.

D. 4.13 & CITY DWG. NO. W06.

5.14 MANHOLES & CATCH BASINS:

A. JOINTS SHALL BE MADE WATERIGHT.

B. SET PRECAST CONCRETE BASE ON 150mm MINIMUM OF GRANULAR BEDDING COMPACTED TO 100% CORRECTED MAXIMUM DRY DENSITY.

C. MAKE EACH JOINT WATERIGHT WITH RUBBER RING GASKETS.

D. PLACE GRANULAR BACKFILL MATERIALS IN A UNIFORM LAYERS TO COMPACTED THICKNESS OF 150mm, COMPACT TO 95% CORRECTED MAXIMUM DRY DENSITY.

E. PLACE FRAME AND COVER ON TOP SECTION TO ELEVATION AS INDICATED. IF ADJUSTMENT REQUIRED USE CONCRETE RINGS TO A MAXIMUM OF 300mm.

F. CLEAN UNITS OF DEBRIS, FOREIGN AND SURPLUS MATERIALS. REMOVE FINIS AND SHARP PROJECTIONS. PREVENT DEBRIS FROM ENTERING SYSTEM.

G. PERFORM FIELD TESTS FOR QUALITY CONTROL OF ALL SANITARY SEWERS. SPECIFICALLY, THE LEAKAGE TESTING SHALL BE COMPLETED IN ACCORDANCE WITH OPSS 407.

5.15 MAINTAIN RECORD DRAWINGS AND RECORD ACCURATELY DEVIATIONS FROM THE ORIGINAL CONTRACT DOCUMENTS CAUSED BY SITE CONDITIONS AND CHANGES IN DESIGN. INSTRUCTIONS, UPDATE DAILY AND WEEKLY. MAKE CHANGES AVAILABLE ON-SITE FOR REVIEW THROUGHOUT THE CONSTRUCTION PERIOD. MARK CHANGES IN RED INK. RECORD CHANGES SHALL INCLUDE BUT NOT BE LIMITED TO CHANGES TO DIMENSIONS, DETAIL CHANGES TO GRADE ELEVATIONS, AND HORIZONTAL AND VERTICAL LOCATIONS OF UNDERGROUND SERVICES, UTILITIES AND APPURTENANCES REFERENCED TO A PERMANENT POINT OF REFERENCE. RECORD CHANGES TO THE DRAWINGS AT THE DATE OF CONSTRUCTION.

5.16 CONCRETE CURBS TO CITY OF OTTAWA DRAWING NO. SC1.1. CONCRETE SIDEWALK TO CITY OF OTTAWA DRAWING NO. S04.

5.17 REINSTATE ALL AREAS DISTURBED BY CONSTRUCTION. REINSTATE PAVEMENTS, CURBS AND SIDEWALKS, TO THICKNESS, STRUCTURE AND ELEVATION WHICH EXISTED BEFORE CONSTRUCTION. REINSTATE LANDSCAPED AREAS TO THE CONDITION AND ELEVATION WHICH EXISTED BEFORE CONSTRUCTION.

5.18 CLEAN AND REINSTATE AREAS AFFECTED BY THE WORK.

6. PAVEMENT

6.1 PAVEMENT STRUCTURE:

LIGHT DUTY PAVEMENT:

50mm HL-3 ASPHALTIC CONCRETE

200mm OPSS GRANULAR A BASE

RE-CYCLED GRANULAR MATERIALS ARE NOT PERMITTED.

HEAVY DUTY PAVEMENT:

40mm HL-3 OR SUPERPAVE 12.5 ASPHALTIC CONCRETE

65mm HL-8 OR SUPERPAVE 19.0 ASPHALTIC CONCRETE

150mm OPSS GRANULAR A BASE

300mm OPSS GRANULAR B TYPE II SUB-BASE

RE-CYCLED GRANULAR MATERIALS ARE NOT PERMITTED.

ASPHALTIC CONCRETE SHALL BE PERFORMANCE GRADE PG58-34.

HOT MIX ASPHALT MATERIALS SHALL BE ACCORDING TO OPSS 1150 OR 1151.

6.2 PAVEMENT SUB-GRADE WITH SUB-BASE MATERIAL, COMPACT TO 95% CORRECTED MAXIMUM DRY DENSITY NOT LESS THAN 100% CORRECTED MAXIMUM DRY DENSITY.

6.3 REMOVE ALL EXISTING ASPHALT AND HAIL TO A FACILITY APPROVED FOR ACCEPTING SUCH MATERIALS. REMOVE ALL WATER AND CONTAMINATION, SUCH AS MUD, LOOSE AGGREGATE OR DEBRIS AND SHALL BE DRY AND CLEAN WHEN THE TACK COAT IS APPLIED. TACK COAT SHALL BE PLACED SUFFICIENTLY AHEAD OF THE PAVING OPERATION TO ALLOW FOR CURING. PAVING AND CONSTRUCTION EQUIPMENT SHALL BE PERMITTED ONTO THE TACK COAT UNTIL IT HAS SET. TACK COAT MATERIAL SHALL CONSIST OF SS-1 EMULSIFIED ASPHALT DILUTED WITH AN EQUAL VOLUME OF WATER. THE UNDILUTED MATERIAL SHALL BE ACCORDING TO OPSS 1103.

6.4 FINISH SURFACE TO SMOOTH CONTOUR AND COMPACT TO NOT LESS THAN 95% CORRECTED MAXIMUM DRY DENSITY BEFORE BEGINNING PAVING OPERATIONS.

6.5 APPLY ASPHALTIC CONCRETE ONLY WHEN BASE OR PREVIOUS COURSE IS DRY AND AIR TEMPERATURE IS ABOVE 5 DEG C.

6.6 ROLL, UNTIL ROLLER MARKS ARE ELIMINATED AND COMPACTED TO NOT LESS THAN 95% OF DENSITY. COMPACT WITH HOT TAMPERS IN AREAS INACCESSIBLE TO A ROLLER. BEVEL EDGES ADJACENT TO GRANULAR SURFACES.

6.14 FINISH SURFACE SMOOTH, TRUE TO GRADE.

6.15 KEEP VEHICULAR TRAFFIC AND OTHER LOADS OFF NEWLY PAVED AREAS UNTIL 24 HOURS AFTER PAVING.

6.16 DRYLY UNUSED AND WASTE ASPHALT TO A FACILITY APPROVED FOR ACCEPTING SUCH MATERIALS.

6.17 APPLY TRAFFIC PAINT AS IDENTIFIED ON PLAN. TRAFFIC PAINT: NON-DARKENING, HOMOGENEOUS, UNIFORM AND SMOOTH, FREE FROM SKIN, DIRT AND OTHER FOREIGN PARTICLES. APPLY TO DRY PAVEMENT SURFACE FREE FROM FROST, ICE, DUST, OIL, GREASE AND OTHER FOREIGN MATERIALS. PROTECT PAVEMENT MARKINGS UNTIL DRY.

WATER SERVICE PROFILE TABLE					
MATERIAL: 200mm PVC PRESSURE CLASS 150 DR18					
"A" LINE					
STATION	DESCRIPTION	GRADE ELEV.	TOP OF PIPE	DEPTH OF COVER	COMMENTS
A+00.0	CONNECTION TO EXISTING 200mm PRIVATE WATERMAIN REMOVE EXISTING ELBOW AND REPLACE WITH 200mm X 200mm TEE TO CITY OF OTTAWA STANDARDS	95.84	±93.20	2.64m	-
A+00.3	200mm x 200mm TEE (EXISTING WS TO REMAIN) TO CITY OF OTTAWA STANDARDS	95.84	93.19	2.65m	-
A+002.2	-	95.82	93.18	2.64m	CROSSING 150 ST INV 93.88 TOP WM 93.18 - 500mm CLEARANCE (MIN. 500 REQ'D)
A+017.5	-	95.83	93.14	2.69m	-
A+025.8	-	95.82	93.11	2.71m	CROSSING 250 ST INV 94.14 TOP WM 93.11 - 100mm CLEARANCE (MIN. 500 REQ'D)
A+027.8	-	95.82	93.10	2.72m	CROSSING 150 ST INV 94.14 TOP WM 93.10 - 1040mm CLEARANCE (MIN. 500 REQ'D)
A+031.0	45 DEG BEND TO CITY OF OTTAWA STANDARDS	95.82	93.09	2.73m	-
A+035.2	-	95.89	93.09	2.80m	CROSSING 200 SAN INV 93.85 TOP WM 93.09 - 500mm CLEARANCE (MIN. 500 REQ'D)
A+038.2	-	95.93	93.09	2.84m	CROSSING 375 ST INV 93.59 TOP WM 93.09 - 500mm CLEARANCE (MIN. 500 REQ'D)
A+057.9	45 DEG BEND TO CITY OF OTTAWA STANDARDS	95.91	93.20	2.71m	-
A+08.2 (B+000.0)	200mm x 150mm TEE (TO PROPOSED BUILDING) TO CITY OF OTTAWA STANDARDS	96.04	93.25	2.79m	-
A+070.2	45 DEG BEND TO CITY OF OTTAWA STANDARDS	96.06	93.26	2.80m	-
A+073.7	-	96.00	93.28	2.72	CROSSING 300 ST INV 93.78 TOP WM 93.28 - 500mm CLEARANCE (MIN. 500 REQ'D)
A+075.9	-	95.97	93.32	2.65m	CROSSING 200 SAN INV 93.88 TOP WM 93.32 - 560mm CLEARANCE (MIN. 500 REQ'D)
A+079.4	45 DEG BEND TO CITY OF OTTAWA STANDARDS	96.08	93.39	2.69m	-
A+094.8	-	96.51	93.71	2.80m	-
A+141.9 (C+000.0)	50mm TAPPED COUPLING OR SERVICE SADDLE AS PER CITY OF OTTAWA DWG W33 (TO PROPOSED BUILDING)	98.43	95.33	3.10m	-
A+142.7	45 DEG BEND TO CITY OF OTTAWA STANDARDS	98.48	95.33	3.15m	-
A+143.6 (D+000.0)	200mm TO 150mm REDUCER TO CITY OF OTTAWA STANDARDS	98.56	95.37	3.19m	-
MATERIAL: 150mm PVC PRESSURE CLASS 150 DR18					
"B" LINE					
STATION	DESCRIPTION	GRADE ELEV.	TOP OF PIPE	DEPTH OF COVER	COMMENTS
B+00.0 (A+08.2)	200mm x 150mm TEE (TO PROPOSED BUILDING) TO CITY OF OTTAWA STANDARDS	96.01	93.23	2.78m	-
B+02.0	150mm VALVE & VALVE BOX AS PER CITY OF OTTAWA DRAWING NO. W24	96.06	93.23	2.83m	-
B+06.0	-	96.15	93.34	2.81m	BOTTOM OF CURB
B+7.7	-	96.33	93.37	2.96m	ENTRY INTO BUILDING
MATERIAL: 50mm PEX TUBING TO AWWA C-904 SDR 9 (CTS)					
"C" LINE					
STATION	DESCRIPTION	GRADE ELEV.	TOP OF PIPE	DEPTH OF COVER	COMMENTS
C+00.0 (A+141.9)	50mm TAPPED COUPLING OR SERVICE SADDLE AS PER CITY OF OTTAWA DWG W33 (TO PROPOSED BUILDING)	98.43	95.33	3.10m	-
C+01.0	50mm CURB STOP & SERVICE POST TO CITY OF OTTAWA STANDARDS	98.40	95.32	3.08m	-
C+05.4	-	98.26	95.29	2.97m	CROSSING 300 STM INV 95.79 TOP WM 95.29 - 500mm CLEARANCE (MIN. 500 REQ'D)
C+05.4	-	98.05	95.29	2.76m	BOTTOM OF CURB
C+12.5	-	98.19	95.29	2.90m	ENTRY INTO BUILDING
MATERIAL: 150mm PVC PRESSURE CLASS 150 DR18					
"D" LINE					
STATION	DESCRIPTION	GRADE ELEV.	TOP OF PIPE	DEPTH OF COVER	COMMENTS
D+00.0 (A+143.6)	200mm TO 150mm REDUCER TO CITY OF OTTAWA STANDARDS	98.56	95.37	3.19m	-
D+01.6	150mm VALVE & VALVE BOX AS PER CITY OF OTTAWA DRAWING NO. W24	98.63	95.45	3.18m	-
D+04.8	FIRE HYDRANT TO CITY OF OTTAWA STANDARDS	98.96	95.61	3.35m	-

CATCH BASIN & MANHOLE SCHEDULE						
REF	TOP	SIZE	TYPE	INVERT AT INLET	INVERT AT OUTLET	NOTES
STORM SEWER						
CB-0	97.95	600 x 600mm	PRE-CAST CONCRETE CATCH-BASIN	-	96.70	TO OPSD 705.010 & CITY OF OTTAWA STANDARDS FRAME & COVER CITY DWG No. 519.1
CB/MH-1	98.00	1200mm	PRE-CAST CONCRETE CATCH-BASIN/ MANHOLE	96.23(NW)	95.84(SE)	TO OPSD 701.010 & CITY OF OTTAWA STANDARDS - FRAMES & COVERS CITY DWG No. 525 & S28.1 OR OPSD 401.010
MH-2	98.14	1200mm	PRE-CAST CONCRETE MANHOLE	95.78(NW)	95.75(S)	TO OPSD 701.010 & CITY OF OTTAWA STANDARDS - FRAMES & COVERS CITY DWG No. 525 & S24.1 OR OPSD 401.010
CB/MH-3	97.01	1200mm	PRE-CAST CONCRETE CATCH-BASIN/ MANHOLE	94.90(N)	94.65(E)	TO OPSD 701.010 & CITY OF OTTAWA STANDARDS EXCEPT WITH A 900mm SUMP - FRAMES & COVERS CITY DWG No. 525 & S24.1 OR OPSD 401.010 INSTALL ICD IN OUTLET PIPE
MH-4	96.32	1200mm	PRE-CAST CONCRETE MANHOLE	93.85(N)	93.84(S)	TO OPSD 701.010 & CITY OF OTTAWA STANDARDS - FRAMES & COVERS CITY DWG No. 525 & S24.1 OR OPSD 401.010
CB-5	95.27	600 x 600mm	PRE-CAST CONCRETE CATCH-BASIN	-	94.07	TO OPSD 705.010 & CITY OF OTTAWA STANDARDS FRAME & COVER CITY DWG No. 519.1
MH-6	95.75	1200mm	PRE-CAST CONCRETE MANHOLE WITH WATERTIGHT LID	93.69(N)	93.63(W)	TO OPSD 701.010 & CITY OF OTTAWA STANDARDS - FRAMES & COVERS CITY DWG No. 525 & S24.1 OR OPSD 401.010
CB/MH-7	95.65	1200mm	PRE-CAST CONCRETE CATCH-BASIN/ MANHOLE	94.370(E)	94.10(N)	TO OPSD 701.010 & CITY OF OTTAWA STANDARDS EXCEPT WITH A 900mm SUMP - FRAMES & COVERS CITY DWG No. 525 & S24.1 OR OPSD 401.010 INSTALL ICD IN OUTLET PIPE
CB/MH-8	95.75	1200mm	PRE-CAST CONCRETE MANHOLE	-	93.88	TO OPSD 701.010 & CITY OF OTTAWA STANDARDS - FRAMES & COVERS CITY DWG No. 525 & S24.1 OR OPSD 401.010
CB-9	95.67	600 x 600mm	PRE-CAST CONCRETE CATCH-BASIN	-	94.06	TO OPSD 705.010 & CITY OF OTTAWA STANDARDS FRAME & COVER CITY DWG No. 519.1
MH-10	95.90	1200mm	PRE-CAST CONCRETE MANHOLE	93.87(N) 93.67(E) 93.67(W)	93.67(S)	TO OPSD 701.010 & CITY OF OTTAWA STANDARDS EXCEPT WITH A 900mm SUMP - FRAMES & COVERS CITY DWG No. 525 & S24.1 OR OPSD 401.010 INSTALL ICD IN OUTLET PIPE
CB-11	95.40	600 x 600mm	PRE-CAST CONCRETE CATCH-BASIN	-	93.95	TO OPSD 705.010 & CITY OF OTTAWA STANDARDS FRAME & COVER CITY DWG No. 519.1
CB/MH-12	95.40	1200mm	PRE-CAST CONCRETE CATCH-BASIN/ MANHOLE	93.92(S) 93.74(N)	93.73(E)	TO OPSD 701.010 & CITY OF OTTAWA STANDARDS - FRAMES & COVERS CITY DWG No. 525 & S28.1 OR OPSD 401.010
MH-13	95.48	SOLENO AQUA-SWIRL AS-4	OIL & GRIT SEPARATOR HDPE MANHOLE	93.43(E)	93.42(W)	-
MH-14	95.17	1200mm	PRE-CAST CONCRETE MANHOLE	93.39(E) ±93.34(S)	±93.33(N)	TO OPSD 701.010 & CITY OF OTTAWA STANDARDS - FRAMES & COVERS CITY DWG No. 525 & S24.1 OR OPSD 401.010
CB/MH-15	95.65	1200mm	PRE-CAST CONCRETE CATCH-BASIN/ MANHOLE	93.92(NE)	93.92(S)	TO OPSD 701.010 & CITY OF OTTAWA STANDARDS - FRAMES & COVERS CITY DWG No. 525 & S28.1 OR OPSD 401.010
CB-16	95.72	600 x 600mm	PRE-CAST CONCRETE CATCH-BASIN	-	93.97	TO OPSD 705.010 & CITY OF OTTAWA STANDARDS FRAME & COVER CITY DWG No. 519.1
SANITARY SEWER						
MH-SA-1	98.26	1200mm	PRE-CAST CONCRETE MANHOLE	95.45(W)	95.39(S)	TO OPSD 701.010 & CITY OF OTTAWA STANDARDS - FRAMES & COVERS CITY DWG No. 525 & S24 OR OPSD 401.010
MH-SA-2	96.27	1200mm	PRE-CAST CONCRETE MANHOLE	94.27(NW) 93.93(N)	93.92(S)	TO OPSD 701.010 & CITY OF OTTAWA STANDARDS - FRAMES & COVERS CITY DWG No. 525 & S24 OR OPSD 401.010
MH-SA-3	95.78	1200mm	PRE-CAST CONCRETE MANHOLE WITH WATERTIGHT LID	93.78(N)	93.72(W)	TO OPSD 701.010 & CITY OF OTTAWA STANDARDS - FRAMES & COVERS CITY DWG No. 525 & S24 OR OPSD 401.010
MH-SA-4	95.49	1200mm	PRE-CAST CONCRETE MANHOLE	93.47(E)	93.44(SW)	TO OPSD 705.010 & CITY OF OTTAWA STANDARDS - FRAMES & COVERS CITY DWG No. 525 & S24 OR OPSD 401.010

REFER TO DETAILS ON DRAWINGS C-6 & C-7