



May 12, 2022

Our File Ref.: 180357

De Saulniers Construction Ltd.  
1120 Marleau Ave.  
Cornwall, ON K6H 2W8

Attention: Christian Mercer

Subject: **Grading Plan Review**  
Proposed New Building – 2020 Bantree Street, Ottawa ON.

LRL Associates Ltd. (LRL) Geotechnical Services has been retained for a Grading Plan review for the proposed building, to be located at 2020 Bantree Street, Ottawa ON.

The grading plan generated by LRL, dated May 12, 2022 was reviewed as part of this desktop study.

As specified in the Geotechnical Report generated for this site, the maximum grade raise allowance is 2.0 m above existing grade.

**After review of the grading plan, it was determined that the site's proposed grades are in compliance with the grade raise restrictions.**

For any questions or concerns pertaining to this memo, please do not hesitate to reach out to the undersigned

Yours truly,  
LRL Associates Ltd.

A handwritten signature in blue ink, appearing to read "B. Johnson", is written over a faint circular stamp.

Brad Johnson, P.Eng.  
Geotechnical Engineer

