

City of Ottawa
Development Review (South Services)
Planning, Real Estate and Economic Development Department
110 Laurier Avenue West, 4th Floor
Ottawa, Ontario
K1P 1J1

October 12, 2022

Project #	Client Reference:
60648725	N/A

**Attn: Kelby Lodoen Unseth MCIP, RPP
Planner II**

**Subject: 2625 Sheffield Road
Ottawa, Ontario
Site Lighting Certificate**

Dear Madam:

This letter is to confirm that the exterior site lighting has been designed to meet the following criteria:

- (i) Has been designed using only fixtures that meet the criteria for full cut-off (sharp cut-off) classification, as recognized by the Illuminating Engineering Society of North America (IESNA).
- (ii) Has been designed with light spillage onto adjacent properties of 0.5 fc maximum spillage.
- (iii) The Owner acknowledges and agrees that, upon completion of the lighting Works and prior to the City releasing any associated securities, the Owner shall provide certification satisfactory to the General Manager, Planning, Real Estate and Economic Development, from a Professional Engineer, licensed in the Province of Ontario, that the site lighting has been constructed in accordance with the Owner's approved design plan.

Should you require any further information, please do not hesitate to contact the undersigned at your earliest convenience.

Sincerely,
AECOM Canada Ltd.



Yehuda Adams, P.Eng
Senior Electrical Engineer
AECOM
(905) 215-1320
yehuda.adams@aecom.com