



16 December 2022

VIA Email

City of Ottawa

Development Review Rural Services
Planning, Infrastructure and Economic Development Department

**Re: Iridian Spectral Technologies
2700 Swansea Crescent, Ottawa**

This letter is to confirm that the exterior light fixtures used for this project meet the criteria for full cut-off classification as recognized by the IESNA and that the resulting light spillage onto adjacent properties is below the maximum allowable spillage (0.5 fc) by City of Ottawa Standards.

If you have any further questions or require any further clarification, please contact me at your earliest convenience.

Yours Truly,

Arborus Consulting

A handwritten signature in black ink, appearing to read 'Robin Hutcheson', written in a cursive style.

Robin Hutcheson, P.Eng., LEED AP CxA
President



309 FIRST AVE
OTTAWA, ON K1S 2G7

613-612-6821

ARBORUS.CA