



## Smith + Andersen

1600 Carling Ave Suite 530 Ottawa Ontario K1Z 1G3  
613 230 1186 f 613 230 2598 [smithandandersen.com](http://smithandandersen.com)

2022-10-17

### City of Ottawa

Infrastructure Services and Community Sustainability  
110 Laurier Avenue West  
Ottawa, ON  
K1P 1J1

**Attention: City Building Official**

**RE: SITE LIGHTING CERTIFICATE  
50 THE DRIVEWAY  
OTTAWA, ONTARIO, K2P 1E2**

Dear City Building Official:

This letter is to confirm that the exterior light fixtures used for this project meet the criteria for full cut-off classification as recognized by the IESNA and that the resulting light spillage onto adjacent properties is below the maximum allowable spillage (0.5 fc) by City of Ottawa Standards.

Yours truly,

SMITH + ANDERSEN

Mike Leong, P.Eng.  
Senior Associate

C.C. Mohamud Abdi, Smith + Andersen

