$m{b}$ hammerschlag & Joffe

h

February 23, 2023

City of Ottawa Planning & Growth Management 100 Constellation Crescent Nepean, Ontario K2G 6J8

Attention: Chief Building Official

Re: Orleans Gardens

1615 Orleans Boulevard

Ottawa, Ontario

Application #PC2022-0209 Our Reference #22-000-257

To whom it may concern,

In regards to the Site Plan Control Approval Application, we advise that the site lighting has been designed at the above mentioned Site Development and meets the following criteria:

- Lighting has been designed using Full Cut-Off (Sharp cut-off) Classification as recognized by IESNA or IES.
- Lighting has been designed to minimize lighting spillage onto adjacent properties with a maximum of 0.5FC allowable as per City of Ottawa requirements.

Please do not hesitate to contact us for any further clarification.

Yours very truly,

HAMMERSCHLAG & JOFFE INC.

Marang

Mark Hammerschlag, P.Eng. /at

