

Memo #1

Mataj Architects Inc.

| | 4 | INT BUILDING ROAD AND CODD'S ROAD OT | · AWA | |
|---|--|--|--|---------------------|
| DATE: 2023-01-16 | | | | |
| Confirmation on p | rotection re | quirements: | | |
| construction with r materials as permi connection and a | non-combut tted by the utomatic sp | ach building proposed for stible exterior cladding. Th OBC classification. Each b orinkler protection in confo ons, please contact the u | e construction will have building will be equippe ormance with NFPA13. | limited combustible |
| | | | | |
| Prepared by Eva Mo Principal Mataj Architects Inc. | | ASSOCIATION OF ARCHITECTS Z ETLEVA GUFAKUGI MATAJ LICENCE 7609 | | |
| Distribution: | | | | |
| Company: | | | | |
| Name: City of Ottaw | /a | Contact: Rod Price | Email: rod@demarcocon | astruction.ca |
| | | | | |
| Delivered by: | | | | |
| □ Fax | ■ Email | ☐ Courier | □ Mail | □ Hand |