

- GUIDE PLATE ANCHOR

- 35M LIFTING ANCHOR

8 REQUIRED


8 REQUIRED

TANK #1 - SECTION VIEW A-A

0.08m

---- KNOCKOUT PANEL

TANK #1 - SECTION VIEW B-B



ACCESS HATCH


INSULATION

MUD SLAB

ALL AROUND

NATIVE SOIL -

AREA PER W51



- 1. CONTRACTOR TO COORDINATE PRE-CAST WATER HOLDING TANKS 68500L MODEL OR EQUIVALENT SHOP DRAWINGS WITH THE MANUFACTURE. 2. ELECTRICAL CONTRACTOR TO CARRY OUT FINAL COORDINATION FOR TIE IN POINTS FOR THE FLOATS PER THE SHOP DRAWINGS PROVIDED BY
- TANK MANUFACTURER. 3. CONTRACTOR TO REFERENCE STRUCTURAL PLAN S150 FOR THE UNDER TANK BASE MATERIAL STRUCTURE DETAILS.
- 4. ENSURE CLEAR, MONOMERIC SILANE SEALER (SIKAGARD® SN-100) COATING, TO PROTECT THE TANKS FROM SOIL CORROSION. TO BE
- 5. CONTRACTOR TO ENSURE PIPE CONNECTION BETWEEN TANKS TO BE MINIMUM 600mm DISTANCE BETWEEN OUTER WALL OF TANKS AND PIPE TO

APPLICATED TO THE TANKS BY THE MANUFACTURE BEFORE DELIVERY TO SITE. ANY TOUCH-UP TO BE PROVIDED BY THE MANUFACTURE.

- BE MINIMUM 200mm SDR 35 PVC PIPE.
- 6. PROPOSED PIPE FITTINGS TO BE DIXON NORTH LINE STORZ OR EQUIVALENT. 7. UNITS ARE SEALED WITH BUTYL TAPE AT THE JOINTS.
- CONTRACTOR TO ENSURE CRANE IS ON-SITE TO OFFLOAD AND SET TANK. 9. EXCAVATION MUST BE READY FOR INSTALL.

DESIGN GWL 86.00

ZONE 1 DSC PANEL

EL. ±86.35

EL. ±85.85

- LOW WATER ALARM TO

- OUTSIDE OF TANK ±84.00

WATER ALARM TO ZONE 50mm RIGID -

INSULATION

MUD SLAB

NATIVE SOIL -

- 10. MIN OVERHEAD CLEARANCE OF 5.5m IS REQUIRED.
- 11. ALL UNITS MUST BE HANDLED WITH PROPER LIFTING EQUIPMENT. 12. TANK DESIGNED FOR A MAXIMUM FILL COVER DEPTH OF 1000mm, MINIMUM ENGINEERING FILL DEPTH OF 350mm.
- 13. TUF-TITE SAFETY LIDS WITH LOCKING CLIP INSTALLED IN ALL OPENINGS AS PER CSA-B66-21.

ELECTRICAL NOTES

DSC SECURITY PANEL

- 1. PROVIDE A DSC SERIES SECURITY PANEL INSTALLED IN IT ROOM. CONTRACTOR TO REVIEW AND COORDINATE WITH OWNER REQUIREMENTS. PROVIDE 120VAC POWER TO THE NEW DSC SERIES SECURITY PANEL FROM IT TOOM PANEL BOARD. PROVIDE COMMUNICATIONS CONNECTION TO
- 2. PROVIDE ALARM TIE FROM DSC MONITORING PANEL INTO THE BUILDING AUTOMATION SYSTEM AND SECURITY SYSTEM RACKS LOCATED IN THE IT ROOM, COMPLETE WITH CAT5E CABLING IN CONDUIT.
- 3. CONTRACTOR TO COORDINATE ALL WORKS WITH HONI AND TO REVIEW THE SITE TO UNDERSTAND THE HONI'S REQUIREMENTS.

LOW LEVEL FLOATS

- 4. PROVIDE TWO (2) ITT FLYGT ENM 10 FLOATS FOR TANK RESERVOIR (MAIN TANK WITH ACCESS HATCH). FLOATS TO BE COMPLETE WITH STAINLESS STEEL SWAY RINGS AND STAINLESS-STEEL HOOKS FOR CABLE SLACK. PROVIDE 1.0m OF FLOAT CABLE SLACK; WRAP SLACK CABLE AROUND STAINLESS-STEEL HOOKS NEAR JUNCTION BOX. FLOATS AND SLACK CABLE TO BE ACCESSIBLE FROM THE LADDER. REFER TO TANK DETAILS FOR FLOAT ELEVATIONS. **JUNCTION BOX**
- 5. PROVIDE A NEMA 4X PVC JUNCTION BOX EQUIPPED WITH BACK PANEL AND TERMINAL BLOCKS FOR THE FIELD AND FLOAT WIRE TERMINATION. 6. MOUNT JUNCTION BOX JUST BELOW THE OPEN HATCH AREA BUT ABOVE THE MAXIMUM WATER LEVEL. **CONDUITS AND WIRING**
- 7. PROVIDE ONE (1) 53mm PVC CONDUIT COMPLETE WITH 2-PAIR 18AWG RWU 90 WIRING FROM THE IT ROOM TO EACH WATER RESERVOIR. PROVIDE SUFFICIENT NUMBER OF CONDUCTORS TO SUIT PLUS 25% SPARE.

CITY OFS COMMENTS 08/06/23 RE-ISSUED FOR CITY SITE PLAN APPROVAL CITY SITE PLAN APPROVAL ISSUED FOR CITY SITE PLAN APPROVAL 21/12/22 RE-ISSUED FOR CITY SITE PLAN APPROVAL ISSUED FOR CITY SITE PLAN APPROVAL 06/04/22 ISSUED FOR CLIENT REVIEW 04/04/22

THESE DRAWINGS HAVE BEEN PRODUCED BY J.L. RICHARDS & ASSOCIAT LIMITED AND ARE SUBJECT TO COPYRIGHT AND USE RESTRICTIONS SET O IN THE APPLICABLE PROJECT CONTRACT, ANY USE, REUSE, OR MODIFICATI OF THESE DRAWINGS FOR PURPOSES OTHER THAN THE ORIGINAL PROJE OR EXECUTION OF THE DESCRIBED WORK IS NOT PERMITTED OR ENDORSE WITHOUT THE PRIOR WRITTEN AUTHORIZATION OF JLR. JLR MAKES NO WARRANTIES, EITHER EXPRESS OR IMPLIED, OF THE SUITABILITY OR FITNES: OF THESE DRAWINGS FOR ANY OTHER PURPOSE, AND ANY PARTY WHICH CHOOSES TO USE, MODIFY, OR OTHERWISE RELY ON THESE DRAWING WITHOUT JLR'S AUTHORIZATION ACCEPTS THESE LIMITATIONS AND DOES S

ISSUE / REVISION

VERIFY SHEET SIZE AND SCALES. THE BAR TO THE RIGHT IS 25mm IF THIS IS A FULL SIZE DRAWING.

AT THEIR SOLE RISK AND WITHOUT LIABILITY TO JLR.

- 0.61mx0.61m OPENING

HATCH PER W51.

ALL AROUND

FOR ALUMINIUM ACCESS

APPROVED

By Adam Brown at 3:08 pm, Jul 25, 2023

NAGER, DEVELOPMENT REVIEW - RURAL

DEPARTMENT, CITY OF OTTAWA



HYDRO ONE OPERATIONS CENTRE, S ORLEANS

3440 FRANK KENNY ROAD

TANK DETAILS

DESIGN: M.D. DRAWN: G.C. CHECKED: D.U. C-009

PLOT DATE: July 20, 2023 1:59:50 PM

— 24" X 12" TUFF- TITE

RISER WITH COVER

TANK #1 - TOP VIEW

3 REQUIRED

JLR #: 31500-000