

August 16, 2022

To whom it may concern
Building Official II, Permit Approvals
City of Ottawa
110 Laurier Ave. West,
Ottawa (Ontario) K1P 1J1

Subject: **Site Lighting Certification | Colizza Bruni – 38 units**
2262 Braeside Avenue, Ottawa, Ontario, K1H 7J6.
COSMEL N°: KK22-013

Ms. Cooper,

The following is to confirm that the proposed site lighting design for the above-mentioned project will comply with the City of Ottawa standards demanding a full cut-off classification fixtures and minimal light spillage (maximum 5.4lux or 0.5fc) on adjacent properties.

If further information is required, please contact us without hesitation. We trust you find the above acceptable.

Sincerely,

Frederic Bernard, ing. P.Eng.

Electrical Division
T 819.205.3283 ext.107
F 819.205.3284
C 819.500.0651
frederic.bernard@cosmel.ca