



Stormwater Management - Grading & Drainage - Storm & Sanitary Sewers - Watermains

700 Long Point Circle  
Ottawa, Ontario K1T 4E9

613-425-8044  
d.gray@dbgrayengineering.com

REVISÉ      June 14, 2023  
December 7, 2023

2167 McGee Side Road  
Office / Warehouse Building  
Ottawa, Ontario

## FIRE FLOW CALCULATIONS FUS Method

RFF = Required Fire Flow in litres per minute  
=  $220CA^{0.5}$

C = Construction Coefficient related to the type of construction of the building  
= 1.0      Type III      Ordinary Construction

A = Total Effective Floor Area in square meters of the building

Mezzanine:	218	100%	218	sq.m
Ground Floor:	1,635	100%	1,635	sq.m
	1,853		1,853	sq.m Total Effective Floor Area

RFF = 9,470 L/min  
= 9,000 L/min (rounded to nearest 1,000 L/min)

Occupancy and Contents Adjustment Factor  
15%      Limited Combustible Contents  
= 1,350 L/min Occupancy and Contents Adjustment Factor

RFF = 10,350 L/min

Automatic Sprinkler Protection Credit  
0%      Sprinkler system designed, installed and maintained in accordance with NFPA standards  
0%      Standard water supply for both the sprinkler system and fire department hose lines  
= 0 L/min Automatic Sprinkler Protection Credit

### Exposure Adjustment Charge

Side	Charge	Distance	Construction	Length	Storeys	Factor
North	0%	over 30 m				0
East	0%	over 30 m				0
South	0%	over 30 m				0
West	0%	over 30 m				0

\* with unprotected openings

0%      Exposure Adjustment Charge  
= 0 L/min Exposure Adjustment Charge

RFF = 10,350 L/min  
= 10,000 L/min (rounded to nearest 1,000 L/min)

Required duration of fire flow  
= 2.0 hours as per Table 1 (FUS 2020)

Required water supply  
= 1,200,000 L