ZONING CONFIRMATION REPORT CHECKLIST – September 26, 2024

Project Information					
Review Date	September 27,	Official Plan	Suburban, Evolving Neighbouhood		
	2024	Designation			
Municipal	2983 Navan	Legal	PART OF LOT 6, CONCESSION 3, OTTAWA		
Address	Road	Description	FRONT, GLOUCESTER, PARTS 2 AND 3		
		-	PLAN 5R-4675, PART 3 PLAN 5R-7985,		
			PART 4 PLAN 5R-11005, EXCEPT PARTS		
			13, 14 AND 16 PLAN 4R-21265, EXCEPT		
			PARTS 1 TO 7 EXPROPRIATION PLAN		
			OC1834435 CITY OF OTTAWA		
Scope of Work	Development of a vacant parcel of land for a commercial block with a gas bar,				
	commercial building and car wash.				
Existing	GM[2546]H[14.5]	By-law	2008-250		
Zoning Code		Number			
Schedule 1/1A	Area C;	Applicable	N/A		
Area	Surbuban(East)	Overlays			

Zoning Review						
Provision	Required	Provided	Compliance			
Permitted Land Use(s)	Convenience Store Drive-Through Facility Restaurant Retail Store Car Wash Gas Bar	Commercial Building, Gas Bar, Drive Through, Car Wash	Yes			
Maximum building height	14.5m as per the H[14.5] exception	5.5m	Yes			
Minimum rear yard setback Abutting a residential zone	7.5m	7.5m	Yes			
Minimum front yard and corner yard setbacks	3.0m	3.0m	Yes			
For a residential use building higher than 11 meters	3.0m	3.0m	Yes			
Minimum interior side yard setbacks for a non-residential or mixed use building from any portion of a lot line abutting a residential zone	5.0m	5.0m	Yes			
Maximum floor space index	2.0	0.1	Yes			

Minimum width of	3.0m	3.0m	Yes
landscaped area			
Abutting a street			
Abutting a			
residential or			
institutional zone			
Parking Space	Convenience Store: 3.4 Cars per	61 spaces provided	Yes
Requirements	100sm of GFA = 9 spaces		
(table 101)			
	Fast-Food Restaurant: 10 cars per		
	100sm of GFA = 34 spaces		
Outdoor Waste Management (Section 110(3)(c)	All outdoor refuse collection and refuse loading areas contained within or accessed via a parking lot must be: (a) located at least 9.0 metres from a lot line abutting a public street; (b) located at least 3.0 metres from any other lot line; and (c) screened from view by an opaque screen with a minimum height of 2.0 metres		Yes

We trust that the above Zoning Confirmation Report Checklist will satisfy the City's requirements. Should have any questions related to the information provided above, please feel free to contact the undersigned.

Yours very truly,

J.L. RICHARDS & ASSOCIATES LIMITED

Prepared by:

Madelen Fellows Planner Reviewed by:

Timothy F. Chadder, RPP, MCIP Senior Consultant, Associate

MF:tc