



Geotechnical Investigation

Proposed Site Redevelopment
5546 Albion Road South
Ottawa, Ontario
Revision 1

Prepared for:

MacEwen Petroleum Inc.
18 Adelaide Street
Maxville ON
K0C 1T0

LRL File No.: 001348

June 2022, *Revised November, 2023*



TABLE OF CONTENTS

1	INTRODUCTION	1
2	SITE AND PROJECT DESCRIPTION	1
3	PROCEDURE	1
4	SUBSURFACE SOIL AND GROUNDWATER CONDITIONS	2
4.1	General	2
4.2	Topsoil.....	2
4.3	Pavement Structure	2
4.4	Fill Material.....	2
4.5	Sand.....	2
4.6	Silt and Clay	3
4.7	Glacial Till.....	3
4.8	Laboratory Analysis	3
4.9	Groundwater Conditions.....	3
5	GEOTECHNICAL CONSIDERATIONS	4
5.1	Foundations	4
5.2	Shallow Foundation.....	4
5.3	Structural Fill.....	4
5.4	Lateral Earth Pressure.....	5
5.5	Settlement	5
5.6	Seismic	6
5.7	Frost Protection	6
5.8	Foundation Walls Backfill (Shallow Foundations).....	6
5.9	Liquefaction Potential	6
5.10	Slab-on-grade Construction.....	6
5.11	Corrosion Potential and Cement Type	7
6	EXCAVATION AND BACKFILLING REQUIREMENTS	7
6.1	Excavation.....	7
6.2	Groundwater Control.....	8
6.3	Pipe Bedding Requirements	8
6.4	Trench Backfill.....	9



7	REUSE OF ON-SITE SOILS.....	9
8	RECOMMENDED PAVEMENT STRUCTURE.....	10
8.1	Paved Areas & Subgrade Preparation.....	10
9	INSPECTION SERVICES	11
10	REPORT CONDITIONS AND LIMITATIONS.....	11

LIST OF TABLES

Table 1 – Gradation Analysis Summary.....	3
Table 2 – Material and Earth Pressure Properties.....	5
Table 3 – Results of Chemical Analysis.....	7
Table 4 – Recommended Pavement Structure.....	10

APPENDICES

Appendix A	Site and Borehole Location Plans
Appendix B	Borehole Logs
Appendix C	Symbols and Terms Used in Borehole Logs
Appendix D	Lab Results
Appendix E	Supporting Documentation – Phase II ESA BH/MW Logs



1 INTRODUCTION

LRL Associates Ltd. (LRL) was retained by MacEwen Petroleum Inc. to perform a geotechnical investigation for the proposed site redevelopment, located at 5546 Albion Road Street South, Ottawa ON.

The purpose of the investigation was to identify the subsurface conditions across the site by the completion of a limited borehole drilling program. Based on the visual and factual information obtained, this report will provide guidelines on the geotechnical engineering aspects of the design of the project, including construction considerations.

This report has been prepared in consideration of the terms and conditions noted above. Should there be any changes in the design features, which may relate to the geotechnical recommendations provided in the report, LRL should be advised in order to review the report recommendations.

2 SITE AND PROJECT DESCRIPTION

The site under investigation is currently a fully operational gas station, consisting of a convenience store and fuelling canopy. The topography of the site is considered to be relatively flat. The site is bound by Albion Street South to the east, and Mitch Owens Road to the south. Access to the site will come by way of Albion and Mitch Owens Road. The location is presented in Figure 1 included in **Appendix A**.

It is understood that development on this site will consist of demolition of the existing convenience store, septic system, fueling canopy, and fuel tanks. A new convenience store, fueling canopy and tanks, and a septic system will all be constructed as part of the proposed development.

3 PROCEDURE

The fieldwork for this investigation was carried out on May 25, 2022. Prior to the fieldwork, the site was cleared for the presence of any underground services and utilities. A total of four (4) boreholes, labelled BH1 through BH4, were drilled onsite to get a general representative of the site's soil condition. It shall be noted, the possible drilling locations was limited to due underground utilities, fuel lines and tanks. The approximate locations of the boreholes are shown in Figure 2 included in **Appendix A**.

The boreholes were advanced using a truck mount CME 75 drill rig equipped with 200 mm diameter continuous flight hollow stem auger supplied and operated by CCC Geotechnical and Environmental Drilling Ltd. A "two man" crew experienced with geotechnical drilling operated the drill rig and equipment.

Sampling of the overburden materials encountered in the boreholes was carried out at regular depth intervals using a 50.8 mm diameter drive open conventional spoon sampler in conjunction with standard penetration testing (SPT) "N" values. The SPT were conducted following the method **ASTM D1586** and the results of SPT, in terms of the number of blows per 0.3 m of split-spoon sampler penetration after first 0.15 m designated as "N" value.

The boreholes were advanced to a depth of 6.71 m below ground surface (bgs). Upon completion, the boreholes were backfilled using the overburden cuttings and topped with asphalt cold patch where required.



The fieldwork was supervised throughout by a member of our engineering staff who oversaw the drilling activities, cared for the samples obtained and logged the subsurface conditions encountered within each of the boreholes. All soil samples collected from the boreholes were placed and sealed in plastic bags to prevent moisture loss. The recovered soil samples collected from the boreholes were classified based on visual examination of the materials recovered and the results of the in-situ testing.

Furthermore, all boreholes were located using a Garmin Etrex Legend GPS (Global Positioning System) receiver using NAD 83 datum (North American Datum).

4 SUBSURFACE SOIL AND GROUNDWATER CONDITIONS

4.1 General

The subsurface conditions encountered in the boreholes were classified based on visual and tactile examination of the materials recovered from the boreholes and the results of in-situ laboratory testing. The soil descriptions presented in this report are based on commonly accepted methods of classification and identification employed in geotechnical practice. Classification and identification of soil were conducted according to the procedure **ASTM D2487** and judgement, and LRL does not guarantee descriptions as exact, but infers accuracy to the extent that is common in current geotechnical practice.

The subsurface soil conditions encountered at the boreholes are given in their respective logs presented in **Appendix B**. A greater explanation of the information presented in the borehole logs can be found in **Appendix C** of this report. These logs indicate the subsurface conditions encountered at a specific test location only. Boundaries between zones on the logs are often not distinct, but are rather transitional and have been interpreted as such.

4.2 Topsoil

Topsoil have a thickness of 75 mm thick was encountered at BH3.

The thickness was based on the amount of topsoil encountered in the split spoon sampler. It shall be noted the actual amount of topsoil onsite could be greater than what was recovered in the spoon sample.

4.3 Pavement Structure

A pavement structure was encountered at boring locations BH1, BH2, and BH4, this consisted of 100 mm thickness of asphalt overlying granular material have a thickness of 300 – 400 mm.

4.4 Fill Material

Underlying the pavement structure in BH1, BH2, and BH4, and the topsoil in BH3, a fill material was encountered and extended to depths ranging between 1.06 and 1.75 m bgs. The fill can generally be described as a mixture of brown sand and gravel. The recorded SPT “N” values of this deposit varied from 21 to 42, indicating the deposit is compact to dense. The natural moisture contents were found to range between 2 and 14%.

4.5 Sand

Underlying the fill in all boring locations, a layer of sand was encountered and extended to depths ranging between 2.97 and 6.71 m bgs. This material can be described as having trace silt, trace clay, greyish brown, and wet. The SPT “N” values were found to range

between Weight of Hammer (WH) and 33, indicating the material is very loose to dense. The natural moisture contents were determined to range between 10 and 48%.

4.6 Silt and Clay

Underlying the sand in BH2 and BH3, a layer of silt and clay was encountered and extended to a depth of 4.42 and 4.12 m bgs. respectively. This material can be described as having trace sand, grey, and wet. The SPT “N” values were found to be WH. The natural moisture contents were determined to be 46 and 50%.

In-situ vane shear readings were carried out in this material and were found to range between 30 and 38 kPa, indicating the material is firm.

4.7 Glacial Till

Underlying the sand in BH4, and the silt and clay in BH2 and BH3, a layer of glacial till was encountered and extended to a depth of 6.71 m bgs. This material can be described as a mixture of silt-sand, some gravel sized stone, trace clay, grey, and wet. The SPT “N” values were found to range between 2 and 17, indicating the material is very loose to compact. The natural moisture contents were determined to range between 10 and 16%.

4.8 Laboratory Analysis

Three (3) soil samples were collected for laboratory gradation analyses. The gradation analyses comprised of sieve and hydrometer were conducted following the procedure **ASTM D422**. Details of laboratory analyses are reflected in **Table 1**.

Table 1: Gradation Analysis Summary

Sample Location	Depth (m)	Percent for Each Soil Gradation							Estimated Hydraulic Conductivity K (m/s)
		Gravel		Sand			Silt (%)	Clay (%)	
		Coarse (%)	Fine (%)	Coarse (%)	Medium (%)	Fine (%)			
BH1	1.5-2.1	0.0	0.0	0.1	24.0	66.1	8.9	0.9	2×10^{-7}
BH2	3.1-3.7	0.0	0.0	0.2	0.4	5.4	51.6	42.4	1×10^{-7}
BH3	4.6-5.2	0.0	12.0	5.9	9.1	26.6	42.7	3.7	2×10^{-6}

The laboratory reports can be found in **Appendix D** of this report.

4.9 Groundwater Conditions

Groundwater was carefully monitored during this field investigation. During drilling, water was encountered at depths ranging between 2.9 and 3.3 m bgs.

The Phase II Environmental Site Assessment (ESA) Borehole/Monitoring Well (BH/MW) Logs were reviewed to get a further understanding of the groundwater elevations on this site.

The groundwater in the BH/MW Logs was measured on August 2, 2022, and found to range between 1.67 and 1.91 m bgs.

The groundwater levels can be found on their respective BH/MW Logs attached to this report in **Appendix E**.

It should be noted that groundwater levels could fluctuate with seasonal weather conditions, (i.e.: rainfall, droughts, spring thawing) and due to construction activities at or in the vicinity of the site.

5 GEOTECHNICAL CONSIDERATIONS

This section of the report provides general geotechnical recommendations for the design aspect of the project based on our interpretation of the information gathered from the boreholes performed at this site and from the project requirements.

This section will detail the specific requirements and limitations with regard to allowable foundation bearing pressure and depth, grade raise and size of the footings.

5.1 Foundations

Based on the subsurface soil conditions established at this site, it is recommended that the footings for the proposed building and canopy be founded below the frost penetration depth, overlying the native sand material. Therefore, all material including incompetent native soil should be removed from the proposed footprints down to the required founding depth.

5.2 Shallow Foundation

Conventional strip and column footings founded over the undisturbed native sand material may be designed using a maximum allowable bearing pressure of **100 kPa** for serviceability limit state (**SLS**) and **150 kPa** for ultimate limit state (**ULS**) factored bearing resistance. The factored ULS value includes the geotechnical resistance factor of 0.5. For this site, a grade raise restriction of 2.0 m above existing grade is required to ensure the underlying silty clay soil is not overloaded. The bearing capacity is contingent on the founding depth being less than 1.8 m below existing grade. If the founding depth is greater than 1.8 m, the bearing capacity may need to be reduced.

In-situ field testing may be required to check the strength and stability of the footings subgrade. Any incompetent subgrade areas as identified from in-situ testing must be sub-excavated and backfilled with approved structural fill. Similarly, any soft or wet areas should also be sub-excavated and backfilled with approved structural fill only. Prior to placing any approved structural fill, the subgrade should be inspected and approved by geotechnical engineer or qualified geotechnical personnel. The bearing pressure is contingent on the water level being 0.3 m below the underside footing elevation in order to have a stable and dry subgrade during construction.

Prior to pouring footings concrete, the subgrade should be inspected and approved by a geotechnical engineer or a representative of geotechnical engineer.

5.3 Structural Fill

For foundations set over undisturbed native soil and where excavation below the underside of the footings is performed in order to reach a suitable founding stratum, consideration should also be given to support the footings on structural fill. The structural fill should be placed over undisturbed native soils in layers not exceeding 300 mm and compacted to 98% of its Standard Proctor Maximum Dry Density (SPMDD) within $\pm 2\%$ of its optimum moisture content. In order to allow the spread of load beneath the footings and to prevent undermining during construction, the structural fill should extend minimum 1.0 m beyond the outside edges of the footings and then outward and downward at 1 horizontal to 1 vertical profile (or flatter) over a distance equal to the depth of the structural



fill below the footing. Furthermore, the structural fill must be tested to ensure that the specified compaction level is achieved.

5.4 Lateral Earth Pressure

The following equation should be used to estimate the intensity of the lateral earth pressure against any earth retaining structure/foundation walls.

$$P = K (\gamma h + q)$$

Where;

P = Earth pressure at depth h;

K = Appropriate coefficient of earth pressure;

γ = Unit weight of compacted backfill, adjacent to the wall;

h = Depth (below adjacent to the highest grade) at which P is calculated;

q = Intensity of any surcharge distributed uniformly over the backfill surface (usually surcharge from traffic, equipment or soil stockpiled and typically considered 10 kPa).

The coefficient of earth pressure at rest (K_0) should be used in the calculation of the earth pressure on the storm water manhole/basement walls, which are expected to be rather rigid and not to deflect.

The above expression assumes that perimeter drainage system prevents the build-up of any hydrostatic pressure behind the foundation wall.

Table 2 below provides various material types and their respective earth pressure properties.

Table 2: Material and Earth Pressure Properties

Type of Material	Bulk Density (kN/m ³)	Friction Angle (Φ)	Pressure Coefficient		
			At Rest (K_0)	Active (K_A)	Passive (K_P)
Granular A	23.0	34	0.44	0.28	3.53
Granular B Type I	20.0	31	0.49	0.32	3.12
Granular B Type II	23.0	32	0.47	0.31	3.25
Sand	19.0	30	0.50	0.33	3.00
Silt and Clay	17.5	19	0.62	0.51	1.97

5.5 Settlement

The estimated total settlement of the shallow foundations, designed using the recommended serviceability limit state capacity value, as well as other recommendations given above, will be less than 25 mm. The differential settlement between adjacent column footings is anticipated to be 15 mm or less.



5.6 Seismic

Based on the information of this geotechnical investigation and in accordance with the Ontario Building Code 2015 (Table 4.1.8.4.A.) and Canadian Foundation Engineering Manual (4th edition), the site can be classified for Seismic Site Response Site Class D.

The above classifications were recommended based on conventional method exercised for Site Classification for Seismic Site Response and in accordance with the generally accepted geotechnical engineering practice. It should be noted that a greater Seismic Site Class might be possible to achieve by carrying out a site-specific Multichannel Analysis of Surface Waves (MASW) survey.

5.7 Frost Protection

All exterior footings for any heated structure exposed to frost conditions should have a minimum of 1.5 m of earth cover. Footings for any unheated structures, signage or lighting, and where snow will be cleared, 1.8 m of earth cover is required. Alternatively, the required frost protection could be provided using a combination of earth cover and extruded polystyrene insulation. Detailed guidelines for footing insulation frost protection can be provided upon request.

In the event that foundations are to be constructed during winter months, the foundation soils are required to be protected from freezing temperatures using suitable construction techniques. The base of all excavations should be insulated from freezing temperatures immediately upon exposure, until heat can be supplied to the building interior and the footings have sufficient soil cover to prevent freezing of the subgrade soils.

5.8 Foundation Walls Backfill (Shallow Foundations)

To prevent possible foundation frost jacking and lateral loading, the backfill material against any foundation walls, grade beams, isolated walls, or piers should consist of free draining, non-frost susceptible material such as sand or sand and gravel meeting OPSS Granular B Type II or I, or a Select Subgrade Material (SSM).

The foundation wall backfill should be compacted to minimum 95% of its SPMDD using light compaction equipment, where no loads will be set over top. The compaction shall be increased to 98% of its SPMDD under walkways, slabs or paved areas close to the foundation or retaining walls. Backfilling against foundation walls should be carried out on both sides of the wall at the same time where applicable.

5.9 Liquefaction Potential

For foundations set over a well graded native sand material above the ground water table which is the case for this site, liquefaction is not a concern.

5.10 Slab-on-grade Construction

Concrete slab-on-grade should rest over compacted, free draining and well graded structural fill only. Therefore, all deleterious material shall be removed from the proposed building's footprint. The exposed undisturbed native subgrade should then be inspected and approved by a qualified geotechnical personnel.

Any underfloor fill needed to raise the general floor grade shall consist of OPSS Granular B Type II or I or SSM material or an approved equivalent, compacted to 95% of its SPMDD. The final lift shall be compacted to 98% of its SPMDD. A minimum 200 mm Granular A



layer meeting the **OPSS 1010** shall be placed underneath the slab and compacted to 100% of its SPMDD.

It is also recommended that the area of extensive exterior slab-on-grade (sidewalks, ramp etc.) shall be constructed using Granular A base of thickness 150 mm with incorporating subdrain facilities. The modulus of subgrade reaction (ks) for the design of the slabs set over competent native soil/structural fill is **24 MPa/m**.

In order to further minimize and control cracking, the floor slab shall be provided with wire or fibre mesh reinforcement and construction or control joints. The construction or control joints should be spaced equal distance in both directions and should not exceed 4.5 m. The wire or fibre mesh reinforcement shall be carried out through the joints.

If any areas of the proposed building area are to remain unheated during the winter period, thermal protection of the slab on grade may be required. The “Guide for Concrete Floor and Slab Construction”, **ACI 302.1R-04** is recommended to follow for the design and construction of vapour retarders below the floor slab. Further details on the insulation requirements could be provided, if necessary.

5.11 Corrosion Potential and Cement Type

A soil sample was submitted to Paracel Laboratories Ltd. for chemical testing. The following **Table 3** below summarizes the results.

Table 3: Results of Chemical Analysis

Sample Location	Depth (m)	pH	Sulphate (µg/g)	Chloride (µg/g)	Resistivity (Ohm.cm)
BH4	1.5 – 2.1	7.33	45	84	4,470

The above results revealed a measured sulphate concentration of 45 µg/g in the sample. Based on the CAN/CSA-A23.1 standards (Concrete Materials and Methods of Concrete Construction), a sulphate concentration of less than 1000 µg/g falls within the negligible category for sulphate attack on buried concrete. The test results from soil samples were below the noted threshold. As such, buried concrete for footings and foundations walls will not require any special additive to resist sulphate attack and the use of normal Portland cement is acceptable.

The pH, resistivity and chloride concentration provide an indication of the degree of corrosiveness of the sub-surface environment. The soil resistivity was measured to be 4,470 ohm.cm, which falls between the “corrosive” range for soil resistivity.

6 EXCAVATION AND BACKFILLING REQUIREMENTS

6.1 Excavation

It is anticipated that the depth of excavation for the building will not be extended below 1.8 m bgs. Most of the excavation being carried out will be through sand. Excavation must be carried out in accordance with Occupational Health and Safety Act and Regulations for construction Projects.

According to the Ontario’s Occupational Health and Safety Act (OHSA), O. Reg. 213/91 and its amendments, the surficial overburden expected to be excavated into at this site can be classified as Type 3. Therefore, shallow temporary excavations can be cut at 1



horizontal to 1 vertical (1H: 1V) for a fully drained excavation starting at the base of the excavation and as per requirements of the OHS regulations.

Any excavated material stockpiled near an excavation or trench should be stored at a distance equal to or greater than the depth of the excavation/trench and construction equipment, traffic should be limited near open excavation.

6.2 Groundwater Control

Based on the subsurface conditions encountered at this site, some minor groundwater seepage or infiltration from the native soils into the shallow temporary excavations during construction may be expected. However, it is anticipated that pumping from open sumps should be sufficient to control groundwater inflow. Any groundwater seepage or infiltration entering the excavation should be removed from the excavation by pumping from sumps within the excavations. Surface water runoff into the excavation should be minimized and diverted away from the excavation if possible.

A permit to take water (PTTW) is required from Ministry of Environment and Climate Change (MOECC), Ontario Reg. 387/04, if more than 400,000 litres per day of groundwater will be pumped during a construction period less than 30 days. Registration in the Environmental Activity and Sector Registry (EASR) is required when the takings of ground water and storm water for the purpose of dewatering construction projects range between 50,000 and 400,000 litres per day.

Based on the field investigation through localized borings, it is anticipated that pumping of groundwater will not exceed 50,000 litres per day. As such, no PTTW nor registration in the EASR is anticipated to be required for the construction of the proposed buildings at this site.

6.3 Pipe Bedding Requirements

It is anticipated that any underground services required as part of this project will be founded over sand. Alternately, underground services may be founded over properly prepared and approved structural fill, where excavation below the invert is required. Consequently all organic material should be removed down to a suitable bearing layer. Any sub-excavation of disturbed soil should be removed and replaced with a Granular B Type II or I or approved equivalent, laid in loose lifts of thickness not exceeding 300 mm and compacted to 95% of its SPMDD. Bedding, thickness of cover material and compaction requirements for any pipes should conform to the manufacturers design requirements and to the detailed installations outlined in the Ontario Provincial Standard Specifications (OPSS) and any applicable standards or requirements.

If services are required to be founded below the groundwater table the native materials may be sensitive to disturbances and may also be susceptible to piping and scouring from water pressure at the base of the excavation. Therefore, special precautions should be taken in these areas to stabilize and confine the base of the excavation such as using recompression (thicker bedding) and/or dewatering methods (pre-pumping). In order to properly compact the bedding, the water table should be kept at least 300 mm below the base of the excavation at all time during the installation of any sewers and structures.

As an alternative to Granular A bedding and only where wet conditions are encountered, the use of "clear stone" bedding, such as 19 mm clear stone, **OPSS 1004**, may be considered only in conjunction with a suitable geotextile filter (such as terrafix 270R or approved equivalent). Without proper filtering, there may be entry of fines from native soils



and trench backfill into the bedding, which could result in loss of support to the pipes and possible surface settlements. The sub-bedding, bedding and cover materials should be compacted in maximum 200 mm thick lifts to at least 95% of its SPMDD within $\pm 2\%$ of its optimum moisture content using suitable vibratory compaction equipment.

6.4 Trench Backfill

All service trenches should be backfilled using compactable material, free of organics, debris and large cobbles or boulders. Acceptable native materials (if encountered and where possible) should be used as backfill between the roadway subgrade level and the depth of seasonal frost penetrations (i.e. 1.8 m below finished grade) in order to reduce the potential for differential frost heaving between the new excavated trench and the adjacent section of roadway. Where native backfill is used, it should match the native materials exposed on the trench walls. Backfill below the zone of seasonal frost penetration could consist of either acceptable native material or imported granular material conforming to OPSS Granular B Type II or I. Any boulders larger than 150 mm in size should not be used as trench backfill.

To minimize future settlement of the backfill and achieve an acceptable subgrade for the roadway, the trench should be compacted in maximum 300 mm thick lifts to at least 95% of its SPMDD. The specified density may be reduced where the trench backfill is not located within or in close proximity to existing roadways or any other structures.

For trenches carried out in existing paved areas, transitions should be constructed to ensure that proper compaction is achieved between any new pavement structure and the existing pavement structure to minimize potential future differential settlement between the existing and new pavement structure. The transition should start at the subgrade level and extend to the underside of the asphaltic concrete level (if any) at a 1 horizontal to 1 vertical slope. This is especially important where trench boxes are used and where no side slopes are provided to the excavation. Where asphaltic concrete is present, it should be cut back to a minimum of 150 mm from the edge of the excavation to allow for proper compaction between the new and existing pavement structures.

7 REUSE OF ON-SITE SOILS

The existing surficial overburden soils consist mostly of sand. This material is considered to be frost susceptible and should not be used as backfill material directly against foundation walls or underneath unheated concrete slabs. However, it could be reused as general backfill material (service trenches, general landscaping/backfilling) if it can be compacted according to the specifications outlined herein at the time of construction and found free from any waste, organics and debris. Any imported material shall conform to OPSS Granular B – Type II or I, SSM or approved equivalent.

It should be noted that the adequacy of any material for reuse as backfill will depend on its water content at the time of its use and on the weather conditions prevailing prior to and during that time. Therefore, all excavated materials to be reused shall be stockpiled in a manner that will prevent any significant changes in their moisture content, especially during wet conditions. Any excavated materials proposed for reuse should be stockpiled in a manner to promote drying and should be inspected and approved for reuse by a geotechnical engineer.



8 RECOMMENDED PAVEMENT STRUCTURE

It is anticipated that the subgrade soils for the new parking areas will consist mostly of fill and/or sand. The construction of the parking areas will be acceptable over these materials once all deleterious materials are removed from the subgrade area. Furthermore, the subgrade must be compacted using a suitable heavy duty compacting equipment and **approved by a geotechnical engineer prior to placing any granular base material.**

The following **Table 4** presents the recommended pavement structures to be constructed over a stable subgrade along the proposed parking areas and access lanes as part of this project.

Table 4: Recommended Pavement Structure

Course	Material	Thickness (mm)	
		Light Duty Parking Area (mm)	Heavy Duty Parking Area (Access Roads, Fire Routes and Trucks) (mm)
Surface	HL3/SP12.5 A/C	50	40
Binder	HL8/SP19.0 A/C	-	50
Base course	Granular A	150	150
Sub base	Granular B Type II	350	450
Total:		550	690

Performance Graded Asphaltic Cement (PGAC) **58-34** is recommended for this project.

The base and subbase granular materials shall conform to **OPSS 1010** material specifications. Any proposed materials shall be tested and approved by a geotechnical engineer prior to delivery to the site and shall be compacted to 98% of its SPMD. Asphaltic concrete shall conform to **OPSS 1150** and be placed and compacted to at least 93% of the Marshall Density. The mix and its constituents shall be reviewed, tested and approved by a geotechnical engineer prior to delivery to the site.

8.1 Paved Areas & Subgrade Preparation

The access lanes and parking areas shall be stripped of vegetation, debris and other obvious objectionable fill material. Following the backfilling and satisfactory compaction of any underground service trenches up to the subgrade level, the subgrade shall be shaped, crowned and proof-rolled. A loaded Tandem axle, dual wheel dump truck or approved equivalent heavy duty smooth drum roller shall be used for proof-rolling. Any resulting loose/soft areas should be sub-excavated down to an adequate bearing layer and replaced with approved backfill.

The preparation of subgrade shall be scheduled and carried out in manner so that a protective cover of overlying granular material (if required) is placed as quickly as possible in order to avoid unnecessary circulation by heavy equipment, except on unexcavated or protected surfaces. Frost protection of the surface shall be implemented if works are carried out during the winter season.

The performance of the pavement structure is highly dependent on the subsurface groundwater conditions and maintaining the subgrade and pavement structure in a dry condition. The surface of the pavement should be properly graded to direct runoff water



towards suitable drainage features. It is recommended that the lateral extent of the subbase and base layers not be terminated vertically immediately behind the curb/edge of pavement line but be extended beyond the curb.

9 INSPECTION SERVICES

The engagement of the services of the geotechnical consultant during construction is recommended to confirm that the subsurface conditions throughout the proposed site do not materially differ from those given in the report and that the construction activities do not adversely affect the intent of the design.

All footing areas and any structural fill areas for the proposed structures should be inspected by LRL to ensure that a suitable subgrade has been reached and properly prepared. The placing and compaction of any granular materials beneath the foundations and slab-on-grade should be inspected to ensure that the materials used conform to the grading and compaction specifications.

The subgrade for the pavement areas and underground services should be inspected and approved by geotechnical personnel. In-situ density testing should be carried out on the pavement granular materials, pipe bedding and backfill to ensure the materials meet the specifications for required compaction.

If footings are to be constructed during winter season, the footing subgrade should be protected from freezing temperatures using suitable construction techniques.

10 REPORT CONDITIONS AND LIMITATIONS

It is stressed that the information presented in this report is provided for the guidance of the designers and is intended for this project only. The use of this report as a construction document or its use by a third party beyond the client specifically listed in the report is neither intended nor authorized by LRL Associates Ltd. Contractors bidding on or undertaking the works should examine the factual results of the investigation, satisfy themselves as to the adequacy of the information for construction, and make their own interpretation of the factual data as it affects their construction techniques, schedule, safety and equipment capabilities.

The professional services for this project include only the geotechnical aspects of the subsurface conditions at this site. The presence or implications of possible contamination resulting from previous uses or activities at this site or adjacent properties, and/or resulting from the introduction onto the site of materials from off-site sources are outside the terms of reference for this report.

The recommendations provided in this report are based on subsurface data obtained at the specific boring locations only. Boundaries between zones presented on the borehole are often not distinct but transitional and were interpreted. Experience indicates that the subsurface soil and groundwater conditions can vary significantly between and beyond the test locations. For this reason, the recommendations given in this report are subject to a field verification of the subsurface soil conditions at the time of construction.

The recommendations are applicable only to the project described in this report. Any changes to the project will require a review by LRL Associates Ltd., to ensure compatibility with the recommendations contained in this project.



We trust this report provides sufficient information for your present purposes. If you have any questions concerning this report or if we may be of further services to you, please do not hesitate to contact the undersigned.

Yours truly,
LRL Associates Ltd.



Brad Johnson, P.Eng.
Geotechnical Engineer



W:\FILES 2001\01348\2022\05 Geotechnical\01 Investigation\05 Reports\001348 -Geotechnical Investigation_Proposed Site Redevelopment_Albion MacEwen.docx



APPENDIX A
Site and Borehole Location Plan



LRJ

ENGINEERING | INGÉNIÉRIE

5430 Canotek Road | Ottawa, ON, K1J 9G2
www.lri.ca | (613) 842-3434

PROJECT

GEOTECHNICAL INVESTIGATION
PROPOSED SITE REDEVELOPMENT
5546 ALBION ROAD SOUTH
OTTAWA, ONTARIO

DRAWING TITLE

SITE LOCATION
SOURCE: GEO-OTTAWA

CLIENT

MACEWEN PETROLEUM INC


DATE

JUNE 2022

PROJECT

001348

FIGURE 1





LRJ

ENGINEERING | INGÉNIÉRIE

5430 Canotek Road | Ottawa, ON, K1J 9G2
www.lri.ca | (613) 842-3434

PROJECT

GEOTECHNICAL INVESTIGATION
PROPOSED SITE REDEVELOPMENT
5546 ALBION ROAD SOUTH
OTTAWA, ONTARIO

DRAWING TITLE

BOREHOLE LOCATION
SOURCE: Imagery 2022 Google, Digital Globe Map Data

CLIENT

MACEWEN PETROLEUM INC

DATE

JUNE 2022

PROJECT

001348

FIGURE 2



APPENDIX B
Borehole Logs



Project No.: 001348

Client: MacEwen Petroleum Inc.

Date: May 25, 2022

Borehole Log: BH2

Project: Proposed Site Redevelopment

Location: 5546 Albion Road S, Ottawa ON

Field Personnel: BJ

Driller: CCC Geotech and Enviro Drilling

Drilling Equipment: Truck Mount CME 850

Drilling Method: Hollow Stew Auger

SUBSURFACE PROFILE		SAMPLE DATA					Shear Strength (kPa)	Water Content (%)	Monitoring Well Details				
Depth ft m	Soil Description	Elev./Depth (m)	Type	Sample Number	N or RQD	Recovery (%)	50	150		25	50	75	
							SPT N Value (Blows/0.3 m)			Liquid Limit (%)			
							20	40	60	80	25	50	75
0	Ground Surface	0.00											
0.41	PAVEMENT STRUCTURE 100 mm of asphalt overlying 300 mm of granular material.			SS1	42	83					42	5	
0.41	FILL sand and gravel, brown, moist, dense.											5	
1.06	SAND trace silt, trace clay, greyish brown, moist, compact to loose.			SS2	36	88					36	10	
1.06													21
1.06				SS3	11	92					11		
1.06													22
2.97	SILT and CLAY trace sand, grey, wet, firm.			SS4	4	79					4		
2.97													50
2.97				SS5	WH	79					0		
2.97													
4.42	GLACIAL TILL silt-sand, some gravel sized stone, trace clay, grey, wet, compact.												
4.42													
4.42				SS7	17	79					17		16
4.42													
4.42													
4.42													
6.71	End of Borehole			SS8	15	75					15		10
6.71													

Eastings: 453334 m

Northing: 5013122 m

Site Datum: NM

Groundsurface Elevation: NM

Top of Riser Elev.: NA

Hole Diameter: 200 mm

Monitoring Well Diameter: N/A

NOTES:



Project No.: 001348

Client: MacEwen Petroleum Inc.

Date: May 25, 2022

Borehole Log: BH3

Project: Proposed Site Redevelopment

Location: 5546 Albion Road S, Ottawa ON

Field Personnel: BJ

Driller: CCC Geotech and Enviro Drilling

Drilling Equipment: Truck Mount CME 850

Drilling Method: Hollow Stew Auger

SUBSURFACE PROFILE		SAMPLE DATA					Shear Strength (kPa)	Water Content (%)	Monitoring Well Details			
Depth ft / m	Soil Description	Elev./Depth (m)	Type	Sample Number	N or RQD	Recovery (%)	50	150		25	50	75
							SPT N Value (Blows/0.3 m)			Liquid Limit (%)		
0	Ground Surface	0.00										
0.075	TOPSOIL about 75 mm thick.						21		4			
1	FILL sand and gravel, asphalt debris, brown, moist, compact.			SS1	21	96						
2												
3				SS2	23	88	23		14			
4												
5	SAND trace silt, trace clay, greyish brown, moist, dense to loose.	1.45										
6				SS3	33	100	33		16			
7												
8				SS4	6	67	6		23			
9												
10	SILT and CLAY trace sand, grey, wet, firm.	2.97										
11				SS5	WH	75	0		46			
12												
13							30					
14	GLACIAL TILL silt-sand, some gravel sized stone, trace clay, grey, wet, compact to loose.	4.12										
15												
16					SS7	17	79	17		12		
17												
18												
19												
20												
21				SS8	4	75	4		10			
22												
	End of Borehole	6.71										

Eastings: 453320 m

Northing: 5013082 m

Site Datum: NM

Groundsurface Elevation: NM

Top of Riser Elev.: NA

Hole Diameter: 200 mm

Monitoring Well Diameter: N/A

NOTES:



Project No.: 001348

Client: MacEwen Petroleum Inc.

Date: May 25, 2022

Borehole Log: BH4

Project: Proposed Site Redevelopment

Location: 5546 Albion Road S, Ottawa ON

Field Personnel: BJ

Driller: CCC Geotech and Enviro Drilling

Drilling Equipment: Truck Mount CME 850

Drilling Method: Hollow Stew Auger

SUBSURFACE PROFILE		SAMPLE DATA					Shear Strength (kPa)	Water Content (%)	Monitoring Well Details				
Depth ft m	Soil Description	Elev./Depth (m)	Type	Sample Number	N or RQD	Recovery (%)	50	150		25	50	75	
							SPT N Value (Blows/0.3 m)			Liquid Limit (%)			
							20	40	60	80	25	50	75
0	Ground Surface	0.00											
0	PAVEMENT STRUCTURE 100 mm of asphalt overlying about 400 mm of granular material..	0.50		SS1	36	79	36				3		
1	FILL sand and gravel, greyish brown, moist, dense.			SS2	42	83	42				5		
2													
3													
4													
5													
6	SAND trace silt, trace clay, greyish brown, wet, compact to loose.	1.75		SS3	26	83	26				16		
7													
8				SS4	10	75	10				26		
9													
10													
11				SS5	7	75	7				23		
12													
13													
14	GLACIAL TILL silt-sand, some gravel sized stone, trace clay, grey, wet, very loose to loose.	4.12											
15													
16				SS7	2	100	2				10		
17													
18													
19													
20													
21				SS8	8	75	8				10		
22													
	End of Borehole	6.71											

Easting: 453346 m

Northing: 5013076 m

Site Datum: NM

Groundsurface Elevation: NM

Top of Riser Elev.: NA

Hole Diameter: 200 mm

Monitoring Well Diameter: N/A

NOTES:

APPENDIX C
Symbols and Terms used in Borehole Logs

Symbols and Terms Used on Borehole and Test Pit Logs

1. Soil Description

The soil descriptions presented in this report are based on commonly accepted methods of classification and identification employed in geotechnical practice. Classification and identification of soil involves some judgement and LRL Associates Ltd. does not guarantee descriptions as exact, but infers accuracy to the extent that is common in current geotechnical practice. Boundaries between zones on the logs are often not distinct but transitional and were interpreted.

a. Proportion

The proportion of each constituent part, as defined by the grain size distribution, is denoted by the following terms:

Term	Proportions
“trace”	1% to 10%
“some”	10% to 20%
prefix (i.e. “sandy” silt)	20% to 35%
“and” (i.e. sand “and” gravel)	35% to 50%

b. Compactness and Consistency

The state of compactness of granular soils is defined on the basis of the Standard Penetration Number (N) as per ASTM D-1586. It corresponds to the number of blows required to drive 300 mm of the split spoon sampler using a metal drop hammer that has a weight of 62.5 kg and free fall distance of 760 mm. For a 600 mm long split spoon, the blow counts are recorded for every 150 mm. The “N” value is obtained by adding the number of blows from the 2nd and 3rd count. Technical refusal indicates a number of blows greater than 50.

The consistency of clayey or cohesive soils is based on the shear strength of the soil, as determined by field vane tests and by a visual and tactile assessment of the soil strength.

The state of compactness of granular soils is defined by the following terms:

State of Compactness Granular Soils	Standard Penetration Number “N”	Relative Density (%)
Very loose	0 – 4	<15
Loose	4 – 10	15 – 35
Compact	10 - 30	35 – 65
Dense	30 - 50	65 - 85
Very dense	> 50	> 85

The consistency of cohesive soils is defined by the following terms:

Consistency Cohesive Soils	Undrained Shear Strength (C_u) (kPa)	Standard Penetration Number “N”
Very soft	<12.5	<2
Soft	12.5 - 25	2 - 4
Firm	25 - 50	4 - 8
Stiff	50 - 100	8 - 15
Very stiff	100 - 200	15 - 30
Hard	>200	>30

c. Field Moisture Condition

Description (ASTM D2488)	Criteria
Dry	Absence of moisture, dusty, dry to touch.
Moist	Damp, but not visible water.
Wet	Visible, free water, usually soil is below water table.

2. Sample Data

a. Elevation depth

This is a reference to the geodesic elevation of the soil or to a benchmark of an arbitrary elevation at the location of the borehole or test pit. The depth of geological boundaries is measured from ground surface.

b. Type

Symbol	Type	Letter Code
	Auger	AU
▲	Split Spoon	SS
	Shelby Tube	ST
	Rock Core	RC

c. Sample Number

Each sample taken from the borehole is numbered in the field as shown in this column.

LETTER CODE (as above) – Sample Number.

d. Recovery (%)

For soil samples this is the percentage of the recovered sample obtained versus the length sampled. In the case of rock, the percentage is the length of rock core recovered compared to the length of the drill run.

3. Rock Description


Rock Quality Designation (RQD) is a rough measure of the degree of jointing or fracture in a rock mass. The RQD is calculated as the cumulative length of rock pieces recovered having lengths of 100 mm or more divided by the length of coring. The qualitative description of the bedrock based on RQD is given below.

Rock Quality Designation (RQD) (%)	Description of Rock Quality
0 – 25	Very poor
25 – 50	Poor
50 – 75	Fair
75 – 90	Good
90 – 100	Excellent

Strength classification of rock is presented below.


Strength Classification	Range of Unconfined Compressive Strength (MPa)
Extremely weak	< 1
Very weak	1 – 5
Weak	5 – 25
Medium strong	25 – 50
Strong	50 – 100
Very strong	100 – 250
Extremely strong	> 250

4. General Monitoring Well Data



**5. Classification of Soils for Engineering Purposes (ASTM D2487)
(United Soil Classification System)**

Major divisions		Group Symbol	Typical Names	Classification Criteria	
Coarse-grained soils More than 50% retained on No. 200 sieve* (>0.075 mm)	Gravels More than 50% of coarse fraction retained on No. 4 sieve(4.75 mm)	Clean gravels <5% fines	GW Well-graded gravel	Classification on basis of percentage of fines: Less than 5% pass No. 200 sieve - GW, GP, SW, SP More than 12% pass No. 200 sieve - GM, GC, SM, SC 5 to 12% pass No. 200 sieve - Borderline classifications, use of dual symbols $C_u = \frac{D_{60}}{D_{10}} \geq 4$; $C_c = \frac{(D_{30})^2}{D_{10} \times D_{60}}$ between 1 and 3 Not meeting either C_u or C_c criteria for GW Atterberg limits below "A" line or PI less than 4 Atterberg limits on or above "A" line and PI > 7 Atterberg limits plotting in hatched area are borderline classifications requiring use of dual symbols If fines are organic add "with orgnic fines" to group name	
			GP Poorly graded gravel		
		Gravels with >12% fines	GM Silty gravel		
			GC Clayey gravel		
	Sands 50% or more of coarse fraction passes No. 4 sieve(<4.75 mm)	Clean sands <5% fines	SW Well-graded sand		$C_u = \frac{D_{60}}{D_{10}} \geq 6$; $C_c = \frac{(D_{30})^2}{D_{10} \times D_{60}}$ between 1 and 3 Not meeting either C_u or C_c criteria for SW Atterberg limits below "A" line or PI less than 4 Atterberg limits on or above "A" line and PI > 7 Atterberg limits plotting in hatched area are borderline classifications requiring use of dual symbols If fines are organic add "with orgnic fines" to group name
			SP Poorly graded sand		
		Sands with >12% fines	SM Silty sand		
			SC Clayey sand		
Fine-grained soils 50% or more passes No. 200 sieve* (<0.075 mm)	Silt and Clays Liquid Limit <50%	Inorganic	ML Silt	If 15 to 29% coarse-grained, add "with sand" or "with gravel" as appropriate. If > 30% coarse-grained, add "sandy" or "gravelly" as appropriate. Class as organic when oven dried liquid limit is < 75% of undried liquid limit.	
			CL Lean Clay -low plasticity		
		Organic	OL Organic clay or silt (Clay plots above 'A' Line)		
	Silt and Clays Liquid Limit >50%	Inorganic	MH Elastic silt		
			CH Fat Clay -high plasticity		
		Organic	OH Organic clay or silt (Clay plots above 'A' Line)		
	Highly Organic Soils	PT	Peat, muck and other highly organic soils		



APPENDIX D
Laboratory Results




PARTICLE SIZE ANALYSIS

ASTM D 422 / LS-702

Client: MacEwewn Petroleum Inc.
Project: Geotechnical Investigation
Location: 5546 Albion Road South, Gloucester, ON.

File No.: 01348
Report No.: 1
Date: May 25, 2022



> 75 mm	% GRAVEL		% SAND			% FINES	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
△	0.0	0.0	0.1	24.0	66.1	8.9	0.9
■	0.0	0.0	0.2	0.4	5.4	51.6	42.4
○	0.0	12.0	5.9	9.1	26.6	42.7	3.7

Location	Sample	Depth, m	D ₆₀	D ₅₀	D ₃₀	D ₁₅	D ₁₀	C _c	C _u
△	BH 1	1.52 - 2.13	0.3500	0.3027	0.1975	0.1154	0.0769	1.4	4.6
■	BH 2	3.05 - 3.66	0.0038	0.0026					
○	BH 3	4.57 - 5.18	0.1772	0.0977	0.0421	0.0146	0.0087	1.1	20.4

Certificate of Analysis

LRL Associates Ltd.

5430 Canotek Road
Ottawa, ON K1J 9G2
Attn: Brad Johnson

Client PO:
Project: 01348
Custody: 67961

Report Date: 3-Jun-2022
Order Date: 30-May-2022

Order #: 2223089

This Certificate of Analysis contains analytical data applicable to the following samples as submitted:

Paracel ID	Client ID
2223089-01	BH4 5-7'

Approved By:



Mark Foto, M.Sc.
Lab Supervisor

Certificate of Analysis

Report Date: 03-Jun-2022

Client: LRL Associates Ltd.

Order Date: 30-May-2022

Client PO:

Project Description: 01348

Analysis Summary Table

Analysis	Method Reference/Description	Extraction Date	Analysis Date
Anions	EPA 300.1 - IC, water extraction	2-Jun-22	3-Jun-22
pH, soil	EPA 150.1 - pH probe @ 25 °C, CaCl buffered ext.	3-Jun-22	3-Jun-22
Resistivity	EPA 120.1 - probe, water extraction	2-Jun-22	2-Jun-22
Solids, %	Gravimetric, calculation	1-Jun-22	1-Jun-22

Certificate of Analysis

Report Date: 03-Jun-2022

Client: LRL Associates Ltd.

Order Date: 30-May-2022

Client PO:

Project Description: 01348

Client ID:	BH4 5-7'	-	-	-
Sample Date:	27-May-22 09:00	-	-	-
Sample ID:	2223089-01	-	-	-
MDL/Units	Soil	-	-	-

Physical Characteristics

% Solids	0.1 % by Wt.	86.9	-	-	-
----------	--------------	------	---	---	---

General Inorganics

pH	0.05 pH Units	7.33	-	-	-
Resistivity	0.10 Ohm.m	44.7	-	-	-

Anions

Chloride	5 ug/g dry	84	-	-	-
Sulphate	5 ug/g dry	45	-	-	-

Certificate of Analysis
 Client: LRL Associates Ltd.
 Client PO:

Report Date: 03-Jun-2022
 Order Date: 30-May-2022
 Project Description: 01348

Method Quality Control: Blank

Analyte	Result	Reporting Limit	Units	Source Result	%REC	%REC Limit	RPD	RPD Limit	Notes
Anions									
Chloride	ND	5	ug/g						
Sulphate	ND	5	ug/g						
General Inorganics									
Resistivity	ND	0.10	Ohm.m						

Certificate of Analysis
 Client: LRL Associates Ltd.
 Client PO:

Report Date: 03-Jun-2022
 Order Date: 30-May-2022
 Project Description: 01348

Method Quality Control: Duplicate

Analyte	Result	Reporting Limit	Units	Source Result	%REC	%REC Limit	RPD	RPD Limit	Notes
Anions									
Chloride	95.0	5	ug/g	90.7			4.7	20	
Sulphate	81.7	5	ug/g	87.9			7.3	20	
General Inorganics									
pH	7.18	0.05	pH Units	7.24			0.8	2.3	
Resistivity	45.5	0.10	Ohm.m	44.7			1.8	20	
Physical Characteristics									
% Solids	79.8	0.1	% by Wt.	80.0			0.2	25	

Certificate of Analysis
 Client: LRL Associates Ltd.
 Client PO:

Report Date: 03-Jun-2022
 Order Date: 30-May-2022
 Project Description: 01348

Method Quality Control: Spike

Analyte	Result	Reporting Limit	Units	Source Result	%REC	%REC Limit	RPD	RPD Limit	Notes
Anions									
Chloride	192	5	ug/g	90.7	102	82-118			
Sulphate	185	5	ug/g	87.9	97.4	80-120			

Certificate of Analysis

Client: LRL Associates Ltd.

Client PO:

Report Date: 03-Jun-2022

Order Date: 30-May-2022

Project Description: 01348

Qualifier Notes:

None

Sample Data Revisions

None

Work Order Revisions / Comments:

None

Other Report Notes:

n/a: not applicable

ND: Not Detected

MDL: Method Detection Limit

Source Result: Data used as source for matrix and duplicate samples

%REC: Percent recovery.

RPD: Relative percent difference.

NC: Not Calculated

Soil results are reported on a dry weight basis when the units are denoted with 'dry'.

Where %Solids is reported, moisture loss includes the loss of volatile hydrocarbons.

APPENDIX E

Supporting Documentation – Phase II ESA BH/MW Logs



Project No.: 01348

Client: MacEwen Petroleum Inc.

Date: July 28, 2022

Borehole Log: BH/MW22-1

Project: Phase II Environmental Site Assessment

Location: 5546 Albion Road, Ottawa, Ontario


Field Personnel: GM

Driller: Strata Drilling Group

Drilling Equipment: Geoprobe 7822DT

Drilling Method: Direct Push

SUBSURFACE PROFILE		SAMPLE DATA						Combustible Soil Vapours ppm 20 40 60 80 % LEL 10 20 30 40 50 60 70 80 90	Monitoring Well Details
Depth	Soil Description	Elev./Depth (m)	Lithology	Type	Sample Number	N or RQD (%)	Recovery (%)		
0.0	Ground Surface	100.17							
0.0 - 0.30	ASPHALT □□□ mm t□□□	99.87			SS1A				
0.30 - 0.80	PAVEMENT STRUCTURE Sand and gravel, dry.	99.37			SSAB	NA	87	VOC, PHC, PAH, Metals O.Reg.153, General inorganics	<0.1
0.80 - 1.0	FILL Sand and gravel to 0.5 m bgs, silty loam to 0.8 m bgs.				SS1C				<0.1
1.0 - 1.9	SAND Medium- to coarse- grained, becoming, fossiliferous, brown becoming grey with depth, oxidized at 1.7 m bgs, moist at 1.5 m bgs becoming saturated at 1.9 m bgs.				SS2A SS2B	NA	53	VOC, PHC, PAH, Metals O.Reg.153, General inorganics	<0.1
1.9 - 3.5					SS3A				<0.1
3.5 - 4.6	GLACIAL TILL Grey silt-sand with gravel, saturated.	96.67			SS3B	NA	100		<0.1
4.6 - 4.60	End of Borehole	95.57			SS3C			VOC, PHC, Metals O.Reg.153, General inorganics	<0.1



Easting: 0453388 **Northing:** 5013088
Site Datum: "R" on "Danger" on storm sewer grate in east portion of the Site
Groundsurface Elevation: 100.17 m **Top of Riser Elev.:** 100.06 m
Hole Diameter: 91 mm **Monitoring Well Diameter:** 51 mm

NOTES
- Duplicate samples collected of SS2B (identified as SS5A).
- Groundwater sample collected on August 04, 2022 was submitted for laboratory analysis of VOC, PHC, PAH, Reg.153 Metals, General Inorganics.



Project No.: 01348
Client: MacEwen Petroleum Inc.
Date: July 29, 2022

Borehole Log: BH/MW22-2


Project: Phase II Environmental Site Assessment
Location: 5546 Albion Road, Ottawa, Ontario
Field Personnel: GM

Driller: Strata Drilling Group

Drilling Equipment: Geoprobe 7822DT

Drilling Method: Direct Push

SUBSURFACE PROFILE		SAMPLE DATA						Combustible Soil Vapours ppm 20 40 60 80 % LEL 10 20 30 40 50 60 70 80 90	Monitoring Well Details
Depth	Soil Description	Elev./Depth (m)	Lithology	Type	Sample Number	N or RQD (%)	Recovery (%)		
0.0	Ground Surface	99.94							
0.0 - 1.0	ASPHALT PAVEMENT STRUCTURE Sand and gravel, dry.	0.00 - 0.40							
1.0 - 2.1	SAND Medium- to coarse-grained, becoming clayey at 1.3 m bgs, and clayey silt at 1.5 to 2.1 m bgs, brown becoming grey with depth, moist at 1.5 m bgs becoming saturated at 2.1 m bgs.	0.40 - 2.80			SS1A SS1B	NA	50		<0.1 <0.1
2.1 - 3.2	GLACIAL TILL Silty sand with gravel, clayey, becoming more compact at 3.0 m bgs, saturated silt at 3.2 m bgs.	2.80 - 4.60			SS2A SS2B SS2C SS3A SS3B SS3C	NA	63	VOC, PHC, PAH, Metals O.Reg.153, General inorganics	<0.1 <0.1 0.6 0.3 <0.1 <0.1 <0.1
4.60	End of Borehole	95.34							



Easting: 0453364 **Northing:** 5013069
Site Datum: "R" on "Danger" on storm sewer grate in east portion of the Site
Groundsurface Elevation: 99.94 m **Top of Riser Elev.:** 99.86 m
Hole Diameter: 91 mm **Monitoring Well Diameter:** 51 mm

NOTES
- Duplicate samples collected of SS2A (identified as SS4A).
- Groundwater sample collected on August 04, 2022 was submitted for laboratory analysis of VOC, PHC, PAH, Reg.153 Metals, General Inorganics.



Project No.: 01348

Client: MacEwen Petroleum Inc.

Date: July 29, 2022

Borehole Log: BH/MW22-3

Project: Phase II Environmental Site Assessment

Location: 5546 Albion Road, Ottawa, Ontario


Field Personnel: GM

Driller: Strata Drilling Group

Drilling Equipment: Geoprobe 7822DT

Drilling Method: Direct Push

SUBSURFACE PROFILE		SAMPLE DATA						Combustible Soil Vapours ppm 20 40 60 80 % LEL 10 20 30 40 50 60 70 80 90	Monitoring Well Details
Depth	Soil Description	Elev./Depth (m)	Lithology	Type	Sample Number	N or RQD (%)	Recovery (%)		
0.0	Ground Surface	100.20							
0.0 - 0.30	ASPHALT PAVEMENT STRUCTURE Sand and gravel, dry.	99.90							
0.30 - 1.50	FILL Sand and gravel, dry.	98.70			SS1A	NA	12		<0.1
1.50 - 1.91	SAND Medium- to coarse- grained, clayey 1.6 m bgs, brown becoming grey with depth, moist at 1.7 m bgs becoming saturated at 1.9 m bgs	95.70			SS2A SS2B SS2C	NA	52	VOC, PHC, PAH, Metals O.Reg.153.	0.6 0.4 <0.1
1.91 - 4.50	GLACIAL TILL Grey silt with gravel, fossiliferous.	95.70			SS3A SS3B SS3C	NA	68	VOC, PHC, Metals O.Reg.153, General inorganics	<0.1 0.1 0.3
4.50	End of Borehole								



Easting: 0453352 **Northing:** 5013075
Site Datum: "R" on "Danger" on storm sewer grate in east portion of the Site
Groundsurface Elevation: 100.20 m **Top of Riser Elev.:** 100.13 m
Hole Diameter: 91 mm **Monitoring Well Diameter:** 51 mm

NOTES
- Duplicate samples collected of SS2C (identified as SS4C).
- Groundwater sample collected on August 04, 2022 was submitted for laboratory analysis of VOC, PHC, PAH, Reg.153 Metals, General Inorganics.



Project No.: 01348
Client: MacEwen Petroleum Inc.
Date: July 29, 2022

Borehole Log: BH/MW22-4


Project: Phase II Environmental Site Assessment
Location: 5546 Albion Road, Ottawa, Ontario
Field Personnel: GM

Driller: Strata Drilling Group

Drilling Equipment: Geoprobe 7822DT

Drilling Method: Direct Push

SUBSURFACE PROFILE			SAMPLE DATA					Combustible Soil Vapours ppm 20 40 60 80 % LEL 10 20 30 40 50 60 70 80 90	Monitoring Well Details
Depth	Soil Description	Elev./Depth (m)	Lithology	Type	Sample Number	N or RQD (%)	Recovery (%)		
0.0	Ground Surface	100.21							
0.0 - 0.45	ASPHALT	0.00							
0.45 - 1.20	PAVEMENT STRUCTURE Sand and gravel, dry.	99.76			SS1A			VOC, PHC, Metals O.Reg.153, General	0.7
1.20 - 1.70	FILL Silty Loam, brown, dry.	99.01			SS1A SS1B	NA	47		0.1
1.70 - 3.50	SAND Medium-grained, brown becoming grey with depth, oxidized at 1.5 m bgs, moist becoming saturated at 2.0 m bgs, fractured rock at 3.5 m bgs.	99.01			SS1C				<0.1
3.50 - 4.60	GLACIAL TILL Silty-sand, clayey with gravel at 4.0 m bgs, grey, saturated.	96.71			SS2A SS1B SS2B	NA	51	VOC, PHC, Metals O.Reg.153, General inorganics	<0.1
4.60 - 15.0	End of Borehole	95.61			SS3A SS3B SS1C SS3C	NA	100		<0.1



Easting: 0453371 **Northing:** 5013099
Site Datum: "R" on "Danger" on storm sewer grate in east portion of the Site
Groundsurface Elevation: 100.21 m **Top of Riser Elev.:** 100.1 m
Hole Diameter: 91 mm **Monitoring Well Diameter:** 51 mm

NOTES
- Duplicate samples collected of SS1B (identified as SS4A).
- Groundwater sample collected on August 04, 2022 was submitted for laboratory analysis of VOC, PHC, PAH, Reg.153 Metals, General Inorganics.