



Site Servicing Report Prince of Wales & Meadowland Drive KDR Redevelopment

SHELL CANADA LIMITED

JULY 19, 2024

225-340 MIDPARK WAY SE
CALGARY, AB
P: 403 640 0990
F: 403 259 6506

Distribution List

Hard Copy	PDF Copy	Association / Company Name
	✓	City of Ottawa
	✓	Shell Canada Ltd.

Revision History

Revision #	Date	Revised By	Revision Description
0	July 19 2024	YVONNE	ORIGINAL

Authors

Report Prepared By:	Inna Nikiforov T.T Civil Technologist CTM Design Services Ltd. Yvonne Faas, P. Eng., Project Engineer CTM Design Services Ltd.
Report Reviewed By:	Bibi Mapp, Project Manager AECOM

Table of Contents

Distribution List	2
Revision History	2
Authors	2
1 Project Information	4
2 Introduction	4
2.1 Location Map	4
2.2 Existing Conditions & Infrastructure	5
2.3 Proposed Conditions	5
3 Water Servicing	6
3.1 Design Criteria	6
3.2 Proposed Servicing	6
3.3 Fire Flows	6
4 Sanitary Servicing	8
5 Storm Service	8
6 Summary	8

1 Project Information


Client: Shell Canada Products
Contact: Kerry Morrison, EPCM Advisor
Project Name: Prince of Wales & Meadowlands KDR
Description: Redevelopment (Knockdown Rebuild) Gas Bar with Canopy, C-store
Location: 1440 Prince of Wales Drive, Ottawa, Ontario
Consultant: CTM Design Services Ltd.
Contact: Yvonne Faas, P.Eng. Civil Engineer

2 Introduction

CTM Design Services Ltd. (CTM) has been retained by Shell Canada Products to provide site servicing plans in support of the redevelopment of a proposed gas station and convenience store in the City of Ottawa. The property is located on the northwest corner of the intersection of Prince of Wales Drive and Meadowlands Drive. The address is 1440 Prince of Wales Drive, Ottawa, Ontario. The location map is shown in Figure 1.

2.1 Location Map

The site is located west of Prince of Wales Drive and north of Meadowlands Drive.



2.2 Existing Conditions & Infrastructure

The subject site 0.444-hectare site, zoned GM15 F(1.0)1, is located at the corner of Prince of Wales Drive and Meadowlands Drive. The site is currently occupied by one c-store and attached canopy over the gas bar which includes 4 dispensers, and a fenced in garbage enclosure. There are two commercial accesses from Prince of Wales Drive and one commercial access from Meadowlands Drive. The existing site cover consists of paved parking and drive areas, and some perimeter grassed landscaping with some mature trees.

The site currently has existing water, storm and sanitary sewer services. Using City of Ottawa block profiles in combination with a survey and GIS mapping, the existing site servicing plan was pieced together. The existing site servicing is shown on the drawing provided.

During the pre-app meeting, the following servicing information was provided.

Water Servicing:

- a) Existing 305 mm diameter CI watermain (install year = 1965) located on Prince of Wales Drive
- b) Existing 203 mm diameter DI watermain (install year = 1971) on Meadowlands Drive

Sanitary Servicing:

- a) Existing 225 mm diameter Conc. Sanitary sewer (Install year = 1966) on Prince of Wales Drive.
- b) Existing 225 mm diameter Conc. Sanitary sewer (install year = 1969)

Storm Servicing:

- a) Existing 450 mm diameter Conc. Storm sewer (install year = 1962) on Prince of Wales Drive.
- b) Existing 300 mm diameter Storm sewer (install year = 1969) on Meadowlands Drive.

Additionally, the City of Ottawa provided Block Profile drawings 2199, Sheet 2 and DR-222 Sheet 2.

2.3 Proposed Conditions

The proposed site will consist of a new C-store, a new 4-dispenser gas bar covered by a canopy, new underground tanks will be installed, new drive-through lanes adjacent to the back property lines, new in-ground waste containers, new retaining wall adjacent to existing parking lot, and new EV charging stations. There will be one commercial access from Prince of Wales Drive and one commercial access from Meadowlands Drive. Most of the site cover will consist of paved parking and drive areas, and some perimeter landscaping frontage; existing mature trees will be protected where possible.

Proposed new services to the new building shown on the site servicing drawing provided. All existing servicing lines within the site will be removed and replaced with new service lines to the new building and the new canopy.

3 Water Servicing

The existing water service line connection to the site will be maintained to the watermain in Meadowlands Drive.

3.1 Design Criteria

The water servicing design adhered to the Ottawa Water Distribution Guidelines and associated Technical Bulletins. A summary of the relevant criteria is presented below:

Average Daily Demand

Demand Type	Amount	Units
Other Commercial	28000	L/gross ha/day
Site Area	1795	sq.m
	0.1795	ha
Average Daily Demand	5026	L/day

Maximum Daily Demand

Commercial	1.5 x avg. day	L/gross ha/day
Maximum Daily Demand	7539	L/day
	0.087	L/s

Maximum Hour Demand

Commercial	1.8 x avg. day	L/gross ha/day
Maximum Hour Demand	9047	L/day
	0.105	L/s

3.2 Proposed Servicing

The existing 203 mm diameter DI watermain on Meadowlands Drive will be the water supply point for the proposed commercial redevelopment.

The proposed water line is 50mm diameter CU to the new building. The reducer and valve are proposed at the property line in the access crossing to Meadowlands Drive.

3.3 Fire Flows

Based on the Fire Underwriters Survey, the following data is provided for calculating the Required Fire Flows (RFF).

$$RFF = 220C\sqrt{A}$$

RFF = the Required Fire Flow in liters per minute (LPM)

C = the Construction Coefficient is related to the type of construction of the building

A = the total Effective Floor Area (effective building area) in square meters of the building.

Following the procedure recommended by the FUS,

- A. $C = 1.0$ for Type III Ordinary Construction
- B. $A = 190$ sq.m
- C. $RFF = 220C\sqrt{A} = 3000$ LPM
- D. Occupancy Contents Adjustment Factor = -15% to +15% (based on E Occupancy and Limited Combustible Contents).

- 15% = - 450	RFF = 2550 to
+ 15% = + 450	RFF = 3450
- E. No Automatic Sprinkler Protection. Increase/Decrease = 0
- F. Exposure Adjustment Charge. Table 6: $0\% + 0\% = 0\%$ Increase = 0
- G. RFF = 3450 LPM rounded to 4000 LPM

Results indicate a hydrant shall be located within 90m of the building.

Reference: Water Supply for Public Fire Protection, A Guide to Recommended Practice in Canada, 2019, Fire Underwriters Survey.

There are two (2) existing fire hydrants located well within 90 m of the site and specifically the building entrance. The closest hydrant is located on the SW corner of the intersection of Prince of Wales Drive and Meadowlands Drive. The next nearest hydrant is located on Prince of Wales Drive, west side, adjacent to the apartment complex.

4 Sanitary Servicing

The existing sanitary service line connection to the site will be maintained to the sanitary main in Meadowlands Drive. The block profiles and survey suggest the existing site service size is 200 mm diameter, adjacent to the access crossing from Meadowland Drive. The proposed sanitary service is a new manhole and new 150mm diameter service line to the new building.

5 Storm Service

The existing storm service line connection to the site will be maintained to the storm main in Meadowlands Drive. The block profiles and survey suggest the existing site service size is 250 mm diameter, adjacent to the access crossing from Meadowlands Drive. The proposed storm service is a new OGS manhole and new 250 mm diam and 300 mm diameter storm lines. The flow rate will be restricted and controlled with an orifice plate in proposed GTMH#1, therefore the outgoing pipe reduction is reasonable to match the existing line. Details for the stormwater management and calculations are provided in a separate report, the Stormwater Management Report.

6 Summary

The proposed redevelopment of this site will tie new servicing to existing services already provided from Meadowlands Drive, as recommended in the pre-app documentation. The existing service lines to the site will be maintained in size and location, thus no disturbance to the existing adjacent roadways.

There are two existing fire hydrants well within 90m of the building opening, which meets the FUS code.