



LRL

ENGINEERING | INGÉNIERIE

February 29, 2024

Our File Ref.: 230673

Lepine Corp
206-555 Legget Dr
Ottawa, Ontario K2K 2X3

Attention: Alex Lalonde

Subject: Site Lighting Certification for 5000 Robert Grant, Ottawa, Ontario

Dear Mr. Lalonde,

The following is to confirm that the proposed site lighting design for the above mentioned project complies with the City of Ottawa standards pertaining to full cut-off classification fixtures and minimal light spillage (maximum 5.38 Lux or 0.5 fc) on adjacent properties.

In the summary of our lighting design simulation, the lighting levels at the property line are as follows:

1. Average lighting level: 1.39 Lux or 0.0 fc
2. Minimum lighting level: 0.0 Lux or 0.0 fc
3. Maximum lighting level: 57.5 Lux or 0.5 fc

The proposed light fixture model is identified in the light simulation document attached. The proposed fixtures are installed at different height levels as identified on luminaire schedule.

Yours truly,
LRL Associates Ltd.

Mackenzie Canto

Mackenzie Canto, Electrical
Technologist



Martin Tessier, P. Eng



