



January 6, 2025

City of Ottawa
110 Laurier Avenue West
Ottawa, Ontario
K1P 1J1

Attention: City Building Official

**Re: 570 March road – Nokia Ottawa Campus
Flow Control Roof Drainage Declaration
Our Reference No. 5961-02**

As requested, Adjeleian Allen Rubeli Limited (AAR) has reviewed the proposed roof concept at for the new buildings at the Nokia Ottawa Campus, Ottawa.

This letter is to be read in conjunction with the letter prepared by Smith+Andersen dated October 25, 2024.

We understand that the roofs will be designed with both conventionally drained roofs and flow controlled roof areas. Where flow control drains are used, the structural design will be coordinated to meet the conditions identified in the Smith+Andersen letter.

In addition, loads due to rain are not considered to act simultaneously with loads due to snow per the OBC.

We trust you will find the above satisfactory. Do not hesitate to contact the undersigned should you need any further clarification or to discuss any aspect of this letter.

Yours truly,
ADJELEIAN ALLEN RUBELI LIMITED



Jean-Michel Carrière, P.Eng.