

**C9.0** SCALE 1:10

PARKING LOT STRIPING SPECIFICATIONS:

1. ALWAYS FOLLOW ALL APPLICABLE GOVERNING AUTHORITY'S STANDARDS. 2. SURFACES SHOULD BE CLEAN, DRY, AND FREE FROM LOOSE OR PEELING PAINT. REMOVE ALL OIL, DUST, GREASE, DIRT, AND OTHER FOREIGN MATERIAL TO ENSURE ADEQUATE ADHESION. DO NOT APPLY WHEN AIR OR SURFACE TEMPERATURES ARE BELOW 40°F.

3. APPLY SHERWIN-WILLIAMS SETFAST PREMIUM ALKYD ZONE MARKING PAINT A300 WHITE OR A303 YELLOW USING EITHER AIRLESS OR CONVENTIONAL LINE STRIPING EQUIPMENT. USE THE FOLLOWING SETTINGS AS A GUIDE-ACTUAL SETTINGS DEPEND ON ATMOSPHERIC CONDITIONS AT THE TIME OF APPLICATION:

1800-2700 PSI

BLINKS 21 (BLEEDER) OR EQUIVALENT

¼"-<sup>3</sup>8" ID

AIRLESSPRESSURE HOSETIP

0.015"-0.017" FILTER ONLY IF NECESSARY, UP TO 1PT/GAL REDUCTION VM&P NAPTHA R1K3

FLUID NOZZLE

INTERNAL MIX, #709 AIR NOZZLE ATOMIZATION PRESSURE 45-80 PSI FLUID PRESSURE 40-70 PSI ONLY IF NECESSARY, UP TO 1PT/GAL REDUCTION

 SHERWIN WILLIAMS, H&C SHARK GRIP SLIP RESISTANT ADDITIVE TO BE MEASURED. AND ADDED TO ALL PAINT PER MANUFACTURER'S WRITTEN SPECIFICATIONS. MIX THOROUGHLY PER MANUFACTURER'S RECOMMENDATIONS SO THAT NO CLUMPING IS APPARENT AND UNTIL EVEN DISTRIBUTION IS ACHIEVED. MAINTAIN EVEN

VM&P NAPTHA R1K3

DISTRIBUTION OF ADDITIVE IN PAINT THROUGHOUT THE APPLICATION PROCESS. MIX PAINT THOROUGHLY BY BOXING, STIRRING, OR POWER AGITATION BEFORE USE. APPLY AT 15 MILS WET TO ACHIEVE A SPREAD RATE OF 400-500 LINEAL FEET OF STANDARD 100mm STRIPE PER GALLON. APPLIED AT THIS RATE AT 70 DEGREES F AND 50% RELATIVE HUMIDITY, PAINT WILL DRY WITH NO TRAFFIC PICKUP AFTER

4. UTILIZE 1-800 STENCIL FOR SITE PAVEMENT MARKINGS (STOP, DRIVE-THRU, EXIT, ARROWS, ETC.) 1-800-783-6245 or 1800STENCIL.COM

• GENERAL CONTRACTOR TO RE-STRIPE THE LOT 45 DAYS AFTER OPENING.

1. ACCESSIBLE PARKING AND ACCESSIBLE AISLES SHALL NOT EXCEED 1.5% IN SLOPE IN ANY DIRECTION. IF ONLY ONE

2. PARKING STALL DIMENSIONING SHALL BE IN ACCORDANCE WITH APPLICABLE GOVERNING AUTHORITY'S AND ADA STANDARDS AND IF DIFFERENT THAN THIS DETAIL SHALL BE THE DIMENSIONING SHOWN ON THE SITE LAYOUT PLAN.

3. GENERAL CONTRACTOR SHALL REFER TO CHICK-FIL-A PARKING LOT STRIPING SPECIFICATIONS.

4. CONTRACTOR SHALL USE 100mm WIDE WHITE REFLECTIVE PAINT FOR STRIPING ON ASPHALT PARKING LOTS.

5. CONTRACTOR SHALL USE 100mm WIDE YELLOW REFLECTIVE PAINT FOR STRIPING ON CONCRETE PARKING LOTS.


6. NO WHEEL STOPS TO BE INSTALLED WHEN PARKING IS

ACCCESSIBLE SIGNS IN BOLLARDS AND BOLLARDS SHALL BE INSTALLED WHEN PARKING IS ADJACENT TO FLUSH CURB OR A

JOHN SEVIGNY C.E.T. MANAGER (A), DEVELOPMENT REVIEW EAST **PLANNING, DEVELOPMENT & BUILDING SERVICES DEPARTMENT, CITY OF OTTAWA** 

**APPROVED** 

By sevignyjo at 8:56 am, Jul 29, 2025



MAX. HEIGHT OF LIGHT POLE IS 7.62m ABOVE GRADE. MAX HEIGHT OF CONCRETE BASE IS .61m ABOVE FINISHED GRADE. MAX. EXPOSED AREA OF LIGHT FIXTURES IS 0.2 sq.m @ EACH FIXTURE.

MAX. 3 FIXTURES PER POLE. . TOTAL EXPOSED AREA OF POLE = 1 sq.m.

LIGHT STANDARD BASE **C9.0** SCALE 1:20

Chick-fil-A 5200 Buffington Road Atlanta, Georgia 30349-2998

exp Services Inc. t: +1.905.793.9800 | f: +1.905.793.0641 1595 Clark Boulevard Brampton, ON L6T 4V1

www.exp.com

Canada

• BUILDINGS • EARTH & ENVIRONMENT • ENERGY • • INDUSTRIAL • INFRASTRUCTURE • SUSTAINABILITY •

10/04/2024

FSR#30038

XXXXXXXX

**REVISION SCHEDULE** NO. DATE DESCRIPTION A 2024-09-20 FOR SPA

CONSULTANT PROJECT # SEPTEMBER 2024

Information contained on this drawing and in all digital files produced for above named project may not be reproduced in any manner without express written or verbal consent from

**GENERIC SITE** DETAILS

SHEET NUMBER

**C9.0** SCALE 1:50