



re: Geotechnical Response to City Comments
Proposed Hydrovac Slurry Processing Facility
1850 Bantree Street - Ottawa
to: Harbour Environmental Group - Mr. Sean Yahene - sean@harbourenvgroup.ca
date: February 18, 2025
file: PG6812-MEMO.01

Further to your request and authorization, Paterson Group (Paterson) prepared the following memorandum to provide geotechnical responses to city comments regarding the proposed hydrovac slurry processing facility, at the aforementioned site. This memorandum should be read in conjunction with Paterson Geotechnical Report PG6812-LET.01 Revision 2 dated October 6, 2023.

Comment:

The Geotechnical Investigation did not note any tree planting restrictions or setback requirements on this site.

Response: Based on the geotechnical investigations completed on February 10, 2023, and September 5 & 6, 2023, a sensitive silty clay deposit was not encountered below the ground surface across the site. Therefore, no tree planting or setback restrictions are applicable in relation to the City of Ottawa tree planting guidelines.

We trust that the current submission meets your immediate requirements.

Best Regards,

Paterson Group Inc.

Pratheep Thirumoolan, M.Eng.



Joey R. Villeneuve, M.A.Sc., P.Eng.

