



The Contractor shall verify and be responsible for all dimensions, DO NOT scale the drawing - any errors or omissions shall be reported to Stantec without delay.

The Copyrights to all designs and drawings are the property of Stantec. Reproduction or use for any purpose other than that authorized by Stantec is forbidden.

PROPOSED VALVE AND VALVE BOX
 PROPOSED VALVE CHAMBER
 PROPOSED REDUCER
 PROPOSED FIRE HYDRANT
 PROPOSED SANITARY SEWER
 PROPOSED STORM SEWER
 PROPOSED STORM SEWER AND BITUMINOUS COKE SYSTEM
 PROPOSED CATCHBASIN MANHOLE
 PROPOSED CATCHBASIN
 EXISTING WATERMAIN
 EXISTING VALVE AND VALVE BOX
 EXISTING VALVE CHAMBER
 EXISTING REDUCER
 EXISTING FIRE HYDRANT
 EXISTING SANITARY SEWER
 EXISTING STORM SEWER
 EXISTING CATCHBASIN MANHOLE
 EXISTING CATCHBASIN
 PROPOSED DEPRESSIONED CURB LOCATIONS
 PROPOSED BARRIER CURB
 THERMAL INSULATION ON STORM SEWER WHERE COVER IS LESS THAN 1.5m. THERMAL INSULATION ON WATERMAIN WHERE COVER IS LESS THAN 2.4m AS PER WZZ.

SCUPPER LOCATIONS
 TYPICAL ROAD CROSS-SECTION
 REFER TO D-26 FOR MORE DETAILS

SERVICE LATERAL LOCATION (SANITARY AND WATER ONLY)
 150mm (6") SANITARY SERVICE CIVIC 502R 208 11.5m (6")
 150mm (6") TUBING WATER SERVICE CIVIC 502R 208 11.5m (6")
 POST, METER AND REMOTE METER
 STANDPOST ON PRIVATE SIDE TO BE LOCATED 5.0m MINIMUM FACE OF CURB. STANDPOST ON PUBLIC SIDE TO BE ON PROPERTY

SERVICE LATERAL LOCATION (SANITARY, WATER AND STORM)
 100mm (4") STORM SERVICE CIVIC 502R 208 11.5m (6")
 130mm (5") SANITARY SERVICE CIVIC 502R 208 11.5m (6")
 150mm (6") TUBING WATER SERVICE CIVIC 502R 208 11.5m (6")
 POST, METER AND REMOTE METER
 STANDPOST ON PRIVATE SIDE TO BE LOCATED 5.0m MINIMUM FACE OF CURB. STANDPOST ON PUBLIC SIDE TO BE ON PROPERTY

File Name: 160402127-DB	JP	PM	JP	25.03.24
	Dwn.	Chkd.	Dsgn.	YY.MM.DD

CONFESION



Project No. _____ Scale _____
 Drawing No. _____ Sheet _____ Revision _____

D07-12-25-0063

