

Legend

- PROPOSED WATERMAIN
- PROPOSED VALVE AND VALVE BOX
- PROPOSED VALVE CHAMBER
- PROPOSED W3 CHAMBER
- PROPOSED REDUCER
- PROPOSED FIRE HYDRANT
- PROPOSED SANITARY SEWER
- PROPOSED STORM SEWER
- PROPOSED CATCHBASIN MANHOLE
- PROPOSED CATCHBASIN
- PROPOSED CB T AND SUBDRAIN
- EXISTING WATERMAIN
- EXISTING VALVE AND VALVE BOX
- EXISTING VALVE CHAMBER
- EXISTING REDUCER
- EXISTING FIRE HYDRANT
- EXISTING COMBINED SEWER
- EXISTING STORM SEWER
- EXISTING CATCHBASIN MANHOLE
- EXISTING CATCHBASIN
- PROPOSED DEPRESSED CURB LOCATIONS
- PROPOSED BARRIER CURB
- THERMAL INSULATION ON STORM SEWER WHERE COVER IS LESS THAN 2.0m AND ON SANITARY SEWER WHERE COVER IS LESS THAN 2.5m AS PER S35
- INSULATION OVER WATERMAIN PER W22 WHERE COVER IS LESS THAN 2.4m
- WATER METER
- REMOTE WATER METER
- PROPOSED 2H RATED FIRE WALL LOCATION
- BACK TO BACK TERRACE HOME SERVICES
- 200mm STORM SERVICE PVC SDR 26 @ 1% MIN
- 150mm SANITARY SERVICE PVC SDR 26 @ 1% MIN
- 15mm PER TUBING WATER SERVICE C/W CURB STOP AND SERVICE POST
- BACK TO BACK TERRACE HOME SERVICE ELEVATIONS

Notes

5	REVISED BUILDING FOOTPRINTS	KV	KS	26.09.02
4	REVISED SITE PLAN AND SERVICE LOCATIONS BLD A & B	KV	KS	26.04.25
3	REVISED SITE PLAN AND CITY COMMENTS	KV	KS	26.05.20
2	WATER ENTRY BUILDING C	KV	KS	26.03.19
1	REVISED SITE PLAN	KV	KS	26.03.17
0	ISSUED FOR SPA	MJS	KS	25.11.02
Revision		By	App'd.	YY.MM.DD
File Name: 16040210.dwg		MJS	DT	25.09.30
Permit-Seal		Dwn.	Chkd.	Dsgn.

Client/Project

MATTAMY HOMES LTD.
50 HINES ROAD, SUITE 100
OTTAWA, ON, K2K 2M5

NORTHWOODS SUBDIVISION
PHASE 6, BLOCK 454
OTTAWA, ON, CANADA

Title

SITE SERVICING PLAN

Project No.

16040210

Drawing No.

SSP-1

Scale

0 2.5 7.5 12.5m
1:250

Sheet

3 of 7

Revision

5

