

Gatineau, February 05th 2018

Vincent Dénommé

Coordinator – Land Development

www.brigit.com

T 819.243.7392 EXT 128

vdenomme@brigit.com

98 Lois, Gatineau,

QC J8Y 3R7

Object : Storm Water Management


Project : Petries Landing 2: Bloc 6-7-8

**(Site Plan Control application
8466 Jeanne-d'Arc Boulevard - File No. : D07-12-17-0093)**

Mr. Dénommé,

Storm water from the roof will be flow controlled in accordance with the requirements of clause 7.4.10.4 of the 2012 Ontario building Code whereby it spills via designed scuppers after 150 mm depth.

If supplementary information is necessary, do not hesitate to contact the undersigned.

A handwritten signature in blue ink, appearing to read "M. Larouche", is written over a horizontal line.

2018-02-05

Michel Larouche, ing, P.eng, PA.LEED®