



**Ottawa Train Yards  
200, 230, 260 Steamline Street  
Ottawa, Ontario**

**Servicing Report & Stormwater Management**

**Type of Document**  
Site Plan Submission

**Client:**  
Controlex Corporation

**Project Number**  
OTT-00243332-A0

**Prepared By:** M. Lafleur, P.Eng.

**Reviewed By:** A. Ansari, P.Eng.

**exp** Services Inc.  
100-2650 Queensview Drive  
Ottawa, ON K2B 8H6  
Canada

**Date Submitted**  
January 2018  
Revised June 2018

# Ottawa Train Yards 200, 230, 260 Steamline Street Ottawa, Ontario

## Servicing Report & Stormwater Management

**Type of Document:**  
Site Plan Submission

**Project Name:**  
Ottawa Train Yards  
200, 230, 260 Steamline Street

**Project Number:**  
OTT-00243332-A0

**Prepared By:**  
exp  
100-2650 Queensview Drive  
Ottawa, ON K2B 8H6  
Canada  
T: 613 688-1899  
F: 613 225-7337  
www.exp.com

  
\_\_\_\_\_  
Marc Lafleur, P.Eng.  
Project Engineer  
Infrastructure Services

  
\_\_\_\_\_  
Alam Ansari, P.Eng.  
Senior Project Manager  
Infrastructure Services



**Date Submitted:**  
January 2018  
Revised June 2018

## Legal Notification

This report was prepared by **exp** Services Inc. for the account of **Ottawa Train Yards Inc.**

Any use which a third party makes of this report, or any reliance on or decisions to be made based on it, are the responsibility of such third parties. **Exp** Services Inc. accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this project.

## Table of Contents

	<b>Page</b>
<b>1.0 Introduction .....</b>	<b>4</b>
<b>2.0 Steamline Street Design .....</b>	<b>4</b>
<b>3.0 Water Servicing .....</b>	<b>4</b>
<b>4.0 Sanitary Sewer Servicing .....</b>	<b>7</b>
<b>5.0 Storm Servicing.....</b>	<b>8</b>
5.1 Storm Servicing Criteria.....	8
5.2 Storm Sewer Design.....	8
<b>6.0 Storm Water Management .....</b>	<b>8</b>
6.1 Design Criteria.....	8
6.1 Pre-Development Conditions .....	9
6.2 Storage Requirements.....	9
<b>7.0 Erosion and Sediment Controls during Construction .....</b>	<b>11</b>
<b>8.0 Summary.....</b>	<b>12</b>

## List of Appendices

Appendix A: Stormwater Management Design

Appendix B: Water

Appendix C: Sanitary Sewer Design

## 1.0 Introduction

**Exp** Services Inc. (**exp**) was retained by Ottawa Train Yards Inc. to prepare a servicing and stormwater management report for the proposed phased residential development located at 200, 230, 260 Steamline Street in the Ottawa Train Yards. The proposed development covers an area of 4.25ha, including 0.75ha of Steamline Street ROW. The project will be developed in multiple phases and is located east of Sandford Fleming Road and south of Terminal Avenue. Road access to the development will be provided by Steamline Street that will be connected to Sandford Fleming Road at the west end and Terminal Road on the north-east end. Since road access to the proposed development will primarily be from Steamline Street, design and construction of the Steamline Street will be completed as part of the residential development.

## 2.0 Steamline Street Design

Steamline Street will be a public local road with a 20m ROW. Design of the Steamline Street has been completed in accordance with the City of Ottawa design guidelines and will be submitted to the city together with the site plan control application for the residential development. The design of Steamline Street includes a 200mm diameter water main that will be connected to the existing 300mm diameter municipal watermain on Sandford Fleming Ave and to the existing 300mm diameter municipal watermain on Terminal Avenue. This water main will be the primary source of water supply for the proposed development. The Steamline Street design also includes a 600, 750 and 825mm diameter storm sewer that will convey storm water flows from the proposed development to the existing 900mm diameter storm sewer north of Steamline Street. The sanitary service for the development will be provided by a new 250mm diameter sanitary sewer along Steamline Street. The sanitary sewer will be connected to the 250mm diameter municipal sanitary sewer on Sandford Fleming Road at the west end of the Street and to the 250mm diameter municipal sanitary sewer at Terminal Avenue at the north-east end.

Due to limited capacity of the existing sanitary sewer on Sandford Fleming Road, only sanitary flows from phases 1 and 2 of the residential development will be conveyed to the municipal sewer along Sandford Fleming Ave. Sanitary flows from phase 3 of the proposed development will be conveyed to the existing sanitary sewer on Terminal Ave.

Capacity analysis of the existing municipal sanitary sewers on Sandford Fleming Road and Terminal Avenue are included in this report. Refer to Appendix C.

## 3.0 Water Servicing

The master servicing report for the subdivision completed in 2002 included a watermain hydraulic analysis that demonstrated that there was adequate water supply to support development of the subject site. The development will primarily be serviced by the new 200 mm diameter watermain along Steamline Street.

In order to lower the risk of water supply interruption each building will be provided with two 200mm diameter water services, separated by an isolation valve. Building # 100 will be serviced from the municipal water main along Sanford Fleming Road. The remaining buildings will be serviced from the new water main along Steamline Street. Water distribution system pressures were checked under maximum day conditions for all three phases of the development and fire water demand for building # 200. Results of analysis indicate that the water distribution system has residual pressure in excess of 140kPa (20psi) which is the minimum pressure required under the city of Ottawa water distribution guidelines.

The residential water demands for the proposed development was calculated based on City of Ottawa Water Distribution Design Guidelines (WDG001 2010) and Technical Bulletins ISDTB-2014-02 and ISTB-2018-02. Based on the proposed number and type of apartments, the proposed development will have 3389 residents. The total number of residents is calculated as follows:

Apartment Type	Persons per Unit	# of Units Phase 1	# of Units Phase 2	# of Units Phase 3	Total # of Units	Total Persons per Unit
Bachelor	1.4	47			47	66
1 Bedroom	1.4	185			185	259
2 Bedroom	2.1	184			184	386
3 Bedroom	3.1	4			4	12
Avg Apt	1.8		865	605	1 470	2645
					<b>Total Pers:</b>	<b>3368</b>

The domestic water demand for the proposed residential development is calculated as follows:

**Water Demand:**

Average daily demand:

$$\begin{aligned}
 &= 3368 \text{ pers} \times 280 \text{ L/pers/day} \\
 &= 943\,040 \text{ L/day} \times (1/86,400 \text{ sec/day}) \\
 &= 10.9 \text{ L/sec}
 \end{aligned}$$

Maximum daily demand:

$$\begin{aligned}
 &= 2.5 \times \text{avg. day} \\
 &= 2.5 \times 10.9 \text{ L/sec} \\
 &= 27.3 \text{ L/sec}
 \end{aligned}$$

Maximum hourly daily demand:

$$\begin{aligned}
 &= 2.2 \times \text{max. day} \\
 &= 2.2 \times 27.3 \text{ L/sec} \\
 &= 60.1 \text{ L/sec}
 \end{aligned}$$

Fire water demand was calculated using the Fire Underwriters Survey criteria from the Office of the Fire Marshall, Ontario. A fire demand of 100 L/s was calculated for building # 200 which is the largest building in the proposed development. Refer to Appendix C for the fire flow calculations and boundary conditions. Fire flow demand was calculated assuming that the building is sprinklered, of fire-resistive construction with limited combustible contents. Refer to Appendix B for fire flow demand calculations.

The City of Ottawa provided boundary conditions at two locations under maximum day for all phases of development and fire water demand of 100L/s. The two boundary condition locations are at the intersection of Steamline Street and Terminal Avenue and intersection of Steamline Street and Sanford Fleming Road. Refer to Appendix B. The boundary conditions are as follows:

Terminal Ave and Steamline Street intersection:

*Minimum HGL = 109.3m*

*Maximum HGL = 118.9m*

*Maximum Day + Fire Flow (100 L/s) HGL= 114.2m*

Sanford Fleming Road and Steamline intersection:

*Minimum HGL = 108.8m*

*Maximum HGL = 118.9m*

*Maximum Day + Fire Flow (100 L/s) HGL= 113.5m*

Pressure checks were performed at the mid point of Steamline Street to check that whether adequate pressure will be available for the proposed development under maximum day + fire flow conditions. Pressure losses have been calculated from the two intersections to the mid point of Steamline Street. Refer to Appendix B for water pressure analysis.

Terminal Ave and Steamline Street intersection:

Road Elevation at the water main on Terminal Avenue is 65.46m

Pressure head at Terminal Avenue under the Max day + Fire scenario will be  $114.2 - 65.46 = 48.74\text{m}$

Water pressure at Terminal Avenue = 68.3psi

Length of 200mm diameter water service from 305mm municipal water main on Terminal Ave to the midpoint of Steamline Street= 201.3m

Hydraulic losses in 200m length of water main = 35.8psi

Pressure at midpoint of Steamline Street=  $68.3 - 35.8 = 32.5\text{psi}$

Available pressure at the building under maximum day + fire flow demand of 135.65 L/sec. is greater than 20psi.

Sandford Fleming Ave and Steamline intersection:

HGL at the 305mm diameter watermain on Sandford Fleming Ave intersection with Steamline Street:

Road Elevation at the water main on Sandford Fleming Ave is 65.55m

Pressure head at Sanford Fleming Avenue under the Max day + Fire scenario will be  $113.5 - 65.55 = 47.95\text{m}$

Water pressure at Sandford Fleming Ave = 69.2psi

Length of 200mm diameter water service from 305mm municipal water main on Sandford Fleming Ave to the middle of Steamline Street= 201.3m

Hydraulic losses in 200m length of water main = 27.8psi

Pressure at midpoint of Steamline Street=  $69.2 - 27.8 = 41.4\text{psi}$

Available pressure along Steamline Street under maximum day + fire flow demand of 135.65 L/sec is greater than 20psi.

Therefore, the existing 200mm diameter water main on Steamline Street will have adequate capacity to service the proposed buildings.

Steamline street is designed to be the fire access route for the proposed development. Fire hydrants are located along the south side of Steamline street with a maximum spacing of 90m as per City of Ottawa design guidelines. For phase I, the fire hydrant at the Sanford Fleming and Steamline intersection is to be relocated and will be within an unobstructed 45m from building 100's Siamese connection. Similarly, the fire hydrant north of building 200 will be within an unobstructed 45m to the Siamese connection as per the Onatrio Building Code.

## **4.0 Sanitary Sewer Servicing**

Sanitary Sewer flows for the proposed development have been calculated in accordance with the City of Ottawa Sewer Design Guidelines (SDG002) and technical bulletin ISTB-2018-01. Refer to Appendix C for the Sanitary Sewer Design sheets. Sewage flows from phases 1 and 2 of the development will be conveyed to the existing 250mm diameter municipal sanitary sewer on Sanford Fleming Road. Due to limited capacity of sanitary sewer on Sanford Fleming Road, sewage flows from phase 3 will be directed to the municipal sanitary sewer on Terminal Avenue. Refer to the Sanitary Drainage Area Plan Figure SA-1 in Appendix C. The municipal sanitary sewers on Sanford Fleming Road and Terminal Avenue have adequate capacity to receive the flows from the proposed development. Capacity analysis of the existing municipal sanitary sewers is included in Appendix C.

The peak flow for phases 1 and 2 is estimated to be 22.39 L/s. The 250mm sanitary sewer on Steamline Street at a grade of 0.5% has a maximum capacity of 42 L/s, based on Manning's equation under full flow conditions. Therefore, the 250mm sanitary sewer on Steamline Street will be adequate to convey the estimated peak sewage flows from Phase 1 and Phase 2 of the development. The sewer design sheet and sanitary drainage area plan included in Appendix C confirm that the existing 250mm sanitary sewer on Sandform Fleming Ave has the capacity to convey the flows from existing developments on Sandform Fleming Ave as well as the flows from the Phase 1 and Phase 2 of the proposed development on Steamline street.



The estimated peak flow from Phase 3 of the development is of 11.36 L/s. The 250mm diameter sewer on Steamline Street at a grade of 0.3% has a maximum capacity of 32.6 L/s. Therefore, the 250mm sanitary sewer on Steamline Street will be adequate to convey the estimated peak sewage flows from Phase 3 to the sewer on Terminal Ave. The sewer design sheet and sanitary drainage area plan included in Appendix C confirm that the existing 250mm sanitary sewer on Terminal Ave has the capacity to convey the flows from existing developments on Terminal Ave as well as the flows from the Phase 3 of the proposed development on Steamline street.

## **5.0 Storm Servicing**

### **5.1 Storm Servicing Criteria**

The design criteria for storm servicing design is summarized below.

- Storm sewers have been designed and sized based on the rational formula and Manning's Equation under free flow conditions for the 5-year storm using a 15-minute inlet time.
- The City of Ottawa IDF curve was used for design purposes.
- Average runoff coefficients were calculated for each inlet drainage area using a runoff coefficient of 0.20 for pervious surfaces and 0.90 for impervious surfaces.
- Runoff coefficients for the 100-year storm were increased by 25% to a maximum of 1.00.

### **5.2 Storm Sewer Design**

The storm water management for the proposed development will be completed in accordance with the design criteria established in the master site servicing report for the subdivision. A new storm sewer will be constructed along Steamline Street which will convey the storm water flows from the proposed development to the existing 900mm diameter storm sewer north of Steamline Street near the intersection with Sandford Fleming Ave, which outlets into the 1200 mm municipal sewer on Terminal Avenue.

## **6.0 Storm Water Management**

### **6.1 Design Criteria**

The major system design for the site development is summarized below.

- The major system has been designed to accommodate on-site detention with sufficient capacity to attenuate the 100-year storm water flows to 5-year pre-development levels. Overland flow routes are provided to convey overland flows towards Terminal Ave and Sandford Fleming Ave.
- On-site storage is provided and calculated for up to the 100-year design storm with maximum ponding depth of 300mm. Calculation of the required on-site storage volumes has been supported by calculations in Appendix A.
- The required storage volumes have been calculated based on the Modified Rational Method.
- The finished floor elevations of the proposed residential buildings are a minimum of 300mm above the overland flow route spill elevations.

## 6.1 Pre-Development Conditions

In the existing condition, the majority of the 3.5 ha site drains to the 900mm diameter storm sewer north of Steamline through a storm sewer network on the property. The master servicing report for the Ottawa Trainyards states that the release rate up to the 100-year event is to be controlled to the 5-year pre-development release rate, using a pre-development runoff coefficient of 0.4. This allowable release rate corresponds to an allowable release rate of 92.92 L/s/ha. The allowable release for each phase of the proposed residential development is calculated as follows:

Allowable Runoff Coefficient:	0.40 (C)
Rainfall Intensity:	$I_{(5\text{year}, 15\text{ min})} = 83.56 \text{ mm/hr}$
Allowable Runoff Rate:	$Q = 2.78CiA = 2.78(0.4)83.56$ $Q = 92.92 \text{ L/s/ha}$
Phase 1 Site Area:	1.08 hectares (A)
Allowable Release Rate:	$Q = 1.08 \text{ ha} \times 92.92 \text{ L/s/ha} = 100.3 \text{ L/s}$
Phase 2 Site Area:	1.46 hectares (A)
Allowable Release Rate:	$Q = 1.46 \text{ ha} \times 92.92 \text{ L/s/ha} = 135.7 \text{ L/s}$
Phase 3 Site Area:	0.98 hectares (A)
Allowable Release Rate:	$Q = 0.98 \text{ ha} \times 92.92 \text{ L/s/ha} = 91.1 \text{ L/s}$

Total allowable release rate for the Site:  $Q = 100.3 \text{ L/s} + 135.7 \text{ L/s} + 91.1 \text{ L/s}$   
 $Q = 327.1 \text{ L/s}$

## 6.2 Storage Requirements

The allowable release rate from the 3.5ha site is 327.1 L/s. Runoff from the surface will be captured using deck drains that will drain into the storm water retention tanks which will be located below grade within the parking garage. The storm water tanks will be equipped with ICDs and backwater valves. Run off from the roof will be controlled using flow control roof drains.

The storm water retention tanks will be sized to provide the required storage for the 100-year storm event. The maximum ponding depth on the roof shall be limited to 150mm. The storage required was determined using the Modified Rational Method. Calculations are provided in Appendix A. Table 6.1 below summarizes the storage provided on rooftops and in storage tanks within the underground parking, for each phase of development.

**Table 6. 1 Summary of 100-Year Storage Requirements**

	# of Buildings	100 Year Allowable Release Rate (L/s)	100 Year Minimum Storage Required (m <sup>3</sup> )	100 Year Rooftop Storage Volume Provided (m <sup>3</sup> )	100 Year Storage Tanks Total Volume Required (m <sup>3</sup> )
<b>Phase 1</b>	2	100.3	316	100	216
<b>Phase 2</b>	3	135.7	427	150	277
<b>Phase 3</b>	2	91.1	287	100	187
<b>TOTALS:</b>	7	327.1	1 030	350	680

Total storage volume required to restrict flows from the site to **327.1 L/s** was calculated to be **1030 m<sup>3</sup>** for the 100-year event.

Storage requirements for Phase 1 of development were determined assuming that 50 m<sup>3</sup> of storage will be provided on each of the roofs of Building 100 and Building 200. Each of the two storage tanks in Phase 1 was sized to receive half of the runoff from the surface, captured in the deck drains. Table 6.2 below summarizes the controlled release rates and storage requirements for Phase 1 of the development. It was determined that each retention tank will provide 112 m<sup>3</sup> of working storage volume.

**Table 6. 2 Phase 1 Summary of 100-Year Storage Requirements**

<b>Phase 1 Area ID</b>	<b>Area (ha)</b>	<b>100 Year Controlled Release Rate (L/s)</b>	<b>100 Year Minimum Storage Required (m<sup>3</sup>)</b>	<b>100 Year Minimum Storage Provided (m<sup>3</sup>)</b>
Building 100	0.13	6.4	50	65
Building 200	0.14	8.4	50	70
Cistern #1	0.41	42.5	112	112
Cistern #2	0.41	42.5	112	112
<b>Total:</b>	1.08	99.8	323.4	359

A 120mm plug type orifice will be provided at the outlet of each storage tank. With a maximum head of 2m the 120mm plug type orifice will have a maximum release rate of 42.5L/s during the 100-year event. Refer to Appendix A for orifice sizing calculations. Flow control roof drains will attenuate the 100-Year flows from Building 100 and Building 200 to 6.4 L/s and 8.4 L/s respectively. The controlled release rate from Phase 1 will be 99.8L/s during the 100-year event which is less than the allowable 100.3 L/s.

The roof drains will be equipped with flow control devices located on the roof. Refer to architect's roof layout plan for exact roof drain locations and to the mechanical consultant's plans for the specifications of the roof drain flow control devices. The storm water retention tanks will be located north of building 100 and 200 and will be equipped with overflow drains which will allow the stormwater runoff exceeding the 100-year event to bypass the plug type orifice. Storm services will connect building 100's retention tank to storm manhole 110 and building 200's retention tank to storm manhole 109, respectively. Refer to the Legend, Notes & Details plan (LN) and the locations and a cross section of the proposed retention tanks.

Surface storage on the site will not be provided since the deck drains will not be equipped with flow control devices. In the event that deck drains at the surface of the site become blocked, overland flow routes are provided across the site from south to north discharging to Steamline Street. Overland flow routes from Steamline Street are provided towards Terminal Ave and Sandford Fleming Ave. The finished floor elevations of the proposed buildings have been set to a minimum of 0.3m above the highest spill elevation of the overland flow routes.

## **7.0 Erosion and Sediment Controls during Construction**

During all construction activities, erosion and sedimentation shall be controlled by the following techniques:

- limiting the extent of exposed soils at any given time,
- re-vegetation of exposed areas as soon as possible,
- installation of filter cloth between frame and cover on all proposed catch basins and catch basin manholes,
- silt fence to be installed 0.3 meters inside and along the site property lines,
- visual inspection shall be completed daily on sediment control barriers and any damage repaired immediately. Care will be taken to prevent damage during construction operations,
- in some cases barriers may be removed temporarily to accommodate the construction operations. The affected barriers will be reinstated at night when construction is completed,
- sediment control devices will be cleaned of accumulated silt as required. The deposits will be disposed of as per the requirements of the contract,
- during the course of construction, if the engineer believes that additional prevention methods are required to control erosion and sedimentation, the contractor will install additional silt fences or other methods as required to the satisfaction of the engineer, and
- construction and maintenance requirements for erosion and sediment controls are to comply with Ontario Provincial Standard Specification (OPSS) OPSS 805.

## 8.0 Summary

This servicing brief outlines the rationale which will be used to service the proposed development. The following summarizes the design for the site:

- The Steamline Street storm sewer system is sized to accommodate the 5-year design storm under free flow conditions.
- The allowable release rate from the proposed residential development site was based on the pre-development runoff coefficient of 0.4 and was determined to be 327.1 L/sec in a 5-year storm event.
- Flow from the site will be attenuated to the allowable release rate by two methods described below:
  - Runoff from the surface will be captured using decks drains that will drain to storage tanks equipped with inlet control devices, located below grade within the parking garage.
  - Flows from the roof of the building will be controlled using flow control roof drains
- An overland flow route is provided for the major storm events from south to north across the site, out letting onto Steamline Street. Overland flow routes are provided from Steamline Street to Terminal Ave and Sandford Fleming Ave.
- A 200mm looped watermain along Steamline Street connected to the the existing 300mm diameter municipal watermain on Terminal Ave and Sandford Fleming Ave will meet the domestic and fire water requirements for the proposed development. Each building will be provided with two 200mm diameter services.
- Each Building will have a 250mm sanitary sewer service connected to the 250mm diameter sanitary sewer along Terminal Ave. Sanitary flows from Phase 1 and Phase 2 will be conveyed to the 250mm sanitary sewer on Sandford Fleming Ave. Sanitary flows from Phase 3 of the proposed development will be conveyed to the 250mm sanitary sewer on Terminal Ave.

## **Appendix A: Stormwater Management Design**

Stormsewer Design Sheet

Storm Drainage Plan

Stormwater Management Design Sheets

Stormwater Storage Tank Cross Section


Ottawa Trainyards - Steamline Street  
Client: Controlex Realty Management  
Project: OTT-00243332-A0  
Date: January 2018



5 year Free Flow Storm Sewer Design Sheet

LOCATION		Area (ha)	R=	INDIV 2.78 AR	ACCUM 2.78 AR	TIME OF CONC.	RAINFALL INTENSITY I	BLDG FLOW Q (l/s)	PEAK FLOW Q (l/s)								
FROM	TO									PIPE SIZE (mm)	PIPE SLOPE (%)	LENGTH (m)	CAPACITY (l/s)	FULL FLOW VELOCITY (m/s)	TIME OF FLOW (min.)	EXCESS CAPACITY (l/s)	Q/Qfull
TRUNK A																	
STM101	STM102	0.15	0.90	0.39	0.39	10.00	104.19		40.15	600.0	0.70	27.6	514.24	1.82	0.25	474.09	0.08
STM102	STM103	0.00	0.90	0.00	0.39	10.25	102.87		39.64	600.0	0.70	27.5	514.24	1.82	0.25	474.60	0.08
Phase 3 Stub		0.49	0.90	1.23	1.23	10.00	104.19		127.74	375.0	1.00	10.0	175.51	1.59	0.10	47.77	0.73
Phase 3 Stub		0.49	0.90	1.23	1.23	10.00	104.19		127.74	375.0	1.00	10.0	175.51	1.59	0.10	47.77	0.73
STM103	STM104	0.00	0.90	0.00	2.84	10.51	101.60		288.26	600.0	0.70	25.3	514.24	1.82	0.23	225.98	0.56
STM104	STM105	0.00	0.00	0.00	2.84	10.74	100.45		285.01	600.0	0.70	26.6	514.24	1.82	0.24	229.23	0.55
STM105	STM106	0.21	0.90	0.52	3.36	10.98	99.28		333.35	600.0	0.70	24.6	514.24	1.82	0.23	180.89	0.65
STM106	STM107	0.00	0.90	0.00	3.74	11.21	98.22		367.64	600.0	0.70	46.0	514.24	1.82	0.42	146.60	0.71
Phase 2 Stub		0.73	0.90	1.83	1.83	10.00	104.19		190.30	450.0	1.00	10.00	285.39	1.79	0.09	95.09	0.67
Phase 2 Stub		0.73	0.90	1.83	1.83	10.00	104.19		190.30	450.0	1.00	10.00	285.39	1.79	0.09	95.09	0.67
STM107	STM108	0.00	0.90	0.00	7.40	11.63	96.31		712.28	750.0	0.70	44.00	932.37	2.11	0.35	220.09	0.76
STM108	STM109	0.20	0.90	0.49	7.89	11.98	94.79		747.80	750.0	0.70	45.10	932.37	2.11	0.36	184.57	0.80
Phase 1 Stub		0.54	0.90	1.35	1.35	10.00	104.19		140.77	375.0	1.00	10.00	175.51	1.59	0.10	34.73	0.80
Phase 1 Stub		0.54	0.90	1.35	1.35	10.00	104.19		140.66	375.0	1.00	10.00	175.51	1.59	0.10	34.85	0.80
STM109	STM110	0.20	0.90	0.50	11.09	12.33	93.29		1034.65	825.0	0.70	51.53	1202.18	2.25	0.38	167.53	0.86
STM110	Outlet	0.00	0.90	0.00	11.09	12.72	91.74		1017.47	825.0	0.91	15.40	1370.70	2.56	0.10	353.23	0.74
TOTAL		4.28		10.70		12.82						393.7					

Notes:  
Rainfall Intensity = 998.071/(T+6.053)<sup>^-0.814</sup>    T= time in minutes







#### ALLOWABLE RELEASE RATE PER PHASE

##### Phase 1

###### 5 Year Event

	C	Intensity	Area
5 Year	0.40	83.56	1.080
2.78CIA=	100.35		
100.3 L/s			

\*\*Use a 15 minute time of concentration

#### QUANTITY STORAGE REQUIREMENTS - 100 Year

1.080 = Area(ha)  
 1.00 = °C

Return Period	Time (min)	Intensity (mm/hr)	Flow Q (L/s)	Allowable Runoff (L/s)	Net Runoff To Be Stored (L/s)	Storage Req'd m <sup>3</sup>
100 YEAR						
	10	178.56	536.1	100.3	435.8	261.5
	20	119.95	360.1	100.3	259.8	311.7
	30	91.87	275.8	100.3	175.5	315.9
	40	75.15	225.6	100.3	125.3	300.6
	50	63.95	192.0	100.3	91.7	275.0
Max =						315.9

##### Phase 2

###### 5 Year Event

	C	Intensity	Area
5 Year	0.40	83.56	1.460
2.78CIA=	135.66		
135.7 L/s			

1.460 = Area(ha)  
 1.00 = °C

Return Period	Time (min)	Intensity (mm/hr)	Flow Q (L/s)	Allowable Runoff (L/s)	Net Runoff To Be Stored (L/s)	Storage Req'd m <sup>3</sup>
100 YEAR						
	10	178.56	724.7	135.7	589.1	353.4
	20	119.95	486.9	135.7	351.2	421.4
	30	91.87	372.9	135.7	237.2	427.0
	40	75.15	305.0	135.7	169.3	406.4
	50	63.95	259.6	135.7	123.9	371.8
Max =						427.0

##### Phase 3

###### 5 Year Event

	C	Intensity	Area
5 Year	0.40	83.56	0.980
2.78CIA=	91.06		
91.1 L/s			

0.980 = Area(ha)  
 1.00 = °C

Return Period	Time (min)	Intensity (mm/hr)	Flow Q (L/s)	Allowable Runoff (L/s)	Net Runoff To Be Stored (L/s)	Storage Req'd m <sup>3</sup>
100 YEAR						
	10	178.56	486.5	91.1	395.4	237.2
	20	119.95	326.8	91.1	235.7	282.9
	30	91.87	250.3	91.1	159.2	286.6
	40	75.15	204.7	91.1	113.7	272.8
	50	63.95	174.2	91.1	83.2	249.5
Max =						286.6

#### Equations:

##### Flow Equation

$$Q = 2.78 \times C \times I \times A$$

Where:

C is the runoff coefficient

I is the intensity of rainfall, City of Ottawa IDF

A is the total drainage area

Ottawa Train Yards - 200, 230, 260 Steamline Street  
 Client: Controlex Realty Management  
 exp Project: OTT-00224645-A0  
 Date: June 2018



### Phase 1 - Stormwater Management Summary

Sub Area I.D.	Sub Area (ha)	Composite C	100 Year Controlled Release (L/s)	100 year Storage Required (m <sup>3</sup> )	100 Year Storage Provided (m <sup>3</sup> )
Building 100	0.13	0.90	6.40	50	65
Building 200	0.14	0.90	8.4	50	70
Cistern #1	0.41	0.90	42.5	112	112
Cistern #2	0.41	0.90	42.5	112	112

<b>TOTAL</b>	<b>1.08</b>		<b>99.8</b>	<b>323.4</b>	<b>359.0</b>
	<b>Total Allowable Release (L/s):</b>		<b>100.3</b>		

**Ottawa Train Yards - 200, 230, 260 Steamline Street**

Client: Controlex Realty Management

exp Project: OTT-00224645-A0

Date: January 2018

**Building 100 Roof Storage****QUANTITY STORAGE REQUIREMENTS - 100 Year**

0.13 = Area(ha)

1.00 = °C

Return Period	Time (min)	Intensity (mm/hr)	Flow Q (L/s)	Allowable Runoff (L/s)	Net Runoff To Be Stored (L/s)	Storage Req'd (m <sup>3</sup> )	Storage Available (m <sup>3</sup> )
100 YEAR							
	10	178.56	64.5	6.4	58.1	34.9	65.0
	20	119.95	43.4	6.4	37.0	44.3	65.0
	30	91.87	33.2	6.4	26.8	48.2	65.0
	40	75.15	27.2	6.4	20.8	49.8	65.0
	50	63.95	23.1	6.4	16.7	50.1	65.0
	60	55.89	20.2	6.4	13.8	49.7	65.0
	70	49.79	18.0	6.4	11.6	48.7	65.0

\* Storage available is calculated using the building area multiplied by the maximum ponding depth of 0.15m, and divided by 3 for a conical pond.

**Equations:****Flow Equation**

$$Q = 2.78 \times C \times I \times A$$

Where:

C is the runoff coefficient

I is the intensity of rainfall, City of Ottawa IDF

A is the total drainage area

**Sample Calc:**

$$\text{Storage Available} = \frac{0.13 \times 10000 \times 0.15}{3} = 65 \text{ m}^3$$

**Ottawa Train Yards - 200, 230, 260 Steamline Street**

Client: Controlex Realty Management

exp Project: OTT-00224645-A0

Date: January 2018

**Building 200 Roof Storage****QUANTITY STORAGE REQUIREMENTS - 100 Year**

0.14 = Area(ha)

1.00 = °C

Return Period	Time (min)	Intensity (mm/hr)	Flow Q (L/s)	Allowable Runoff (L/s)	Net Runoff To Be Stored (L/s)	Storage Req'd (m <sup>3</sup> )	Storage Available (m <sup>3</sup> )
100 YEAR							
	10	178.56	69.5	8.4	61.1	36.7	70.0
	20	119.95	46.7	8.4	38.3	45.9	70.0
	30	91.87	35.8	8.4	27.4	49.2	70.0
	40	75.15	29.2	8.4	20.8	50.0	70.0
	50	63.95	24.9	8.4	16.5	49.5	70.0
	60	55.89	21.8	8.4	13.4	48.1	70.0
	70	49.79	19.4	8.4	11.0	46.1	70.0

\* Storage available is calculated using the building area multiplied by the maximum ponding depth of 0.15m, and divided by 3 for a conical pond.

**Equations:****Flow Equation**

$$Q = 2.78 \times C \times I \times A$$

Where:

C is the runoff coefficient

I is the intensity of rainfall, City of Ottawa IDF

A is the total drainage area

**Sample Calc:**

$$\text{Storage Available} = \frac{0.14 \times 10000 \times 0.15}{3} = 70 \text{ m}^3$$

Ottawa Train Yards - 200, 230, 260 Steamline Street  
 Client: Contrex Realty Management  
 exp Project: OTT-00224645-A0  
 Date: January 2018



## Phase 1 Storage Tank Release Rates and Storage Requirements

### QUANTITY STORAGE REQUIREMENTS - 100 Year

0.41 = Area(ha) per storage tank  
 1.00 = °C

Return Period	Time (min)	Intensity (mm/hr)	Flow Q (L/s)	Controlled Runoff (L/s)	Net Runoff To Be Stored (L/s)	Storage Req'd m <sup>3</sup>
100 YEAR	10	178.56	201.0	42.5	158.5	95.1
	15	142.89	160.9	42.5	118.4	106.5
	20	119.95	135.1	42.5	92.5	111.1
	25	103.85	116.9	42.5	74.4	111.6
	30	91.87	103.4	42.5	60.9	109.7
	35	82.58	93.0	42.5	50.5	106.0
	40	75.15	84.6	42.5	42.1	101.0

### Equations:

#### Flow Equation

$$Q = 2.78 \times C \times I \times A$$

Where:

C is the runoff coefficient

I is the intensity of rainfall, City of Ottawa IDF

A is the total drainage area

### Orifice Sizing

Event	Flow (L/s)	Head (m)	ORIFICE AREA(m <sup>2</sup> )	SQUARE (1-side mm)	CIRC (mmØ)
100 Year	42.5	2.00	0.011	106	120

### Orifice Control Sizing

$$Q = 0.6 \times A \times (2gh)^{1/2}$$

Where:

Q is the release rate in m<sup>3</sup>/s

A is the orifice area in m<sup>2</sup>

g is the acceleration due to gravity, 9.81m/s<sup>2</sup>

h is the head of water above the orifice centre in m

d is the diameter of the orifice in m

## **Appendix B: Water**

Boundary Conditions

Fire Flow Calculations

Water Pressure Analysis

**Boundary Condition for Steamline Development**

**Legend**

**Pipe Ownership**

- Private (Green line)
- Public (Blue line)

**Map Details:**

- Streets:** TERMINAL AVE, STEAMLINE ST, INDUSTRIAL AVE, RIVERSIDE DR, SANDFORD FLEMING AVE, ALTA VISTA DR, NEIGHBORHOOD WAY.
- Watermain Network:** Green lines representing private watermain pipes with diameters ranging from 102mm to 305mm.
- Public Watermain:** Blue lines representing public watermain pipes with diameters of 1200mm, 305mm, and 152mm.
- Steamline:** A red line representing the steamline, starting from a red circle node on STEAMLINE ST and extending towards the northeast.
- Connection Points:** Green crosses marking the connection points between the steamline and the watermain network.
- Assumed future 203mm watermain:** A yellow callout box pointing to a green line segment.
- Demands were assigned to a node ~200m from either connection point:** A yellow callout box pointing to a red circle node on STEAMLINE ST.
- Topography:** Contour lines indicating elevation, with values ranging from 1420 to 1525.
- Property Boundaries:** Grey lines delineating individual lots.
- North Arrow:** Located in the top right corner, pointing towards the top of the map.

### Legend

**Pipe Ownership**

- Private
- Public

## Legend

### Pipe Ownership

- Private
- Public

### Legend

**Pipe Ownership**

- Private
- Public

## Legend

### Pipe Ownership

- Private
- Public

Assumed future 203mm watermain

Demands were assigned to a node ~200m from either connection point

## Marc Alain Lafleur

---

**From:** Oram, Cody <Cody.Oram@ottawa.ca>  
**Sent:** Wednesday, December 20, 2017 10:28 AM  
**To:** Marc Alain Lafleur  
**Cc:** Alam Ansari  
**Subject:** RE: Steamline Residential Development - Request for Water Boundary Conditions  
**Attachments:** Steamline Development Dec 2017.pdf

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

The following are boundary conditions, HGL, for hydraulic analysis at Steamline Development (zone 1E) assumed to be connected to the 305mm on Terminal and 305mm on Sandford Fleming (see attached PDF for location).

	305mm on Terminal	305mm on Sandford Flemming
	HGL (m)	HGL (m)
Min HGL	109.3	108.8
Max HGL	118.9	118.9
Max Day + Fire Flow (100 L/s)	114.2	113.5

*Assumed a future 200mm watermain (loop, ~400m long) on Steamline between both connection points.  
Demands were assigned at the middle of this future watermain*

These are for current conditions and are based on computer model simulation.

*Disclaimer: The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of watermains deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation.*

**Cody Oram**, P.Eng. Senior Engineer

Development Review, South Services

Planning, Infrastructure and Economic Development Department | Services de planification, d'infrastructure et de développement économique

City of Ottawa | Ville d'Ottawa

110 Laurier Avenue West. Ottawa, ON | 110, avenue. Laurier Ouest. Ottawa (Ontario) K1P 1J1





---

**From:** Marc Alain Lafleur [mailto:MarcAlain.Lafleur@exp.com]  
**Sent:** Wednesday, December 13, 2017 4:59 PM  
**To:** Oram, Cody <Cody.Oram@ottawa.ca>  
**Cc:** Alam Ansari <alam.ansari@exp.com>  
**Subject:** RE: Steamline Residential Development - Request for Water Boundary Conditions

Hi Cody,

Please find attached FUS calculation sheet for the fireflow calculation.

We have revised the domestic demands to include the 3 phases of residential development along Steamline Street, as well as the future commercial development north of Steamline.

The revised demands are as follows:

Average day:	14.6L/s	(13.7L/s Residential and 0.94L/s Commercial)
Max day:	35.65L/s	(34.25L/s Residential and 1.4L/s Commercial)
Peak Hour:	77.85L/s	(75.35L/s Residential and 2.5L/s Commercial)
Max Day + Fire	135.65L/s	

Please let me know if you would like to discuss.

Thank you



**Marc Alain Lafleur, M.Eng., P.Eng.**

Project Engineer, Infrastructure

exp Services Inc.

t: +1.613.688.1899 x3298 | e: [marcalain.lafleur@exp.com](mailto:marcalain.lafleur@exp.com)

100-2650 Queensview Drive

Ottawa, ON K2B 8H6

Canada

[exp.com](http://exp.com) | [legal disclaimer](#)

*keep it green, read from the screen*

---

**From:** Oram, Cody [mailto:Cody.Oram@ottawa.ca]  
**Sent:** Wednesday, December 13, 2017 4:08 PM  
**To:** Marc Alain Lafleur <[MarcAlain.Lafleur@exp.com](mailto:MarcAlain.Lafleur@exp.com)>  
**Cc:** Alam Ansari <[alam.ansari@exp.com](mailto:alam.ansari@exp.com)>  
**Subject:** RE: Steamline Residential Development - Request for Water Boundary Conditions

Hi Marc,

Will the property north of Steamline be serviced from this watermain in the future? If so an estimated water demand based on future use should be included when designing the watermain.

Also the fire flow seems low. Please provide calculations to support. When calculating the fire flow requirements and affected pipe sizing, designers shall use the FUS method.

Regards,  
Cody

---

**From:** Marc Alain Lafleur [<mailto:MarcAlain.Lafleur@exp.com>]  
**Sent:** Wednesday, December 13, 2017 1:33 PM  
**To:** Oram, Cody <[Cody.Oram@ottawa.ca](mailto:Cody.Oram@ottawa.ca)>  
**Cc:** Alam Ansari <[alam.ansari@exp.com](mailto:alam.ansari@exp.com)>  
**Subject:** Steamline Residential Development - Request for Water Boundary Conditions

Hi Cody,

Can you please provide the boundary conditions for the proposed Residential development on Steamline Street in the Ottawa Train Yards?

The attached map identifies the locations of the proposed watermain connections. Water looping will be provided from the 300mm diameter watermain on Terminal Ave and the 300mm diameter watermain on Sandford Fleming Ave.

The water demands are as follows:

Average Day demand: 1.9L/s  
Max Day: 4.8L/s  
Peak Hour: 10.6L/s  
Max Day + Fire: 104.8L/s

Please let me know if you require any further information.

Thank you.



**Marc Alain Lafleur, M.Eng., P.Eng.**

Project Engineer, Infrastructure  
**exp** Services Inc.

t: +1.613.688.1899 x3298 | e: [marcalain.lafleur@exp.com](mailto:marcalain.lafleur@exp.com)

100-2650 Queensview Drive  
Ottawa, ON K2B 8H6  
Canada

[exp.com](http://exp.com) | [legal disclaimer](#)

*keep it green, read from the screen*

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

,

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

,

**TABLE 1: FIRE FLOW REQUIREMENTS BASED ON FIRE UNDERWRITERS SURVEY(FUS) 1999  
MODIFIED AS PER TECHNICAL BULLETIN ISTB-2018-02  
PROJECT: OTY Steamline Multi Residence**



An estimate of the Fire Flow required for a given fire area may be estimated by:

$$F = 220 * C * \text{SQRT}(A)$$

where:

F = required fire flow in litres per minute

A = total floor area in m<sup>2</sup> (including all storeys, but excluding basements at least 50% below grade)

C = coefficient related to the type of construction

Task	Options	Multiplier	Input	Value Used	Fire Flow Total (L/min)
Choose Building Frame (C)	Wood Frame	1.5	Fire Resistive Construction	0.6	
	Ordinary Construction	1			
	Non-combustible Construction	0.8			
	Fire Resistive Construction	0.6			
Input Building Floor Areas (A)	Floor 3-8		3695	6495.0 m <sup>2</sup>	
	Floor 2		1400		
	Floor 1		1400		
	Basement (At least 50% below grade, not included)		0		
Fire Flow (F)	F = 220 * C * SQRT(A)				10,638
Fire Flow (F)	Rounded to nearest 1,000				<b>11,000</b>

**Reductions/Increases Due to Factors Effecting Burning**

Task	Options	Multiplier			Input						Value Used	Fire Flow Change (L/min)	Fire Flow Total (L/min)					
Choose Combustibility of Building Contents	Non-combustible	-25%			Limited Combustible						-15%	-1,650	9,350					
	Limited Combustible	-15%																
	Combustible	0%																
	Free Burning	15%																
	Rapid Burning	25%																
Choose Reduction Due to Sprinkler System	Adequate Sprinkler Conforms to NFPA13	-30%			Adequate Sprinkler Conforms to NFPA13						-30%	-2,805	6,545					
	No Sprinkler	0%			Standard Water Supply for Fire Department Hose Line and for Sprinkler System						-10%	-1,100	5,445					
	Standard Water Supply for Fire Department Hose Line and for Sprinkler System	-10%																
	Not Standard Water Supply or Unavailable	0%																
	Fully Supervised Sprinkler System	-10%																
	Not Fully Supervised or N/A	0%			Fully Supervised Sprinkler System						-10%	-1,100	4,345					
Choose Structure Exposure Distance	Exposures	Separation Dist (m)	Cond	Separation Conditon	Exposing Wall type	Exposed Wall Length												
						Length (m)	No of Storeys	Lenth-height Factor	Sub- Conditon	Charge (%)	Total Charge (%)	Total Exposure Charge (L/min)						
						Side 1	36	5	30.1 to 45	Type B				50	16	800	5E	5%
						Side 2	85	6	> 45.1	Type B				51	1	51	6	0%
						Side 3	24	4	20.1 to 30	Type B				54	30	1620	4E	10%
	Side 4	45	5	30.1 to 45	Type B	36.8	2	73.6	5C	5%								
Obtain Required Fire Flow	Total Required Fire Flow, Rounded to the Nearest 1,000 L/min =												6,000					
	Total Required Fire Flow, L/s =												100					

**Exposure Charges for Exposing Walls of Wood Frame Construction (from Table G5)**

Type A	Wood-Frame or non-combustible
Type B	Ordinary or fire-resistive with unprotected openings
Type C	Ordinary or fire-resistive with semi-protected openings
Type D	Ordinary or fire-resistive with blank wall

**Conditions for Separation**

Separation Dist	Condition
0m to 3m	1
3.1m to 10m	2
10.1m to 20m	3
20.1m to 30m	4
30.1m to 45m	5
> 45.1m	6

Ottawa Train Yards  
200, 230, 260 Steamline Street  
Client: Controlex  
exp Project: Ott-00243332-A0  
Date: January 2018

Pressure check at Building 590 for Max Day + Fireflow  
Max day35.65L/s) + FireFlow(100L/s) HGL= 113.5 m Terminal Ave  
Max day35.65L/s) + FireFlow(100L/s) HGL= 114.2 m Sanford Fleming Ave

Description	From	To	Flow (L/sec)	Pipe Dia (mm)	Dia (m)	Q (m³/sec)	Area (m2)	C	Vel (m/s)	Slope of HGL (m/m)	Pipe Length (m)	Frictional Head Loss hf (m)	Equivalent Pipe Length of Fittings (m)	Minor Loss of Fittings hb (m)	Total Losses (m) hb + hf	Start Ground Elev(m)	End Ground Elev (m)	Static Head (m)	Pressure From kPa (psi)	Pressure To kPa (psi)	Pressure Drop (psi)
Max Day + Fire Flow	Main Terminal Ave	0+210	135.65	200	0.200	0.13565	0.0314159	125	4.3179	0.0875	201.3	17.60462331	84.8	7.41616	25.02078	65.46	65.60	-0.14	471.1 (68.3)	224.4 (32.5)	35.8
Max Day + Fire Flow	Main Sandford Flemming	0+210	135.65	200	0.200	0.13565	0.0314159	125	4.3179	0.0875	201.3	17.60462331	21.8	1.90651	19.51113	65.55	65.60	-0.05	477.1 (69.2)	285.3 (41.4)	27.8

Resistance of Fittings and Valves for 200mm WM from Terminal to 0+200

Fittings	Loss in Equiv. Length in Pipe Diameters	Equiv. Length (metres)	Quantity (each)	Total Equiv. Length (m)
Standard 90° Elbow	32	6.40	9	57.6
11.25 Degree Elbow	4	0.80	8	6.4
45 Degree Elbow	16	3.20	0	0
Gate Valve Full -Open	13	2.60	8	20.8
		Total:	25	84.8


Resistance of Fittings and Valves for 200mm WM from Sanford Fleming to 0+200

Fittings	Loss in Equiv. Length in Pipe Diameters	Equiv. Length (metres)	Quantity (each)	Total Equiv. Length
Standard 90° Elbow	32	6.40	2	12.8
11.25 Degree Elbow	4	0.80	0	0
45 Degree Elbow	16	3.20	2	6.4
Gate Valve Full -Open	13	2.60	1	2.6
		Total:	5	21.8

## **Appendix C: Sanitary Sewer Design**

Sanitary Drainage Area Plan

Sanitary Sewer Design Sheets





## SANITARY SEWER CALCULATION SHEET - Sandford Fleming Ave 250mm Dia. Sewer

LOCATION				RESEDENTIAL AREAS AND POPULAITONS										COMMERCIAL			INSTITUTIONAL		INFILTRATION			TOTAL FLOW (L/s)	SEWER DATA								
Street	MH From	MH To	ID	Area (ha)**						POPULATION		Peak Factor	Peak Flow (L/sec)	AREA (ha)		Peak Flow (L/sec)	AREA (Ha)	ACCU AREA (Ha)	AREA (ha)		INFILT FLOW (L/s)		Nom Dia (mm)	Actual Dia (mm)	Slope (%)	Length (m)	Capacity (L/sec)	Q/Q <sub>CAP</sub> (%)	Full Velocity (m/s)		
					Bachelor	1-Bed Apt.	2-Bed Apt.	3-Bed Apt.	Avg. Apt.	INDIV	ACCU			INDIV	ACCU				INDIV	ACCU											
380 Terminal Ave	MH1	MH2	WH1	2.9000										2.260	2.26	1.0986111			2.900	2.900	0.96	1.10	250	251.46	0.25	57.000	30.2	4%	0.606575756		
	MH2	MH3													2.26	1.0986111				2.900	0.96	1.10	250	251.46	0.50	82.000	42.7	3%	0.86		
															2.26	1.0986111				2.900	0.96	1.10									
BLD 100/200 - Steamline Rd		MH3	PH1	0.2000	47.00	185	184	4		723.6	723.6	3.31	7.76		2.26	1.0986111			0.200	3.100	1.02	8.86									
BLD 300/400/500 - Steamline Rd		MH3	PH2	0.2700					865	1557	2280.6	3.03	22.39		2.26	1.0986111			0.270	3.370	1.11	23.49									
1424 Sanford Fleming	MH3	MH4	PO3	3.1300							2280.6	3.03	22.39	2.600	4.86	2.3625			3.130	6.500	2.15	24.76	250	251.46	0.81	77.000	54.4	46%	1.09		
											2280.6	3.03	22.39		4.86	2.3625				6.500	2.15	24.76	250	251.46	0.86	77.000	56.0	44%	1.13		
	MH4	MH5									2280.6	3.03	22.39		4.86	2.3625				6.500	2.15	24.76	250	251.46	0.44	15.868	40.1	62%	0.81		
Intersection Sanford Flemming & Industrial	MH5	MH6	ROW	0.26							2280.6	3.03	22.39		4.86	2.3625			0.260	6.760	2.23	26.99	250	251.46	0.42	77.000	39.1	69%	0.79		
				6.760	185				865		2281						6.760				136.91										
				280	Commercial Peak Factor =				1.5	(when area >20%)	Peak Population Flow, (L/sec) =				P*q*M/86.4				Unti Type	Persons/Unit				Designed:		Project:					
Residential Avg. Daily Flow, q (L/p/day) =				28,000					1.0	(when area <20%)	Peak Extraneous Flow, (L/sec) =				I*Ac				Bachelor	1.4				M.A. Lafleur, P.Eng.		Steamline Rd Multi- Res Project					
Commercial Avg. Daily Flow (L/gross ha/day) =				0.324							Residential Peaking Factor, M =				1 + (14/(4+P^0.5)) * K				Single Apt. Unit	1.4											
or L/gross ha/sec =																			2-bed Apt. Unit	2.1				Checked:		Location:					
Institutional Avg. Daily Flow (L/s/ha) =				35,000	Institutional Peak Factor =				1.5	(when area >20%)	A <sub>c</sub> = Cumulative Area (hectares)								3-bed Apt. Unit	3.1											
or L/gross ha/sec =				0.405					1.0	(when area <20%)	P = Population (thousands)								Average Apt. Unit	1.8											
Light Industrial Flow (L/gross ha/day) =				35,000																											
or L/gross ha/sec =				0.405093	Residential Correction Factor, K =				0.80		Sewer Capacity, Qcap (L/sec) =				1/N S <sup>1/2</sup> R <sup>2/3</sup> A <sub>c</sub>								A. Ansari, P.Eng.		Ottawa, Ontario						
Light Industrial Flow (L/gross ha/day) =				55,000	Manning N =				0.013		(Manning's Equation)												File Reference:		Page No:						
or L/gross ha/sec =				0.637	Peak extraneous flow, I (L/s/ha) =				0.33	(Total I/I)					**Infiltration areas do not include areas consisting of underground parking structures.								243332 SAN Design Sheet Sanford Fleming.xlsx		1 of 1						


User Input Required  
Formula that user will need to copy down and UPDATE as required.  
Formula that user will need to copy down as required  
Project Information to be updated  
Design Parameter that user should review





SANITARY SEWER CALCULATION SHEET - Terminal Ave 250mm Dia. Sewer

LOCATION				RESEDENTIAL AREAS AND POPULAITONS										COMMERCIAL			INSTITUTIONAL		INFILTRATION			TOTAL FLOW (L/s)	SEWER DATA												
Street	MH From	MH To	ID	Area (ha)**						POPULATION		Peak Factor	Peak Flow (L/sec)	AREA (ha)		Peak Flow (L/sec)	AREA (Ha)	ACCU AREA (Ha)	AREA (ha)		INFILT FLOW (L/s)		Nom Dia (mm)	Actual Dia (mm)	Slope (%)	Length (m)	Capacity (L/sec)	Q/Q <sub>CAP</sub> (%)	Full Velocity (m/s)						
					Bachelor	1-Bed Apt.	2-Bed Apt.	3-Bed Apt.	Avg. Apt.	INDIV	ACCU			INDIV	ACCU				INDIV	ACCU															
395 Terminal	MH116	MH117	395 Term	1.8400								4.00		1.500	1.5	0.73			1.84	1.84	0.61	0.73	250	251.46	0.28	96.400	32.0	2%	0.64						
												4.00			1.5	0.73				1.84	0.61	0.73													
405 Terminal	MH117	MH115	405 Term	0.2000								4.00		0.870	2.37	1.15			0.20	2.04	0.67	1.15	250	251.46	0.28	96.400	32.0	4%	0.64						
												4.00			2.37	1.15				2.04	0.67	1.15													
Steamline - Phase 3		MH115	PH3	0.1800					605	1089	1089	3.22	11.36		2.37	1.15			0.18	2.22	0.73	12.52													
	MH118	MH119	ROW	0.3400							1089	3.22	11.36		2.37	1.15			0.34	2.56	0.84	12.52	250	251.46	0.28	81.800	32.0	39%	0.64						
				2.560						605	1089						2.560			28.79															
Residential Avg. Daily Flow, q (L/p/day) =				280	Commercial Peak Factor =				1.5	(when area >20%)	Peak Population Flow, (L/sec) =				P*q*M/86.4		<u>Unti Type</u>		<u>Persons/Unit</u>		Designed:					Project:									
Commercial Avg. Daily Flow (L/gross ha/day) =				28,000					1.0	(when area <20%)	Peak Extraneous Flow, (L/sec) =				I*Ac		Bachelor		1.4		M.A. Lafleur, P.Eng.					Steamline Rd Multi- Res Project									
or L/gross ha/sec =				0.324							Residential Peaking Factor, M =				1 + (14/(4+P^0.5)) * K		Single Apt. Unit		1.4		Checked:					Location:									
Institutional Avg. Daily Flow (L/s/ha) =				35,000	Institutional Peak Factor =				1.5	(when area >20%)	A <sub>c</sub> = Cumulative Area (hectares)						2-bed Apt. Unit		2.1		A. Ansari, P.Eng.					Ottawa, Ontario									
or L/gross ha/sec =				0.405					1.0	(when area <20%)	P = Population (thousands)						3-bed Apt. Unit		3.1																
Light Industrial Flow (L/gross ha/day) =				35,000													Average Apt. Unit		1.8																
or L/gross ha/sec =				0.405093	Residential Correction Factor, K =				0.80		Sewer Capacity, Qcap (L/sec) =				1/N S <sup>1/2</sup> R <sup>2/3</sup> A <sub>c</sub>						File Reference:					Page No:									
Light Industrial Flow (L/gross ha/day) =				55,000	Manning N =				0.013		(Manning's Equation)										243332 SAN Design Sheet Terminal.xlsx					1 of 1									
or L/gross ha/sec =				0.637	Peak extraneous flow, I (L/s/ha) =				0.33	(Total I/I)																									
																**Infiltration areas do not include areas consisting of underground parking structures.																			


User Input Required  
Formula that user will need to copy down and UPDATE as required.  
Formula that user will need to copy down as required  
Project Information to be updated  
Design Parameter that user should review