



Roderick Lahey Architect Inc.
56 Beech Street
Ottawa, ON K1S 3J6

Monday, June 3, 2019

Attn: Michael Laprade

Re: Westgate Phase 1 Redevelopment

Dear Michael,

We have designed the site lighting for Westgate Phase 1, 1309 Carling Avenue, in accordance with the following guides as requested by the City of Ottawa:

1. It must be designed using only fixtures that meet the criteria for Full Cut-Off (Sharp cut-off) Classification as recognized by the Illuminating Engineering Society of North America (IESNA or IES), and;
2. It must result in minimal spillage onto adjacent properties. As a guideline, 0.5 fc is normally the maximum allowable spillage.

Should you have any questions or comments, please do not hesitate to contact the undersigned.

Yours truly,



Anas Shaklab, P.Eng.
Quadrant Engineering Ltd.

AS : lw